

COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION AIR QUALITY PROGRAM

STATE ONLY OPERATING PERMIT

Issue Date: August 20, 2019 Effective Date: September 1, 2019

Expiration Date: August 31, 2024

In accordance with the provisions of the Air Pollution Control Act, the Act of January 8, 1960, P.L. 2119, as amended, and 25 Pa. Code Chapter 127, the Owner, [and Operator if noted] (hereinafter referred to as permittee) identified below is authorized by the Department of Environmental Protection (Department) to operate the air emission source(s) more fully described in this permit. This Facility is subject to all terms and conditions specified in this permit. Nothing in this permit relieves the permittee from its obligations to comply with all applicable Federal, State and Local laws and regulations.

The regulatory or statutory authority for each permit condition is set forth in brackets. All terms and conditions in this permit are federally enforceable unless otherwise designated.

State Only Permit No: 01-05020

Federal Tax Id - Plant Code: 23-1324775-1

Owner Information

Name: KNOUSE FOODS COOP INC

Mailing Address: PO BOX 807

BIGLERVILLE, PA 17307-0807

Plant Information

Plant: KNOUSE FOODS COOP INC/BIGLERVILLE

Location: 01 Adams County 01908 Biglerville Borough

SIC Code: 2033 Manufacturing - Canned Fruits And Vegetables

Responsible Official

Name: CHARLES BENNETT Title: MGR ENV AFFAIRS Phone: (717) 677 - 9115

Permit Contact Person

Name: CHARLES BENNETT Title: MGR ENV AFFAIRS Phone: (717) 677 - 9115

[Signature]

WILLIAM R. WEAVER, SOUTHCENTRAL REGION AIR PROGRAMMANAGER





SECTION A. Table of Contents

Section A. Facility/Source Identification

Table of Contents Site Inventory List

Section B. General State Only Requirements

- #001 Definitions.
- #002 Operating Permit Duration.
- #003 Permit Renewal.
- #004 Operating Permit Fees under Subchapter I.
- #005 Transfer of Operating Permits.
- #006 Inspection and Entry.
- #007 Compliance Requirements.
- #008 Need to Halt or Reduce Activity Not a Defense.
- #009 Duty to Provide Information.
- #010 Revising an Operating Permit for Cause.
- #011 Operating Permit Modifications
- #012 Severability Clause.
- #013 De Minimis Emission Increases.
- #014 Operational Flexibility.
- #015 Reactivation
- #016 Health Risk-based Emission Standards and Operating Practice Requirements.
- #017 Circumvention.
- #018 Reporting Requirements.
- #019 Sampling, Testing and Monitoring Procedures.
- #020 Recordkeeping.
- #021 Property Rights.
- #022 Alternative Operating Scenarios.

Section C. Site Level State Only Requirements

- C-I: Restrictions
- C-II: Testing Requirements
- C-III: Monitoring Requirements
- C-IV: Recordkeeping Requirements
- C-V: Reporting Requirements
- C-VI: Work Practice Standards
- C-VII: Additional Requirements
- C-VIII: Compliance Certification
- C-IX: Compliance Schedule

Section D. Source Level State Only Requirements

- D-I: Restrictions
- D-II: Testing Requirements
- D-III: Monitoring Requirements
- D-IV: Recordkeeping Requirements
- D-V: Reporting Requirements
- D-VI: Work Practice Standards
- D-VII: Additional Requirements

Note: These same sub-sections are repeated for each source!

Page 2

Section E. Source Group Restrictions

- E-I: Restrictions
- E-II: Testing Requirements
- E-III: Monitoring Requirements





SECTION A. Table of Contents

E-IV: Recordkeeping RequirementsE-V: Reporting RequirementsE-VI: Work Practice StandardsE-VII: Additional Requirements

Section F. Alternative Operating Scenario(s)

F-I: Restrictions

F-II: Testing Requirements
F-III: Monitoring Requirements
F-IV: Recordkeeping Requirements
F-V: Reporting Requirements
F-VI: Work Practice Standards
F-VII: Additional Requirements

Section G. Emission Restriction Summary


Section H. Miscellaneous





SECTION A. Site Inventory List

Source	D Source Name	Capacity	/Throughput	Fuel/Material
01	NO. 1 BOILER (1990)	29.300	MMBTU/HR	
		209.000	Gal/HR	NO. 5 FUEL OIL /WDLF
		25,100.000	CF/HR	NATURAL GAS
		200.000	Gal/HR	NO. 2 FUEL OIL
02	NO. 2 BOILER (1945)	9.900	MMBTU/HR	
		9.700	MCF/HR	NATURAL GAS
07	FIRE PUMP (CUMMINS CFP7EQSB6) (175 HP, CI	10.000	Gal/HR	DIESEL
	RICE, NSPS IIII)			
FML01	FUEL OIL /WDLF TANK			
FML02	NATURAL GAS PIPELINE			
FML03	DIESEL FUEL			
S001	STACK			
S07	STACK, FIRE PUMP			









#001 [25 Pa. Code § 121.1]

Definitions.

Words and terms that are not otherwise defined in this permit shall have the meanings set forth in Section 3 of the Air Pollution Control Act (35 P.S. § 4003) and in 25 Pa. Code § 121.1.

#002 [25 Pa. Code § 127.446]

Operating Permit Duration.

- (a) This operating permit is issued for a fixed term of five (5) years and shall expire on the date specified on Page 1 of this permit.
- (b) The terms and conditions of the expired permit shall automatically continue pending issuance of a new operating permit, provided the permittee has submitted a timely and complete application and paid applicable fees required under 25 Pa. Code Chapter 127, Subchapter I and the Department is unable, through no fault of the permittee, to issue or deny a new permit before the expiration of the previous permit.

#003 [25 Pa. Code §§ 127.412, 127.413, 127.414, 127.446 & 127.703(b)&(c)]

Permit Renewal.

- (a) The permittee shall submit a timely and complete application for renewal of the operating permit to the appropriate Regional Air Program Manager. The application for renewal of the operating permit shall be submitted at least six (6) months and not more than 18 months before the expiration date of this permit.
- (b) The application for permit renewal shall include the current permit number, a description of any permit revisions that occurred during the permit term, and any applicable requirements that were promulgated and not incorporated into the permit during the permit term. An application is complete if it contains sufficient information to begin processing the application, has the applicable sections completed and has been signed by a responsible official.
- (c) The permittee shall submit with the renewal application a fee for the processing of the application and an additional annual administrative fee as specified in 25 Pa. Code § 127.703(b) and (c). The fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" and shall be for the amount specified in the following schedule specified in 25 Pa. Code § 127.703(b) and (c).
 - (1) Three hundred dollars for applications filed during the 2000-2004 calendar years.
 - (2) Three hundred seventy-five dollars for applications filed for the calendar years beginning in 2005.
- (d) The renewal application shall also include submission of proof that the local municipality and county, in which the facility is located, have been notified in accordance with 25 Pa. Code § 127.413.
- (e) The application for renewal of the operating permit shall also include submission of supplemental compliance review forms in accordance with the requirements of 25 Pa. Code § 127.412(b) and § 127.412(j).
- (f) The permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the permit application, shall promptly submit such supplementary facts or corrected information as necessary to address any requirements that become applicable to the source after the permittee submits a complete application, but prior to the date the Department takes action on the permit application.

#004 [25 Pa. Code § 127.703]

Operating Permit Fees under Subchapter I.

- (a) The permittee shall pay fees according to the following schedule specified in 25 Pa. Code § 127.703(b):
 - (1) Three hundred dollars for applications filed during the 2000-2004 calendar years.
 - (2) Three hundred seventy-five dollars for applications filed for the calendar years beginning in 2005.

This fee schedule shall apply to the processing of an application for an operating permit as well as the extension,







modification, revision, renewal, and re-issuance of each operating permit or part thereof.

- (b) The permittee shall pay an annual operating permit administrative fee according to the fee schedule established in 25 Pa. Code § 127.703(c).
 - (1) Two hundred fifty dollars for applications filed during the 1995-1999 calendar years.
 - (2) Three hundred dollars for applications filed during the 2000-2004 calendar years.
 - (3) Three hundred seventy-five dollars for applications filed during the years beginning in 2005.
- (c) The applicable fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund".

#005 [25 Pa. Code §§ 127.450 (a)(4) and 127.464]

Transfer of Operating Permits.

- (a) This operating permit may not be transferred to another person, except in cases of transfer-of-ownership that are documented and approved by the Department.
- (b) In accordance with 25 Pa. Code § 127.450(a)(4), a change in ownership of the source shall be treated as an administrative amendment if the Department determines that no other change in the permit is required and a written agreement has been submitted to the Department identifying the specific date of the transfer of permit responsibility, coverage and liability between the current and the new permittee and a compliance review form has been submitted to, and the permit transfer has been approved by, the Department.
- (c) This operating permit is valid only for those specific sources and the specific source locations described in this permit.

#006 [25 Pa. Code § 127.441 and 35 P.S. § 4008] Inspection and Entry.

- (a) Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Department or authorized representatives of the Department to perform the following:
- (1) Enter at reasonable times upon the permittee's premises where a source is located or emissions related activity is conducted, or where records are kept under the conditions of this permit;
 - (2) Have access to and copy, at reasonable times, any records that are kept under the conditions of this permit;
- (3) Inspect at reasonable times, any facilities, equipment including monitoring and air pollution control equipment, practices, or operations regulated or required under this permit;
- (4) Sample or monitor, at reasonable times, any substances or parameters, for the purpose of assuring compliance with the permit or applicable requirements as authorized by the Clean Air Act, the Air Pollution Control Act, or the regulations promulgated under the Acts.
- (b) Pursuant to 35 P.S. § 4008, no person shall hinder, obstruct, prevent or interfere with the Department or its personnel in the performance of any duty authorized under the Air Pollution Control Act or regulations adopted thereunder including denying the Department access to a source at this facility. Refusal of entry or access may constitute grounds for permit revocation and assessment of criminal and/or civil penalties.
- (c) Nothing in this permit condition shall limit the ability of the EPA to inspect or enter the premises of the permittee in accordance with Section 114 or other applicable provisions of the Clean Air Act.

#007 [25 Pa. Code §§ 127.441 & 127.444]

Compliance Requirements.

(a) The permittee shall comply with the conditions of this operating permit. Noncompliance with this permit constitutes







a violation of the Clean Air Act and the Air Pollution Control Act and is grounds for one or more of the following:

- (1) Enforcement action
- (2) Permit termination, revocation and reissuance or modification
- (3) Denial of a permit renewal application
- (b) A person may not cause or permit the operation of a source which is subject to 25 Pa. Code Article III unless the source(s) and air cleaning devices identified in the application for the plan approval and operating permit and the plan approval issued for the source is operated and maintained in accordance with specifications in the applications and the conditions in the plan approval and operating permit issued by the Department. A person may not cause or permit the operation of an air contamination source subject to 25 Pa. Code Chapter 127 in a manner inconsistent with good operating practices.
- (c) For purposes of Sub-condition (b) of this permit condition, the specifications in applications for plan approvals and operating permits are the physical configurations and engineering design details which the Department determines are essential for the permittee's compliance with the applicable requirements in this State-Only permit. Nothing in this sub-condition shall be construed to create an independent affirmative duty upon the permittee to obtain a predetermination from the Department for physical configuration or engineering design detail changes made by the permittee.

#008 [25 Pa. Code § 127.441]

Need to Halt or Reduce Activity Not a Defense.

It shall not be a defense for the permittee in an enforcement action that it was necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

#009 [25 Pa. Code §§ 127.442(a) & 127.461]

Duty to Provide Information.

- (a) The permittee shall submit reports to the Department containing information the Department may prescribe relative to the operation and maintenance of each source at the facility.
- (b) The permittee shall furnish to the Department, in writing, information that the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. Upon request, the permittee shall also furnish to the Department copies of records that the permittee is required to maintain in accordance with this permit.

#010 [25 Pa. Code § 127.461]

Revising an Operating Permit for Cause.

This operating permit may be terminated, modified, suspended or revoked and reissued if one or more of the following applies:

- (1) The permittee constructs or operates the source subject to the operating permit so that it is in violation of the Air Pollution Control Act, the Clean Air Act, the regulations thereunder, a plan approval, a permit or in a manner that causes air pollution.
- (2) The permittee fails to properly or adequately maintain or repair an air pollution control device or equipment attached to or otherwise made a part of the source.
- (3) The permittee has failed to submit a report required by the operating permit or an applicable regulation.
- (4) The EPA determines that the permit is not in compliance with the Clean Air Act or the regulations thereunder.

#011 [25 Pa. Code §§ 127.450 & 127.462]

Operating Permit Modifications

(a) The permittee is authorized to make administrative amendments, minor operating permit modifications and







significant operating permit modifications, under this permit, as outlined below:

- (b) Administrative Amendments. The permittee shall make administrative operating permit amendments (as defined in 25 Pa. Code § 127.450(a)), according to procedures specified in § 127.450 unless precluded by the Clean Air Act or its regulations.
- (c) Minor Operating Permit Modifications. The permittee shall make minor operating permit modifications (as defined 25 Pa. Code § 121.1) in accordance with 25 Pa. Code § 127.462.
- (d) Permit modifications which do not qualify as minor permit modifications under 25 Pa. Code § 127.541 will be treated as a significant operating permit revision subject to the public notification procedures in §§ 127.424 and 127.425.

#012 [25 Pa. Code § 127.441]

Severability Clause.

The provisions of this permit are severable, and if any provision of this permit is determined by a court of competent jurisdiction to be invalid or unenforceable, such a determination will not affect the remaining provisions of this permit.

#013 [25 Pa. Code § 127.449]

De Minimis Emission Increases.

- (a) This permit authorizes de minimis emission increases in accordance with 25 Pa. Code § 127.449 so long as the permittee provides the Department with seven (7) days prior written notice before commencing any de minimis emissions increase. The written notice shall:
 - (1) Identify and describe the pollutants that will be emitted as a result of the de minimis emissions increase.
- (2) Provide emission rates expressed in tons per year and in terms necessary to establish compliance consistent with any applicable requirement.
- (b) The Department may disapprove or condition de minimis emission increases at any time.
- (c) Except as provided below in (d), the permittee is authorized to make de minimis emission increases (expressed in tons per year) up to the following amounts without the need for a plan approval or prior issuance of a permit modification:
- (1) Four tons of carbon monoxide from a single source during the term of the permit and 20 tons of carbon monoxide at the facility during the term of the permit.
- (2) One ton of NOx from a single source during the term of the permit and 5 tons of NOx at the facility during the term of the permit.
- (3) One and six-tenths tons of the oxides of sulfur from a single source during the term of the permit and 8.0 tons of oxides of sulfur at the facility during the term of the permit.
- (4) Six-tenths of a ton of PM10 from a single source during the term of the permit and 3.0 tons of PM10 at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act, the regulations thereunder or 25 Pa. Code Article III.
- (5) One ton of VOCs from a single source during the term of the permit and 5.0 tons of VOCs at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act, the regulations thereunder or 25 Pa. Code Article III.
 - (6) Other sources and classes of sources determined to be of minor significance by the Department.
- (d) In accordance with § 127.14, the permittee is authorized to install the following minor sources without the need for a plan approval or permit modification:



01-05020



SECTION B. General State Only Requirements

- (1) Air conditioning or ventilation systems not designed to remove pollutants generated or released from other sources.
 - (2) Combustion units rated at 2,500,000 or less Btu per hour of heat input.
- (3) Combustion units with a rated capacity of less than 10,000,000 Btu per hour heat input fueled by natural gas supplied by a public utility or by commercial fuel oils which are No. 2 or lighter, viscosity less than or equal to 5.82 c St, and which meet the sulfur content requirements of 25 Pa. Code §123.22 (relating to combustion units). For purposes of this permit, commercial fuel oil shall be virgin oil which has no reprocessed, recycled or waste material added.
 - (4) Space heaters which heat by direct heat transfer.
 - (5) Laboratory equipment used exclusively for chemical or physical analysis.
 - (6) Other sources and classes of sources determined to be of minor significance by the Department.
- (e) This permit does not authorize de minimis emission increases if the emissions increase would cause one or more of the following:
- (1) Increase the emissions of a pollutant regulated under Section 112 of the Clean Air Act except as authorized in Subparagraphs (c)(4) and (5) of this permit condition.
- (2) Subject the facility to the prevention of significant deterioration requirements in 25 Pa. Code Chapter 127, Subchapter D and/or the new source review requirements in Subchapter E.
- (3) Violate any applicable requirement of this permit, the Air Pollution Control Act, the Clean Air Act, or the regulations promulgated under either of the acts.
- (f) Emissions authorized under this permit condition shall be included in the monitoring, recordkeeping and reporting requirements of this permit.
- (g) Except for de minimis emission increases, installation of minor sources made pursuant to this permit condition and Plan Approval Exemptions under 25 Pa. Code § 127.14 (relating to exemptions), the permittee is prohibited from making changes or engaging in activities that are not specifically authorized under this permit without first applying for a plan approval. In accordance with § 127.14(b), a plan approval is not required for the construction, modification, reactivation, or installation of the sources creating the de minimis emissions increase.
- (h) The permittee may not meet de minimis emission threshold levels by offsetting emission increases or decreases at the same source.

#014 [25 Pa. Code § 127.3]

Operational Flexibility.

The permittee is authorized to make changes within the facility in accordance with the regulatory provisions outlined in 25 Pa. Code § 127.3 (relating to operational flexibility) to implement the operational flexibility requirements provisions authorized under Section 6.1(i) of the Air Pollution Control Act and the operational flexibility terms and conditions of this permit. The provisions in 25 Pa. Code Chapter 127 which implement the operational flexibility requirements include the following:

- (1) Section 127.14 (relating to exemptions)
- (2) Section 127.447 (relating to alternative operating scenarios)
- (3) Section 127.448 (relating to emissions trading at facilities with Federally enforceable emissions caps)
- (4) Section 127.449 (relating to de minimis emission increases)
- (5) Section 127.450 (relating to administrative operating permit amendments)





- (6) Section 127.462 (relating to minor operating permit modifications)
- (7) Subchapter H (relating to general plan approvals and general operating permits)

#015 [25 Pa. Code § 127.11]

Reactivation

- (a) The permittee may not reactivate a source that has been out of operation or production for at least one year unless the reactivation is conducted in accordance with a plan approval granted by the Department or in accordance with reactivation and maintenance plans developed and approved by the Department in accordance with 25 Pa. Code § 127.11a(a).
- (b) A source which has been out of operation or production for more than five (5) years but less than 10 years may be reactivated and will not be considered a new source if the permittee satisfies the conditions specified in 25 Pa. Code § 127.11a(b).

#016 [25 Pa. Code § 127.36]

Health Risk-based Emission Standards and Operating Practice Requirements.

- (a) When needed to protect public health, welfare and the environment from emissions of hazardous air pollutants from new and existing sources, the permittee shall comply with the health risk-based emission standards or operating practice requirements imposed by the Department, except as precluded by §§ 6.6(d)(2) and (3) of the Air Pollution Control Act [35 P.S. § 4006.6(d)(2) and (3)].
- (b) A person challenging a performance or emission standard established by the Department has the burden to demonstrate that performance or emission standard does not meet the requirements of Section 112 of the Clean Air Act.

#017 [25 Pa. Code § 121.9]

Circumvention.

No person may permit the use of a device, stack height which exceeds good engineering practice stack height, dispersion technique or other technique which, without resulting in reduction of the total amount of air contaminants emitted, conceals or dilutes an emission of air contaminants which would otherwise be in violation of 25 Pa. Code Article III, except that with prior approval of the Department, the device or technique may be used for control of malodors.

#018 [25 Pa. Code §§ 127.402(d) & 127.442]

Reporting Requirements.

- (a) The permittee shall comply with the applicable reporting requirements of the Clean Air Act, the regulations thereunder, the Air Pollution Control Act and 25 Pa. Code Article III including Chapters 127, 135 and 139.
- (b) The permittee shall submit reports to the Department containing information the Department may prescribe relative to the operation and maintenance of any air contamination source.
- (c) Reports, test data, monitoring data, notifications and requests for renewal of the permit shall be submitted to the:

Regional Air Program Manager
PA Department of Environmental Protection
(At the address given in the permit transmittal letter, or otherwise notified)

- (d) Any records or information including applications, forms, or reports submitted pursuant to this permit condition shall contain a certification by a responsible official as to truth, accuracy and completeness. The certifications submitted under this permit shall require a responsible official of the facility to certify that based on information and belief formed after reasonable inquiry, the statements and information in the documents are true, accurate and complete.
- (e) Any records, reports or information submitted to the Department shall be available to the public except for such







records, reports or information which meet the confidentiality requirements of § 4013.2 of the Air Pollution Control Act and §§ 112(d) and 114(c) of the Clean Air Act. The permittee may not request a claim of confidentiality for any emissions data generated for the facility.

#019 [25 Pa. Code §§ 127.441(c) & 135.5]

Sampling, Testing and Monitoring Procedures.

- (a) The permittee shall comply with the monitoring, recordkeeping or reporting requirements of 25 Pa. Code Chapter 139 and the other applicable requirements of 25 Pa. Code Article III and additional requirements related to monitoring, reporting and recordkeeping required by the Clean Air Act and the regulations thereunder including the Compliance Assurance Monitoring requirements of 40 CFR Part 64, where applicable.
- (b) Unless alternative methodology is required by the Clean Air Act and regulations adopted thereunder, sampling, testing and monitoring required by or used by the permittee to demonstrate compliance with any applicable regulation or permit condition shall be conducted in accordance with the requirements of 25 Pa. Code Chapter 139.

#020 [25 Pa. Code §§ 127.441(c) and 135.5]

Recordkeeping.

- (a) The permittee shall maintain and make available, upon request by the Department, the following records of monitored information:
 - (1) The date, place (as defined in the permit) and time of sampling or measurements.
 - (2) The dates the analyses were performed.
 - (3) The company or entity that performed the analyses.
 - (4) The analytical techniques or methods used.
 - (5) The results of the analyses.
 - (6) The operating conditions as existing at the time of sampling or measurement.
- (b) The permittee shall retain records of any required monitoring data and supporting information for at least five (5) years from the date of the monitoring, sample, measurement, report or application. Supporting information includes the calibration data and maintenance records and original strip-chart recordings for continuous monitoring instrumentation, and copies of reports required by the permit.
- (c) The permittee shall maintain and make available to the Department upon request, records including computerized records that may be necessary to comply with the reporting, recordkeeping and emission statement requirements in 25 Pa. Code Chapter 135 (relating to reporting of sources). In accordance with 25 Pa. Code Chapter 135, § 135.5, such records may include records of production, fuel usage, maintenance of production or pollution control equipment or other information determined by the Department to be necessary for identification and quantification of potential and actual air contaminant emissions.

#021 [25 Pa. Code § 127.441(a)]

Property Rights.

This permit does not convey any property rights of any sort, or any exclusive privileges.

#022 [25 Pa. Code § 127.447]

Alternative Operating Scenarios.

The permittee is authorized to make changes at the facility to implement alternative operating scenarios identified in this permit in accordance with 25 Pa. Code § 127.447.



31-05020



SECTION C. Site Level Requirements

I. RESTRICTIONS.

Emission Restriction(s).

001 [25 Pa. Code §123.1]

Prohibition of certain fugitive emissions

The permittee may not allow the emission into the outdoor atmosphere of any fugitive air contaminant from a source other than the following:

- (1) Construction or demolition of buildings or structures.
- (2) Grading, paying and maintenance of roads and streets.
- (3) Use of roads and streets. Emissions from material in or on trucks, railroad cars and other vehicular equipment are not considered as emissions from use of roads and streets.
- (4) Clearing of land.
- (5) Stockpiling of materials.
- (6) Open burning operations.
- (7) Sources and classes of sources other than those identified above, for which the operator has obtained a determination from the Department that fugitive emissions from the source, after appropriate control, meet the following requirements:
- (a) the emissions are of minor significance with respect to causing air pollution;
- (b) the emissions are not preventing or interfering with the attainment or maintenance of any ambient air standard.

002 [25 Pa. Code §123.2]

Fugitive particulate matter

The permittee may not allow fugitive particulate matter to be emitted into the outdoor atmosphere from a source specified in Section C, Condition # 001, if the emissions are visible at the point the emissions pass outside the permittee's property.

003 [25 Pa. Code §123.31]

Limitations

The permittee may not allow the emission into the outdoor atmosphere of any malodorous air contaminants from any source in such a manner that the malodors are detectable outside the permittee's property.

004 [25 Pa. Code §123.41]

Limitations

The permittee may not allow the emission of visible air contaminants into the outdoor atmosphere in such a manner that the opacity of the emission is either of the following:

- (1) Equal to or greater than 20 % for a period or periods aggregating more than three minutes in any one hour.
- (2) Equal to or greater than 60 % at any time.

005 [25 Pa. Code §123.42]

Exceptions

The emission limitations of Section C, Condition #004 (25 Pa Code section 123.41) shall not apply when:

- (1) The presence of uncombined water is the only reason for failure of the emission to meet the limitation.
- (2) The emission results from the operation of equipment used solely to train and test persons in observing the opacity of visible emissions;
- (3) The emission results from sources specified in Section C, Condition #001 subsections (1)-(7).







SECTION C. **Site Level Requirements**

006 [25 Pa. Code §129.14]

Open burning operations

(a) The permittee may not allow or conduct open burning of materials in such a manner that:

- (1) The emissions are visible, at any time, at the point such emissions pass outside the permittee's property.
- (2) Malodorous air contaminants from the open burning are detectable outside the permittee's property.
- (3) The emissions interfere with the reasonable enjoyment of life and property.
- (4) The emissions cause damage to vegetation or property.
- (5) The emissions are or may be deleterious to human or animal health.

Exceptions. The requirements of subsection (a), above, do not apply where the open burning operations result from:

- (1) A fire set to prevent or abate a fire hazard, when approved by the Department and set by or under the supervision of a public officer.
 - (2) Any fire set for the purpose of instructing personnel in fire fighting, when approved by the Department.
 - (3) A fire set for the prevention and control of disease or pests, when approved by the Department.
 - (4) A fire set solely for recreational or ceremonial purposes.
 - (5) A fire set solely for cooking food.

This permit does not constitute authorization to burn solid waste pursuant to section 610 (3) of the Solid Waste Management Act (SWMA). 35 PS Section 6018.610 (3) or any other provision of the SWMA.

II. TESTING REQUIREMENTS.

007 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The Department reserves the right to require exhaust stack testing of the sources and controls referenced in this permit to measure emissions for purposes including verification of permit condition compliance and estimation of annual air emissions.

008 [25 Pa. Code §139.1]

Sampling facilities.

Upon the request of the Department, the permittee shall provide adequate sampling ports, safe sampling platforms and adequate utilities for the performance by the Department of tests on such sources. In the request, the Department will set forth the time period in which the facilities shall be provided as well as the specifications for such facilities.

009 [25 Pa. Code §139.11]

General requirements.

- (a) As specified in 25 Pa. Code Section 139.11(1), performance tests shall be conducted while the source is operating at maximum routine operating conditions or under such other conditions, within the capacity of the equipment, as may be requested by the Department.
- (b) As specified in 25 Pa. Code Section 139.11(2), the Department will consider test results for approval where sufficient information is provided to verify the source conditions existing at the time of the test and where adequate data is available to show the manner in which the test was conducted. Information submitted to the Department shall include, at a minimum, all of the following:
- (1) A thorough source description, including a description of any air cleaning devices and the flue.



01-05020 KNOUSE FOODS COOP INC/BIGLERVILLE

SECTION C. **Site Level Requirements**

- (2) Process conditions, for example, the throughput rate of material, and other conditions which may affect emissions from the process.
- (3) The location of the sampling ports.
- (4) Effluent characteristics, including velocity, temperature, moisture content, gas density (percentage CO, CO2, O2, and N2), static and barometric pressures.
- (5) Sample collection techniques employed, including procedures used, equipment descriptions, and data to verify that isokinetic sampling for particulate matter collection occurred and that acceptable test conditions were met.
- (6) Laboratory procedures and results.
- (7) Calculated results.

Ш MONITORING REQUIREMENTS.

010 [25 Pa. Code §123.43]

Measuring techniques

Visible emissions may be measured using either of the following:

- (1) A device approved by the Department and maintained to provide accurate opacity measurements.
- (2) Observers, trained and certified, to measure plume opacity with the naked eye, as per EPA Method 9, or with the aid of any devices approved by the Department.

[25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall conduct a weekly inspection during regular business workdays around the plant periphery during the daylight hours when the plant is in production to detect visible emissions, fugitive visible emissions and malodorous air contaminants. Weekly inspections are necessary to determine:

- a) The presence of visible emissions. Visible emissions may be measured according to the methods specified in Section C, Condition #011. Alternatively, plant personnel who observe such visible emissions shall report each incident to the Department within four (4) hours of the occurrence and arrange for a certified observer to read the visible emissions.
- b) Presence of fugitive emissions beyond the facility property boundaries, as stated in Section C, Condition #002.
- c) Presence of odorous air contaminants beyond the facility property boundaries as stated in Section C, Condition #003.

IV. RECORDKEEPING REQUIREMENTS.

012 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall maintain a logbook of inspections as referenced in Section C, Condition #012. The logbook shall include, at minimum, the following information:

- 1.) The name of the company representative doing the observation.
- 2.) The date and time of the monitoring.
- 3.) The wind direction.
- 4.) A description of any emissions and/or malodors observed and the actions taken to mitigate them. If none are present, record "NONE."

These records shall be maintained at the facility for the most recent five (5) year period and be made available to the Department upon request.







SECTION C. Site Level Requirements

013 [25 Pa. Code §127.441]

Operating permit terms and conditions.

Unless otherwise noted, all records required by this and subsequent operating permits shall be maintained for the most recent five-year period and shall be readily available to the Department upon request. The most recent two years of records must be retained at the facility. The remaining three years of records may be retained off site. The records may be retained on paper, microfilm, microfiche, or electronic media.

014 [25 Pa. Code §135.5]

Recordkeeping

The permittee shall maintain and make available upon request by the Department, records including computerized records that may be necessary to comply with 25 Pa. Code Sections 135.3, and 135.21 (relating to reporting, fuel usage, maintenance of production or pollution control equipment or other information determined by the Department to be necessary for identification and quantification of potential and actual air contaminant emissions). If direct recordkeeping is not possible or practical, sufficient records shall be kept to provide the needed information by indirect means.

V. REPORTING REQUIREMENTS.

015 [25 Pa. Code §127.442]

Reporting requirements.

The permittee shall report malfunctions to the Department. As defined in 40 CFR Section 60.2 and incorporated by reference in 25 Pa. Code Chapter 122, a malfunction is any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner. Failures that are caused in part by poor maintenance or careless operation are not malfunctions. Malfunctions shall be reported as follows:

- (a) Malfunctions which pose an imminent danger to public health, safety, welfare and the environment, shall be immediately reported to the Department by telephone. The telephone report of such malfunctions shall occur no later than two hours after discovery of the incident. Telephone reports can be made to the Air Quality Program at (717) 705-4886 during normal business hours, or to the Department's Emergency Hotline at any time. The Emergency Hotline phone number is changed/updated periodically. The current Emergency Hotline phone number can be found at https://www.dep.pa.gov/About/Regional/SouthcentralRegion/Pages/default.aspx. The permittee shall submit a written report of instances of such malfunctions to the Department within three (3) days of the telephone report.
- (b) Unless otherwise required by this permit, any other malfunction that is not subject to the reporting requirement of subsection (a) above, shall be reported to the Department, in writing, within five (5) days of malfunction discovery.

VI. WORK PRACTICE REQUIREMENTS.

016 [25 Pa. Code §123.1]

Prohibition of certain fugitive emissions

The permittee shall take all reasonable actions to prevent particulate matter from becoming airborne from any source specified in Section C, Condition #001(1)-(7). These actions shall include, but are not limited to the following:

- (1) Use, where possible, of water or chemicals for control of dust in the demolition of buildings or structures, construction operations, the grading of roads, or the clearing of land.
- (2) Application of asphalt, oil, water, or suitable chemicals on dirt roads, material stockpiles, and other surfaces which may give rise to airborne dusts.
- (3) Paving and maintenance of roadways.
- (4) Prompt removal of earth or other material from paved streets onto which earth or other material has been transported by trucking or earth moving equipment, erosion by water, or other means.

017 [25 Pa. Code §127.444]

Compliance requirements.

The permittee shall operate and maintain all sources and air cleaning devices identified in this operating permit in accordance with the manufacturer's recommendations/specifications, as well as consistent with good operating practices.







SECTION C. Site Level Requirements

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VIII. COMPLIANCE CERTIFICATION.

No additional compliance certifications exist except as provided in other sections of this permit including Section B (relating to State Only General Requirements).

IX. COMPLIANCE SCHEDULE.

No compliance milestones exist.





SECTION D. Source Level Requirements

Source ID: 01 Source Name: NO. 1 BOILER (1990)


Source Capacity/Throughput: 29.300 MMBTU/HR

209.000 Gal/HR NO. 5 FUEL OIL /WDLF

25,100.000 CF/HR NATURAL GAS 200.000 Gal/HR NO. 2 FUEL OIL

Conditions for this source occur in the following groups: 40 CFR PART 60 SUBPART DC

6J EXISTING OIL >=10 MMBTU



I. RESTRICTIONS.

Emission Restriction(s).

001 [25 Pa. Code §123.11]

Combustion units

The permittee shall limit the emissions of particulate matter to 0.4 pounds per million BTU of heat input or less.

Fuel Restriction(s).

002 [25 Pa. Code §127.441]

Operating permit terms and conditions.

1. Contaminant Limits: The permittee shall not accept at the facility any waste derived liquid fuel (WDLF) which is represented by the oil supplier as failing to meet the following standards, or for which the facility does not have documentation from the waste oil supplier regarding the following standards:

Constituent/Property Limitation Level Analytical Technique*

Sulfur less than or equivalent to 0.5% (by weight) ASTM D3227, D1552, D4294, D 129

Arsenic less than or equal to 5 ppmw EPA Method 6010, 6020, 7010, 7061, or 7062

Cadmium less than or equal to 2 ppmw EPA Method 6010, 6020, 7000, or 7010
Chromium less than or equal to 10 ppmw EPA Method 6010, 7000, or 7010
Lead less than or equal to 100 ppmw EPA Method 6010, 7000, or 7010
Total Halogens (TX) less than or equal to 1,000 ppmw EPA Method 9075, 9076, or 9077

PCB not detectable ** EPA Method 8082

Flash Point greater than or equal to 100F EPA Method 1010 or ASTM D93

- * Alternative methods may be used when approved in writing by the Department.
- ** PCBs shall not be present in a quantifiable level, defined in 40 CFR 761.1 as 2 micrograms per gram from any resolvable gas chromatographic peak, i.e. 2 mg/kg.
- 2. TX Screening: Prior to accepting each shipment of WDLF delivered to the facility, the permittee shall test each shipment for total halogens using EPA Reference Method 9077, or an alternate test method if approved in writing by the Department. If the test of any shipment reveals total halogens in excess of 1,000 ppmw, then the permittee shall refuse to accept the shipment. The permittee shall keep records of the results of sampling required by this condition for at least two years.
- 3. Taking and Retaining Samples: The permittee shall take and retain a sample of each shipment of WDLF that is delivered to the facility. The samples shall be retained for at least six months, and shall be made available to the Department upon





SECTION D. Source Level Requirements

request. The samples are to be sealed and identified with the identity of the oil supplier, the date of delivery, the delivery invoice number and the total gallons of WDLF in the shipment.

- 4. Auditing for WDLF: For at least 1 out of every 15 shipments of WDLF received at the facility, the permittee shall take an additional sample for the purpose of conducting a complete analysis for all the constituents/properties listed in condition 1, above. The permittee shall use test methods specified in condition 1, unless an alternate test method has been approved in writing by the Department. The permittee may accept the WDLF that is the subject of such analysis and may use oil from any tank to which such oil has been added, for up to 15 days from the date of delivery of the relevant shipment, pending receipt of the analysis results. If the analysis results show exceedences of any of the limits listed in condition 1, above, then the permittee shall cease using WDLF from the tank(s) in which the relevant shipment was placed, and shall not resume using oil from the tank(s) until either:
- a. the Department has granted written approval to resume use of the WDLF based on an alternate demonstration of acceptability of the WDLF in the tank(s) for use as fuel at the facility, or
- b. the WDLF remaining in the tank(s) has been re-sampled and
- i. if the re-sample meets the limits in condition 1, the Department has granted written permission to resume using the WDLF, or
- ii. if the re-sample fails to meet the limits in condition 1, the Department has granted written permission to resume using the tank(s) after the permittee has emptied the WDLF from the tank(s) and has made proper disposal arrangements, and the tank(s) have been refilled with WDLF that meet the limits in condition 1 above.

The permittee shall cease using the WDLF from such tank(s) not later than 2 hours after making the original determination, or having had reasonable opportunity to make the determination that the off-specification WDLF was placed in the tanks. The permittee shall keep records of the results of sampling required by this condition for at least two years.

Upon successful demonstration for each suppliers of their accuracy in ensuring delivery of eight (8) consecutive samples of on-specification WDLF fuels that comply with properties listed in condition 1, above, the auditing frequency of shipments may be decreased by the Department. The auditing frequencies shall be determined for each individual supplier on a case-by-case basis depending on the recorded compliance history and margin of compliance.

- 5. Department Sampling: If the analysis results from any random tank sampling conducted by the Department show exceedences of any of the limits listed in condition 1, above, then the permittee shall cease using WDLF from the affected tank(s) and shall not resume using oil from the tank(s) until either:
- a. the Department has granted written approval to resume use of the WDLF based on an alternate demonstration of compliance for the original sample, or
- b. the Department has granted written permission to resume placing WDLF in the tank(s) after the permittee has emptied the contaminated WDLF from the tank(s) and has made proper disposal arrangements.

The permittee shall cease using the oil from such tank(s) not later than 2 hours after receiving notification from the Department of the exceedence.

6. Limitations: This permit shall not be construed to authorize the permittee to transport, treat, process or refine any fuels, or to blend off-specification waste oil with other fuels for the purpose of producing an on-specification mixture.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).





SECTION D. **Source Level Requirements**

MONITORING REQUIREMENTS. III.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

WORK PRACTICE REQUIREMENTS. VI.

003 [25 Pa. Code §127.441]

Operating permit terms and conditions.

[Additional authority for this permit condition is also derived from EPA letter to Mr. Charles A. Bennett dated 13 February 2001.]

This permit is valid only if Boiler No. 1 is limited to a maximum oil-fired heat input capacity of less than 30 million Btu/hr.

ADDITIONAL REQUIREMENTS.

004 [25 Pa. Code §123.22]

Combustion units

- (a) Nonair basin areas. Combustion units in nonair basin areas must confirm with the following:
- (1) General Provision. A person may not permit the emission into the outdoor atmosphere of sulfur oxides, expressed as SO2, from a combustion unit in excess of the rate of 4 pounds per million Btu of heat input over a 1-hour period, except as provided in paragraph (4).
 - (2) Commercial Fuel oil
- (i) Except as specified in subparagraphs (ii) and (iii), a person may not offer for sale, deliver for use, exchange in trade or permit the use of commercial fuel oil in nonair basin areas if the commercial fuel oil contains sulfur in excess of the applicable maximum allowable sulfur content set forth in the following tables:

Grades Commercial Fuel Oil Maximum Allowable % Sulfur by Weight through June 30, 2016


No. 2 0.5


> Maximum Allowable Sulfur Content Beginning July 1, 2016, Expressed as Parts per Million (ppm) by Weight or Percentage by Weight


Grades Commercial Fuel oil (Consistent with ASTM D396)

No. 2 500 ppm (0.05%)No. 5 5,000 ppm (0.5%)









- (iii) Beginning July 1, 2016, the Department may temporarily suspend or increase the applicable maximum allowable sulfur content for a commercial fuel oil set forth in subparagraph (i) if the following occur:
- (A) The Department receives a written request at the address specified in subsection (d) for a suspension or increase on the basis that compliant commercial fuel oil is not reasonably available in a nonair basin area. The request must include the following:
 - (I) The nonair basin county or counties for which the suspension or increase is requested.
 - (II) The reason compliant commercial fuel oil is not reasonably available.
- (III) The duration of time for which the suspension or increase is requested and the justification for the requested duration.
- (B) The Department determines that an insufficient quantity of compliant commercial fuel oil is reasonably available in the nonair basin area and that the circumstances leading to the insufficiency are due to events that could not have been reasonably foreseen or prevented and are not due to lack of prudent planning on the part of the transferor of the commercial fuel oil into or within the specified nonair basin area.
- (C) The Department approves the request, in writing, prior to the transferor distributing the noncompliant commercial fuel oil into or within the specified nonair basin area.
- (iv) The Department will limit a suspension or increase in the applicable maximum allowable sulfur content granted under subparagraph (iii) to the shortest duration in which adequate supplies of compliant commercial fuel oil can be made reasonably available, but in no case longer than 60 days from the date the Department grants the suspension or increase.
- (3) Equivalency provision. Paragraph 2 does not apply to a person who uses equipment or a process, or to the owner or operator of an installation where equipment or a process is used, to reduce the sulfur emissions from the burning of a fuel with a higher sulfur content than that specified in paragraph 2. The emissions may not exceed those which would result from the use of commercial fuel oil that meets the applicable maximum allowable sulfur content specified in paragraph 2.
 - (4) [N/A. NOT SOLID FOSSIL FUEL FIRED.]
- (b) through (e): [N/A- THESE ARE FOR AIR BASINS.]
- (f) Sampling and testing.
- (1) For the purpose of determining compliance with the requirements of this section, the actual sulfur content of commercial fuel oil shall be determined by one of the following:
- (i) In accordance with the sample collection, test methods and procedures specified under § 139.16 (relating to sulfur in fuel oil).
 - (ii) Other methods developed or approved by the Department or the Administrator of the EPA, or both.
 - (2) [N/A- NOT A REFINERY]
 - (3) [N/A- FACILITY IS ULTIMATE CONSUMER]
- (g) Recordkeeping and reporting.
 - (1) Beginning with the refinery owner or operator who sells or transfers commercial fuel oil into or within this

01-05020



SECTION D. Source Level Requirements

Commonwealth for use in this Commonwealth and ending with the ultimate consumer, each time the physical custody of, or title to, a shipment of commercial fuel oil changes hands on or after July 1, 2016, the transferor shall provide to the transferee an electronic or paper record described in this paragraph. This record must legibly and conspicuously contain the following information:

- (i) The date of the sale or transfer.
- (ii) The name and address of the transferor.
- (iii) The name and address of the transferee.
- (iv) The volume of commercial fuel oil being sold or transferred.
- (v) The identification of the sulfur content of the shipment of commercial fuel oil, determined using the sampling and testing methods specified in subsection (b)(1), expressed as one of the following statements:
 - (A) For a shipment of No. 2 commercial fuel oil, "The sulfur content of this shipment is 500 ppm or below."
 - (B) [N/A- No. 4 OIL NOT USED]
- (C) For a shipment of No. 5, No. 6 and heavier commercial fuel oil, "The sulfur content of this shipment is 5,000 ppm or below."
 - (vi) The location of the commercial fuel oil at the time of transfer.
- (vii) Except for a transfer to a truck carrier, an owner or operator of a retail outlet or an ultimate consumer, the transferor may substitute the information required under subparagraphs (i)—(vi) with the use of a product code if the following are met:
 - (A) The product code includes the information required under subparagraphs (i)—(vi).
 - (B) The product code is standardized throughout the distribution system in which it is used.
 - (C) Each downstream party is given sufficient information to know the full meaning of the product code.

[NOTE: THE FACILITY IS REQUIRED TO MAINTAIN A RECORD CONTAINING THE INFORMATION IN THIS PARAGRAPH AS PER PARAGRAPH (g)(5) OF THIS SECTION]

- (2) [N/A- FACILITY IS NOT A REFINERY OWNER OR OPERATOR.]
- (3) [N/A- FACILITY IS NOT TERMINAL OWNER OR OPERATOR.]
- (4) The permittee shall do both of the following:
- (i) Maintain the applicable records required under paragraph (c)(1) in electronic or paper format for 2 years unless a longer period is required under § 127.511(b)(2) (relating to monitoring and related recordkeeping and reporting requirements).
 - (ii) Provide an electronic or written copy of the applicable record to the Department upon request.
- (5) The permittee shall maintain in electronic or paper format the record containing the information listed in paragraph (c)(1).
 - (i) [N/A- FACILITY IS NOT A PRIVATE RESIDENCE.]
 - (ii) [N/A- FACILITY IS NOT AN APARTMENT OR CONDOMINIUM BUILDING HOUSING PRIVATE RESIDENTS.]





M South

SECTION D. Source Level Requirements

(h) Written request. The written request for suspension of or increase in the sulfur content limit on the basis that compliant commercial fuel oil is not reasonably available shall be addressed to the Department of Environmental Protection, Bureau of Air Quality, Chief of the Division of Compliance and Enforcement, P. O. Box 8468, Harrisburg, Pennsylvania 17105-8468.








SECTION D. **Source Level Requirements**

Source ID: 02 Source Name: NO. 2 BOILER (1945)

> Source Capacity/Throughput: 9.900 MMBTU/HR

> > 9.700 MCF/HR NATURAL GAS



RESTRICTIONS.

Emission Restriction(s).

001 [25 Pa. Code §123.11]

Combustion units

The permittee shall limit the emissions of particulate matter to 0.4 pounds per million BTU of heat input or less.

002 [25 Pa. Code §123.21] **General**

(b) No person may permit the emission into the outdoor atmosphere of sulfur oxides from a source in a manner that the concentration of the sulfur oxides, expressed as SO2, in the effluent gas exceeds 500 parts per million, by volume, dry basis.

Fuel Restriction(s).

003 [25 Pa. Code §127.441]

Operating permit terms and conditions.

This combustion unit shall only operate on natural gas.

TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

MONITORING REQUIREMENTS. III.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

RECORDKEEPING REQUIREMENTS. IV.

004 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee must maintain usage records on a monthly basis of cubic feet of natural gas. The records must be maintained for five (5) years and made available to the Department's representative upon request.

REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).







SECTION D. **Source Level Requirements**

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

ADDITIONAL REQUIREMENTS. VII.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).








SECTION D. Source Level Requirements

Source ID: 07 Source Name: FIRE PUMP (CUMMINS CFP7EQSB6) (175 HP, CI RICE, NSPS IIII)

Source Capacity/Throughput: 10.000 Gal/HR DIESEL

Conditions for this source occur in the following groups: 4I NEW DIESEL <500 HP EMERGENCY



I. RESTRICTIONS.

Emission Restriction(s).

001 [25 Pa. Code §123.13]

Processes

No persom may permit the emission into the outdoor atmosphere of particulate matter from Source ID 07 in a manner that the concentration of particulate matter in the effluent gas exceeds 0.04 grain per dry standard cubic foot, as per Section 123.13(c)(1)(i).

002 [25 Pa. Code §123.21]

General

No person may permit the emission into the outdoor atmosphere of sulfur oxides from a source in a manner that the concentration of the sulfur oxides, expressed as SO2, in the effluent gas exceeds 500 parts per million, by volume, dry basis.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).





SECTION D. Source Level Requirements

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).



01-05020



SECTION E. Source Group Restrictions.

Group Name: 40 CFR PART 60 SUBPART DC

Group Description: 40 CFR Part 60 Subpart Dc (NG/Other Fuels-fired)

Sources included in this group

ID	Name
01	NO. 1 BOILER (1990)

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VII. ADDITIONAL REQUIREMENTS.

001 [25 Pa. Code §127.441]

Operating permit terms and conditions.

Individual sources within this source group that are subject to 40 CFR Part 60 Subpart Dc shall comply with all applicable requirements of the Subpart. The 40 CFR 60.4(a) requires submission of copies of all requests, reports and other communications to both the Department and the EPA. The EPA copies shall be forwarded to:

Director Air Protection Division (3AP00) U.S. EPA Region III 1650 Arch Street Philadelphia, PA 19103-2029

The Department copies shall be forwarded to:

Regional Air Program Manager PA Department of Environmental Protection 909 Elmerton Avenue Harrisburg, PA 17110-8200

In the event that the Federal Subpart that is the subject of this Source Group is revised, the permittee shall comply with the revised version of the subpart, and shall not be required to comply with any provisions in this permit designated as having



SECTION E. **Source Group Restrictions.**

the subpart as their authority, to the extent that such permit provisions would be inconsistent with the applicable provisions of the revised subpart.

002 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.40c] Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Applicability and delegation of authority.

- § 60.40c Applicability and delegation of authority.
- (a) Except as provided in paragraphs (d), (e), (f), and (g) of this section, the affected facility to which this subpart applies is each steam generating unit for which construction, modification, or reconstruction is commenced after June 9, 1989 and that has a maximum design heat input capacity of 29 megawatts (MW) (100 million British thermal units per hour (MMBtu/h)) or less, but greater than or equal to 2.9 MW (10 MMBtu/h).
- (b) In delegating implementation and enforcement authority to a State under section 111(c) of the Clean Air Act, § 60.48c(a)(4) shall be retained by the Administrator and not transferred to a State.
- (c) [NA UNIT(S) NOT ASSOCIATED WITH COMBUSTION RESEARCH]
- (d) [NA UNIT(S) NOT ASSOCIATED WITH COMBUSTION RESEARCH]
- (e) [NA UNIT(S) NOT ASSOCIATED WITH STATIONARY COMBUSTION TURBINE]
- (f) [NA NOT SUBJECT TO NSPS AAAA OR CCCC]
- (g) [NA NOT SUBJECT TO NSPS BBBB]
- (h) [NA NOT SUBJECT TO NSPS J OR Ja]
- (i) [NA UNIT(S) ARE NOT TEMPORARY BOILERS]
- [72 FR 32759, June 13, 2007, as amended at 74 FR 5090, Jan. 28, 2009; 77 FR 9461, Feb. 16, 2012]
- § 60.42c Standard for sulfur dioxide (SO2).
- (a) [NA UNIT(S) NOT COAL FIRED]
- (b) [NA UNIT(S) NOT COAL FIRED]
- (c) [NA UNIT(S) NOT COAL FIRED]
- (d) On and after the date on which the initial performance test is completed or required to be completed under § 60.8, whichever date comes first, no owner or operator of an affected facility that combusts oil shall cause to be discharged into the atmosphere from that affected facility any gases that contain SO2 in excess of 215 ng/J (0.50 lb/MMBtu) heat input from oil; or, as an alternative, no owner or operator of an affected facility that combusts oil shall combust oil in the affected facility that contains greater than 0.5 weight percent sulfur. The percent reduction requirements are not applicable to affected facilities under this paragraph.
- (e) [NA MULTIPLE SIMULTANEOUS FUELS NOT USED]
- (f) [NA UNIT(S) NOT COAL FIRED]
- (g) [NA PARAGRAPH (h) APPLIES]
- (h) For affected facilities listed under paragraphs (h)(1), (2), (3), or (4) of this section, compliance with the emission limits or fuel oil sulfur limits under this section may be determined based on a certification from the fuel supplier, as described under § 60.48c(f), as applicable.



SECTION E. Source Group Restrictions.

- (1) Distillate oil-fired affected facilities with heat input capacities between 2.9 and 29 MW (10 and 100 MMBtu/hr).
- (2) Residual oil fired affected facilities with heat input capacities between 2.9 and 8.7 MW (10 and 30 MMBtu/hr).
- (3) [NA UNIT(S) NOT COAL FIRED]
- (4) Other fuels-fired affected facilities with heat input capacities between 2.9 and 8.7 MW (10 and 30 MMBtu/hr).
- (i) The SO2 emission limits, fuel oil sulfur limits, and percent reduction requirements under this section apply at all times, including periods of startup, shutdown, and malfunction.
- (j) [NA UNIT(S) NOT IN NON-CONTINENTAL AREA]

[72 FR 32759, June 13, 2007, as amended at 74 FR 5090, Jan. 28, 2009; 77 FR 9462, Feb. 16, 2012]


- § 60.43c Standard for particulate matter (PM).
- (a) [NA UNIT(S) NOT COAL FIRED]
- (b) [NA UNIT(S) NOT WOOD FIRED]
- (c) [NA UNIT(S) < 30 MMBTU]
- (d) [NA UNIT(S) NOT SUBJECT TO PM LIMITS]
- (e)(1) [NA UNIT(S) < 30 MMBTU]
 - (2) [NA UNIT(S) < 30 MMBTU]
 - (3) [NA UNIT(S) < 30 MMBTU]
- (4) An owner or operator of an affected facility that commences construction, reconstruction, or modification after February 28, 2005, and that combusts only oil that contains no more than 0.50 weight percent sulfur or a mixture of 0.50 weight percent sulfur oil with other fuels not subject to a PM standard under § 60.43c and not using a post-combustion technology (except a wet scrubber) to reduce PM or SO2 emissions is not subject to the PM limit in this section.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009; 77 FR 9462, Feb. 16, 2012]

- \S 60.44c Compliance and performance test methods and procedures for sulfur dioxide.
- (a) (g) [NA PARAGRAPH (h) APPLIES]
- (h) For affected facilities subject to § 60.42c(h)(1), (2), or (3) where the owner or operator seeks to demonstrate compliance with the SO2 standards based on fuel supplier certification, the performance test shall consist of the certification from the fuel supplier, as described in § 60.48c(f), as applicable.
- (i) [NA UNIT(S) NOT COAL FIRED]
- (j) [NA PARAGRAPH (h) APPLIES]

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009]

- § 60.45c Compliance and performance test methods and procedures for particulate matter.
- (a) [NA UNIT(S) NOT SUBJECT TO PM LIMITS]
- (b) [NA UNIT(S) NOT SUBJECT TO PM LIMITS]



SECTION E. **Source Group Restrictions.**

(c) [NA - UNIT(S) NOT SUBJECT TO PM LIMITS]

(d) The owner or operator of an affected facility seeking to demonstrate compliance under § 60.43c(e)(4) shall follow the applicable procedures under § 60.48c(f). For residual oil-fired affected facilities, fuel supplier certifications are only allowed for facilities with heat input capacities between 2.9 and 8.7 MW (10 to 30 MMBtu/h).

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009; 76 FR 3523, Jan. 20, 2011; 77 FR 9463, Feb. 16, 2012]

- § 60.46c Emission monitoring for sulfur dioxide.
- (a) (d) [NA PARAGRAPH (e) APPLIES]
- (e) The monitoring requirements of paragraphs (a) and (d) of this section shall not apply to affected facilities subject to § 60.42c(h) (1), (2), or (3) where the owner or operator of the affected facility seeks to demonstrate compliance with the SO2 standards based on fuel supplier certification, as described under § 60.48c(f), as applicable.
- (f) [NA PARAGRAPH (e) APPLIES]
- § 60.47c Emission monitoring for particulate matter.
- (a) (f) [NA NOT SUBJECT TO PM LIMIT OR OPACITY STANDARD]

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009; 76 FR 3523, Jan. 20, 2011; 77 FR 9463, Feb. 16, 2012]

- § 60.48c Reporting and recordkeeping requirements.
- (a) [NA STARTUP IS IN THE PAST]
- (b) The owner or operator of each affected facility subject to the SO2 emission limits of § 60.42c, or the PM or opacity limits of § 60.43c, shall submit to the Administrator the performance test data from the initial and any subsequent performance tests and, if applicable, the performance evaluation of the CEMS and/or COMS using the applicable performance specifications in appendix B of this part.
- (c) [NA NOT SUBJECT TO PM LIMIT OR OPACITY STANDARD]
- (d) The owner or operator of each affected facility subject to the SO2 emission limits, fuel oil sulfur limits, or percent reduction requirements under § 60.42c shall submit reports to the Administrator.
- (e) The owner or operator of each affected facility subject to the SO2 emission limits, fuel oil sulfur limits, or percent reduction requirements under § 60.42c shall keep records and submit reports as required under paragraph (d) of this section, including the following information, as applicable.
 - (1) Calendar dates covered in the reporting period.
 - (2) (10) [NA FUEL SUPPLIER CERTIFICATION USED]
- (11) If fuel supplier certification is used to demonstrate compliance, records of fuel supplier certification as described under paragraph (f)(1), (2), (3), or (4) of this section, as applicable. In addition to records of fuel supplier certifications, the report shall include a certified statement signed by the owner or operator of the affected facility that the records of fuel supplier certifications submitted represent all of the fuel combusted during the reporting period.
- (f) Fuel supplier certification shall include the following information:
 - (1) For distillate oil





SECTION E. **Source Group Restrictions.**

- (i) The name of the supplier;
- (ii) A statement from the supplier that the oil companies with the specification under the definition of distillate oil in Section 60.41; and
 - (iii) Sulfur content or maximum sulfur content of the oil.
 - (2) For residual oil:
 - (i) The name of the oil supplier;
- (ii) The location of the oil when the sample was drawn for analysis to determine the sulfur content of the oil, specifically including whether the oil was sampled as delivered to the affected facility, or whether the sample was drawn from oil in storage at the oil supplier's or oil refiner's facility, or other location;
 - (iii) The sulfur content of the oil from which the shipment came (or of the shipment itself); and
 - (iv) The method used to determine the sulfur content of the oil.
 - (3) [NA UNIT(S) NOT COAL FIRED]
 - (4) For other fuels:
 - (i) The name of the supplier of the fuel;
 - (ii) The potential sulfur emissions rate or maximum potential sulfur emissions rate of the fuel in ng/J heat input; and
 - (iii) The method used to determine the potential sulfur emissions rate of the fuel.
- (g)(1) Except as provided under paragraphs (g)(2) and (g)(3) of this section, the owner or operator of each affected facility shall record and maintain records of the amount of each fuel combusted during each operating day.
- (2) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility that combusts only natural gas, wood, fuels using fuel certification in § 60.48c(f) to demonstrate compliance with the SO2 standard, fuels not subject to an emissions standard (excluding opacity), or a mixture of these fuels may elect to record and maintain records of the amount of each fuel COMBUSTED during each calendar month.
- (3) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility or multiple affected facilities located on a contiguous property unit where the only fuels combusted in any steam generating unit (including steam generating units not subject to this subpart) at that property are natural gas, wood, distillate oil meeting the most current requirements in § 60.42C to use fuel certification to demonstrate compliance with the SO2 standard, and/or fuels, excluding coal and residual oil, not subject to an emissions standard (excluding opacity) may elect to record and maintain records of the total amount of each steam generating unit fuel DELIVERED to that property during each calendar month.
- (h) [NA UNIT(S) NO ANNUAL CAPACITY FACTOR]
- (j) The reporting period for the reports required under this subpart is each six-month period. All reports shall be submitted to the Administrator and shall be postmarked by the 30th day following the end of the reporting period. [SIX MONTHS PERIODS SHALL BE DEFINED AS CALENDAR HALVES]

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009]



01-05020



SECTION E. Source Group Restrictions.

Group Name: 4I NEW DIESEL <500 HP EMERGENCY

Group Description: 175 hp Engine-Pump

Sources included in this group

ID	Name
07	FIRE PUMP (CUMMINS CFP7EQSB6) (175 HP, CI RICE, NSPS IIII)

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VII. ADDITIONAL REQUIREMENTS.

001 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4200]
Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
Am I subject to this subpart?

- § 60.4200 Am I subject to this subpart?
- (a) The provisions of this subpart are applicable to manufacturers, owners, and operators of stationary compression ignition (CI) internal combustion engines (ICE) and other persons as specified in paragraphs (a)(1) through (4) of this section. For the purposes of this subpart, the date that construction commences is the date the engine is ordered by the owner or operator.
- (1) [NA NOT AN ENGINE MANUFACTURER]
- (2) Owners and operators of stationary CI ICE that commence construction after July 11, 2005, where the stationary CI ICE are:
- (i) [NA ENGINES ARE FIRE PUMP ENGINES]
- (ii) Manufactured as a certified National Fire Protection Association (NFPA) fire pump engine after July 1, 2006.
- (3) [NA ENGINES NOT MODIFIED/RECONSTRUCTED]



SECTION E.

01-05020

Source Group Restrictions.

- (4) The provisions of § 60.4208 of this subpart are applicable to all owners and operators of stationary CI ICE that commence construction after July 11, 2005.
- (b) [NA TEST CELL NOT INVOLVED]
- (c) If you are an owner or operator of an area source subject to this subpart, you are exempt from the obligation to obtain a permit under 40 CFR part 70 or 40 CFR part 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart applicable to area sources.
- (d) [NA NATIONAL SECURITY EXEMPTION NOT RELEVANT]
- (e) [NA NOT TEMPORARY REPLACEMENT UNIT(S)]

[71 FR 39172, July 11, 2006, as amended at 76 FR 37967, June 28, 2011]

Emission Standards for Owners and Operators

- § 60.4204 What emission standards must I meet for non-emergency engines if I am an owner or operator of a stationary CI internal combustion engine?
- (ii) [NA UNIT(S) ARE EMERGENCY]
- § 60.4205 What emission standards must I meet for emergency engines if I am an owner or operator of a stationary CI internal combustion engine?
- (a) [NA ENGINES 2007 MODEL YEAR OR LATER]
- (b) [NA ENGINES ARE FIRE PUMP ENGINES]
- (c) Owners and operators of fire pump engines with a displacement of less than 30 liters per cylinder must comply with the emission standards in table 4 to this subpart, for all pollutants.

TABLE 4 REQUIREMENTS

Maximum Engine Power: 130<=KW<225 (175<=HP<300)

Model Year: 2009 and later

Standards expressed as g/kW-hr (g/hp-hr)

NMHC + NOX: 4.0 (3.0)

CO: 3.5 (2.6) PM: 0.20 (0.15)

END OF TABLE 4 REQUIREMENTS

- (d) [NA UNITS(S) < 30 L/CYL]
- (e) [NA DOES NOT CONDUCT PERFORMANCE TESTS IN USE]
- (f) [NA NOT MODIFIED/RECONSRUCTED]
- [71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011]
- § 60.4206 How long must I meet the emission standards if I am an owner or operator of a stationary CI internal combustion engine?

Owners and operators of stationary CI ICE must operate and maintain stationary CI ICE that achieve the emission standards as required in §§ 60.4204 and 60.4205 over the entire life of the engine.







SECTION E. **Source Group Restrictions.**

[76 FR 37969, June 28, 2011]

Fuel Requirements for Owners and Operators

- § 60.4207 What fuel requirements must I meet if I am an owner or operator of a stationary CI internal combustion engine subject to this subpart?
- (a) Beginning October 1, 2007, owners and operators of stationary CI ICE subject to this subpart that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(a).
- (b) Beginning October 1, 2010, owners and operators of stationary CI ICE subject to this subpart with a displacement of less than 30 liters per cylinder that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(b) for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to October 1, 2010, may be used until depleted.
- (c) [Reserved]
- (d) [NA <30 L/CYL]
- (e) [NA NO NATIONAL SECURITY EXEMPTION]

[71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011; 78 FR 6695, Jan. 30, 2013]

Other Requirements for Owners and Operators

- § 60.4208 What is the deadline for importing or installing stationary CI ICE produced in previous model years?
- (a) [NA UNITS MANUFACTURED IN 2011]
- (b) [NA UNITS MANUFACTURED IN 2011]
- (c) (g) [NA UNIT(S) ARE EMERGENCY]
- (h) [NA IMPORTATION NOT RELEVANT IN THIS CASE]
- (i) The requirements of this section do not apply to owners or operators of stationary CI ICE that have been modified, reconstructed, and do not apply to engines that were removed from one existing location and reinstalled at a new location.
- [71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011]
- § 60.4209 What are the monitoring requirements if I am an owner or operator of a stationary CI internal combustion engine?

If you are an owner or operator, you must meet the monitoring requirements of this section. In addition, you must also meet the monitoring requirements specified in § 60.4211.

- (a) If you are an owner or operator of an emergency stationary CI internal combustion engine that does not meet the standards applicable to non-emergency engines, you must install a non-resettable hour meter prior to startup of the engine.
- (b) [NA NO DIESEL PARTICULATE FILTER]

[71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011]

Compliance Requirements

§ 60.4211 What are my compliance requirements if I am an owner or operator of a stationary CI internal combustion engine?







SECTION E. **Source Group Restrictions.**

- (a) If you are an owner or operator and must comply with the emission standards specified in this subpart, you must do all of the following, except as permitted under paragraph (g) of this section:
- (1) Operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instructions:
- (2) Change only those emission-related settings that are permitted by the manufacturer; and
- (3) Meet the requirements of 40 CFR parts 89, 94 and/or 1068, as they apply to you.
- (b) [NA YEAR/HP COMBINATIONS OF UNITS ARE NOT SUBJECT TO TABLE 3]
- (c) If you are an owner or operator of a 2007 model year and later stationary CI internal combustion engine and must comply with the emission standards specified in § 60.4204(b) or § 60.4205(b), or if you are an owner or operator of a CI fire pump engine that is manufactured during or after the model year that applies to your fire pump engine power rating in table 3 to this subpart and must comply with the emission standards specified in § 60.4205(c), you must comply by purchasing an engine certified to the emission standards in § 60.4204(b), or § 60.4205(b) or (c), as applicable, for the same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power. The engine must be installed and configured according to the manufacturer's emission-related specifications, except as permitted in paragraph (g) of this section. [ENGINE IS CERTIFIED TIER 3; COMPLIES WITH TABLE 4 LIMITS]
- (d) [NA UNITS NOT SUBJECT TO § 60.4204(c) or § 60.4205(d)]
- (e) [NA NOT MODIFIED/RECONSRUCTED]
- (f) If you own or operate an emergency stationary ICE, you must operate the emergency stationary ICE according to the requirements in paragraphs (f)(1) through (3) of this section. In order for the engine to be considered an emergency stationary ICE under this subpart, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f)(1) through (3) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1) through (3) of this section, the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.
- (1) There is no time limit on the use of emergency stationary ICE in emergency situations.
- (2) You may operate your emergency stationary ICE for any combination of the purposes specified in paragraphs (f)(2)(i) through (iii) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraph (f)(3) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (f)(2).
- (i) Emergency stationary ICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE beyond 100 hours per calendar year.
- (ii)-(iii) [NA VACATED BY COURT ORDER]
- (3) Emergency stationary ICE may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in paragraph (f)(2) of this section. Except as provided in paragraph (f)(3)(i) of this section, the 50 hours per calendar year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.
- (i) [NA UNIT IS FIRE PUMP ENGINE AND DOES NOT GENERATE ELECTRICITY]







SECTION E. Source Group Restrictions.

- (ii) [Reserved]
- (g) If you do not install, configure, operate, and maintain your engine and control device according to the manufacturer's emission-related written instructions, or you change emission-related settings in a way that is not permitted by the manufacturer, you must demonstrate compliance as follows:
- (1) [NA > 100 HP]
- (2) If you are an owner or operator of a stationary CI internal combustion engine greater than or equal to 100 HP and less than or equal to 500 HP, you must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, you must conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of startup, or within 1 year after an engine and control device is no longer installed, configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after you change emission-related settings in a way that is not permitted by the manufacturer.
- (3) [NA < 500 HP]
- (h) The requirements for operators and prohibited acts specified in 40 CFR 1039.665 apply to owners or operators of stationary CI ICE equipped with AECDs for qualified emergency situations as allowed by 40 CFR 1039.665.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37970, June 28, 2011; 78 FR 6695, Jan. 30, 2013; 81 FR 44219, July 7, 2016]

Testing Requirements for Owners and Operators

§ 60.4212 What test methods and other procedures must I use if I am an owner or operator of a stationary CI internal combustion engine with a displacement of less than 30 liters per cylinder?

[NA – TESTING NOT REQUIRED FOR CERTIFIED UNITS WHICH ARE NOT ALTERED PER 60.4211(g)]

[71 FR 39172, July 11, 2006, as amended at 76 FR 37971, June 28, 2011]

§ 60.4213 What test methods and other procedures must I use if I am an owner or operator of a stationary CI internal combustion engine with a displacement of greater than or equal to 30 liters per cylinder?

[NA - DISPLACEMENT < 30 L/CYL]

[71 FR 39172, July 11, 2006, as amended at 76 FR 37971, June 28, 2011]

Notification, Reports, and Records for Owners and Operators

§ 60.4214 What are my notification, reporting, and recordkeeping requirements if I am an owner or operator of a stationary CI internal combustion engine?

- (a) [NA UNIT(S) ARE EMERGENCY]
- (b) If the stationary CI internal combustion engine is an emergency stationary internal combustion engine, the owner or operator is not required to submit an initial notification. Starting with the model years in table 5 to this subpart, if the emergency engine does not meet the standards applicable to non-emergency engines in the applicable model year, the owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time.

TABLE 5 REQUIREMENTS

You must comply with the labeling requirements in § 60.4210(f) and the recordkeeping requirements in § 60.4214(b) for



(01-05020



SECTION E. Source Group Restrictions.

new emergency stationary CI ICE beginning in the following model years:

ENGINE POWER: KW>=130 (HP>=175)

STARTING MODEL YEAR: 2011

[EXCERPT FROM 60.4210(f)]: Starting with the model years shown in table 5 to this subpart, stationary CI internal combustion engine manufacturers must add a permanent label stating that the engine is for stationary emergency use only to each new emergency stationary CI internal combustion engine greater than or equal to 19 KW (25 HP) that meets all the emission standards for emergency engines in § 60.4202 but does not meet all the emission standards for non-emergency engines in § 60.4201. The label must be added according to the labeling requirements specified in 40 CFR 1039.135(b). Engine manufacturers must specify in the owner's manual that operation of emergency engines is limited to emergency operations and required maintenance and testing. [END OF EXCERPT]

END OF TABLE 5 REQUIREMENTS

- (c) [NA NO DIESEL PARTICULATE FILTER]
- (d) [NA UNIT IS FIRE PUMP ENGINE AND DOES NOT GENERATE ELECTRICITY]
- (e) Owners or operators of stationary CI ICE equipped with AECDs pursuant to the requirements of 40 CFR 1039.665 must report the use of AECDs as required by 40 CFR 1039.665(e).

[71 FR 39172, July 11, 2006, as amended at 78 FR 6696, Jan. 30, 2013; 81 FR 44219, July 7, 2016]

General Provisions

§ 60.4218 What parts of the General Provisions apply to me?

Table 8 to this subpart shows which parts of the General Provisions in §§ 60.1 through 60.19 apply to you.

Regulatory Changes

Individual sources within this source group that are subject to 40 CFR Part 60 Subpart IIII shall comply with all applicable requirements of the Subpart. 40 CFR 60.4 requires submission of copies of all requests, reports and other communications to both the Department and the EPA. The EPA copies shall be forwarded to:

Director
Air Protection Division (3AP00)
U.S. EPA Region III
1650 Arch Street
Philadelphia, PA 19103-2029

The Department copies shall be forwarded to:

Regional Air Program Manager PA Department of Environmental Protection 909 Elmerton Avenue Harrisburg, PA 17110-8200

In the event that the Federal Subpart that is the subject of this Source Group is revised, the permittee shall comply with the revised version of the subpart, and shall not be required to comply with any provisions in this permit designated as having the subpart as their authority, to the extent that such permit provisions would be inconsistent with the applicable provisions of the revised subpart.



01-05020



SECTION E. Source Group Restrictions.

Group Name: 6J EXISTING OIL >=10 MMBTU
Group Description: 6J EXISTING OIL >=10 MMBTU

Sources included in this group

ID	Name
01	NO. 1 BOILER (1990)

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VII. ADDITIONAL REQUIREMENTS.

001 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11193]

SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources

Am I subject to this subpart?

§ 63.11193 Am I subject to this subpart?

You are subject to this subpart if you own or operate an industrial, commercial, or institutional boiler as defined in § 63.11237 that is located at, or is part of, an area source of hazardous air pollutants (HAP), as defined in § 63.2, except as specified in § 63.11195.

§ 63.11194 What is the affected source of this subpart?

- (a) This subpart applies to each new, reconstructed, or existing affected source as defined in paragraphs (a)(1) and (2) of this section.
- (1) The affected source of this subpart is the collection of all existing industrial, commercial, and institutional boilers within a subcategory, as listed in § 63.11200 and defined in § 63.11237, located at an area source.
- (2) The affected source of this subpart is each new or reconstructed industrial, commercial, or institutional boiler within a subcategory, as listed in § 63.11200 and as defined in § 63.11237, located at an area source.



KNOUSE FOODS COOP INC/BIGLERVILLE



SECTION E. Source Group Restrictions.

- (b) An affected source is an existing source if you commenced construction or reconstruction of the affected source on or before June 4, 2010.
- (c) [NA THE SOURCES IN THIS GROUP ARE EXISTING]
- (d) [NA THE SOURCES IN THIS GROUP ARE EXISTING]
- (e) An existing dual-fuel fired boiler meeting the definition of gas-fired boiler, as defined in § 63.11237, that meets the applicability requirements of this subpart after June 4, 2010 due to a fuel switch from gaseous fuel to solid fossil fuel, biomass, or liquid fuel is considered to be an existing source under this subpart as long as the boiler was designed to accommodate the alternate fuel.
- (f) If you are an owner or operator of an area source subject to this subpart, you are exempt from the obligation to obtain a permit under 40 CFR part 70 or part 71 as a result of this subpart. You may, however, be required to obtain a title V permit due to another reason or reasons. See 40 CFR 70.3(a) and (b) or 71.3(a) and (b). Notwithstanding the exemption from title V permitting for area sources under this subpart, you must continue to comply with the provisions of this subpart.

[76 FR 15591, Mar. 21, 2011, as amended at 78 FR 7506, Feb. 1, 2013]


§ 63.11195 Are any boilers not subject to this subpart?

The types of boilers listed in paragraphs (a) through (k) of this section are not subject to this subpart and to any requirements in this subpart.

- (a) [NA NO UNITS PART OF SOURCES SUBJECT TO OTHER PART 63 SUBPART]
- (b) [NA NO CAA SECTION 129 UNITS]
- (c) [NA UNITS DO NOT BURN HAZARDOUS WASTE].
- (d) [NA UNITS ARE NOT R&D]
- (e) [NA UNITS ARE NOT DEFINED AS GAS-FIRED]
- (f) [NA UNITS NOT DEFINED AS HOT WATER HEATERS]
- (g) [NA UNITS NOT USED AS CONTROL DEVICES]
- (h) [NA UNITS DO NOT QUALIFY AS TEMPORARY UNITS]
- (i) [NA UNITS ARE NOT DEFINED AS RESIDENTIAL]
- (j) [NA UNITS ARE NOT DEFINED AS ELECTRIC]
- (k) [NA UNITS ARE NOT EGUs]

[76 FR 15591, Mar. 21, 2011, as amended at 78 FR 7506, Feb. 1, 2013; 81 FR 63125, Sept. 14, 2016]

- § 63.11196 What are my compliance dates?
- (a) If you own or operate an existing affected boiler, you must achieve compliance with the applicable provisions in this subpart as specified in paragraphs (a)(1) through (3) of this section.
- (1) If the existing affected boiler is subject to a work practice or management practice standard of a tune-up, you must achieve compliance with the work practice or management practice standard no later than March 21, 2014.
- (2) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]



01-05020

- (3) If the existing affected boiler is subject to the energy assessment requirement, you must achieve compliance with the energy assessment requirement no later than March 21, 2014.
- (b) [NA THE SOURCES IN THIS GROUP ARE EXISTING]
- (c) [NA THE SOURCES IN THIS GROUP ARE EXISTING]
- (d) [NA NSPS 4C AND 4D EXEMPTIONS NOT INVOKED]

[76 FR 15591, Mar. 21, 2011, as amended at 78 FR 7506, Feb. 1, 2013]

Emission Limits, Work Practice Standards, Emission Reduction Measures, and Management Practices

§ 63.11200 What are the subcategories of boilers?

The subcategories of boilers, as defined in § 63.11237 are:

- (a) [NA SOURCES IN THIS GROUP ARE OIL-FIRED]
- (b) [NA SOURCES IN THIS GROUP ARE OIL-FIRED]
- (c) Oil.
- (d) [NA SOURCES IN THIS GROUP ARE NOT DEFINED AS SEASONAL]
- (e) [NA SOURCES IN THIS GROUP >= 10 MMBTU]
- (f) [NA SOURCES IN THIS GROUP DO NOT HAVE OXYGEN TRIM SYSTEM]
- (g) [NA SOURCES IN THIS GROUP ARE NOT DEFINED AS LIMITED USE]

[78 FR 7506, Feb. 1, 2013]

- § 63.11201 What standards must I meet?
- (a) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- (b) You must comply with each work practice standard, emission reduction measure, and management practice specified in Table 2 to this subpart that applies to your boiler. An energy assessment completed on or after January 1, 2008 that meets or is amended to meet the energy assessment requirements in Table 2 to this subpart satisfies the energy assessment requirement. A facility that operates under an energy management program established through energy management systems compatible with ISO 50001, that includes the affected units, also satisfies the energy assessment requirement.

TABLE 2 REQUIREMENTS:

As stated in § 63.11201, you must comply with the following applicable work practice standards, emission reduction measures, and management practices:

- 4. If your boiler is in this subcategory: Existing oil-fired boilers with heat input capacity greater than 5 MMBtu/hr that do not meet the definition of seasonal boiler or limited-use boiler, or use an oxygen trim system that maintains an optimum air-tofuel ratio, you must meet the following: Conduct an initial tune-up as specified in § 63.11214, and conduct a tune-up of the boiler biennially as specified in § 63.11223.
- 16. If your boiler is in this subcategory: Existing coal-fired, biomass-fired, or oil-fired boilers (units with heat input capacity of 10 MMBtu/hr and greater), not including limited-use boilers, you must meet the following: must have a one-time energy assessment performed by a qualified energy assessor. An energy assessment completed on or after January 1, 2008, that





meets or is amended to meet the energy assessment requirements in this table satisfies the energy assessment requirement. Energy assessor approval and qualification requirements are waived in instances where past or amended energy assessments are used to meet the energy assessment requirements. A facility that operated under an energy management program developed according to the ENERGY STAR guidelines for energy management or compatible with ISO 50001 for at least 1 year between January 1, 2008, and the compliance date specified in §63.11196 that includes the affected units also satisfies the energy assessment requirement. The energy assessment must include the following with extent of the evaluation for items (1) to (4) appropriate for the on-site technical hours listed in §63.11237:

- (1) A visual inspection of the boiler system,
- (2) An evaluation of operating characteristics of the affected boiler systems, specifications of energy use systems, operating and maintenance procedures, and unusual operating constraints,
- (3) An inventory of major energy use systems consuming energy from affected boiler(s) and which are under control of the boiler owner or operator,
- (4) A review of available architectural and engineering plans, facility operation and maintenance procedures and logs, and fuel usage,
- (5) A list of major energy conservation measures that are within the facility's control,
- (6) A list of the energy savings potential of the energy conservation measures identified, and
- (7) A comprehensive report detailing the ways to improve efficiency, the cost of specific improvements, benefits, and the time frame for recouping those investments.

END OF TABLE 2 REQUIREMENTS

- (c) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO OPERATING LIMITS]
- (d) These standards apply at all times the affected boiler is operating, except during periods of startup and shutdown as defined in § 63.11237, during which time you must comply only with Table 2 to this subpart.

[76 FR 15591, Mar. 21, 2011, as amended at 78 FR 7506, Feb. 1, 2013]

General Compliance Requirements

- § 63.11205 What are my general requirements for complying with this subpart?
- (a) At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator that may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.
- (b) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- (c) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]

[76 FR 15591, Mar. 21, 2011, as amended at 78 FR 7506, Feb. 1, 2013]

Initial Compliance Requirements

§ 63.11210 What are my initial compliance requirements and by what date must I conduct them?






- (a) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- (b) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- (c) For existing affected boilers that have applicable work practice standards, management practices, or emission reduction measures, you must demonstrate initial compliance no later than the compliance date that is specified in § 63.11196 and according to the applicable provisions in § 63.7(a)(2), except as provided in paragraph (j) of this section.
- (d) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- (e) –(g) [NA THE SOURCES IN THIS GROUP ARE EXISTING]
- (h) [NA NSPS 4C AND 4D EXEMPTIONS NOT INVOKED]
- (i) For affected boilers that switch fuels or make a physical change to the boiler that results in the applicability of a different subcategory within subpart JJJJJJ or the boiler becoming subject to subpart JJJJJJ, you must demonstrate compliance within 180 days of the effective date of the fuel switch or the physical change. Notification of such changes must be submitted according to § 63.11225(g).
- (j) [NA FACILITY IS MINOR FOR HAP]
- (k) [NA UNITS HAVE OPERATED SINCE 6J EFFECTIVE DATE]
- [76 FR 15591, Mar. 21, 2011, as amended at 78 FR 7507, Feb. 1, 2013; 81 FR 63125, Sept. 14, 2016]
- § 63.11211 How do I demonstrate initial compliance with the emission limits?
- [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- § 63.11212 What stack tests and procedures must I use for the performance tests?
- [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO PERFORMANCE TESTING]
- § 63.11213 What fuel analyses and procedures must I use for the performance tests?
- [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO PERFORMANCE TESTING]
- § 63.11214 How do I demonstrate initial compliance with the work practice standard, emission reduction measures, and management practice?
- (a) [NA SOURCES IN THIS GROUP ARE OIL-FIRED]
- (b) If you own or operate an existing or new biomass-fired boiler or an existing or new oil-fired boiler, you must conduct a performance tune-up according to §63.11210(c) or (g), as applicable, and §63.11223(b). If you own or operate an existing biomass-fired boiler or existing oil-fired boiler, you must submit a signed statement in the Notification of Compliance Status report that indicates that you conducted an initial tune-up of the boiler.
- (c) If you own or operate an existing affected boiler with a heat input capacity of 10 million Btu per hour or greater, you must submit a signed certification in the Notification of Compliance Status report that an energy assessment of the boiler and its energy use systems was completed according to Table 2 to this subpart and that the assessment is an accurate depiction of your facility at the time of the assessment or that the maximum number of on-site technical hours specified in the definition of energy assessment applicable to the facility has been expended.
- (d) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- [76 FR 15591, Mar. 21, 2011, as amended at 78 FR 7508, Feb. 1, 2013; 81 FR 63126, Sept. 14, 2016]





Continuous Compliance Requirements

- § 63.11220 When must I conduct subsequent performance tests or fuel analyses?
- [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO PERFORMANCE TESTING OR FUEL ANALYSES]
- § 63.11221 Is there a minimum amount of monitoring data I must obtain?
- [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- § 63.11222 How do I demonstrate continuous compliance with the emission limits?
- [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- § 63.11223 How do I demonstrate continuous compliance with the work practice and management practice standards?
- (a) For affected sources subject to the work practice standard or the management practices of a tune-up, you must conduct a performance tune-up according to paragraph (b) of this section and keep records as required in § 63.11225(c) to demonstrate continuous compliance. You must conduct the tune-up while burning the type of fuel (or fuels in the case of boilers that routinely burn two types of fuels at the same time) that provided the majority of the heat input to the boiler over the 12 months prior to the tune-up.
- (b) Except as specified in paragraphs (c) through (f) of this section, you must conduct a tune-up of the boiler biennially to demonstrate continuous compliance as specified in paragraphs (b)(1) through (7) of this section. Each biennial tune-up must be conducted no more than 25 months after the previous tune-up. For a new or reconstructed boiler, the first biennial tune-up must be no later than 25 months after the initial startup of the new or reconstructed boiler.
- (1) As applicable, inspect the burner, and clean or replace any components of the burner as necessary (you may delay the burner inspection until the next scheduled unit shutdown, not to exceed 36 months from the previous inspection). Units that produce electricity for sale may delay the burner inspection until the first outage, not to exceed 36 months from the previous inspection.
- (2) Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern. The adjustment should be consistent with the manufacturer's specifications, if available.
- (3) Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure that it is correctly calibrated and functioning properly (you may delay the inspection until the next scheduled unit shutdown, not to exceed 36 months from the previous inspection). Units that produce electricity for sale may delay the inspection until the first outage, not to exceed 36 months from the previous inspection.
- (4) Optimize total emissions of CO. This optimization should be consistent with the manufacturer's specifications, if available, and with any nitrogen oxide requirement to which the unit is subject.
- (5) Measure the concentrations in the effluent stream of CO in parts per million, by volume, and oxygen in volume percent, before and after the adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken using a portable CO analyzer.
- (6) Maintain on-site and submit, if requested by the Administrator, a report containing the information in paragraphs (b)(6)(i) through (iii) of this section.
- (i) The concentrations of CO in the effluent stream in parts per million, by volume, and oxygen in volume percent, measured at high fire or typical operating load, before and after the tune-up of the boiler.
- (ii) A description of any corrective actions taken as a part of the tune-up of the boiler.
- (iii) The type and amount of fuel used over the 12 months prior to the tune-up of the boiler, but only if the unit was physically and legally capable of using more than one type of fuel during that period. Units sharing a fuel meter may estimate the fuel



use by each unit.

- (7) If the unit is not operating on the required date for a tune-up, the tune-up must be conducted within 30 days of startup.
- (c) [NA SOURCES IN THIS GROUP DO NOT HAVE OXYGEN TRIM SYSTEM]
- (d) [NA SOURCES IN THIS GROUP ARE NOT DEFINED AS SEASONAL]
- (e) [NA SOURCES IN THIS GROUP >=10 MMBTU]
- (f) [NA SOURCES IN THIS GROUP ARE NOT DEFINED AS SEASONAL]
- (g) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- [76 FR 15591, Mar. 21, 2011, as amended at 78 FR 7509, Feb. 1, 2013; 81 FR 63127, Sept. 14, 2016]
- § 63.11224 What are my monitoring, installation, operation, and maintenance requirements?
- (a) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- (b) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- (c) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- (d) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO OPERATING LIMITS]
- (e) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- (f) [NA BLDS NOT USED OR REQUIRED]
- [76 FR 15591, Mar. 21, 2011, as amended at 78 FR 7510, Feb. 1, 2013]
- § 63.11225 What are my notification, reporting, and recordkeeping requirements?
- (a) You must submit the notifications specified in paragraphs (a)(1) through (5) of this section to the administrator.
- (1) You must submit all of the notifications in §§ 63.7(b); 63.8(e) and (f); and 63.9(b) through (e), (g), and (h) that apply to you by the dates specified in those sections except as specified in paragraphs (a)(2) and (4) of this section.
- (2) An Initial Notification must be submitted no later than January 20, 2014 or within 120 days after the source becomes subject to the standard.
- (3) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO PERFORMANCE TESTING]
- (4) You must submit the Notification of Compliance Status no later than 120 days after the applicable compliance date specified in §63.11196 unless you own or operate a new boiler subject only to a requirement to conduct a biennial or 5-year tune-up or you must conduct a performance stack test. If you own or operate a new boiler subject to a requirement to conduct a tune-up, you are not required to prepare and submit a Notification of Compliance Status for the tune-up. If you must conduct a performance stack test, you must submit the Notification of Compliance Status within 60 days of completing the performance stack test. You must submit the Notification of Compliance Status in accordance with paragraphs (a)(4)(i) and (vi) of this section. The Notification of Compliance Status must include the information and certification(s) of compliance in paragraphs (a)(4)(i) through (v) of this section, as applicable, and signed by a responsible official.
- (i) You must submit the information required in § 63.9(h)(2), except the information listed in § 63.9(h)(2)(i)(B), (D), (E), and (F). If you conduct any performance tests or CMS performance evaluations, you must submit that data as specified in paragraph (e) of this section. If you conduct any opacity or visible emission observations, or other monitoring procedures or methods, you must submit that data to the Administrator at the appropriate address listed in § 63.13.





- (ii) "This facility complies with the requirements in § 63.11214 to conduct an initial tune-up of the boiler."
- (iii) "This facility has had an energy assessment performed according to § 63.11214(c)."
- (iv) [NA BLDS NOT USED OR REQUIRED]
- (v) [NA SOURCES IN THIS GROUP ARE OIL-FIRED]
- (vi) The notification must be submitted electronically using the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) (www.epa.gov/cdx). However, if the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the written Notification of Compliance Status must be submitted to the Administrator at the appropriate address listed in § 63.13.
- (5) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- (b) You must prepare, by March 1 of each year, and submit to the delegated authority upon request, an annual compliance certification report for the previous calendar year containing the information specified in paragraphs (b)(1) through (4) of this section. You must submit the report by March 15 if you had any instance described by paragraph (b)(3) of this section. For boilers that are subject only to the energy assessment requirement and/or a requirement to conduct a biennial or 5-year tune-up according to §63.11223(a) and not subject to emission limits or operating limits, you may prepare only a biennial or 5-year compliance report as specified in paragraphs (b)(1) and (2) of this section.
- (1) Company name and address.
- (2) Statement by a responsible official, with the official's name, title, phone number, email address, and signature, certifying the truth, accuracy and completeness of the notification and a statement of whether the source has complied with all the relevant standards and other requirements of this subpart. Your notification must include the following certification(s) of compliance, as applicable, and signed by a responsible official:
- (i) "This facility complies with the requirements in § 63.11223 to conduct a biennial or 5-year tune-up, as applicable, of each boiler."
- (ii) [NA SOURCES IN THIS GROUP ARE OIL-FIRED]
- (iii) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- (3) If the source experiences any deviations from the applicable requirements during the reporting period, include a description of deviations, the time periods during which the deviations occurred, and the corrective actions taken.
- (4) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- (c) You must maintain the records specified in paragraphs (c)(1) through (7) of this section.
- (1) As required in § 63.10(b)(2)(xiv), you must keep a copy of each notification and report that you submitted to comply with this subpart and all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted.
- (2) You must keep records to document conformance with the work practices, emission reduction measures, and management practices required by § 63.11214 and § 63.11223 as specified in paragraphs (c)(2)(i) through (vi) of this section.
- (i) Records must identify each boiler, the date of tune-up, the procedures followed for tune-up, and the manufacturer's specifications to which the boiler was tuned.
- (ii) [NA SOURCES IN THIS GROUP ARE OIL-FIRED]
- (iii) For each boiler required to conduct an energy assessment, you must keep a copy of the energy assessment report.







- (iv) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- (v) [NA SOURCES IN THIS GROUP ARE NOT DEFINED AS SEASONAL]
- (vi) [NA SOURCES IN THIS GROUP ARE NOT DEFINED AS LIMITED USE]
- (3) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO FUEL ANALYSES]
- (4) Records of the occurrence and duration of each malfunction of the boiler, or of the associated air pollution control and monitoring equipment.
- (5) Records of actions taken during periods of malfunction to minimize emissions in accordance with the general duty to minimize emissions in § 63.11205(a), including corrective actions to restore the malfunctioning boiler, air pollution control, or monitoring equipment to its normal or usual manner of operation.
- (6) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO EMISSION LIMITS]
- (7) [NA BLDS NOT USED OR REQUIRED]
- (d) Your records must be in a form suitable and readily available for expeditious review. You must keep each record for 5 years following the date of each recorded action. You must keep each record on-site or be accessible from a central location by computer or other means that instantly provide access at the site for at least 2 years after the date of each recorded action. You may keep the records off site for the remaining 3 years.
- (e) [NA SOURCES IN THIS GROUP ARE NOT SUBJECT TO PERFORMANCE TESTING]
- (f) [NA SOURCES IN THIS GROUP ARE OIL-FIRED]
- (g) If you have switched fuels or made a physical change to the boiler and the fuel switch or change resulted in the applicability of a different subcategory within this subpart, in the boiler becoming subject to this subpart, or in the boiler switching out of this subpart due to a fuel change that results in the boiler meeting the definition of gas-fired boiler, as defined in §63.11237, or you have taken a permit limit that resulted in you becoming subject to this subpart or no longer being subject to this subpart, you must provide notice of the date upon which you switched fuels, made the physical change, or took a permit limit within 30 days of the change. The notification must identify:
- (1) The name of the owner or operator of the affected source, the location of the source, the boiler(s) that have switched fuels, were physically changed, or took a permit limit, and the date of the notice.
- (2) The date upon which the fuel switch, physical change, or permit limit occurred.

[76 FR 15591, Mar. 21, 2011, as amended at 78 FR 7511, Feb. 1, 2013; 81 FR 63127, Sept. 14, 2016]

§63.11226 [Reserved]

Other Requirements and Information

§ 63.11235 What parts of the General Provisions apply to me?

Table 8 to this subpart shows which parts of the General Provisions in §§ 63.1 through 63.15 apply to you.

§ 63.11236 Who implements and enforces this subpart? [INCORPORATED BY REFERENCE]

§ 63.11237 What definitions apply to this subpart? [INCORPORATED BY REFERENCE]





SECTION F. Alternative Operation Requirements.

No Alternative Operations exist for this State Only facility.





SECTION G. Emission Restriction Summary.

No emission restrictions listed in this section of the permit.







SECTION H. Miscellaneous.

#001. Insignificant Source List: The following equipment and activities are not subject to any other specific work practices, testing, monitoring, recordkeeping, or reporting requirements:

- 1. Pneumatic transportaion and of granulated sugar controlled by a baghouse installed on top of the 60,000 lb capacity silo (has six bag filters).
- 2. Steam exhausts from various process locations.
- 3. Laboratory hoods in the two R & D and Tech Center rooms.
- 4. Three (3) Natural gas fired space heaters, these are direct heat transfer shop heaters subject to 25 Pa. Code Section 127.14 (a)(4) exemptions.
- 5. Gasoline fired transfer pump installed in 1990s (SI RICE, 4SRB, rated at 9 hp, equivalent heat input ~0.1 mmbtu/hr), subject to the area source MACT Subpart ZZZZ (permittee is required to keep records of operating hours and the routine manufacturer's recommended maintenance performed on the engine).
- 6. One(1) 15,000 gallon underground fuel / reclaimed oil storage tank (not heated but the circulating oil leakoff has heating).
- 7. One (1) 280 gallon diesel day tank for fire pump.
- 8. Source ID 06, Five (5) Cold Cleaning Stations (Degreasers). These units are converted from solvent based to aqueous solution, and are on lease from the Safety Kleen.
- #002. This natural minor permit replaces the synthetic minor permit expiring July 31, 2019.





***** End of Report ******