



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
AIR QUALITY PROGRAM

**STATE ONLY SYNTHETIC MINOR OPERATING PERMIT**

Issue Date: July 14, 2022

Effective Date: July 14, 2022

Expiration Date: July 13, 2027

In accordance with the provisions of the Air Pollution Control Act, the Act of January 8, 1960, P.L. 2119, as amended, and 25 Pa. Code Chapter 127, the Owner, [and Operator if noted] (hereinafter referred to as permittee) identified below is authorized by the Department of Environmental Protection (Department) to operate the air emission source(s) more fully described in this permit. This Facility is subject to all terms and conditions specified in this permit. Nothing in this permit relieves the permittee from its obligations to comply with all applicable Federal, State and Local laws and regulations.

The regulatory or statutory authority for each permit condition is set forth in brackets. All terms and conditions in this permit are federally enforceable unless otherwise designated.

**State Only Permit No: 09-00004**

Synthetic Minor

Federal Tax Id - Plant Code: 38-2363773

**Owner Information**

Name: OLIVER HEALTHCARE PKG CO  
Mailing Address: 905 PENNSYLVANIA BLVD  
FEASTERVILLE, PA 19053-7815

**Plant Information**

Plant: OLIVER HEALTHCARE PKG/FEASTERVILLE  
Location: 09 Bucks County 09006 Lower Southampton Township  
SIC Code: 2671 Manufacturing - Paper Coated And Laminated, Packaging

**Responsible Official**

Name: RICHARD KREPPPEL  
Title: PLT MGR IV  
Phone: (215) 322 - 7900 Ext.1366 Email: rkreppel@oliverhcp.com

**Permit Contact Person**

Name: SONIA JILLSON  
Title: PROCESS ENGR MGR  
Phone: (215) 322 - 7900 Ext.6257 Email: sjillson@oliverhcp.com

[Signature] \_\_\_\_\_  
JAMES D. REBARCHAK, SOUTHEAST REGION AIR PROGRAM MANAGER



## SECTION A. Table of Contents

### Section A. Facility/Source Identification

Table of Contents  
Site Inventory List

### Section B. General State Only Requirements

- #001 Definitions.
- #002 Operating Permit Duration.
- #003 Permit Renewal.
- #004 Operating Permit Fees under Subchapter I.
- #005 Transfer of Operating Permits.
- #006 Inspection and Entry.
- #007 Compliance Requirements.
- #008 Need to Halt or Reduce Activity Not a Defense.
- #009 Duty to Provide Information.
- #010 Revising an Operating Permit for Cause.
- #011 Operating Permit Modifications
- #012 Severability Clause.
- #013 De Minimis Emission Increases.
- #014 Operational Flexibility.
- #015 Reactivation
- #016 Health Risk-based Emission Standards and Operating Practice Requirements.
- #017 Circumvention.
- #018 Reporting Requirements.
- #019 Sampling, Testing and Monitoring Procedures.
- #020 Recordkeeping.
- #021 Property Rights.
- #022 Alternative Operating Scenarios.
- #023 Reporting
- #024 Report Format

### Section C. Site Level State Only Requirements

- C-I: Restrictions
- C-II: Testing Requirements
- C-III: Monitoring Requirements
- C-IV: Recordkeeping Requirements
- C-V: Reporting Requirements
- C-VI: Work Practice Standards
- C-VII: Additional Requirements
- C-VIII: Compliance Certification
- C-IX: Compliance Schedule

### Section D. Source Level State Only Requirements

- D-I: Restrictions
- D-II: Testing Requirements
- D-III: Monitoring Requirements
- D-IV: Recordkeeping Requirements
- D-V: Reporting Requirements
- D-VI: Work Practice Standards
- D-VII: Additional Requirements

Note: These same sub-sections are repeated for each source!

### Section E. Source Group Restrictions

- E-I: Restrictions



## **SECTION A. Table of Contents**

- E-II: Testing Requirements
- E-III: Monitoring Requirements
- E-IV: Recordkeeping Requirements
- E-V: Reporting Requirements
- E-VI: Work Practice Standards
- E-VII: Additional Requirements

### **Section F. Alternative Operating Scenario(s)**




- F-I: Restrictions
- F-II: Testing Requirements
- F-III: Monitoring Requirements
- F-IV: Recordkeeping Requirements
- F-V: Reporting Requirements
- F-VI: Work Practice Standards
- F-VII: Additional Requirements

### **Section G. Emission Restriction Summary**

### **Section H. Miscellaneous**

**SECTION A. Site Inventory List**

Source ID	Source Name	Capacity/Throughput	Fuel/Material
101	ROTOGRAVURE 1 PRESS, 14" GRAVURE		
102	FLEXOGRAPHIC 3 PRESS, FLEXO GALLUS		
103	ROTOGRAVURE 46 PRESS, 21" INTRA ROTO		
104	FLEXOGRAPHIC 9 PRESS, 6.5 WEBTRON		
105	FLEXOGRAPHIC 31 PRESS, 17.5" PROPHETEER		
106	FLEXOGRAPHIC 63 PRESS, 7" FLEXO ALLIED		
108	FLEXOGRAPHIC NO. 70 PRESS, JULIET 608		
109	LETTERPRESS 120, HEIDELBERG 18"X23"		
110	FLEXOGRAPHIC 74 PRESS, 24" W/ ROTARY SCREEN	N/A	INK
201	COLD DEGREASER 2		
202	COLD DEGREASER		
204	ULTRASONIC CLEANER	0.156 Lbs/HR	DYNASOLVE
205	20 KW EMERGENCY GENERATOR ENGINE	300.000 CF/HR	Natural Gas
206	DIESEL ICE - EMERGENCY GENERATOR IT		
207	DIESEL ICE - FIRE PUMP		
208	SOLVENT BATHS		
FML1	NATURAL GAS		
FML2	DIESEL		
S01	STACK 1		
S02	STACK 2		
S03	STACK 3		
S04	STACK 4		
S110	110 STACK		
S205	GENERATOR ENGINE STACK		
S206	DIESEL ICE - EMERGENCY GENERATOR IT STACK		
S207	DIESEL ICE - FIRE PUMP ENGINE STACK		
S208	SOLVENT BATH STACK		
Z01	FUGITIVE		

**PERMIT MAPS**



## PERMIT MAPS

PROC  
104 → STAC  
S01

PROC  
105 → STAC  
S02

PROC  
106 → STAC  
Z01

PROC  
108 → STAC  
S04

PROC  
109 → STAC  
Z01

PROC  
110 → STAC  
S110

PROC  
201 → STAC  
Z01

PROC  
202 → STAC  
Z01

PROC  
204 → STAC  
Z01

PROC  
205 → STAC  
S205

FML  
FML1 →

PROC  
206 → STAC  
S206

FML  
FML2 →

PROC  
207 → STAC  
S207

FML  
FML2 →

PROC  
208 → STAC  
S208

**SECTION B. General State Only Requirements****#001 [25 Pa. Code § 121.1]****Definitions.**

Words and terms that are not otherwise defined in this permit shall have the meanings set forth in Section 3 of the Air Pollution Control Act (35 P.S. § 4003) and in 25 Pa. Code § 121.1.

**#002 [25 Pa. Code § 127.446]****Operating Permit Duration.**

(a) This operating permit is issued for a fixed term of five (5) years and shall expire on the date specified on Page 1 of this permit.

(b) The terms and conditions of the expired permit shall automatically continue pending issuance of a new operating permit, provided the permittee has submitted a timely and complete application and paid applicable fees required under 25 Pa. Code Chapter 127, Subchapter I and the Department is unable, through no fault of the permittee, to issue or deny a new permit before the expiration of the previous permit.

**#003 [25 Pa. Code §§ 127.412, 127.413, 127.414, 127.446 & 127.703(b)]****Permit Renewal.**

(a) The permittee shall submit a timely and complete application for renewal of the operating permit to the appropriate Regional Air Program Manager. The application for renewal of the operating permit shall be submitted at least six (6) months and not more than 18 months before the expiration date of this permit.

(b) The application for permit renewal shall include the current permit number, a description of any permit revisions that occurred during the permit term, and any applicable requirements that were promulgated and not incorporated into the permit during the permit term. An application is complete if it contains sufficient information to begin processing the application, has the applicable sections completed and has been signed by a responsible official.

(c) The permittee shall submit with the renewal application a fee for the processing of the application as specified in 25 Pa. Code § 127.703(b). The fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" and submitted with the fee form to the respective regional office.

(d) The renewal application shall also include submission of proof that the local municipality and county, in which the facility is located, have been notified in accordance with 25 Pa. Code § 127.413.

(e) The application for renewal of the operating permit shall also include submission of supplemental compliance review forms in accordance with the requirements of 25 Pa. Code § 127.412(b) and § 127.412(j).

(f) The permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the permit application, shall promptly submit such supplementary facts or corrected information as necessary to address any requirements that become applicable to the source after the permittee submits a complete application, but prior to the date the Department takes action on the permit application.

**#004 [25 Pa. Code § 127.703]****Operating Permit Fees under Subchapter I.**

(a) The permittee shall pay the annual operating permit maintenance fee according to the following fee schedule in either paragraph (1) or (2) in accordance with 25 Pa. Code § 127.703(d) on or before December 31 of each year for the next calendar year.

(1) For a synthetic minor facility, a fee equal to:

(i) Four thousand dollars (\$4,000) for calendar years 2021—2025.

(ii) Five thousand dollars (\$5,000) for calendar years 2026—2030.

(iii) Six thousand three hundred dollars (\$6,300) for the calendar years beginning with 2031.

**SECTION B. General State Only Requirements**

(2) For a facility that is not a synthetic minor, a fee equal to:

- (i) Two thousand dollars (\$2,000) for calendar years 2021—2025.
- (ii) Two thousand five hundred dollars (\$2,500) for calendar years 2026—2030.
- (iii) Three thousand one hundred dollars (\$3,100) for the calendar years beginning with 2031.

(b) The applicable fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" with the permit number clearly indicated and submitted to the respective regional office.

**#005 [25 Pa. Code §§ 127.450 (a)(4) and 127.464]****Transfer of Operating Permits.**

(a) This operating permit may not be transferred to another person, except in cases of transfer-of-ownership that are documented and approved by the Department.

(b) In accordance with 25 Pa. Code § 127.450(a)(4), a change in ownership of the source shall be treated as an administrative amendment if the Department determines that no other change in the permit is required and a written agreement has been submitted to the Department identifying the specific date of the transfer of permit responsibility, coverage and liability between the current and the new permittee and a compliance review form has been submitted to, and the permit transfer has been approved by, the Department.

(c) This operating permit is valid only for those specific sources and the specific source locations described in this permit.

**#006 [25 Pa. Code § 127.441 and 35 P.S. § 4008]****Inspection and Entry.**

(a) Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Department or authorized representatives of the Department to perform the following:

(1) Enter at reasonable times upon the permittee's premises where a source is located or emissions related activity is conducted, or where records are kept under the conditions of this permit;

(2) Have access to and copy, at reasonable times, any records that are kept under the conditions of this permit;

(3) Inspect at reasonable times, any facilities, equipment including monitoring and air pollution control equipment, practices, or operations regulated or required under this permit;

(4) Sample or monitor, at reasonable times, any substances or parameters, for the purpose of assuring compliance with the permit or applicable requirements as authorized by the Clean Air Act, the Air Pollution Control Act, or the regulations promulgated under the Acts.

(b) Pursuant to 35 P.S. § 4008, no person shall hinder, obstruct, prevent or interfere with the Department or its personnel in the performance of any duty authorized under the Air Pollution Control Act or regulations adopted thereunder including denying the Department access to a source at this facility. Refusal of entry or access may constitute grounds for permit revocation and assessment of criminal and/or civil penalties.

(c) Nothing in this permit condition shall limit the ability of the EPA to inspect or enter the premises of the permittee in accordance with Section 114 or other applicable provisions of the Clean Air Act.

**#007 [25 Pa. Code §§ 127.441 & 127.444]****Compliance Requirements.**

(a) The permittee shall comply with the conditions of this operating permit. Noncompliance with this permit constitutes a violation of the Clean Air Act and the Air Pollution Control Act and is grounds for one or more of the following:

**SECTION B. General State Only Requirements**

- (1) Enforcement action
- (2) Permit termination, revocation and reissuance or modification
- (3) Denial of a permit renewal application

(b) A person may not cause or permit the operation of a source which is subject to 25 Pa. Code Article III unless the source(s) and air cleaning devices identified in the application for the plan approval and operating permit and the plan approval issued for the source is operated and maintained in accordance with specifications in the applications and the conditions in the plan approval and operating permit issued by the Department. A person may not cause or permit the operation of an air contamination source subject to 25 Pa. Code Chapter 127 in a manner inconsistent with good operating practices.

(c) For purposes of Sub-condition (b) of this permit condition, the specifications in applications for plan approvals and operating permits are the physical configurations and engineering design details which the Department determines are essential for the permittee's compliance with the applicable requirements in this State-Only permit. Nothing in this sub-condition shall be construed to create an independent affirmative duty upon the permittee to obtain a predetermination from the Department for physical configuration or engineering design detail changes made by the permittee.

**#008 [25 Pa. Code § 127.441]****Need to Halt or Reduce Activity Not a Defense.**

It shall not be a defense for the permittee in an enforcement action that it was necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

**#009 [25 Pa. Code §§ 127.442(a) & 127.461]****Duty to Provide Information.**

(a) The permittee shall submit reports to the Department containing information the Department may prescribe relative to the operation and maintenance of each source at the facility.

(b) The permittee shall furnish to the Department, in writing, information that the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. Upon request, the permittee shall also furnish to the Department copies of records that the permittee is required to maintain in accordance with this permit.

**#010 [25 Pa. Code § 127.461]****Revising an Operating Permit for Cause.**

This operating permit may be terminated, modified, suspended or revoked and reissued if one or more of the following applies:

- (1) The permittee constructs or operates the source subject to the operating permit so that it is in violation of the Air Pollution Control Act, the Clean Air Act, the regulations thereunder, a plan approval, a permit or in a manner that causes air pollution.
- (2) The permittee fails to properly or adequately maintain or repair an air pollution control device or equipment attached to or otherwise made a part of the source.
- (3) The permittee has failed to submit a report required by the operating permit or an applicable regulation.
- (4) The EPA determines that the permit is not in compliance with the Clean Air Act or the regulations thereunder.

**#011 [25 Pa. Code §§ 127.450, 127.462, 127.465 & 127.703]****Operating Permit Modifications**

(a) The permittee is authorized to make administrative amendments, minor operating permit modifications and significant operating permit modifications, under this permit, as outlined below:



**SECTION B. General State Only Requirements**

(b) Administrative Amendments. The permittee shall submit the application for administrative operating permit amendments (as defined in 25 Pa. Code § 127.450(a)), according to procedures specified in § 127.450 unless precluded by the Clean Air Act or its regulations.

(c) Minor Operating Permit Modifications. The permittee shall submit the application for minor operating permit modifications (as defined 25 Pa. Code § 121.1) in accordance with 25 Pa. Code § 127.462.

(d) Significant Operating Permit Modifications. The permittee shall submit the application for significant operating permit modifications in accordance with 25 Pa. Code § 127.465.

(e) The applicable fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" with the permit number clearly indicated and submitted to the respective regional office.

**#012 [25 Pa. Code § 127.441]****Severability Clause.**

The provisions of this permit are severable, and if any provision of this permit is determined by a court of competent jurisdiction to be invalid or unenforceable, such a determination will not affect the remaining provisions of this permit.

**#013 [25 Pa. Code § 127.449]****De Minimis Emission Increases.**

(a) This permit authorizes de minimis emission increases in accordance with 25 Pa. Code § 127.449 so long as the permittee provides the Department with seven (7) days prior written notice before commencing any de minimis emissions increase. The written notice shall:

(1) Identify and describe the pollutants that will be emitted as a result of the de minimis emissions increase.

(2) Provide emission rates expressed in tons per year and in terms necessary to establish compliance consistent with any applicable requirement.

(b) The Department may disapprove or condition de minimis emission increases at any time.

(c) Except as provided below in (d), the permittee is authorized to make de minimis emission increases (expressed in tons per year) up to the following amounts without the need for a plan approval or prior issuance of a permit modification:

(1) Four tons of carbon monoxide from a single source during the term of the permit and 20 tons of carbon monoxide at the facility during the term of the permit.

(2) One ton of NO<sub>x</sub> from a single source during the term of the permit and 5 tons of NO<sub>x</sub> at the facility during the term of the permit.

(3) One and six-tenths tons of the oxides of sulfur from a single source during the term of the permit and 8.0 tons of oxides of sulfur at the facility during the term of the permit.

(4) Six-tenths of a ton of PM<sub>10</sub> from a single source during the term of the permit and 3.0 tons of PM<sub>10</sub> at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act, the regulations thereunder or 25 Pa. Code Article III.

(5) One ton of VOCs from a single source during the term of the permit and 5.0 tons of VOCs at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act, the regulations thereunder or 25 Pa. Code Article III.

(6) Other sources and classes of sources determined to be of minor significance by the Department.

(d) In accordance with § 127.14, the permittee is authorized to install the following minor sources without the need for a plan approval or permit modification:

**SECTION B. General State Only Requirements**

- (1) Air conditioning or ventilation systems not designed to remove pollutants generated or released from other sources.
  - (2) Combustion units rated at 2,500,000 or less Btu per hour of heat input.
  - (3) Combustion units with a rated capacity of less than 10,000,000 Btu per hour heat input fueled by natural gas supplied by a public utility or by commercial fuel oils which are No. 2 or lighter, viscosity less than or equal to 5.82 c St, and which meet the sulfur content requirements of 25 Pa. Code §123.22 (relating to combustion units). For purposes of this permit, commercial fuel oil shall be virgin oil which has no reprocessed, recycled or waste material added.
  - (4) Space heaters which heat by direct heat transfer.
  - (5) Laboratory equipment used exclusively for chemical or physical analysis.
  - (6) Other sources and classes of sources determined to be of minor significance by the Department.
- (e) This permit does not authorize de minimis emission increases if the emissions increase would cause one or more of the following:
- (1) Increase the emissions of a pollutant regulated under Section 112 of the Clean Air Act except as authorized in Subparagraphs (c)(4) and (5) of this permit condition.
  - (2) Subject the facility to the prevention of significant deterioration requirements in 25 Pa. Code Chapter 127, Subchapter D and/or the new source review requirements in Subchapter E.
  - (3) Violate any applicable requirement of this permit, the Air Pollution Control Act, the Clean Air Act, or the regulations promulgated under either of the acts.
- (f) Emissions authorized under this permit condition shall be included in the monitoring, recordkeeping and reporting requirements of this permit.
- (g) Except for de minimis emission increases, installation of minor sources made pursuant to this permit condition and Plan Approval Exemptions under 25 Pa. Code § 127.14 (relating to exemptions), the permittee is prohibited from making changes or engaging in activities that are not specifically authorized under this permit without first applying for a plan approval. In accordance with § 127.14(b), a plan approval is not required for the construction, modification, reactivation, or installation of the sources creating the de minimis emissions increase.
- (h) The permittee may not meet de minimis emission threshold levels by offsetting emission increases or decreases at the same source.

**#014 [25 Pa. Code § 127.3]****Operational Flexibility.**

The permittee is authorized to make changes within the facility in accordance with the regulatory provisions outlined in 25 Pa. Code § 127.3 (relating to operational flexibility) to implement the operational flexibility requirements provisions authorized under Section 6.1(i) of the Air Pollution Control Act and the operational flexibility terms and conditions of this permit. The provisions in 25 Pa. Code Chapter 127 which implement the operational flexibility requirements include the following:

- (1) Section 127.14 (relating to exemptions)
- (2) Section 127.447 (relating to alternative operating scenarios)
- (3) Section 127.448 (relating to emissions trading at facilities with Federally enforceable emissions caps)
- (4) Section 127.449 (relating to de minimis emission increases)
- (5) Section 127.450 (relating to administrative operating permit amendments)

**SECTION B. General State Only Requirements**

(6) Section 127.462 (relating to minor operating permit modifications)

(7) Subchapter H (relating to general plan approvals and general operating permits)

**#015 [25 Pa. Code § 127.11]****Reactivation**

(a) The permittee may not reactivate a source that has been out of operation or production for at least one year unless the reactivation is conducted in accordance with a plan approval granted by the Department or in accordance with reactivation and maintenance plans developed and approved by the Department in accordance with 25 Pa. Code § 127.11a(a).

(b) A source which has been out of operation or production for more than five (5) years but less than 10 years may be reactivated and will not be considered a new source if the permittee satisfies the conditions specified in 25 Pa. Code § 127.11a(b).

**#016 [25 Pa. Code § 127.36]****Health Risk-based Emission Standards and Operating Practice Requirements.**

(a) When needed to protect public health, welfare and the environment from emissions of hazardous air pollutants from new and existing sources, the permittee shall comply with the health risk-based emission standards or operating practice requirements imposed by the Department, except as precluded by §§ 6.6(d)(2) and (3) of the Air Pollution Control Act [35 P.S. § 4006.6(d)(2) and (3)].

(b) A person challenging a performance or emission standard established by the Department has the burden to demonstrate that performance or emission standard does not meet the requirements of Section 112 of the Clean Air Act.

**#017 [25 Pa. Code § 121.9]****Circumvention.**

No person may permit the use of a device, stack height which exceeds good engineering practice stack height, dispersion technique or other technique which, without resulting in reduction of the total amount of air contaminants emitted, conceals or dilutes an emission of air contaminants which would otherwise be in violation of 25 Pa. Code Article III, except that with prior approval of the Department, the device or technique may be used for control of malodors.

**#018 [25 Pa. Code §§ 127.402(d) & 127.442]****Reporting Requirements.**

(a) The permittee shall comply with the applicable reporting requirements of the Clean Air Act, the regulations thereunder, the Air Pollution Control Act and 25 Pa. Code Article III including Chapters 127, 135 and 139.

(b) The permittee shall submit reports to the Department containing information the Department may prescribe relative to the operation and maintenance of any air contamination source.

(c) Reports, test data, monitoring data, notifications and requests for renewal of the permit shall be submitted to the:

Regional Air Program Manager  
PA Department of Environmental Protection  
(At the address given in the permit transmittal letter, or otherwise notified)

(d) Any records or information including applications, forms, or reports submitted pursuant to this permit condition shall contain a certification by a responsible official as to truth, accuracy and completeness. The certifications submitted under this permit shall require a responsible official of the facility to certify that based on information and belief formed after reasonable inquiry, the statements and information in the documents are true, accurate and complete.

(e) Any records, reports or information submitted to the Department shall be available to the public except for such

**SECTION B. General State Only Requirements**

records, reports or information which meet the confidentiality requirements of § 4013.2 of the Air Pollution Control Act and §§ 112(d) and 114(c) of the Clean Air Act. The permittee may not request a claim of confidentiality for any emissions data generated for the facility.

**#019 [25 Pa. Code §§ 127.441(c) & 135.5]****Sampling, Testing and Monitoring Procedures.**

(a) The permittee shall comply with the monitoring, recordkeeping or reporting requirements of 25 Pa. Code Chapter 139 and the other applicable requirements of 25 Pa. Code Article III and additional requirements related to monitoring, reporting and recordkeeping required by the Clean Air Act and the regulations thereunder including the Compliance Assurance Monitoring requirements of 40 CFR Part 64, where applicable.

(b) Unless alternative methodology is required by the Clean Air Act and regulations adopted thereunder, sampling, testing and monitoring required by or used by the permittee to demonstrate compliance with any applicable regulation or permit condition shall be conducted in accordance with the requirements of 25 Pa. Code Chapter 139.

**#020 [25 Pa. Code §§ 127.441(c) and 135.5]****Recordkeeping.**

(a) The permittee shall maintain and make available, upon request by the Department, the following records of monitored information:

- (1) The date, place (as defined in the permit) and time of sampling or measurements.
- (2) The dates the analyses were performed.
- (3) The company or entity that performed the analyses.
- (4) The analytical techniques or methods used.
- (5) The results of the analyses.
- (6) The operating conditions as existing at the time of sampling or measurement.

(b) The permittee shall retain records of any required monitoring data and supporting information for at least five (5) years from the date of the monitoring, sample, measurement, report or application. Supporting information includes the calibration data and maintenance records and original strip-chart recordings for continuous monitoring instrumentation, and copies of reports required by the permit.

(c) The permittee shall maintain and make available to the Department upon request, records including computerized records that may be necessary to comply with the reporting, recordkeeping and emission statement requirements in 25 Pa. Code Chapter 135 (relating to reporting of sources). In accordance with 25 Pa. Code Chapter 135, § 135.5, such records may include records of production, fuel usage, maintenance of production or pollution control equipment or other information determined by the Department to be necessary for identification and quantification of potential and actual air contaminant emissions.

**#021 [25 Pa. Code § 127.441(a)]****Property Rights.**

This permit does not convey any property rights of any sort, or any exclusive privileges.

**#022 [25 Pa. Code § 127.447]****Alternative Operating Scenarios.**

The permittee is authorized to make changes at the facility to implement alternative operating scenarios identified in this permit in accordance with 25 Pa. Code § 127.447.

**SECTION B. General State Only Requirements****#023 [25 Pa. Code §135.3]****Reporting**

(a) If the facility is a Synthetic Minor Facility, the permittee shall submit by March 1 of each year an annual emissions report for the preceding calendar year. The report shall include information for all active previously reported sources, new sources which were first operated during the preceding calendar year, and sources modified during the same period which were not previously reported. All air emissions from the facility should be estimated and reported.

(b) A source owner or operator of a Synthetic Minor Facility may request an extension of time from the Department for the filing of an annual emissions report, and the Department may grant the extension for reasonable cause.

**#024 [25 Pa. Code §135.4]****Report Format**

If applicable, the emissions reports shall contain sufficient information to enable the Department to complete its emission inventory. Emissions reports shall be made by the source owner or operator in a format specified by the Department.

**SECTION C. Site Level Requirements****I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §121.7]****Prohibition of air pollution.**

No person may permit air pollution as that term is defined in the Air Pollution Control Act 35 P.S. (Section 4003).

**# 002 [25 Pa. Code §123.1]****Prohibition of certain fugitive emissions**

(a) No person may permit the emission into the outdoor atmosphere of fugitive air contaminant from a source other than the following:

- (1) Construction or demolition of buildings or structures.
- (2) Grading, paving and maintenance of roads and streets.
- (3) Use of roads and streets. Emissions from material in or on trucks, railroad cars and other vehicular equipment are not considered as emissions from use of roads and streets.
- (4) Clearing of land.
- (5) Stockpiling of materials.
- (6) Open burning operations, as specified in 25 Pa. Code § 129.14.
- (7) N/A
- (8) N/A

(9) Sources and classes of sources other than those identified in (1)-(8) of this condition, for which the permittee has obtained a determination from the Department that fugitive emissions from the source, after appropriate control, meet the following requirements:

- (i) The emissions are of minor significance with respect to causing air pollution; and
- (ii) The emissions are not preventing or interfering with the attainment or maintenance of any ambient air quality standard.

**# 003 [25 Pa. Code §123.2]****Fugitive particulate matter**

A person may not permit fugitive particulate matter to be emitted into the outdoor atmosphere from a source specified in 25 Pa. Code § 123.1(a) (relating to prohibition of certain fugitive emissions) if such emissions are visible at the point the emissions pass outside the person's property

**# 004 [25 Pa. Code §123.31]****Limitations**

A person may not permit the emission into the outdoor atmosphere of any malodorous air contaminants from any source in such a manner that the malodors are detectable outside the property of the person on whose land the source is being operated.

**# 005 [25 Pa. Code §123.41]****Limitations**

A person may not permit the emission into the outdoor atmosphere of visible air contaminants in such a manner that the opacity of the emission is either of the following:

- (a) Equal to or greater than 20% for a period or periods aggregating more than three minutes in any 1 hour.
- (b) Equal to or greater than 60% at any time.

**# 006 [25 Pa. Code §123.42]****Exceptions**

The opacity limitations as per 25 Pa. Code § 123.41 shall not apply to a visible emission in either of the following instances:

- (a) When the presence of uncombined water is the only reason for failure to meet the limitations.
- (b) When the emission results from the operation of equipment used solely to train and test persons in observing the opacity of visible emissions.
- (c) When the emission results from the sources specified in 25 Pa. Code § 123.1(a)(1)-(8) (relating to prohibition of certain fugitive emissions).

**SECTION C. Site Level Requirements****# 007 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall limit total facility-wide VOC emissions to 24.9 tons per year, based on a 12-month rolling sum.

**# 008 [25 Pa. Code §129.14]****Open burning operations**

No person may permit the open burning of material in the Southeast Air Basin except where the open burning operations result from:

- (a) a fire set to prevent or abate a fire hazard, when approved by the Department and set by or under the supervision of a public officer;
- (b) any fire set for the purpose of instructing personnel in fire fighting, when approved by the Department;
- (c) a fire set for the prevention and control of disease or pests, when approved by the Department;
- (d) a fire set in conjunction with the production of agricultural commodities in their unmanufactured state on the premises of the farm operation;
- (e) a fire set for the purpose of burning domestic refuse, when the fire is on the premises of a structure occupied solely as a dwelling by two families or less and when the refuse results from the normal occupancy of the structure;
- (f) a fire set solely for recreational or ceremonial purposes; or
- (g) a fire set solely for cooking food.

**II. TESTING REQUIREMENTS.****# 009 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) If at any time the Department has cause to believe that air contaminant emissions from any source may be in excess of the limitations specified in this Permit, or established pursuant to, any applicable rule or regulation contained in 25 Pa. Code Article III, the permittee shall be required to conduct whatever tests are deemed necessary by the Department to determine the actual emission rate(s).

(b) Such testing shall be conducted in accordance with the provisions of 25 Pa. Code Chapter 139 and the most current version of the DEP Source Testing Manual, when applicable, and in accordance with any restrictions or limitations established by the Department at such time as it notifies the permittee that testing is required.

**# 010 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) The permittee shall submit one paper copy plus one electronic copy of all source test submissions (notifications, protocols, reports, supplemental information, etc.) to both the AQ Program Manager for the Southeast Regional Office and the PSIMS Administrator in Central Office (mail and email addresses are provided below). Any questions or concerns about source testing submissions can be sent to RA-EPstacktesting@pa.gov and the PSIMS Administrator will address them.

(b) The following pertinent information shall be listed on the title page.

1. Test Date(s)

- a. For protocols, provide the proposed date on which testing will commence or "TBD"
- b. For reports, provide the first and last day of testing

2. Facility Identification Number (Facility - ID): For test programs that were conducted under a multi-site protocol, also include the PF Id under which the protocol was stored in PSIMS, as indicated in the protocol response letter.

3. Source ID(s) for the applicable source(s) and air pollution control device(s): The term Source ID is used in the permit but "Other Id" is used in DEP electronic systems. They are the same number and must also be listed for control equipment

**SECTION C. Site Level Requirements**

## 4. Testing Requirements (all that apply)

- a. Plan approval number(s)
- b. Operating permit number
- c. Applicable federal subpart(s) (i.e. 40 CFR 60, Subpart JJJJ)
- d. Special purpose(s) (Consent Order, RFD, RACT II, Tier II, etc.)

- (c) Mail all paper submissions to both the PSIMS Administrator and the Air Quality Program Manager for the Southeast Regional Office. Mailing addresses are provided below.

Central Office  
 Pennsylvania Department of Environmental Protection  
 Attn: PSIMS Administrator  
 P.O. Box 8468  
 Harrisburg, PA 17105-8468

Southeast Region  
 Pennsylvania Department of Environmental Protection  
 Attn: Air Quality Program Manager  
 2 East Main Street  
 Norristown, PA 19401

- (d) Eliminate shading, color ink for data emphasis, small font size, and color saturation as the scanning to create an electronic file is done in black and white. Shading and color emphasis do not scan well and make the electronic copies difficult to read.
- (e) Email all electronic submissions to both the PSIMS Administrator in Central Office and the Air Quality Program Manager for the Southeast Regional Office. Email addresses are provided below.

Central Office  
 RA-EPstacktesting@pa.gov

Southeast Region  
 RA-EPSEstacktesting@pa.gov

- (f) The Department limits emails to 15 MB and PSIMS has a file size limitation of 100 MB for electronic files. Submit just one electronic file (convert any Microsoft Word or Excel files to an Adobe PDF format and combine them with the report or protocol), unless the submission contains CONFIDENTIAL information.
- (g) If confidential information must be submitted, submit both a public copy, which has been redacted, and a confidential copy. The cover page of each submittal should state whether it is a "Public Copy" or "Confidential Copy" and each page of the latter must be marked "CONFIDENTIAL".

**III. MONITORING REQUIREMENTS.****# 011 [25 Pa. Code §123.43]****Measuring techniques**

Visible emissions may be measured using either of the following:

- (a) a device approved by the Department and maintained to provide accurate opacity measurements; or
- (b) observers, trained and qualified to measure plume opacity with the naked eye or with the aid of any devices approved by the Department.



**SECTION C. Site Level Requirements****# 012 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) The permittee shall monitor the facility, once per operating day, for the following:

- (1) odors which may be objectionable (as per 25 Pa. Code §123.31);
- (2) visible emissions (as per 25 Pa. Code §§123.41 and 123.42); and
- (3) fugitive particulate matter (as per 25 Pa. Code §§ 123.1 and 123.2).

(b) Objectionable odors, fugitive particulate emissions, and visible emissions that are caused or may be caused by operations at the site shall:

- (1) be investigated;
- (2) be reported to the facility management, or individual(s) designated by the permittee;
- (3) have appropriate corrective action taken (for emissions that originate on-site); and
- (4) be recorded in a permanent written log.

(c) After six (6) months of daily monitoring, and upon the permittee's request, the Department will determine the feasibility of decreasing the monitoring frequency to weekly.

(d) After six (6) months of weekly monitoring, and upon the permittee's request, the Department will determine the feasibility of decreasing the frequency of monitoring to monthly.

(e) The Department reserves the right to change the above monitoring requirements at any time, based on but not limited to: the review of the compliance certification (if applicable), complaints, monitoring results, and/or Department findings.

**IV. RECORDKEEPING REQUIREMENTS.****# 013 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall maintain sufficient records and perform calculations demonstrating compliance with the VOC emission limit from all sources, on a monthly and 12-month rolling basis.

**# 014 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall maintain a record of all monitoring of fugitive emissions, visible emissions and odors, including those that deviate from the conditions found in this permit. The record of deviations shall contain, at a minimum, the following items:

- (a) Date, time, and location of the incident(s).
- (b) The cause of the event.
- (c) The corrective action taken, if necessary to abate the situation and prevent future occurrences.

**# 015 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall maintain records of all the facility's increases of emissions from the following categories:

- (a) De minimis increases without notification to the Department.
- (b) De minimis increases with notification to the Department, via letter.
- (c) Increases resulting from a Request for Determination (RFD) to the Department.
- (d) Increases resulting from the issuance of a plan approval and subsequent operating permit.

**SECTION C. Site Level Requirements****V. REPORTING REQUIREMENTS.****# 016 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) The permittee shall report malfunctions, emergencies or incidents of excess emissions to the Department. A malfunction is any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner. An emergency is any situation arising from sudden and reasonably unforeseeable events beyond the control of the owner or operator of a facility which requires immediate corrective action to restore normal operation and which causes the emission source to exceed emissions, due to unavoidable increases in emissions attributable to the situation. An emergency shall not include situations caused by improperly designed equipment, lack of preventive maintenance, careless or improper operation, or operator error.

(b) When the malfunction, emergency or incident of excess emissions poses an imminent danger to the public health, safety, welfare, or environment, it shall be reported to the Department and the County Emergency Management Agency by telephone within one (1) hour after the discovery of the malfunction, emergency or incident of excess emissions. The owner or operator shall submit a written or emailed report of instances of such malfunctions, emergencies or incidents of excess emissions to the Department within three (3) business days of the telephone report.

Please direct call to the Department to:  
DEP Regional Office Air Program Manager  
484-250-5920

(c) The report shall describe the following:

- (1) Name, permit or authorization number, and location of the facility;
- (2) Nature and cause of the malfunction, emergency or incident;
- (3) Date and time when the malfunction, emergency or incident was first observed;
- (4) Expected duration of excess emissions;
- (5) Estimated rate of emissions; and
- (6) Corrective actions or preventative measures taken.

(d) Any malfunction, emergency or incident of excess emissions that is not subject to the notice requirements of paragraph (b) of this condition shall be reported to the Department by telephone within 24 hours (or by 4:00 PM of the next business day, whichever is later) of discovery and in writing or by e-mail within five (5) business days of discovery. The report shall contain the same information required by paragraph (c), and any permit specific malfunction reporting requirements.

(e) During an emergency an owner or operator may continue to operate the source at their discretion provided they submit justification for continued operation of a source during the emergency and follow all the notification and reporting requirements in accordance with paragraphs (b)-(d), as applicable, including any permit specific malfunction reporting requirements.

(f) Reports regarding malfunctions, emergencies or incidents of excess emissions shall be submitted to the appropriate DEP Regional Office Air Program Manager.

(g) Any emissions resulted from malfunction or emergency are to be reported in the annual emissions inventory report, if the annual emissions inventory report is required by permit or authorization.

**# 017 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) If required by Section 112(r) of the Clean Air Act, the permittee shall develop and implement an accidental release program consistent with requirements of the Clean Air Act, 40 CFR Part 68 (relating to chemical accident prevention provisions) and the Federal Chemical Safety Information, Site Security and Fuels Regulatory Relief Act (P.L. 106-40).

(b) The permittee shall prepare and implement a Risk Management Plan (RMP) which meets the requirements of Section 112(r) of the Clean Air Act, 40 CFR Part 68 and the Federal Chemical Safety Information, Site Security and Fuels Regulatory Relief Act when a regulated substance listed in 40 CFR § 68.130 is present in a process in more than the threshold quantity at a facility. The permittee shall submit the RMP to the federal Environmental Protection Agency according to the

**SECTION C. Site Level Requirements**

following schedule and requirements:

- (1) The permittee shall submit the first RMP to a central point specified by EPA no later than the latest of the following:
  - (i) Three years after the date on which a regulated substance is first listed under 40 CFR § 68.130; or,
  - (ii) The date on which a regulated substance is first present above a threshold quantity in a process.
- (2) The permittee shall submit any additional relevant information requested by the Department or EPA concerning the RMP and shall make subsequent submissions of RMPs in accordance with 40 CFR § 68.190.
- (3) The permittee shall certify that the RMP is accurate and complete in accordance with the requirements of 40 CFR Part 68, including a checklist addressing the required elements of a complete RMP.
- (c) As used in this permit condition, the term "process" shall be as defined in 40 CFR § 68.3. The term "process" means any activity involving a regulated substance including any use, storage, manufacturing, handling, or on-site movement of such substances or any combination of these activities. For purposes of this definition, any group of vessels that are interconnected, or separate vessels that are located such that a regulated substance could be involved in a potential release, shall be considered a single process.
- (d) If this facility is subject to 40 CFR Part 68, as part of the certification required under this permit, the permittee shall:
  - (1) Submit a compliance schedule for satisfying the requirements of 40 CFR Part 68 by the date specified in 40 CFR § 68.10(a); or,
  - (2) Certify that this facility is in compliance with all requirements of 40 CFR Part 68 including the registration and submission of the RMP.
- (e) If this facility is subject to 40 CFR Part 68, the permittee shall maintain records supporting the implementation of an accidental release program for five (5) years in accordance with 40 CFR § 68.200.
- (f) When this facility is subject to the accidental release program requirements of Section 112(r) of the Clean Air Act and 40 CFR Part 68, appropriate enforcement action will be taken by the Department if the permittee fails to register and submit the RMP or a revised plan pursuant to 40 CFR Part 68.

**VI. WORK PRACTICE REQUIREMENTS.****# 018 [25 Pa. Code §123.1]****Prohibition of certain fugitive emissions**

A person responsible for any source specified 25 Pa. Code § 123.1 shall take all reasonable actions to prevent particulate matter from becoming airborne. These actions shall include, but not be limited to, the following

- (a) Use, where possible, of water or suitable chemicals, for control of dust in the demolition of buildings or structures, construction operations, the grading of roads, or the clearing of land.
- (b) Application of asphalt, water, or other suitable chemicals, on dirt roads, material stockpiles and other surfaces which may give rise to airborne dusts.
- (c) Paving and maintenance of roadways.
- (d) Prompt removal of earth or other material from paved streets onto which earth or other material has been transported by trucking or earth moving equipment, erosion by water, or by other means.

**# 019 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall ensure that the source(s) and air pollution control device(s), listed in this permit, where applicable, of

**SECTION C. Site Level Requirements**

this permit, are operated and maintained in a manner consistent with good operating and maintenance practices, and in accordance with manufacturer's specifications.

**# 020 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall immediately, upon discovery, implement measures, which may include the application for the installation of an air cleaning device(s), if necessary, to reduce the air contaminant emissions to within applicable limitations, if at any time the operation of the source(s) identified in this permit, is causing the emission of air contaminants in excess of the limitations specified in, or established pursuant to, 25 Pa. Code Article III or any other applicable rule promulgated under the Clean Air Act.

**# 021 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee may not modify any air contaminant source identified in this permit, prior to obtaining Department approval, except those modifications authorized by Condition #013(g) of Section B, of this permit.

**VII. ADDITIONAL REQUIREMENTS.****# 022 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee is required to:

1. Calculate the potential VOC emissions from each flexible packaging and letterpress printing press operation in accordance with 25 Pa. Code §§129.67a(a)(1)(i) and 129.67b(a)(1)(i).
2. Submit the calculations to DEP; and
3. Modify the operating permit to incorporate additional requirements under 25 Pa. Code §§129.67a and 129.67b if the potential VOC emissions are 25 tpy or greater from each flexible packaging or letterpress printing operation.

**VIII. COMPLIANCE CERTIFICATION.**

No additional compliance certifications exist except as provided in other sections of this permit including Section B (relating to State Only General Requirements).

**IX. COMPLIANCE SCHEDULE.**

No compliance milestones exist.


**SECTION D. Source Level Requirements**

Source ID: 101

Source Name: ROTOGRAVURE 1 PRESS, 14" GRAVURE

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 1  
GROUP 4

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**SECTION D. Source Level Requirements**


Source ID: 102

Source Name: FLEXOGRAPHIC 3 PRESS, FLEXO GALLUS

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 1

GROUP 4

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**SECTION D. Source Level Requirements**


Source ID: 103

Source Name: ROTOGRAVURE 46 PRESS, 21" INTRA ROTO

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 1

GROUP 4

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).


**SECTION D. Source Level Requirements**

Source ID: 104

Source Name: FLEXOGRAPHIC 9 PRESS, 6.5 WEBTRON

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 1  
GROUP 4

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).




**SECTION D. Source Level Requirements**

Source ID: 105

Source Name: FLEXOGRAPHIC 31 PRESS, 17.5" PROPHETEER

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 1  
GROUP 4

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**SECTION D. Source Level Requirements**


Source ID: 106

Source Name: FLEXOGRAPHIC 63 PRESS, 7" FLEXO ALLIED

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 1

GROUP 4

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**SECTION D. Source Level Requirements**


Source ID: 108

Source Name: FLEXOGRAPHIC NO. 70 PRESS, JULIET 608

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 1

GROUP 4

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).


**SECTION D. Source Level Requirements**

Source ID: 109

Source Name: LETTERPRESS 120, HEIDELBERG 18"X23"

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 1

**I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Authority for this condition is derived from 25 Pa. Code §129.67b(a)(1)(v)]

Emissions below 450 pounds per month and 2.7 tons per 12-month rolling period.

The total actual VOC emissions from all inks (including varnishes), coatings, adhesives and fountain solutions combined from all offset lithographic printing presses, all letterpress printing presses and all VOC emissions from related cleaning activities at the facility are less than 450 pounds (204.1 kilograms) per month and 2.7 tons (2,455 kilograms) per 12-month rolling period, before consideration of add-on controls.

**II. TESTING REQUIREMENTS.****# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Authority for this condition is derived from 25 Pa. Code §129.67b(h)(1)(i) and (3)]

(1) Sampling of an ink, varnish, coating, fountain solution or cleaning solution and testing for the VOC content of the ink, varnish, coating, fountain solution or cleaning solution shall be performed in accordance with the procedures and test methods specified in Chapter 139.

(2) Other test methods demonstrated to provide results that are acceptable for purposes of determining compliance with this section may be used if prior approval is obtained in writing from the Department and the EPA.

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**IV. RECORDKEEPING REQUIREMENTS.****# 003 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Authority for this condition is derived from 25 Pa. Code §§129.67b(f)(3) and (4)]

Recordkeeping requirements. The owner or operator of a printing press subject to 25 Pa. Code 129.67b shall maintain records sufficient to demonstrate compliance. Records maintained for compliance demonstrations may include purchase, use, production and other records.

(1) An owner or operator claiming exemption from a VOC control provision of this section based on potential or actual VOC emissions, as applicable, shall maintain records that demonstrate to the Department that the press or facility is exempt.

(2) The owner or operator may group materials into classes using the highest VOC content in any material in a class to represent that class of material.

**SECTION D. Source Level Requirements****V. REPORTING REQUIREMENTS.****# 004 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Authority for this condition is derived from 25 Pa. Code §129.67b(g)(1)]

The owner or operator of an offset lithographic printing press or a letterpress printing press subject to 25 Pa. Code §129.67b shall meet the following reporting requirements:

(1) The records required under Pa. Code 129.67b(f) shall be maintained onsite for 2 years unless a longer period is required by a plan approval or operating permit issued under Chapter 127 (relating to construction, modification, reactivation and operation of sources). The records shall be submitted to the Department in an acceptable format upon receipt of a written request.

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**SECTION D. Source Level Requirements**

Source ID: 110


Source Name: FLEXOGRAPHIC 74 PRESS, 24" W/ ROTARY SCREEN

Source Capacity/Throughput:

N/A

INK

Conditions for this source occur in the following groups: GROUP 4

**I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall limit VOC emissions from this press (including clean-up operations) to 1.25 tons per year based on a 12-month rolling sum.

**II. TESTING REQUIREMENTS.****# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) The permittee shall use data from Certified Product Data Sheets (CPDS), Safety Data Sheets (SDS), or batch specification sheets to calculate emissions of Volatile Organic Compounds (VOC) and Hazardous Air Pollutants (HAP) from this source.

(b) The permittee, as an alternative to the CPDS, SDS, and batch specification sheets may use USEPA Method 24 (or any subsequent USEPA approved method) to determine the VOC and HAP content of the inks or coatings.

Note: Compliance with this testing condition assures compliance with 25 Pa. Code §§ 129.67a(f)(1) and (2).

**III. MONITORING REQUIREMENTS.****# 003 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) The permittee shall monitor the amount and type of inks, coatings, and solvents used in gallons or pounds, per job.

(b) The permittee shall monitor the amount of cleanup solvents used on a monthly basis.

(c) The following shall be monitored for each ink, coating, and solvent:

- (1) Weight per gallon, as supplied
- (2) Percent (by weight) of volatile organic compounds (VOCs) per gallon, as supplied
- (3) Percent solids (by weight) per gallon, as supplied
- (4) Percent water and exempt solvents (by weight), as supplied
- (5) VOC density (lb of VOC/gal of VOC), as supplied

(d) The permittee shall monitor the hours of operation for this source on a monthly basis.

**IV. RECORDKEEPING REQUIREMENTS.****# 004 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) The permittee shall maintain records of the amount and type of inks, coatings, and solvents used in gallons or pounds, per job.

**SECTION D. Source Level Requirements**

- (b) The permittee shall maintain the amount of cleanup solvents used on a monthly basis.
- (c) The following records shall be maintained for each ink, coating, and solvent:
- (1) Weight per gallon, as supplied
  - (2) Percent (by weight) of volatile organic compounds (VOCs) per gallon, as supplied
  - (3) Percent solids (by weight) per gallon, as supplied
  - (4) Percent water and exempt solvents (by weight), as supplied
  - (5) VOC density (lb of VOC/gal of VOC), as supplied
- (d) The permittee shall maintain records of the hours of operation for this source on a monthly basis.
- (e) The permittee shall maintain records of the CPDS, SDS, or batch specification sheets for all inks, coatings, and solvents used.
- (f) The permittee shall calculate and maintain records of VOC emissions from the press on a monthly, and 12-month rolling basis.

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VI. WORK PRACTICE REQUIREMENTS.****# 005 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall operate and maintain this press in accordance with manufacturer's specifications and good air pollution control practices.

**# 006 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The following work practice standards shall be followed:

- (a) all VOC-containing materials shall be stored in closed, nonabsorbent, non-leaking containers when not being mixed or transferred to another container;
- (b) cloth and paper, or other absorbent applicators, moistened with coatings, solvents or cleaning solvents, shall be stored in closed, nonabsorbent, non-leaking containers; and
- (c) all spills shall be cleaned up as soon as possible.

Compliance with 25 Pa. Code §§ 129.67a(g)(1), (2) and (3) under Group 4 sources assures compliance with this condition.

**VII. ADDITIONAL REQUIREMENTS.****# 007 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The source consists of a 2-color flexographic printing press, manufactured by Gonderflex, with 2 printing stations, 24" web width, 300 fpm line speed. This press is equipped with a rotary screen unit, manufactured by SPG Prints.


**SECTION D. Source Level Requirements**

Source ID: 201

Source Name: COLD DEGREASER 2

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 2

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VII. ADDITIONAL REQUIREMENTS.****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

This source consists of a solvent tank with steel construction from Graymills. Model is 300A. Pump has been removed. Inside Tank Dimensions 21" x 44" x 23.75(H)". Designed for 42 gallons with pump.




**SECTION D. Source Level Requirements**

Source ID: 202

Source Name: COLD DEGREASER

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 2

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VII. ADDITIONAL REQUIREMENTS.****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

This source consists of a stainless steel solvent tank from Graymills. Model is TURBO 4330 (special part # with stainless steel construction and without the pump was TS4330-F). Inside Tank Dimensions: 27.5" x 56.5" x 63(H)". Designed for 142 gallons of liquid (with pump).

**SECTION D. Source Level Requirements**


Source ID: 204

Source Name: ULTRASONIC CLEANER

Source Capacity/Throughput:

0.156 Lbs/HR

DYNASOLVE

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**III. MONITORING REQUIREMENTS.****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall monitor:

- (a) The amount and type of solvent used in the ultrasonic cleaner on a monthly and 12-month rolling basis.
- (b) VOC emissions from the ultrasonic cleaner on a monthly and 12-month rolling basis.

**IV. RECORDKEEPING REQUIREMENTS.****# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall maintain records of:

- (a) The amount and type of solvent used in the ultrasonic cleaner on a monthly and 12-month rolling basis.
- (b) SDS/CPDS sheets for the solvent(s) used in the ultrasonic cleaner.
- (c) VOC emissions from the ultrasonic cleaner on a monthly and 12-month rolling basis.

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VI. WORK PRACTICE REQUIREMENTS.****# 003 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

- (a) The ultrasonic cleaner shall be kept covered at all times when the unit is not in use.
- (b) Spills during solvent transfer and use of the ultrasonic cleaner shall be cleaned up immediately.
- (c) Waste solvent shall be collected and stored in closed containers.

**SECTION D. Source Level Requirements**

(d) This source shall be operated and maintained in accordance with manufacturer's specifications and good operating practices.

**VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**SECTION D. Source Level Requirements**

Source ID: 205

Source Name: 20 KW EMERGENCY GENERATOR ENGINE

Source Capacity/Throughput: 300.000 CF/HR Natural Gas

Conditions for this source occur in the following groups: GROUP 3

**I. RESTRICTIONS.****Fuel Restriction(s).**

# 001 [25 Pa. Code §127.441]

**Operating permit terms and conditions.**

The permittee shall only use natural gas as fuel for this source.

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**III. MONITORING REQUIREMENTS.**

# 002 [25 Pa. Code §127.441]

**Operating permit terms and conditions.**

The permittee shall monitor the hours of operation for this source on a monthly and 12-month rolling basis.

**IV. RECORDKEEPING REQUIREMENTS.**

# 003 [25 Pa. Code §127.441]

**Operating permit terms and conditions.**

The permittee shall maintain records of the following:

- (a) Hours of operation for this source on a monthly and 12-month rolling basis.
- (b) All maintenance and inspection activities conducted to demonstrate compliance with the work practice standards.
- (c) NO<sub>x</sub> emission calculations on a monthly and 12-month rolling basis.

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VI. WORK PRACTICE REQUIREMENTS.**

# 004 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6603]

**Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines**

**SECTION D. Source Level Requirements****What emission limitations, operating limitations, and other requirements must I meet if I own or operate an existing stationary RICE located at an area source of HAP emissions?**

[Additional authority for the following work practice standards are derived from Table 2d of the RICE MACT: 40 C.F.R Part 63, Subpart ZZZZ.]

The permittee shall:

- (a) Change oil and filter every 500 hours of operation or annually, whichever comes first;
- (b) Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and
- (c) Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.

**# 005 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6625]****Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines****What are my monitoring, installation, operation, and maintenance requirements?**

This source shall be equipped with a non-resettable hour meter.

**VII. ADDITIONAL REQUIREMENTS.****# 006 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

This source consists of one (1) 20 kW natural gas-fired emergency electric generator engine manufactured by Ford, Model No. LRG-425I-6005-A. 2.5 L, 153 CID. The engine build date is 02/12/2001. The engine is rated at 70 hp.

**# 007 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6640]****Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines****How do I demonstrate continuous compliance with the emission limitations, operating limitations, and other requirements?**

- (a) The permittee shall operate the emergency stationary R.I.C.E. according to the requirements in the most recent version of 40 C.F.R. Section 63.6640(f).
- (b) If the permittee does not operate the engine according to the requirements of 40 C.F.R. Section 63.6640(f), the engine will not be considered an emergency engine under 40 C.F.R. Part 63 Subpart ZZZZ and must meet all requirements for non-emergency engines.

**SECTION D. Source Level Requirements**

Source ID: 206

Source Name: DIESEL ICE - EMERGENCY GENERATOR IT

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 3

**I. RESTRICTIONS.****Emission Restriction(s).**

**# 001 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4205]  
Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines  
What emission standards must I meet for emergency engines if I am an owner or operator of a stationary CI internal co**

Owners and operators of 2007 model year and later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new nonroad CI engines in § 60.4202, for all pollutants, for the same model year and maximum engine power for their 2007 model year and later emergency stationary CI ICE.

NMHC+NO<sub>x</sub> - 4.7 g/kW-hr

CO - 5.0 g/kW-hr

PM - 0.40 g/kW-hr

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**III. MONITORING REQUIREMENTS.**

**# 002 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4209]  
Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines  
What are the monitoring requirements if I am an owner or operator of a stationary CI internal combustion engine?**

The owner or operator of an emergency stationary CI internal combustion engine that does not meet the standards applicable to non-emergency engines must install a non-resettable hour meter prior on the engine.

**IV. RECORDKEEPING REQUIREMENTS.**

**# 003 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4214]  
Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines  
What are my notification, reporting, and recordkeeping requirements if I am an owner or operator of a stationary CI internal combustion engine?**

If the stationary CI internal combustion engine is an emergency stationary internal combustion engine, the owner or operator is not required to submit an initial notification. Starting with the model years in table 5 to this subpart, if the emergency engine does not meet the standards applicable to non-emergency engines in the applicable model year, the owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time.

**SECTION D. Source Level Requirements****V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VI. WORK PRACTICE REQUIREMENTS.****# 004 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4211]****Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines****What are my compliance requirements if I am an owner or operator of a stationary CI internal combustion engine?**

If you are an owner or operator and must comply with the emission standards specified in this subpart, you must do all of the following, except as permitted under paragraph (4) of this section:

(1) Operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instructions;

(2) Change only those emission-related settings that are permitted by the manufacturer; and

(3) Meet the requirements of 40 CFR part 1068, as they apply to you.

(4) If you do not install, configure, operate, and maintain your engine and control device according to the manufacturer's emission-related written instructions, or you change emission-related settings in a way that is not permitted by the manufacturer, you must demonstrate compliance as follows:

(a) If you are an owner or operator of a stationary CI internal combustion engine with maximum engine power less than 100 HP, you must keep a maintenance plan and records of conducted maintenance to demonstrate compliance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, if you do not install and configure the engine and control device according to the manufacturer's emission-related written instructions, or you change the emission-related settings in a way that is not permitted by the manufacturer, you must conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of such action.

**# 005 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6590]****Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines****What parts of my plant does this subpart cover?**

Stationary RICE subject to Regulations under 40 CFR Part 60. A new or reconstructed stationary RICE located at an area source must meet the requirements of 40 CFR 63 Part ZZZZ by meeting the requirements of 40 CFR part 60 subpart IIII.

**VII. ADDITIONAL REQUIREMENTS.****# 006 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

Cummins Engine

Date of manufacture: October 5, 2020

Installation date: March 2021

Model 4BT3.3-G5

ESN 72055536

69 hp, 51.4 kW

**# 007 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4200]****Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines****Am I subject to this subpart?**

Owners and operators of stationary CI ICE that commence construction after July 11, 2005, where the stationary CI ICE are manufactured after April 1, 2006, and are not fire pump engines are subject to 40 CFR Part 60, Subpart IIII.

**SECTION D. Source Level Requirements****# 008 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4207]****Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines****What fuel requirements must I meet if I am an owner or operator of a stationary CI internal combustion engine subject to this subpart?**

Beginning October 1, 2010, owners and operators of stationary CI ICE subject to this subpart with a displacement of less than 30 liters per cylinder that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 1090.305 for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to October 1, 2010, may be used until depleted.

## §1090.305 ULSD standards

- (a) Overview. Except as specified in §1090.300(a), diesel fuel must meet the ULSD per-gallon standards of this section.
- (b) Sulfur standard. Maximum sulfur content of 15 ppm.
- (c) Cetane index or aromatic content. Diesel fuel must meet one of the following standards:
  - (1) Minimum cetane index of 40.
  - (2) Maximum aromatic content of 35 volume percent




**SECTION D. Source Level Requirements**

Source ID: 207

Source Name: DIESEL ICE - FIRE PUMP

Source Capacity/Throughput:

Conditions for this source occur in the following groups: GROUP 3

**I. RESTRICTIONS.****Emission Restriction(s).**

**# 001 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4205]  
Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines  
What emission standards must I meet for emergency engines if I am an owner or operator of a stationary CI internal co**

Owners and operators of fire pump engines with a displacement of less than 30 liters per cylinder must comply with the emission standards listed below:

NMHC - 4.06/kW-hr  
PM - 0.20 g/kW-hr

**# 002 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4211]  
Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines  
What are my compliance requirements if I am an owner or operator of a stationary CI internal combustion engine?**

If you are an owner or operator of a 2007 model year and later stationary CI internal combustion engine and must comply with the emission standards specified in § 60.4204(b) or § 60.4205(b), or if you are an owner or operator of a CI fire pump engine that is manufactured during or after the model year that applies to your fire pump engine power rating in table 3 to this subpart and must comply with the emission standards specified in 40 CFR § 60.4205(c), you must comply by purchasing an engine certified to the emission standards in 40 CFR § 60.4204(b), or § 60.4205(b) or (c), as applicable, for the same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power. The engine must be installed and configured according to the manufacturer's emission-related specifications, except as permitted in 40 CFR § 60.4211(g).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**III. MONITORING REQUIREMENTS.**

**# 003 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4209]  
Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines  
What are the monitoring requirements if I am an owner or operator of a stationary CI internal combustion engine?**

If you are an owner or operator of an emergency stationary CI internal combustion engine that does not meet the standards applicable to non-emergency engines, you must install a non-resettable hour meter prior to startup of the engine.

**IV. RECORDKEEPING REQUIREMENTS.**

**# 004 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4214]  
Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines  
What are my notification, reporting, and recordkeeping requirements if I am an owner or operator of a stationary CI internal combustion engine?**

**SECTION D. Source Level Requirements**

If the stationary CI internal combustion engine is an emergency stationary internal combustion engine, the owner or operator is not required to submit an initial notification. Starting with the model year 2011, if the emergency engine does not meet the standards applicable to non-emergency engines in the applicable model year, the owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time.

**V. REPORTING REQUIREMENTS.****# 005 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4214]****Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines****What are my notification, reporting, and recordkeeping requirements if I am an owner or operator of a stationary CI internal combustion engine?**

If you own or operate an emergency stationary CI ICE with a maximum engine power more than 100 HP that operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 60.4211(f)(2)(ii) and (iii) or that operates for the purposes specified in § 60.4211(f)(3)(i), you must submit an annual report according to the requirements in paragraphs (d)(1) through (3) of this section.

(1) The report must contain the following information:

(i) Company name and address where the engine is located.

(ii) Date of the report and beginning and ending dates of the reporting period.

(iii) Engine site rating and model year.

(iv) Latitude and longitude of the engine in decimal degrees reported to the fifth decimal place.

(v) Hours operated for the purposes specified in § 60.4211(f)(2)(ii) and (iii), including the date, start time, and end time for engine operation for the purposes specified in § 60.4211(f)(2)(ii) and (iii).

(vi) Number of hours the engine is contractually obligated to be available for the purposes specified in § 60.4211(f)(2)(ii) and (iii).

(vii) Hours spent for operation for the purposes specified in § 60.4211(f)(3)(i), including the date, start time, and end time for engine operation for the purposes specified in § 60.4211(f)(3)(i). The report must also identify the entity that dispatched the engine and the situation that necessitated the dispatch of the engine.

(2) The first annual report must cover the calendar year 2015 and must be submitted no later than March 31, 2016. Subsequent annual reports for each calendar year must be submitted no later than March 31 of the following calendar year.

(3) The annual report must be submitted electronically using the subpart specific reporting form in the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) ([www.epa.gov/cdx](http://www.epa.gov/cdx)). However, if the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the written report must be submitted to the Administrator at the appropriate address listed in § 60.4.

**VI. WORK PRACTICE REQUIREMENTS.****# 006 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4207]****Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines****What fuel requirements must I meet if I am an owner or operator of a stationary CI internal combustion engine subject to this subpart?**

Beginning October 1, 2010, owners and operators of stationary CI ICE subject to this subpart with a displacement of less than 30 liters per cylinder that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR §1090.305 for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to October 1, 2010, may be used until depleted.

**SECTION D. Source Level Requirements**

ULSD standards (40 CFR §1090.305)

- (a) Maximum sulfur content of 15 ppm.
- (b) Cetane index or aromatic content. Diesel fuel must meet one of the following standards:
  - (1) Minimum cetane index of 40.
  - (2) Maximum aromatic content of 35 volume percent.

**# 007 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4211]  
Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines  
What are my compliance requirements if I am an owner or operator of a stationary CI internal combustion engine?**

If you own or operate an emergency stationary ICE, you must operate the emergency stationary ICE according to the requirements in paragraphs (1) through (3) of this section. In order for the engine to be considered an emergency stationary ICE under this subpart, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (1) through (3) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (1) through (3) of this section, the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.

- (1) There is no time limit on the use of emergency stationary ICE in emergency situations.
- (2) You may operate your emergency stationary ICE for any combination of the purposes specified in paragraphs (2)(i) through (iii) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraph (3) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (2).
  - (i) Emergency stationary ICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE beyond 100 hours per calendar year.

**# 008 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4211]  
Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines  
What are my compliance requirements if I am an owner or operator of a stationary CI internal combustion engine?**

The owner or operator must comply with the emission standards specified below, except as permitted under paragraph (4) of this section:

- (1) Operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instructions;
- (2) Change only those emission-related settings that are permitted by the manufacturer; and
- (3) Meet the requirements of 40 CFR part 1068, as they apply to you.
- (4) If you do not install, configure, operate, and maintain your engine and control device according to the manufacturer's emission-related written instructions, or you change emission-related settings in a way that is not permitted by the manufacturer, you must demonstrate compliance as follows:

If you are an owner or operator of a stationary CI internal combustion engine greater than or equal to 100 HP and less than or equal to 500 HP, you must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, you must conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of startup, or within 1 year after an engine and control device is no longer installed,

**SECTION D. Source Level Requirements**

configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after you change emission-related settings in a way that is not permitted by the manufacturer.

**# 009 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6590]****Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines****What parts of my plant does this subpart cover?**

Stationary RICE subject to Regulations under 40 CFR Part 60. A new or reconstructed stationary RICE located at an area source must meet the requirements of 40 CFR 63 Part ZZZZ by meeting the requirements of 40 CFR part 60 subpart IIII.

**VII. ADDITIONAL REQUIREMENTS.****# 010 [25 Pa. Code §127.441]****Operating permit terms and conditions.**


Pump Model JU6H-UFADMG  
 Model 6068N014416  
 ESN PE606N014416  
 183 hp

**SECTION D. Source Level Requirements**

Source ID: 208

Source Name: SOLVENT BATHS

Source Capacity/Throughput:

**I. RESTRICTIONS.****Emission Restriction(s).**

# 001 [25 Pa. Code §127.441]

**Operating permit terms and conditions.**

The permittee shall limit HAP emissions to less than or equal to 0.5 tons per 12-month rolling sum.

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**III. MONITORING REQUIREMENTS.**

# 002 [25 Pa. Code §127.441]

**Operating permit terms and conditions.**

The permittee shall monitor the amount of trichloroethylene used and emissions on a monthly basis.

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VI. WORK PRACTICE REQUIREMENTS.**

# 003 [25 Pa. Code §127.441]

**Operating permit terms and conditions.**

The permittee shall estimate emissions from the solvent baths using a DEP-approved method.

**VII. ADDITIONAL REQUIREMENTS.**

# 004 [25 Pa. Code §127.441]

**Operating permit terms and conditions.**

There are 3 solvent baths at the facility. The solvent baths are located in 905 Building Press Area, 915 Building Cleanroom, and the Technical Lab.

**SECTION E. Source Group Restrictions.**

Group Name: GROUP 1

Group Description: PRINTING OPERATIONS PRIOR TO 2015

Sources included in this group

ID	Name
101	ROTOGRAVURE 1 PRESS, 14" GRAVURE
102	FLEXOGRAPHIC 3 PRESS, FLEXO GALLUS
103	ROTOGRAVURE 46 PRESS, 21" INTRA ROTO
104	FLEXOGRAPHIC 9 PRESS, 6.5 WEBTRON
105	FLEXOGRAPHIC 31 PRESS, 17.5" PROPHETEER
106	FLEXOGRAPHIC 63 PRESS, 7" FLEXO ALLIED
108	FLEXOGRAPHIC NO. 70 PRESS, JULIET 608
109	LETTERPRESS 120, HEIDELBERG 18"X23"

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**II. TESTING REQUIREMENTS.****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code §139 and 40 CFR part 60, Appendix A.]

(a) The permittee shall test their coating(s), as applied for the following, in accordance with Method 24, as specified in 40 CFR Part 60, Appendix A:

- (1) Volatile matter content.
- (2) Water content.
- (3) Density.
- (4) Volume solids.
- (5) Weight solids.

(b) The permittee shall test each coating for each delivery, except those that are delivered having the same lot or batch number that have been previously tested.

(c) The above testing requirements shall be waived if the permittee can demonstrate compliance with any of the following:

- (1) A statement from the supplier that EPA Method 24 was used,
- (2) A Certified Product Data Sheet is received from the supplier, or
- (3) A Safety Data Sheet (using the upper bound) is used in the calculations to demonstrate compliance with the VOC limitation for this source.

**III. MONITORING REQUIREMENTS.****# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall monitor:

(a) The following parameters for each coating, thinner and other component as supplied, on a monthly basis:

- (1) The coating, thinner or component name and identification number.
- (2) The volume used.
- (3) The mix ratio.
- (4) The density or specific gravity.
- (5) The weight percent of total volatiles, water, solids and exempt solvents.

**SECTION E. Source Group Restrictions.**

- (b) The VOC content of each coating, thinner and other component as supplied.
- (c) The VOC content of each as applied coating.

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VI. WORK PRACTICE REQUIREMENTS.**

**# 003 [25 Pa. Code §127.441]**

**Operating permit terms and conditions.**

The following work practice standards shall be followed:

- (a) All VOC-containing materials shall be stored in closed, nonabsorbent, non-leaking containers when not being mixed or transferred to another container.
- (b) Cloth and paper, or other absorbent applicators, moistened with coatings, solvents or cleaning solvents, shall be stored in closed, nonabsorbent, non-leaking containers.
- (c) All spills shall be cleaned up as soon as possible.

Compliance with 25 Pa. Code §§ 129.67a(g)(1), (2) and (3) under Group 4 sources assures compliance with this condition.

**VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**SECTION E. Source Group Restrictions.**

Group Name: GROUP 2

Group Description: COLD DEGREASERS

Sources included in this group

ID	Name
201	COLD DEGREASER 2
202	COLD DEGREASER

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**III. MONITORING REQUIREMENTS.****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall monitor the VOC emissions from the cold degreasers on a monthly and 12-month rolling basis.

**IV. RECORDKEEPING REQUIREMENTS.****# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall record the VOC emissions from the cold degreasers on a monthly and 12-month rolling basis.

**# 003 [25 Pa. Code §129.63]****Degreasing operations**

A person who sells or offers for sale any solvent containing VOCs for use in a cold cleaning machine shall provide, to the purchaser, the following written information:

- (i) The name and address of the solvent supplier.
- (ii) The type of solvent including the product or vendor identification number.
- (iii) The vapor pressure of the solvent measured in mm hg at 20°C (68°F).

The permittee shall maintain records for at least five (5) years and shall provide to the Department, on request, the information specified above. An invoice, bill of sale, certificate that corresponds to a number of sales, Safety Data Sheet (SDS), or other appropriate documentation acceptable to the Department may be used to comply with 25 Pa. Code 129.63(a).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VI. WORK PRACTICE REQUIREMENTS.****# 004 [25 Pa. Code §129.63]****Degreasing operations**

The permittee shall maintain the following parameters:

- (1) Immersion cold cleaning machines shall have a freeboard ratio of 0.50 or greater.
- (2) Immersion cold cleaning machines and remote reservoir cold cleaning machines shall:
  - (i) Have a permanent, conspicuous label summarizing the operating requirements in paragraph (3). In addition, the



**SECTION E. Source Group Restrictions.**

label

shall include the following discretionary good operating practices:

- (a) Cleaned parts should be drained at least 15 seconds or until dripping ceases, whichever is longer. Parts having cavities or blind holes shall be tipped or rotated while the part is draining. During the draining, tipping or rotating, the parts should be positioned so that solvent drains directly back to the cold cleaning machine.
  - (b) When a pump-agitated solvent bath is used, the agitator should be operated to produce a rolling motion of the solvent with no observable splashing of the solvent against the tank walls or the parts being cleaned.
  - (c) Work area fans should be located and positioned so that they do not blow across the opening of the degreaser unit.
  - (ii) Be equipped with a cover that shall be closed at all times except during cleaning of parts or the addition or removal of solvent. For remote reservoir cold cleaning machines which drain directly into the solvent storage reservoir, a perforated drain with a diameter of not more than 6 inches shall constitute an acceptable cover.
- (3) Cold cleaning machines shall be operated in accordance with the following procedures:
- (i) Waste solvent shall be collected and stored in closed containers. The closed containers may contain a device that allows pressure relief, but does not allow liquid solvent to drain from the container.
  - (ii) Flushing of parts using a flexible hose or other flushing device shall be performed only within the cold cleaning machine. The solvent spray shall be a solid fluid stream, not an atomized or shower spray.
  - (iii) Sponges, fabric, wood, leather, paper products and other absorbent materials may not be cleaned in the cold cleaning machine.
  - (iv) Air agitated solvent baths may not be used.
  - (v) Spills during solvent transfer and use of the cold cleaning machine shall be cleaned up immediately.

**# 005 [25 Pa. Code §129.63]****Degreasing operations**

- (a) A person may not use, sell or offer for sale for use in a cold cleaning machine any solvent with a vapor pressure of 1.0 millimeter of mercury (mm Hg) or greater and containing greater than 5% VOC by weight, measured at 20°C (68°F) containing VOCs.
- (b) The above does not apply.
  - (1) If the owner or operator of the cold cleaning machine demonstrates, and the Department approves in writing, that compliance with (a), above, will result in unsafe operating conditions.
  - (2) To immersion cold cleaning machines with a freeboard ratio equal to or greater than 0.75.

**VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**SECTION E. Source Group Restrictions.**

Group Name: GROUP 3

Group Description: INTERNAL COMBUSTION ENGINES

Sources included in this group

ID	Name
205	20 KW EMERGENCY GENERATOR ENGINE
206	DIESEL ICE - EMERGENCY GENERATOR IT
207	DIESEL ICE - FIRE PUMP

**I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §123.13]****Processes**

No person may permit the emission into the outdoor atmosphere of particulate matter from this source in excess of 0.04 gr/dscf, pursuant to 25 Pa. Code § 123.13 (c)(1)(i).

**# 002 [25 Pa. Code §123.21]****General**

No person may permit the emission into the outdoor atmosphere of sulfur oxides from this source in a manner that the concentration of the sulfur oxides, expressed as SO<sub>2</sub>, in the effluent gas exceeds 500 ppmvd

**# 003 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

NO<sub>x</sub> emissions from this generator engine shall not exceed the following:

- (a) 100 lbs/hr,
- (b) 1,000 lbs/day,
- (c) 2.75 tons/ozone season (May 1 - Sept 30), and
- (c) 6.6 tons/yr, based on a 12-month rolling sum.

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**SECTION E. Source Group Restrictions.****VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**SECTION E. Source Group Restrictions.**

Group Name: GROUP 4

Group Description: Pa. Code §129.67a

Sources included in this group

ID	Name
101	ROTOGRAVURE 1 PRESS, 14" GRAVURE
102	FLEXOGRAPHIC 3 PRESS, FLEXO GALLUS
103	ROTOGRAVURE 46 PRESS, 21" INTRA ROTO
104	FLEXOGRAPHIC 9 PRESS, 6.5 WEBTRON
105	FLEXOGRAPHIC 31 PRESS, 17.5" PROPHETEER
106	FLEXOGRAPHIC 63 PRESS, 7" FLEXO ALLIED
108	FLEXOGRAPHIC NO. 70 PRESS, JULIET 608
110	FLEXOGRAPHIC 74 PRESS, 24" W/ ROTARY SCREEN

**I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Authority for this condition is derived from 25 Pa. Code §129.67a(1)(ii)]

(1) Actual VOC emissions at or above threshold.

The total actual VOC emissions from all inks, coatings and adhesives combined from all flexible packaging printing presses and all VOC emissions from related cleaning activities at the facility are equal to or greater than 450 pounds per month or 2.7 tons per 12-month rolling period, before consideration of add-on controls.

**II. TESTING REQUIREMENTS.****# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Authority for this condition is derived from 25 Pa. Code §§ 129.67a(f)(1)(i) and (3)]

(1) Sampling of an ink or coating and testing for the VOC content of the ink or coating shall be performed in accordance with the procedures and test methods specified in Chapter 139.

(2) Other test methods demonstrated to provide results that are acceptable for purposes of determining compliance with this section may be used if prior approval is obtained in writing from the Department and the EPA.

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**IV. RECORDKEEPING REQUIREMENTS.****# 003 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Authority for this condition is derived from 25 Pa. Code §129.67a(e)(3), (4) and (5)]

The owner or operator of a flexible packaging printing press subject to 25 Pa. Code § 129.67a shall maintain records sufficient to demonstrate compliance with the requirements. Records maintained for compliance demonstrations may include purchase, use, production and other records.

(1) An owner or operator claiming exemption from a VOC control provision of this section based on potential or actual VOC emissions, as applicable, shall maintain records that demonstrate to the Department that the press or facility is exempt.

(2) The owner or operator may group materials into classes using the highest VOC content in any material in a class to

**SECTION E. Source Group Restrictions.**

represent that class of material.

(3) The records required under 25 Pa. Code §§ 129.67a(e)(1)—(4) shall be maintained for 2 years, unless a longer period is required by a plan approval or operating permit issued under Chapter 127 (relating to construction, modification, reactivation and operation of sources). The records shall be submitted to the Department in an acceptable format upon receipt of a written request.

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VI. WORK PRACTICE REQUIREMENTS.****# 004 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Authority for this condition is derived from 25 Pa. Code §§ 129.67a(g)(1), (2) and (3)]

Work practice requirements for cleaning activities.

(1) The owner or operator of a flexible packaging printing press subject to 25 Pa. Code §§ 129.67a(a)(1)(i), (1)(ii) or (2) shall comply with the following work practices for cleaning activities at the facility:

- (i) Store all VOC-containing cleaning solutions, waste cleaning solutions and used shop towels in closed containers.
- (ii) Ensure that mixing vessels and storage containers used for VOC-containing cleaning solutions, waste cleaning solutions and used shop towels are kept closed at all times, except when depositing or removing these solutions or shop towels.
- (iii) Minimize spills of VOC-containing cleaning solutions and waste cleaning solutions and clean up spills immediately.
- (iv) Convey VOC-containing cleaning solutions, waste cleaning solutions and used shop towels from one location to another in closed containers or pipes.

(2) The requirements in 25 Pa. Code 129.67a(g)(1) apply to the following activities:

- (i) Cleaning of ink, coating or adhesive from a press.
- (ii) Cleaning of ink, coating or adhesive from press parts, including press parts that have been removed from the press for cleaning.
- (iii) Cleaning of ink, coating or adhesive from areas around a press.

(3) The requirements in 25 Pa. Code § 129.67a(g)(1) do not apply to the following activities:

- (i) Cleaning electronic components of a press.
- (ii) Cleaning in pre-press (for example, platemaking) operations.
- (iii) Cleaning in post-press (for example, binding) operations.
- (iv) Using janitorial supplies (for example, detergents or floor cleaners) for general cleaning around a press.
- (v) The use of parts washers or cold cleaners at a flexible packaging printing facility. The use of parts washers and cold cleaners is regulated under § 129.63 (relating to degreasing operations).

**VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).



**SECTION F. Alternative Operation Requirements.**

No Alternative Operations exist for this State Only facility.

**SECTION G. Emission Restriction Summary.**

Source Id	Source Descriptor		
109	LETTERPRESS 120, HEIDELBERG 18"X23"		
<b>Emission Limit</b>			<b>Pollutant</b>
2.700	Tons/Yr		VOC
450.000	Lbs/Mth		VOC
110	FLEXOGRAPHIC 74 PRESS, 24" W/ ROTARY SCREEN		
<b>Emission Limit</b>			<b>Pollutant</b>
1.250	Tons/Yr	12-month rolling sum	VOC
205	20 KW EMERGENCY GENERATOR ENGINE		
<b>Emission Limit</b>			<b>Pollutant</b>
2.750	Tons	Ozone season	NOX
2.750	Tons/OZNESEAS		NOX
6.600	Tons/Yr	12-month rolling sum	NOX
6.600	Tons/Yr		NOX
100.000	Lbs/Hr		NOX
1,000.000	Lbs/Day		NOX
206	DIESEL ICE - EMERGENCY GENERATOR IT		
<b>Emission Limit</b>			<b>Pollutant</b>
2.750	Tons/OZNESEAS		NOX
6.600	Tons/Yr		NOX
100.000	Lbs/Hr		NOX
1,000.000	Lbs/Day		NOX
207	DIESEL ICE - FIRE PUMP		
<b>Emission Limit</b>			<b>Pollutant</b>
2.750	Tons/OZNESEAS		NOX
6.600	Tons/Yr		NOX
100.000	Lbs/Hr		NOX
1,000.000	Lbs/Day		NOX

**Site Emission Restriction Summary**

Emission Limit			Pollutant
24.900	Tons/Yr	12-month rolling sum	VOC

**SECTION H. Miscellaneous.**

#001. Certain terms and conditions of this permit are based on the previous Operating Permit OP-09-0004.

#002. The Department has determined that emissions from the following sources, excluding those indicated as site level requirements in Section C of this permit, are of insignificant size and do not require additional limitations, monitoring, or recordkeeping.

- (a) 1 natural gas steam boiler rated at 0.582 MMBtu/hr (Maintenance-Boiler room)
- (b) 8 natural gas space heaters rated at 0.10 MMBtu/hr, each (Building 1 warehouse)
- (c) 12 natural gas space heaters rated at 0.10 MMBtu/hr, each (Building 2 warehouse)
- (d) 1 natural gas water heater rated at 0.04 MMBtu/hr (Building 2)
- (e) 1 natural gas HVAC heater rated at 0.10 MMBtu/hr (Building 2)
- (f) 1 natural gas hot water heater rated at 0.20 MMBtu/hr (Building 1)
- (g) 9 natural gas HVAC units rated at 0.25 MMBtu/hr, each (Building 1)

#003. APS Id. 620443; Authorization No. 688708 - An administrative amendment was done to identify a change in ownership in accordance with 25 Pa. Code Section 127.450(a)(4).

#004. APS Id. 697846; AUTH No. 799663 - An administrative amendment was done to identify a change in name to Oliver-Tolas Healthcare Packaging and a change in Responsible Official.

#005. APS No. 697846; AUTH No. 841480 - renewal of the synthetic minor operating permit. March 2011.

#006. The operating permit is being renewed under APS No. 697846; and AUTH No. 1088976. An ultrasonic cleaner (Source 204) and a 20 kW natural gas fired emergency generator engine (Source 205), have been added to the list of permitted sources in Section D.

#007. NOVEMBER 2020: Administrative Amendment (APS No. 1017287; AUTH ID 1315976) – This administrative amendment incorporates a change in the company's name from Oliver-Tolas Healthcare Packaging to Oliver Healthcare Packaging, terms and conditions for a flexographic printing press and operations (Source ID 110) under Plan Approval 09-0004A and changing Source ID 200 to Source ID 202 (refer to RFD 1115 and operating permit under AUTH No. 841480).

#008 JULY 2022 - Renewal of synthetic minor operating permit (AUTH No. 1341023)

(1) Emission Sources added to the operating permit

- (i) One diesel-fired engine/emergency generator (Source ID 206)
- (ii) One diesel-fired engine/fire pump (Source ID 207)
- (iii) Solvent baths (Source ID 208)
- (iv) Trim system (insignificant)

(2) Four Source Groups have been incorporated into the operating permit. The Source Group and the specific sources are identified below:

- (i) GROUP 1 (Printing Operations Prior to 2015) - Source IDs 101, 102, 103, 104, 105, 106, 108 and 109
- (ii) GROUP 2 (Cold Degreasers) - Source IDs 201 and 202
- (iii) GROUP 3 (Internal Combustion Engines) - Source IDs 204, 206 and 207
- (iv) GROUP 4 (25 Pa. Code §129.67a) - Source IDs 101, 102, 103, 104, 105, 108 and 110

(3) These conditions (Section C) were modified to bring clarity to what was previously stated in the operating permit. These changes did not result in any changes to the method of compliance for those changed conditions.

- (i) Condition #002
- (ii) Condition #003
- (iii) Condition #006
- (iv) Condition #016
- (v) Condition #019

(4) Permit conditions added to the operating permit based on actual emissions from the printing operations in accordance with 25



**SECTION H. Miscellaneous.**

Pa. Code §§129.67a (Control of VOC emissions from flexible packaging printing presses) and 25 Pa. Code §129.67b (Control of VOC emissions from offset lithographic printing presses and letterpress printing presses).

(5) The following regulations have been determined to be non-applicable to the operations at the facility.

(i) 40 CFR Part 60, Subpart JJJJ – Standards of Performance for Stationary Spark Ignition Internal Combustion Engines

(ii) 40 CFR Part 63, Subpart KK - National Emissions Standard for the Printing and Publishing Industries

(vi) 40 CFR Part 63, Subpart JJJJJJ – National Emissions Standards for Hazardous Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources

(vii) 25 Pa. Code § 129.52 - Surface Coating Processes

(viii) 25 Pa. Code § 129.52b - Control of VOC emissions from paper, film and foil surface coating processes

(ix) 25 Pa. Code § 129.67 - Graphic Arts Systems

(x) 25 Pa Code § 129.67b(c) and (e) - Control of VOC emissions from offset lithographic printing presses and letterpress printing presses

(xi) 25 Pa. Code §129.77 - Control of emissions from the use or application of adhesives, sealants, primers and solvents



\*\*\*\*\* End of Report \*\*\*\*\*

---