



COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION AIR QUALITY PROGRAM

STATE ONLY SYNTHETIC MINOR OPERATING PERMIT

Issue Date:	February 26, 2019	Effective Date:	September 5, 2023
Revision Date:	September 5, 2023	Expiration Date:	February 29, 2024

Revision Type: Amendment

36-05152

In accordance with the provisions of the Air Pollution Control Act, the Act of January 8, 1960, P.L. 2119, as amended, and 25 Pa. Code Chapter 127, the Owner, [and Operator if noted] (hereinafter referred to as permittee) identified below is authorized by the Department of Environmental Protection (Department) to operate the air emission source(s) more fully described in this permit. This Facility is subject to all terms and conditions specified in this permit. Nothing in this permit relieves the permittee from its obligations to comply with all applicable Federal, State and Local laws and regulations.

The regulatory or statutory authority for each permit condition is set forth in brackets. All terms and conditions in this permit are federally enforceable unless otherwise designated.

State Only Permit No: 36-05152				
	Synthetic Minor			
Federal Tax	Id - Plant Code: 38-3020060-1			
	Owner Information			
Name: KELLOGG USA LLC				
Mailing Address: 2050 STATE RD				
LANCASTER, PA 17601-1821				
	Plant Information			
Plant: KELLOGG USA LLC/EAST HEMPFIELD				
Location: 36 Lancaster County	36928 East Hempfield Township			
SIC Code: 2043 Manufacturing - Cereal Breakfast Fo	ods			
	Responsible Official			
Name: DAVID WRIGHT				
Title: PLANT MANAGER				
Phone: (717) 742 - 6185	Email: david.wright@kellogg.com			
Ρ	ermit Contact Person			
Name: TARA MILLER				
Title: EHS MANAGER				
Phone: (570) 546 - 0230	Email: tara.miller@kellogg.com			
[Signature]				
WILLIAMR. WEAVER, SOUTHCENTRAL REGION A	IR PROGRAM MANAGER			





SECTION A. Table of Contents

Section A. Facility/Source Identification

Table of Contents Site Inventory List

Section B. General State Only Requirements

- #001 Definitions.
- #002 Operating Permit Duration.
- #003 Permit Renewal.
- #004 Operating Permit Fees under Subchapter I.
- #005 Transfer of Operating Permits.
- #006 Inspection and Entry.
- #007 Compliance Requirements.
- #008 Need to Halt or Reduce Activity Not a Defense.
- #009 Duty to Provide Information.
- #010 Revising an Operating Permit for Cause.
- #011 Operating Permit Modifications
- #012 Severability Clause.
- #013 De Minimis Emission Increases.
- #014 Operational Flexibility.
- #015 Reactivation
- #016 Health Risk-based Emission Standards and Operating Practice Requirements.
- #017 Circumvention.
- #018 Reporting Requirements.
- #019 Sampling, Testing and Monitoring Procedures.
- #020 Recordkeeping.
- #021 Property Rights.
- #022 Alternative Operating Scenarios.
- #023 Reporting
- #024 Report Format

Section C. Site Level State Only Requirements

- C-I: Restrictions
- C-II: Testing Requirements
- C-III: Monitoring Requirements
- C-IV: Recordkeeping Requirements
- C-V: Reporting Requirements
- C-VI: Work Practice Standards
- C-VII: Additional Requirements
- C-VIII: Compliance Certification
- C-IX: Compliance Schedule

Section D. Source Level State Only Requirements

- D-I: Restrictions
- D-II: Testing Requirements
- D-III: Monitoring Requirements
- D-IV: Recordkeeping Requirements
- D-V: Reporting Requirements
- D-VI: Work Practice Standards
- D-VII: Additional Requirements

Note: These same sub-sections are repeated for each source!

Section E. Source Group Restrictions

E-I: Restrictions

36-05152



SECTION A. Table of Contents

- E-II: Testing Requirements
- E-III: Monitoring Requirements
- E-IV: Recordkeeping Requirements
- E-V: Reporting Requirements
- E-VI: Work Practice Standards
- E-VII: Additional Requirements

Section F. Alternative Operating Scenario(s)

- F-I: Restrictions
- F-II: Testing Requirements
- F-III: Monitoring Requirements
- F-IV: Recordkeeping Requirements
- F-V: Reporting Requirements
- F-VI: Work Practice Standards
- F-VII: Additional Requirements

Section G. Emission Restriction Summary

Section H. Miscellaneous





SECTION A. Site Inventory List


Source I	D Source Name	Capacity	/Throughput	Fuel/Material
031	BOILER 1	66.000	MMBTU/HR	
		64.700	MCF/HR	NATURAL GAS/BIOGAS
032	BOILER 2	66.000	MMBTU/HR	
		64.700	MCF/HR	NATURAL GAS/BIOGAS
100	MISC COMBUSTION SOURCES			
100A	BULK HANDLING SYSTEM			
100B	CORN LINE			
100C	BRAN LINE			
100D	SHRED LINE			
100E	COMBOLINE			
100F	CRISPIXLINE			
100H	COATING LINE 2			
103	PACKING AREA (L12, L14, L23)			
104	FLAVOR			
201	VOC SOURCES			
301	INKS/PARTS SOLVENTS			
401	FLARE			
501	VACUUM SYSTEM			
601	PARTS WASHERS			
801	MISCELLANEOUS SOURCES			
901	20KW EMERGENCY GENERATOR			
902	25KW EMERGENCY GENERATOR			
903	EMERGENCY FIRE PUMP			
C100	GENERIC CONTROL DEVICE			
C102	COATING LINE 2 SIZE 36 ROTOCLONE			
C103	PACKING AREA (L12, L14, L23) BAGHOUSE			
C105	COATING LINE 2 SIZE 27 ROTOCLONE			
C106	COATING LINE 2 BAGHOUSE			
FM001	NATURAL GAS PIPELINE			
FM002	WASTEWATER TREATMENT PLANT BIOGAS			
FM003	LIQUID PROPANE			
FM004	DIESEL FUEL			
S031	BOILER STACK			
S100	GENERIC STACK			
S102	COATING LINE 2 SIZE 36 ROTOCLONE STACK			
S103	PACKING AREA (L12, L14, L23) STACK			
S105	COATING LINE 2 SIZE 27 ROTOCLONE STACK			
S106	COATING LINE 2 BAGHOUSE STACK			
S401	FLARE EMISSIONS			
S801	UNSPECIFIED NAME			





SECTION A. Site Inventory List


Source II	D Source Name	Capacity/Throughput	Fuel/Material
S901	20KW EMERGENCY GENERATOR STACK		
S902	25KW EMERGENCY GENERATOR STACK		
S903	EMERGENCY FIRE PUMP STACK		
Z201	VOC FUGITIVE EMISSIONS		
Z301	FUGITIVE SOLVENT EMISSIONS		
Z601	PARTS WASHER EVAP.		





36-05152









PERMIT MAPS				
PROC 903 → STAC S903				
FML FM004				





#001 [25 Pa. Code § 121.1] Definitions. Words and terms that are not otherwise defined in this permit shall have the meanings set forth in Section 3 of the Air Pollution Control Act (35 P.S. § 4003) and in 25 Pa. Code § 121.1. #002 [25 Pa. Code § 127.446] **Operating Permit Duration.** (a) This operating permit is issued for a fixed term of five (5) years and shall expire on the date specified on Page 1 of this permit. (b) The terms and conditions of the expired permit shall automatically continue pending issuance of a new operating permit, provided the permittee has submitted a timely and complete application and paid applicable fees required under 25 Pa. Code Chapter 127, Subchapter I and the Department is unable, through no fault of the permittee, to issue or deny a new permit before the expiration of the previous permit. #003 [25 Pa. Code §§ 127.412, 127.413, 127.414, 127.446 & 127.703(b)] Permit Renewal. (a) The permittee shall submit a timely and complete application for renewal of the operating permit to the appropriate Regional Air Program Manager. The application for renewal of the operating permit shall be submitted at least six (6) months and not more than 18 months before the expiration date of this permit. (b) The application for permit renewal shall include the current permit number, a description of any permit revisions that occurred during the permit term, and any applicable requirements that were promulgated and not incorporated into the permit during the permit term. An application is complete if it contains sufficient information to begin processing the application, has the applicable sections completed and has been signed by a responsible official. (c) The permittee shall submit with the renewal application a fee for the processing of the application as specified in 25 Pa. Code § 127.703(b). The fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" and submitted with the fee form to the respective regional office. (d) The renewal application shall also include submission of proof that the local municipality and county, in which the facility is located, have been notified in accordance with 25 Pa. Code § 127.413. (e) The application for renewal of the operating permit shall also include submission of supplemental compliance review forms in accordance with the requirements of 25 Pa. Code § 127.412(b) and § 127.412(j). (f) The permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the permit application, shall promptly submit such supplementary facts or corrected information as necessary to address any requirements that become applicable to the source after the permittee submits a complete application, but prior to the date the Department takes action on the permit application. #004 [25 Pa. Code § 127.703] **Operating Permit Fees under Subchapter I.** (a) The permittee shall pay the annual operating permit maintenance fee according to the following fee schedule in either paragraph (1) or (2) in accordance with 25 Pa. Code § 127.703(d) on or before December 31 of each year for the next calendar year. (1) For a synthetic minor facility, a fee equal to: (i) Four thousand dollars (\$4,000) for calendar years 2021-2025. (ii) Five thousand dollars (\$5,000) for calendar years 2026-2030. (iii) Six thousand three hundred dollars (\$6,300) for the calendar years beginning with 2031.



(2) For a facility that is not a synthetic minor, a fee equal to:

(i) Two thousand dollars (\$2,000) for calendar years 2021-2025.

(ii) Two thousand five hundred dollars (\$2,500) for calendar years 2026-2030.

(iii) Three thousand one hundred dollars (\$3,100) for the calendar years beginning with 2031.

(b) The applicable fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" with the permit number clearly indicated and submitted to the respective regional office.

#005 [25 Pa. Code §§ 127.450 (a)(4) and 127.464]

Transfer of Operating Permits.

(a) This operating permit may not be transferred to another person, except in cases of transfer-of-ownership that are documented and approved by the Department.

(b) In accordance with 25 Pa. Code § 127.450(a)(4), a change in ownership of the source shall be treated as an administrative amendment if the Department determines that no other change in the permit is required and a written agreement has been submitted to the Department identifying the specific date of the transfer of permit responsibility, coverage and liability between the current and the new permittee and a compliance review form has been submitted to, and the permit transfer has been approved by, the Department.

(c) This operating permit is valid only for those specific sources and the specific source locations described in this permit.

#006 [25 Pa. Code § 127.441 and 35 P.S. § 4008]

Inspection and Entry.

(a) Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Department or authorized representatives of the Department to perform the following:

(1) Enter at reasonable times upon the permittee's premises where a source is located or emissions related activity is conducted, or where records are kept under the conditions of this permit;

(2) Have access to and copy, at reasonable times, any records that are kept under the conditions of this permit;

(3) Inspect at reasonable times, any facilities, equipment including monitoring and air pollution control equipment, practices, or operations regulated or required under this permit;

(4) Sample or monitor, at reasonable times, any substances or parameters, for the purpose of assuring compliance with the permit or applicable requirements as authorized by the Clean Air Act, the Air Pollution Control Act, or the regulations promulgated under the Acts.

(b) Pursuant to 35 P.S. § 4008, no person shall hinder, obstruct, prevent or interfere with the Department or its personnel in the performance of any duty authorized under the Air Pollution Control Act or regulations adopted thereunder including denying the Department access to a source at this facility. Refusal of entry or access may constitute grounds for permit revocation and assessment of criminal and/or civil penalties.

(c) Nothing in this permit condition shall limit the ability of the EPA to inspect or enter the premises of the permittee in accordance with Section 114 or other applicable provisions of the Clean Air Act.

#007 [25 Pa. Code §§ 127.441 & 127.444]

Compliance Requirements.

(a) The permittee shall comply with the conditions of this operating permit. Noncompliance with this permit constitutes a violation of the Clean Air Act and the Air Pollution Control Act and is grounds for one or more of the following:





- (1) Enforcement action
- (2) Permit termination, revocation and reissuance or modification
- (3) Denial of a permit renewal application

(b) A person may not cause or permit the operation of a source which is subject to 25 Pa. Code Article III unless the source(s) and air cleaning devices identified in the application for the plan approval and operating permit and the plan approval issued for the source is operated and maintained in accordance with specifications in the applications and the conditions in the plan approval and operating permit issued by the Department. A person may not cause or permit the operation of an air contamination source subject to 25 Pa. Code Chapter 127 in a manner inconsistent with good operating practices.

(c) For purposes of Sub-condition (b) of this permit condition, the specifications in applications for plan approvals and operating permits are the physical configurations and engineering design details which the Department determines are essential for the permittee's compliance with the applicable requirements in this State-Only permit. Nothing in this sub-condition shall be construed to create an independent affirmative duty upon the permittee to obtain a predetermination from the Department for physical configuration or engineering design detail changes made by the permittee.

#008 [25 Pa. Code § 127.441]

Need to Halt or Reduce Activity Not a Defense.

It shall not be a defense for the permittee in an enforcement action that it was necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

#009 [25 Pa. Code §§ 127.442(a) & 127.461]

Duty to Provide Information.

(a) The permittee shall submit reports to the Department containing information the Department may prescribe relative to the operation and maintenance of each source at the facility.

(b) The permittee shall furnish to the Department, in writing, information that the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. Upon request, the permittee shall also furnish to the Department copies of records that the permittee is required to maintain in accordance with this permit.

#010 [25 Pa. Code § 127.461]

Revising an Operating Permit for Cause.

This operating permit may be terminated, modified, suspended or revoked and reissued if one or more of the following applies:

(1) The permittee constructs or operates the source subject to the operating permit so that it is in violation of the Air Pollution Control Act, the Clean Air Act, the regulations thereunder, a plan approval, a permit or in a manner that causes air pollution.

(2) The permittee fails to properly or adequately maintain or repair an air pollution control device or equipment attached to or otherwise made a part of the source.

(3) The permittee has failed to submit a report required by the operating permit or an applicable regulation.

(4) The EPA determines that the permit is not in compliance with the Clean Air Act or the regulations thereunder.

#011 [25 Pa. Code §§ 127.450, 127.462, 127.465 & 127.703]

Operating Permit Modifications

(a) The permittee is authorized to make administrative amendments, minor operating permit modifications and significant operating permit modifications, under this permit, as outlined below:





(b) Administrative Amendments. The permittee shall submit the application for administrative operating permit amendments (as defined in 25 Pa. Code § 127.450(a)), according to procedures specified in § 127.450 unless precluded by the Clean Air Act or its regulations.

(c) Minor Operating Permit Modifications. The permittee shall submit the application for minor operating permit modifications (as defined 25 Pa. Code § 121.1) in accordance with 25 Pa. Code § 127.462.

(d) Significant Operating Permit Modifications. The permittee shall submit the application for significant operating permit modifications in accordance with 25 Pa. Code § 127.465.

(e) The applicable fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" with the permit number clearly indicated and submitted to the respective regional office.

#012 [25 Pa. Code § 127.441]

Severability Clause.

The provisions of this permit are severable, and if any provision of this permit is determined by a court of competent jurisdiction to be invalid or unenforceable, such a determination will not affect the remaining provisions of this permit.

#013 [25 Pa. Code § 127.449]

De Minimis Emission Increases.

(a) This permit authorizes de minimis emission increases in accordance with 25 Pa. Code § 127.449 so long as the permittee provides the Department with seven (7) days prior written notice before commencing any de minimis emissions increase. The written notice shall:

(1) Identify and describe the pollutants that will be emitted as a result of the de minimis emissions increase.

(2) Provide emission rates expressed in tons per year and in terms necessary to establish compliance consistent with any applicable requirement.

(b) The Department may disapprove or condition de minimis emission increases at any time.

(c) Except as provided below in (d), the permittee is authorized to make de minimis emission increases (expressed in tons per year) up to the following amounts without the need for a plan approval or prior issuance of a permit modification:

(1) Four tons of carbon monoxide from a single source during the term of the permit and 20 tons of carbon monoxide at the facility during the term of the permit.

(2) One ton of NOx from a single source during the term of the permit and 5 tons of NOx at the facility during the term of the permit.

(3) One and six-tenths tons of the oxides of sulfur from a single source during the term of the permit and 8.0 tons of oxides of sulfur at the facility during the term of the permit.

(4) Six-tenths of a ton of PM10 from a single source during the term of the permit and 3.0 tons of PM10 at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act, the regulations thereunder or 25 Pa. Code Article III.

(5) One ton of VOCs from a single source during the term of the permit and 5.0 tons of VOCs at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act, the regulations thereunder or 25 Pa. Code Article III.

(6) Other sources and classes of sources determined to be of minor significance by the Department.

(d) In accordance with § 127.14, the permittee is authorized to install the following minor sources without the need for a plan approval or permit modification:



(1) Air conditioning or ventilation systems not designed to remove pollutants generated or released from other sources.

(2) Combustion units rated at 2,500,000 or less Btu per hour of heat input.

(3) Combustion units with a rated capacity of less than 10,000,000 Btu per hour heat input fueled by natural gas supplied by a public utility or by commercial fuel oils which are No. 2 or lighter, viscosity less than or equal to 5.82 c St, and which meet the sulfur content requirements of 25 Pa. Code §123.22 (relating to combustion units). For purposes of this permit, commercial fuel oil shall be virgin oil which has no reprocessed, recycled or waste material added.

(4) Space heaters which heat by direct heat transfer.

(5) Laboratory equipment used exclusively for chemical or physical analysis.

(6) Other sources and classes of sources determined to be of minor significance by the Department.

(e) This permit does not authorize de minimis emission increases if the emissions increase would cause one or more of the following:

(1) Increase the emissions of a pollutant regulated under Section 112 of the Clean Air Act except as authorized in Subparagraphs (c)(4) and (5) of this permit condition.

(2) Subject the facility to the prevention of significant deterioration requirements in 25 Pa. Code Chapter 127, Subchapter D and/or the new source review requirements in Subchapter E.

(3) Violate any applicable requirement of this permit, the Air Pollution Control Act, the Clean Air Act, or the regulations promulgated under either of the acts.

(f) Emissions authorized under this permit condition shall be included in the monitoring, recordkeeping and reporting requirements of this permit.

(g) Except for de minimis emission increases, installation of minor sources made pursuant to this permit condition and Plan Approval Exemptions under 25 Pa. Code § 127.14 (relating to exemptions), the permittee is prohibited from making changes or engaging in activities that are not specifically authorized under this permit without first applying for a plan approval. In accordance with § 127.14(b), a plan approval is not required for the construction, modification, reactivation, or installation of the sources creating the de minimis emissions increase.

(h) The permittee may not meet de minimis emission threshold levels by offsetting emission increases or decreases at the same source.

#014 [25 Pa. Code § 127.3]

Operational Flexibility.

The permittee is authorized to make changes within the facility in accordance with the regulatory provisions outlined in 25 Pa. Code § 127.3 (relating to operational flexibility) to implement the operational flexibility requirements provisions authorized under Section 6.1(i) of the Air Pollution Control Act and the operational flexibility terms and conditions of this permit. The provisions in 25 Pa. Code Chapter 127 which implement the operational flexibility requirements include the following:

- (1) Section 127.14 (relating to exemptions)
- (2) Section 127.447 (relating to alternative operating scenarios)
- (3) Section 127.448 (relating to emissions trading at facilities with Federally enforceable emissions caps)
- (4) Section 127.449 (relating to de minimis emission increases)
- (5) Section 127.450 (relating to administrative operating permit amendments)



#015

#016

#017

#018



36-05152 **SECTION B. General State Only Requirements** (6) Section 127.462 (relating to minor operating permit modifications) (7) Subchapter H (relating to general plan approvals and general operating permits) [25 Pa. Code § 127.11] Reactivation (a) The permittee may not reactivate a source that has been out of operation or production for at least one year unless the reactivation is conducted in accordance with a plan approval granted by the Department or in accordance with reactivation and maintenance plans developed and approved by the Department in accordance with 25 Pa. Code § 127.11a(a). (b) A source which has been out of operation or production for more than five (5) years but less than 10 years may be reactivated and will not be considered a new source if the permittee satisfies the conditions specified in 25 Pa. Code § 127.11a(b). [25 Pa. Code § 127.36] Health Risk-based Emission Standards and Operating Practice Requirements. (a) When needed to protect public health, welfare and the environment from emissions of hazardous air pollutants from new and existing sources, the permittee shall comply with the health risk-based emission standards or operating practice requirements imposed by the Department, except as precluded by §§ 6.6(d)(2) and (3) of the Air Pollution Control Act [35 P.S. § 4006.6(d)(2) and (3)]. (b) A person challenging a performance or emission standard established by the Department has the burden to demonstrate that performance or emission standard does not meet the requirements of Section 112 of the Clean Air Act. [25 Pa. Code § 121.9] Circumvention. No person may permit the use of a device, stack height which exceeds good engineering practice stack height, dispersion technique or other technique which, without resulting in reduction of the total amount of air contaminants emitted, conceals or dilutes an emission of air contaminants which would otherwise be in violation of 25 Pa. Code Article III, except that with prior approval of the Department, the device or technique may be used for control of malodors. [25 Pa. Code §§ 127.402(d) & 127.442] **Reporting Requirements.** (a) The permittee shall comply with the applicable reporting requirements of the Clean Air Act, the regulations thereunder, the Air Pollution Control Act and 25 Pa. Code Article III including Chapters 127, 135 and 139. (b) The permittee shall submit reports to the Department containing information the Department may prescribe relative to the operation and maintenance of any air contamination source. (c) Reports, test data, monitoring data, notifications and requests for renewal of the permit shall be submitted to the: Regional Air Program Manager PA Department of Environmental Protection (At the address given in the permit transmittal letter, or otherwise notified) (d) Any records or information including applications, forms, or reports submitted pursuant to this permit condition shall contain a certification by a responsible official as to truth, accuracy and completeness. The certifications submitted under this permit shall require a responsible official of the facility to certify that based on information and belief formed after reasonable inquiry, the statements and information in the documents are true, accurate and

(e) Any records, reports or information submitted to the Department shall be available to the public except for such

complete.





SECT	ON B. General State Only Requirements
	records, reports or information which meet the confidentiality requirements of § 4013.2 of the Air Pollution Control Act and §§ 112(d) and 114(c) of the Clean Air Act. The permittee may not request a claim of confidentiality for any emissions data generated for the facility.
#019	[25 Pa. Code §§ 127.441(c) & 135.5]
Samplin	g, Testing and Monitoring Procedures.
	(a) The permittee shall comply with the monitoring, recordkeeping or reporting requirements of 25 Pa. Code Chapter 139 and the other applicable requirements of 25 Pa. Code Article III and additional requirements related to monitoring, reporting and recordkeeping required by the Clean Air Act and the regulations thereunder including the Compliance Assurance Monitoring requirements of 40 CFR Part 64, where applicable.
	(b) Unless alternative methodology is required by the Clean Air Act and regulations adopted thereunder, sampling, testing and monitoring required by or used by the permittee to demonstrate compliance with any applicable regulation or permit condition shall be conducted in accordance with the requirements of 25 Pa. Code Chapter 139.
#020	[25 Pa. Code §§ 127.441(c) and 135.5]
Record	eeping.
	(a) The permittee shall maintain and make available, upon request by the Department, the following records of monitored information:
	(1) The date, place (as defined in the permit) and time of sampling or measurements.
	(2) The dates the analyses were performed.
	(3) The company or entity that performed the analyses.
	(4) The analytical techniques or methods used.
	(5) The results of the analyses.
	(6) The operating conditions as existing at the time of sampling or measurement.
	(b) The permittee shall retain records of any required monitoring data and supporting information for at least five (5) years from the date of the monitoring, sample, measurement, report or application. Supporting information includes the calibration data and maintenance records and original strip-chart recordings for continuous monitoring instrumentation, and copies of reports required by the permit.
	(c) The permittee shall maintain and make available to the Department upon request, records including computerized records that may be necessary to comply with the reporting, recordkeeping and emission statement requirements in 25 Pa. Code Chapter 135 (relating to reporting of sources). In accordance with 25 Pa. Code Chapter 135, § 135.5, such records may include records of production, fuel usage, maintenance of production or pollution control equipment or other information determined by the Department to be necessary for identification and quantification of potential and actual air contaminant emissions.
#021	[25 Pa. Code § 127.441(a)]
Property	rights.
	This permit does not convey any property rights of any sort, or any exclusive privileges.
#022	[25 Pa. Code § 127.447]
Alternat	ive Operating Scenarios.
	The permittee is authorized to make changes at the facility to implement alternative operating scenarios identified in this permit in accordance with 25 Pa. Code § 127.447.





#023 [25 Pa. Code §135.3]

Reporting

(a) If the facility is a Synthetic Minor Facility, the permittee shall submit by March 1 of each year an annual emissions report for the preceding calendar year. The report shall include information for all active previously reported sources, new sources which were first operated during the preceding calendar year, and sources modified during the same period which were not previously reported. All air emissions from the facility should be estimated and reported.

(b) A source owner or operator of a Synthetic Minor Facility may request an extension of time from the Department for the filing of an annual emissions report, and the Department may grant the extension for reasonable cause.

#024 [25 Pa. Code §135.4]

Report Format

If applicable, the emissions reports shall contain sufficient information to enable the Department to complete its emission inventory. Emissions reports shall be made by the source owner or operator in a format specified by the Department.





I. RESTRICTIONS.

Emission Restriction(s).

001 [25 Pa. Code §123.1] Prohibition of certain fugitive emissions

No person shall permit the emission into the outdoor atmosphere of any fugitive air contaminant from a source other than the following:

(a) Construction or demolition of a building or structure.

(b) Grading, paving and maintenance of roads and streets.

(c) Use of roads and streets. Emissions from material in or on trucks, railroad cars and other vehicular equipment are not considered as emissions from use of roads and streets.

(d) Clearing of land.

(e) Stockpiling of material.

(f) Open burning operations.

(g) Sources and classes of sources other than those identified above, for which the operator has obtained a determination from the Department, in accordance with 25 Pa. Code §123.1 (b), that fugitive emissions from the source, after appropriate control, meet the following requirements:

(1) The emissions are of minor significance with respect to causing air pollution.

(2) The emissions are not preventing or interfering with the attainment or maintenance of any ambient air standard.

002 [25 Pa. Code §123.2]

Fugitive particulate matter

No person shall emit particulate matter into the outdoor atmosphere from a source specified in Condition #001 if the emissions are visible at the point the emissions pass outside the person's property.

003 [25 Pa. Code §123.31]

Limitations

No person shall permit the emission into the outdoor atmosphere of any malodorous air contaminants from any source in such a manner that the malodors are detectable outside the property of the person on whose land the source is being operated.

004 [25 Pa. Code §123.41]

Limitations

No person shall permit the emission into the outdoor atmosphere of visible air contaminants in such a manner that the opacity of the emission is either of the following:

(a) Equal to or greater than 20% for a period or periods aggregating more than three minutes in any 1 hour.

(b) Equal to or greater than 60% at any time.

005 [25 Pa. Code §123.42]


Exceptions

The emission limitation of 25 Pa. Code §123.41 shall not apply when:

(a) The presence of uncombined water is the only reason for failure of the emission to meet the limitation.

(b) The emission results from the operation of equipment used solely to train and test persons in observing the opacity of visible emissions.

(c) The emission results from sources specified in Section C, Condition #001.





Ž

SECTION C. Site Level Requirements

006 [25 Pa. Code §127.441] Operating permit terms and conditions. The permittee shall limit the actual emissions of the facility for any consecutive twelve-month period to below 49 tons of volatile organic compounds (VOC). # 007 [25 Pa. Code §129.14] **Open burning operations** (a) No person shall conduct open burning of materials in such a manner that: (1) The emissions are visible, at any time, at the point such emissions pass outside the property of the person on whose land the open burning is being conducted. (2) Malodorous air contaminants from the open burning are detectable outside the property of the person on whose land the open burning is being conducted. (3) The emissions interfere with the reasonable enjoyment of life and property. (4) The emissions cause damage to vegetation or property. (5) The emissions are or may be deleterious to human or animal health. (b) Exceptions. The requirements of Subsection (a) do not apply where the open burning operations result from: (1) A fire set to prevent or abate a fire hazard, when approved by the Department and set by or under the supervision of a public official. (2) Any fire set for the purpose of instructing personnel in fire fighting, when approved by the Department. (3) A fire set for the prevention and control of disease or pests, when approved by the Department. (4) A fire set solely for recreational or ceremonial purposes. (5) A fire set solely for cooking food. (c) This permit does not constitute authorization to burn solid waste pursuant to Section 610(3) of the Solid Waste Management Act, 35 P.S. Section 6018.610(3), or any other provision of the Solid Waste Management Act. II. TESTING REQUIREMENTS. # 008 [25 Pa. Code §127.441] Operating permit terms and conditions. The Department reserves the right to require exhaust stack testing of the sources referenced in this permit as necessary during the permit term to verify emissions for purposes including emission fees, malfunctions or permit condition violations. # 009 [25 Pa. Code §139.1] Sampling facilities. Upon the request of the Department, the permittee shall provide adequate sampling ports, safe sampling platforms and adequate utilities for the performance by the Department of tests on such sources. The Department will set forth, in the request, the time period in which the facilities shall be provided as well as the specifications for such facilities. # 010 [25 Pa. Code §139.11] General requirements. (a) As specified in 25 Pa. Code Section 139.11(1), performance tests shall be conducted while the source is operating at maximum routine operating conditions or under such other conditions, within the capacity of the equipment, as may be requested by the Department.





(b) As specified in 25 Pa. Code Section 139.11(2), the Department will consider test results for approval where sufficient information is provided to verify the source conditions existing at the time of the test and where adequate data is available to show the manner in which the test was conducted. Information submitted to the Department shall include, at a minimum, all of the following:

(1) A thorough source description, including a description of any air cleaning devices and the flue.

(2) Process conditions, for example, the fuel firing rate, boiler pressure or temperature, and other conditions which may affect emissions from the process.

(3) The location of the sampling ports.

(4) Effluent characteristics, including velocity, temperature, moisture content, gas density (percentage CO, CO2, O2, and N2), static and barometric pressures.

(5) Sample collection techniques employed, including procedures used, equipment descriptions, and data to verify that isokinetic sampling for particulate matter collection occurred and that acceptable test conditions were met.

(6) Laboratory procedures and results.

(7) Calculated results.

III. MONITORING REQUIREMENTS.

011 [25 Pa. Code §123.43]

Measuring techniques

Visible emissions may be measured using either of the following:

1) A device approved by the Department and maintained to provide accurate opacity measurements.

2) Observers, trained and certified, to measure plume opacity with the naked eye (i.e. EPA Reference Method 9) or with the aid of device(s) approved by the Department.

012 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall conduct a monthly inspection around the plant periphery during daylight hours when the plant is in production to detect visible emissions, fugitive emissions and malodors as follows:

(a) Visible emissions in excess of the limits stated in Section C, Condition #004. Visible emissions may be measured according to the methods specified in Section C, Condition #011, or alternately, plant personnel who observe such emissions may report the incidence of visible emissions to the Department within two hours of each incident and make arrangements for a certified observer to verify the visible emissions.

(b) The presence of fugitive visible emissions beyond the plant property boundaries, as stated in Section C, Condition #002.

(c) The presence of odorous air contaminants beyond the plant property boundaries as stated in Section C, Condition #003.

IV. RECORDKEEPING REQUIREMENTS.

013 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall maintain records of the monthly usage of natural gas supplied to the boilers and total annual natural gas usage for the production facility.

The permittee shall maintain hours of operation for each boiler, by shift, and each process oven, based on daily (24-hour)





process line operation.

The permittee shall retain these records for a minimum of five (5) years. The records shall be made available to the Department upon its request.

[Additional authority for this permit condition is derived from RACT OP No. 36-2037A.]

014 [25 Pa. Code §127.441]

Operating permit terms and conditions.

Unless otherwise noted, all records required by this and subsequent operating permits shall be maintained for the most recent five-year period and shall be readily available to the Department upon request. The most recent two years of records must be retained at the facility. The remaining three years of records may be retained off site. The records may be retained on paper, microfilm, microfiche or computer disks. If the records are retained on computer disks, the records must be in commonly available software. Commonly available software is usually compatible with a Microsoft application such as Word or Excel.

015 [25 Pa. Code §127.441] Operating permit terms and conditions.

The permittee shall maintain records of the monthly inspections around the plant periphery. The records shall include, at a minimum, the following information:

1.) Name of the company representative doing the observation.

- 2.) Date and time of the monitoring.
- 3.) Wind direction.

4.) Description of any emissions and/or malodors observed and actions to mitigate them. If none are present, record "NONE."

016 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall monthly calculate and/or estimate and record the quantities of volatile organic compounds (VOC) emitted by the facility in the preceding month as follows:

a) The permittee will track the amount of flavor used on a monthly basis and calculate actual emissions based on flavor usage and the VOC content in each flavoring.

- b) The permittee will calculate monthly emissions from the combustion sources based on actual fuel usage.
- c) The permittee will estimate the monthly VOC emissions from the use of ink products, pesticides and parts washers.
- d) The permittee shall estimate and record the monthly VOC emissions from the use of sanitizers and cleaning chemicals.

The permittee shall also monthly calculate and/or estimate and record the quantities of volatile organic compounds (VOC) emitted by the facility in the preceding twelve months to demonstrate compliance with the twelve consecutive month limitation of less than 49 tons per year of VOC.

017 [25 Pa. Code §135.3]

Reporting

Source owners or operators shall maintain and make available upon request by the Department, records including computerized records that may be necessary to comply with 25 PA Code 135.3 and 135.21 (relating to reporting, and emission statements). These may include records of production, fuel usage, maintenance of production or pollution control equipment or other information determined by the Department to be necessary for identification and quantification of potential and actual air contaminant emissions. If direct recordkeeping is not possible or practical, sufficent records shall be kept to provide the needed information by indirect means.

V. REPORTING REQUIREMENTS.

018 [25 Pa. Code §127.442]

Reporting requirements.

The permittee shall report malfunctions to the Department. A malfunction is any sudden, infrequent and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner. Failures that are caused in part by poor maintenance or careless operation are not malfunctions. Malfunctions shall be reported as follows:





(a) Any malfunction which poses an imminent danger to the public health, safety, welfare, and environment, shall be immediately reported to the Department by telephone. The telephone report of such malfunctions shall occur no later than two (2) hours after the incident. The permittee shall submit a written report of instances of such malfunctions to the Department within three (3) days of the telephone report.

(b) Unless otherwise required by this permit, any other malfunction that is not subject to the reporting requirements of part (a) above, shall be reported to the Department, in writing, within five (5) days of malfunction discovery.

(c) Telephone reports can be made to the Reading District Office at (610)916-0100 during normal business hours or to the Department's Emergency Hotline: (866)825-0208 at any time.

019 [25 Pa. Code §135.3]

Reporting

a) The permittee shall submit by March 1 of each year a source report for the preceding calendar year. The report shall include information for all previously reported sources, new sources which were first operated during the preceding calendar year and sources modified during the same period which were not previously reported.

b) The source owner or operator may request an extension of time from the Department for the filing of a source report, and the Department may grant the extension for reasonable cause.

020 [25 Pa. Code §135.4]

Report format

All source reports shall contain sufficient information to enable the Department to complete its emission inventory. Source reports shall be made by the source owner or operator in a format specified by the Department.

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VII. ADDITIONAL REQUIREMENTS.

021 [25 Pa. Code §123.1]

Prohibition of certain fugitive emissions

The permittee shall take all reasonable actions to prevent particulate matter from the sources identified in Section C, Condition #001(a) through (e) from becoming airborne. These actions shall include, but are not limited to, the following:

(a) Use, where possible, of water or chemicals for control of dust in the demolition of buildings or structures, construction operations, the grading of roads, or the clearing of land.

(b) Application of asphalt, oil, water or suitable chemicals on dirt roads, material stockpiles and other surfaces which create airborne dusts.

(c) Paving and maintenance of roadways.

(d) Prompt removal of earth or other material from paved streets onto which earth or other material has been transported by trucking or earth moving equipment, erosion by water, or other means.

022 [25 Pa. Code §127.441]

Operating permit terms and conditions.

All air pollution sources and air pollution control devices referenced in this permit shall be operated and maintained in accordance with the manufacturer's general recommendations and good air pollution control practices.

023 [25 Pa. Code §127.441]

Operating permit terms and conditions.

Operation of any air emissions source is contingent upon proper operation of its associated emissions control system, unless otherwise approved by the Department.





VIII. COMPLIANCE CERTIFICATION.

No additional compliance certifications exist except as provided in other sections of this permit including Section B (relating to State Only General Requirements).

IX. COMPLIANCE SCHEDULE.

No compliance milestones exist.

36-05152		KELLOGG USA LLC/EAST HEMPFIELD		
SECTION D. Sourc	e Level Requirements			
Source ID: 031	Source Name: BOILER 1			
	Source Capacity/Throughput:	66.000 MMBTU/HR 64.700 MCF/HR	NATURAL GAS/BIOGAS	
Conditions for this sourc	e occur in the following groups: 01 03			
CU 031 → STAC S031]			
FML FM001				
FML FM002				

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

36-05152	KELLOGG USA LLC/EAST HEMPFIELD		
SECTION D. Source Level Requirements			
Source ID: 032 Source Name: BOILER 2			
Source Capacity/Throughput:	66.000 MMBTU/HR 64.700 MCF/HR NATURAL GAS/BIOGAS		
Conditions for this source occur in the following groups: 01 03			
$ \begin{array}{c} CU\\ 032 \end{array} \longrightarrow \begin{array}{c} STAC\\ S031 \end{array} $			
FML M001			

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).


V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.



I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).






SECTION D. Source Level Requirements

Source ID: 100A

Source Name: BULK HANDLING SYSTEM

Source Capacity/Throughput:

Conditions for this source occur in the following groups: 02



I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.





SECTION D. Source Level Requirements

Source ID: 100B

Source Name: CORN LINE

Source Capacity/Throughput:

Conditions for this source occur in the following groups: 02

PROC		CNTL	STAC	
100B	-	C100	S100	

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.



Ž

SECTION D. Source Level Requirements

Source ID: 100C

Source Name: BRAN LINE

Source Capacity/Throughput:

Conditions for this source occur in the following groups: 02

PROC		CNTL	STAC	
100C	-	C100	S100	

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.





SECTION D. Source Level Requirements

Source ID: 100D

Source Name: SHRED LINE

Source Capacity/Throughput:

Conditions for this source occur in the following groups: 02

PROC	CNTL	STAC	
100D	C100	S100	

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.





SECTION D. Source Level Requirements

Source ID: 100E

Source Name: COMBO LINE

Source Capacity/Throughput:

Conditions for this source occur in the following groups: 02

PR	OC		CNTL		STAC]
10	00E -	7	C100		S100	
-						-

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.





SECTION D. Source Level Requirements

Source ID: 100F

Source Name: CRISPIX LINE

Source Capacity/Throughput:

Conditions for this source occur in the following groups: 02

PROC		CNTL	STAC	
100F	-	C100	S100	

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.





SECTION D. Source Level Requirements

Source ID: 100H

Source Name: COATING LINE 2

Source Capacity/Throughput:

PROC 100H	→	CNTL C102		STAC S102
	Þ	CNTL C105	-	STAC S105
	Ļ	CNTL C106	-	STAC S106

I. RESTRICTIONS.

Emission Restriction(s).

001 [25 Pa. Code §123.13]

Processes

No person shall permit the emission into the outdoor atmosphere of particulate matter from the source in excess of 0.04 grains per dry standard cubic foot of effluent gas.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

III. MONITORING REQUIREMENTS.

002 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall maintain instrumentation to monitor the water pressure into each rotoclone in pounds per square inch and the pressure drop across the baghouse.

IV. RECORDKEEPING REQUIREMENTS.

003 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall weekly record the pressure drop across the baghouse and the water pressure into each rotoclone.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

004 [25 Pa. Code §127.441] Operating permit terms and conditions.

The permittee shall operate the rotoclones and baghouse at all times when their source is operating.

005 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall operate the rotoclones and baghouse with their source in accordance with the manufacturer's specifications.





SECTION D. Source Level Requirements

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).





SECTION D. Source Level Requirements

Source ID: 103

Source Name: PACKING AREA (L12, L14, L23)

Source Capacity/Throughput:



I. RESTRICTIONS.

Emission Restriction(s).

001 [25 Pa. Code §127.441] Operating permit terms and conditions.

No person shall permit the emission into the outdoor atmosphere of particulate matter from the source in excess of 0.01 grains per dry standard cubic foot of effluent gas.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

III. MONITORING REQUIREMENTS.

002 [25 Pa. Code §127.441] Operating permit terms and conditions.

The permittee shall maintain instrumentation to monitor the pressure drop across the fabric collector.

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

003 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall operate the collector at all times that its source is operating.

004 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall operate the collector with its source in accordance with manufacturer's specifications.

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).






SECTION D. Source Level Requirements

Source ID: 104

Source Name: FLAVOR

Source Capacity/Throughput:

Conditions for this source occur in the following groups: 02



I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.






SECTION D. Source Level Requirements

Source ID: 201

Source Name: VOC SOURCES

Source Capacity/Throughput:

Conditions for this source occur in the following groups: 05



I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.





SECTION D. Source Level Requirements

Source ID: 301

Source Name: INKS/PARTS SOLVENTS

Source Capacity/Throughput:



I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

36-05152		KELLOGG USA LLC/EAST HEMPFIELD	Ž
SECTION D. Source	ce Level Requirements		
Source ID: 401	Source Name: FLARE		
	Source Capacity/Throughput:		
PROC 401 → STAC S401			
FML FM002			

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).






SECTION D. Source Level Requirements

Source ID: 501

Source Name: VACUUM SYSTEM

Source Capacity/Throughput:

Conditions for this source occur in the following groups: 02



I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.






SECTION D. Source Level Requirements

Source ID: 601

Source Name: PARTS WASHERS

Source Capacity/Throughput:



I. RESTRICTIONS.

Emission Restriction(s).

001 [25 Pa. Code §129.63] Degreasing operations

After December 22, 2002, the permittee may not use, sell or offer for sale for use in a cold cleaning machine any solvent with a vapor pressure of 1.0 millimeter or mercury (mm Hg) or greater and containing greater than 5% VOC by weight, measured at 20°C (68°F) containing VOCs.

The above requirement does not apply:

(i) To cold cleaning machines used in extreme cleaning service.

(ii) If the owner or operator of the cold cleaning machine demonstrates, and the Department approves in writing, that compliance with this condition will result in unsafe operating conditions.

(iii) To immersion cold cleaning machines with a freeboard ratio equal to or greater than 0.75.

Throughput Restriction(s).

002 [25 Pa. Code §129.63]

Degreasing operations

Immersion cold cleaning machines shall have a freeboard ratio of 0.50 or greater.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

003 [25 Pa. Code §129.63]

Degreasing operations

The permittee shall maintain for at least two (2) years and shall provide to the Department, on request, the following information:

- (i) The name and address of the solvent supplier.
- (ii) The type of solvent including the product or vendor identification number.
- (iii) The vapor pressure of the solvent measured in mm Hg at 20°C (68°F).

An invoice, bill of sale, certificate that corresponds to a number of sales, Material Safety Data Sheet (MSDS), or other appropriate documentation acceptable to the Department may be used to comply with this section.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).





SECTION D. Source Level Requirements

VI. WORK PRACTICE REQUIREMENTS.

004 [25 Pa. Code §129.63]

Degreasing operations

The permittee shall operate the cold cleaning machines in accordance with the following procedures:

(i) Waste solvent shall be collected and stored in closed containers. The closed containers may contain a device that allows pressure relief, but does not allow liquid solvent to drain from the container.

(ii) Flushing of parts using a flexible hose or other flushing device shall be performed only within the cold cleaning machine. The solvent spray shall be a solid fluid stream, not an atomized or shower spray.

(iii) Sponges, fabric, wood, leather, paper products and other absorbent materials may not be cleaned in the cold cleaning machine.

(iv) Air agitated solvent baths may not be used.

(v) Spills during solvent transfer and use of the cold cleaning machine shall be cleaned up immediately.

005 [25 Pa. Code §129.63]

Degreasing operations

Immersion cold cleaning machines shall be equipped with a cover that shall be closed at all times except during cleaning of parts or the addition or removal of solvent. For remote reservoir cold cleaning machines which drain directly into the solvent storage reservoir, a perforated drain with a diameter of not more than six (6) inches shall constitute an acceptable cover.

006 [25 Pa. Code §129.63]

Degreasing operations

For immersion cold cleaning machines and remote reservoir cold cleaning machines, the permittee shall:

Have a permanent, conspicuous label summarizing the operating requirements in Section D, Condition #004. In addition, the label shall include the following discretionary good operating practices:

(A) Cleaned parts should be drained at least 15 seconds or until dripping ceases, whichever is longer. Parts having cavities or blind holes shall be tipped or rotated while the part is draining. During the draining, tipping or rotating, the parts should be positioned so that solvent drains directly back to the cold cleaning machine.

(B) When a pump-agitated solvent bath is used, the agitator should be operated to produce a rolling motion of the solvent with no observable splashing of the solvent against the tank walls or the parts being cleaned.

(C) Work area fans should be located and positioned so that they do not blow across the opening of the degreaser unit.

VII. ADDITIONAL REQUIREMENTS.

007 [25 Pa. Code §129.63]

Degreasing operations

The permittee that operates a parts washer or cold cleaning machines that use 2 gallons or more of solvents containing greater than 5% VOC content by weight for the cleaning of metal parts shall comply with the requirements listed in this section.





SECTION D. Source Level Requirements

Source ID: 801

Source Name: MISCELLANEOUS SOURCES

Source Capacity/Throughput:



I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).






SECTION D. Source Level Requirements

Source ID: 901

Source Name: 20KW EMERGENCY GENERATOR

Source Capacity/Throughput:

Conditions for this source occur in the following groups: 04



I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.






SECTION D. Source Level Requirements

Source ID: 902

Source Name: 25KW EMERGENCY GENERATOR

Source Capacity/Throughput:

Conditions for this source occur in the following groups: 04



I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.






SECTION D. Source Level Requirements

Source ID: 903

Source Name: EMERGENCY FIRE PUMP

Source Capacity/Throughput:

Conditions for this source occur in the following groups: 04



I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.





Group Name: 01

Group Description: Boilers

Sources included in this group

36-05152

ID	Name
031	BOILER 1
032	BOILER 2

I. RESTRICTIONS.

Emission Restriction(s).

001 [25 Pa. Code §123.11]

Combustion units

No person shall permit the emission into the outdoor atmosphere of particulate matter from the individual combustion units in excess of 0.4 pound per million Btu of heat input.

002 [25 Pa. Code §123.22]

Combustion units

No person may permit the emission into the outdoor atmosphere of sulfur oxides, expressed as SO2, from a combustion unit in excess of the rate of 4 pounds per million Btu of heat input over any 1-hour period.

Fuel Restriction(s).

003 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall operate the Group 01 boilers on commercial natural gas and/or biogas.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

004 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee must maintain usage records on a calendar year basis of cubic feet of natural gas and/or biogas.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VII. ADDITIONAL REQUIREMENTS.

005 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11195]

SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources

Are any boilers not subject to this subpart?

§ 63.11195(e) - The above boilers as defined in accordance with Section 63.111237 are gas-fired boilers that burn





gaseous fuels not combined with any solid fuels, burn liquid fuel only during periods of gas curtailment, gas supply emergencies, or periodic testing on liquid fuel which does not exceed a combined total of 48 hours during any calendar year for each boiler. By operating the above boilers in this manner, the combustion units are exempt from the requirements of 40 CFR Part 63, Subpart JJJJJJ.





Group Name: 02

Group Description: Particulate Matter Sources

Sources included in this group

ID	Name
100A	BULK HANDLING SYSTEM
100B	CORN LINE
100C	BRAN LINE
100D	SHRED LINE
100E	COMBO LINE
100F	CRISPIXLINE
104	FLAVOR
501	VACUUM SYSTEM

I. RESTRICTIONS.

Emission Restriction(s).

001 [25 Pa. Code §123.13]

Processes

No person shall permit the emission into the outdoor atmosphere of particulate matter from the sources in Group 02 in excess of 0.04 grains per dry standard cubic foot of effluent gas, per unit.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

III. MONITORING REQUIREMENTS.

002 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall maintain instrumentation to monitor the pressure drop across each of the Group 02 fabric collectors.

003 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The facility shall provide instrumentation to measure the pressure drop across the air cleaning devices.

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

004 [25 Pa. Code §127.441]
Operating permit terms and conditions.
The permittee shall operate the collector at all times that its source is operating.
005 [25 Pa. Code §127.441]
Operating permit terms and conditions.
The permittee shall operate the collector with its source in accordance with manufacturer's specifications.





VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).





Group Name: 03

Group Description: 40 CFR 60, Subpart Dc Boilers

Sources included in this group

ID	Name
031	BOILER 1
032	BOILER 2

I. RESTRICTIONS.

Emission Restriction(s).

001 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.42c] Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Standard for sulfur dioxide.

(a) thru (c) NA - FACILITY DOES NOT COMBUST COAL

(d) NA - FACILITY DOES NOT COMBUST OIL

(e) NA - FACILITY DOES NOT COMBUST OIL OR COAL

(f) NA - FUEL NOT PRETREATED

(g) NA - FACILITY DOES NOT COMBUST OIL OR COAL

(h) NA - FACILITY DOES NOT COMBUST OIL OR COAL AND BOILERS ARE GREATER THAN 30 MMBTU/HR

(i) NA - FACILITY DOES NOT COMBUST OIL OR COAL

(j) NA - FACILITY LOCATED IN CONTINENTAL AREA

002 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.43c]

Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Standard for particulate matter.

(a) NA - FACILITY DOES NOT COMBUST COAL

(b) NA - FACILITY DOES NOT COMBUST WOOD

(c), (d) & (e) NA - FACILITY DOES NOT COMBUST WOOD, COAL OR OIL

II. TESTING REQUIREMENTS.

003 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.44c] Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Compliance and performance test methods and procedures for sulfur dioxide.

(a) thru (j) NA - FACILITY DOES NOT COMBUST COAL, WOOD OR OIL

004 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.45c] Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Compliance and performance test methods and procedures for particulate matter.

(a) NA - BOILERS ARE NOT SUBJECT TO 60.43C PM STANDARDS

(b) thru (d) NA - PM STANDARD DOES NOT APPLY

III. MONITORING REQUIREMENTS.

005 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.46c] Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Emission monitoring for sulfur dioxide

(a) NA - FACILITY DOES NOT COMBUST COAL, WOOD OR OIL





(b) & (c) NA - NOT USING CEMS

(d) & (e) NA - FACILITY DOES NOT COMBUST COAL, WOOD OR OIL

(f) NA - NOT USING CEMS

006 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.47c] Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Emission monitoring for particulate matter.

(a) NA - FACILITY NOT SUBJECT TO 60.43C PM STANDARDS.

(b) NA - FACILITY DOES NOT OPERATE A CONTINUOUS OPACITY MONITORING SYSTEM (COMS)

(c) NA - FACILITY NOT SUBJECT TO 60.43C PM STANDARDS.

(d) NA - FACILITY DOES NOT USE CEM

(e) NA - FACILITY NOT SUBJECT TO 60.43C PM STANDARDS AND DOES NOT USE COMS

(f) NA - FACILITY NOT SUBJECT TO 60.43C PM STANDARDS

IV. RECORDKEEPING REQUIREMENTS.

007 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.48c] Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Reporting and recordkeeping requirements.

(a) thru (f) listed under reporting requirements

(g)(1) Except as provided under paragraphs (g)(2) and (g)(3) of this section, the owner or operator of each affected facility shall record and maintain records of the amount of each fuel combusted during each operating day.

(g)(2) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility that combusts only natural gas, wood, fuels using fuel certification in § 60.48c(f) to demonstrate compliance with the SO2 standard, fuels not subject to an emissions standard (excluding opacity), or a mixture of these fuels may elect to record and maintain records of the amount of each fuel combusted during each calendar month.

(g)(3) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility or multiple affected facilities located on a contiguous property unit where the only fuels combusted in any steam generating unit (including steam generating units not subject to this subpart) at that property are natural gas, wood, distillate oil meeting the most current requirements in § 60.42C to use fuel certification to demonstrate compliance with the SO2 standard, and/or fuels, excluding coal and residual oil, not subject to an emissions standard (excluding opacity) may elect to record and maintain records of the total amount of each steam generating unit fuel delivered to that property during each calendar month.

(h) NA - FACILITY NOT SUBJECT TO ANNUAL CAPACITY FACTOR

(i) All records required under this section shall be maintained by the owner or operator of the affected facility for a period of two years following the date of such record.

(j) Listed under reporting requirements

V. REPORTING REQUIREMENTS.

008 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.48c] Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Reporting and recordkeeping requirements.

(a) NA - NOTIFICATION RECEIVED JULY 11, 2013

(b) NA - FACILITY IS NOT SUBJECT TO 60.42C EMISSION LIMITS OR 60.43C PM STANDARDS.





(c) NA - FACILITY IS NOT SUBJECT TO 60.43C PM STANDARDS

(d) & (e) NA - FACILITY IS NOT SUBJECT TO 60.42C EMISSION LIMITS

(f) NA - FUEL SUPPLIER CERTIFICATION IS NOT REQUIRED FOR NATURAL GAS/BIO GAS

(g), (h) & (i) listed under recordkeeping requirements

(j) NA - FUEL REPORTS ARE NOT REQUIRED

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VII. ADDITIONAL REQUIREMENTS.

009 [25 Pa. Code §127.441] Operating permit terms and conditions.

In the event that the Federal Subpart that is the subject of this Source Group is revised, the permittee shall comply with the revised version of the subpart, and shall not be required to comply with any provisions in this permit designated as having the subpart as their authority, to the extent that such permit provisions would be inconsistent with the applicable provisions of the revised subpart.

010 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.40c] Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Applicability and delegation of authority.

Boilers 1 & 2 are subject to Subpart Dc of the Standards of Performance for New Stationary Sources and shall comply with all applicable requirements of this Subpart. 40 CFR Section 60.4 requires submission of copies of all requests, reports, applications, submittals and other communications to both EPA and the Department. The EPA copies shall be forwarded to:

Director of Air Protection Division US EPA, Region III 1650 Arch Street Philadelphia, Pa 19103-2029

The Department copies shall be forwarded to:

Regional Air Program Manager PA Department of Environmental Protection 909 Elmerton Avenue Harrisburg, PA 17110-820





Group Name: 04

Group Description: 40 CFR 63, Subpart ZZZZ - Stationary Reciprocating Internal Combustion Engines

Sources included in this group

ID	Name
901	20KW EMERGENCY GENERATOR
902	25KW EMERGENCY GENERATOR
903	EMERGENCY FIRE PUMP

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VII. ADDITIONAL REQUIREMENTS.

001 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6585]
 Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines
 Am I subject to this subpart?

§ 63.6585 Am I subject to this subpart?

You are subject to this subpart if you own or operate a stationary RICE at a major or area source of HAP emissions, except if the stationary RICE is being tested at a stationary RICE test cell/stand.

(a) A stationary RICE is any internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.

(b) A major source of HAP emissions is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons (9.07 megagrams) or more per year or any combination of HAP at a rate of 25 tons (22.68 megagrams) or more per year, except that for oil and gas production facilities, a major source of HAP emissions is determined for each surface site.

(c) An area source of HAP emissions is a source that is not a major source.





(d) If you are an owner or operator of an area source subject to this subpart, your status as an entity subject to a standard or other requirements under this subpart does not subject you to the obligation to obtain a permit under 40 CFR part 70 or 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart as applicable.

(e) [NA-NOT USED FOR NATIONAL SECURITY PURPOSES]

(f) [NA – RICE NOT RESIDENTIAL, COMMERCIAL OR INSTITUTIONAL]

[69 FR 33506, June 15, 2004, as amended at 73 FR 3603, Jan. 18, 2008; 78 FR 6700, Jan. 30, 2013]

§ 63.6590 What parts of my plant does this subpart cover?

This subpart applies to each affected source.

(a) Affected source. An affected source is any existing, new, or reconstructed stationary RICE located at a major or area source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand.

- (1) Existing stationary RICE.
- (i) [NA-NOT A MAJOR HAP SOURCE]
- (ii) [NA NOT A MAJOR HAP SOURCE]

(iii) For stationary RICE located at an area source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

(iv) A change in ownership of an existing stationary RICE does not make that stationary RICE a new or reconstructed stationary RICE.

(2) New stationary RICE.

- (i) [NA-NOT A MAJOR HAP SOURCE]
- (ii) [NA-NOT A MAJOR HAP SOURCE]
- (iii) [NA-NOT A NEW SOURCE]
- (3) [NA-NOT A RECONSTRUCTED SOURCE]

(b) Stationary RICE subject to limited requirements. (1) An affected source which meets either of the criteria in paragraphs (b)(1)(i) through (ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of § 63.6645(f).

- (i) [NA NOT A MAJOR HAP SOURCE]
- (ii) [NA-NOT A MAJOR HAP SOURCE]
- (2) [NA NOT A MAJOR HAP SOURCE AND DOES NOT COMBUST LFG]

(3) The following stationary RICE do not have to meet the requirements of this subpart and of subpart A of this part, including initial notification requirements:

(i) [NA - NOT A MAJOR HAP SOURCE]

(ii) [NA – NOT A MAJOR HAP SOURCE]





(iii) [NA - NOT A MAJOR HAP SOURCE]

(iv) [NA - NOT A MAJOR HAP SOURCE]

(v) [NA - NOT A MAJOR HAP SOURCE AND DOES NOT COMBUST LFG]

(c) [NA-NOT SUBJECT TO SUBPARTS IIII OR JJJJ]

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9674, Mar. 3, 2010; 75 FR 37733, June 30, 2010; 75 FR 51588, Aug. 20, 2010; 78 FR 6700, Jan. 30, 2013]

§ 63.6595 When do I have to comply with this subpart?

(a) Affected sources. (1) If you have an existing stationary RICE, excluding existing non-emergency CI stationary RICE, with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the applicable emission limitations, operating limitations and other requirements no later than June 15, 2007. IF YOU HAVE an existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, an existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or AN EXISTING STATIONARY CI RICE LOCATED AT AN AREA SOURCE OF HAP EMISSIONS, YOU MUST COMPLY WITH THE APPLICABLE EMISSION LIMITATIONS, OPERATING LIMITATIONS, AND OTHER REQUIREMENTS NO LATER THAN MAY 3, 2013.

IF YOU HAVE an existing stationary SI RICE with a site rating of less than or equal to 500 brake HP located at a major source of hap emissions, or AN EXISTING STATIONARY SI RICE LOCATED AT AN AREA SOURCE OF HAP EMISSIONS, YOU MUST COMPLY WITH THE APPLICABLE EMISSION LIMITATIONS, OPERATING LIMITATIONS, AND OTHER REQUIREMENTS NO LATER THAN OCTOBER 19, 2013.

(2) [NA - NOT A MAJOR HAP SOURCE]

(3) [NA – NOT A MAJOR HAP SOURCE]

(4) [NA-NOT A MAJOR HAP SOURCE]

(5) [NA-NOT A MAJOR HAP SOURCE]

(6) [NA-NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(7) [NA-NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(b) Area sources that become major sources. If you have an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP, the compliance dates in paragraphs (b)(1) and (2) of this section apply to you.

(1) Any stationary RICE for which construction or reconstruction is commenced after the date when your area source becomes a major source of HAP must be in compliance with this subpart upon startup of your affected source.

(2) Any stationary RICE for which construction or reconstruction is commenced before your area source becomes a major source of HAP must be in compliance with the provisions of this subpart that are applicable to RICE located at major sources within 3 years after your area source becomes a major source of HAP.

(c) If you own or operate an affected source, you must meet the applicable notification requirements in § 63.6645 and in 40 CFR part 63, subpart A.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9675, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010; 78 FR 6701, Jan. 30, 2013]

Emission and Operating Limitations





§ 63.6600 What emission limitations and operating limitations must I meet if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?

[NA-NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

§ 63.6601 What emission limitations must I meet if I own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 brake HP and less than or equal to 500 brake HP located at a major source of HAP emissions?

[NA-NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

§ 63.6602 What emission limitations and other requirements must I meet if I own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions?

[NA-NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

§ 63.6603 What emission limitations, operating limitations, and other requirements must I meet if I own or operate an existing stationary RICE located at an area source of HAP emissions?

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart.

(a) If you own or operate an existing stationary RICE located at an area source of HAP emissions, YOU MUST COMPLY WITH THE REQUIREMENTS IN TABLE 2d to this subpart and the operating limitations in Table 2b to this subpart that apply to you.

TABLE 2d REQUIREMENTS:

4. For each EMERGENCY STATIONARY CI RICE and black start stationary CI RICE**, you must meet the following requirement, except during periods of startup:

a. Change oil and filter every 500 hours of operation or annually, whichever comes first*;

b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and

c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.

5. For each EMERGENCY STATIONARY SI RICE; black start stationary SI RICE; non-emergency, non-black start 4SLB stationary RICE >500 HP that operate 24 hours or less per calendar year; non-emergency, non-black start 4SRB stationary RICE >500 HP that operate 24 hours or less per calendar year**, you must meet the following requirement, except during periods of startup:

a. Change oil and filter every 500 hours of operation or annually, whichever comes first*;

b. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and

c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.

*Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in Table 2d of this subpart.

**If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in Table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has





36-05152

ended or the unacceptable risk under federal, state, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the federal, state or local law under which the risk was deemed unacceptable.

[END OF TABLE 2d REQUIREMENTS]

- (b) [NA-EMERGENCYENGINE(S)]
- (c) [NA-EMERGENCYENGINE(S)]
- (d) [NA-EMERGENCYENGINE(S)]
- (e) [NA-EMERGENCYENGINE(S)]
- (f) [NA-EMERGENCYENGINE(S)]

[75 FR 9675, Mar. 3, 2010, as amended at 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011; 78 FR 6701, Jan. 30, 2013]

§ 63.6604 What fuel requirements must I meet if I own or operate a stationary CI RICE?

(a) [NA-EMERGENCYENGINE(S)]

(b) Beginning January 1, 2015, if you own or operate an existing emergency CI stationary RICE with a site rating of more than 100 brake HP and a displacement of less than 30 liters per cylinder that uses diesel fuel and operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii) or that operates for the purpose specified in § 63.6640(f)(4)(ii), you must use diesel fuel that meets the requirements in 40 CFR 80.510(b) for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to January 1, 2015, may be used until depleted.

(c) [NA-NOT A MAJOR SOURCE]

(d) [NA - NOT IN SPECIFIED GEOGRAPHIC LOCATIONS]

[78 FR 6702, Jan. 30, 2013]

General Compliance Requirements

§ 63.6605 What are my general requirements for complying with this subpart?

(a) You must be in compliance with the emission limitations, operating limitations, and other requirements in this subpart that apply to you at all times.

(b) At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

[75 FR 9675, Mar. 3, 2010, as amended at 78 FR 6702, Jan. 30, 2013]

Testing and Initial Compliance Requirements

§ 63.6610 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?





[NA – NOT A MAJOR HAP SOURCE]

§ 63.6611 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a new or reconstructed 4SLB SI stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions?

[NA - NOT A MAJOR HAP SOURCE]

§ 63.6612 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions?

[NA-NO PERFORMANCE TESTING REQUIRED]

§ 63.6615 When must I conduct subsequent performance tests?

[NA-NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

§ 63.6620 What performance tests and other procedures must I use?

[NA - NO PERFORMANCE TESTING REQUIRED]

§ 63.6625 What are my monitoring, installation, collection, operation, and maintenance requirements?

- (a) [NA-CEMS NOT REQUIRED]
- (b) [NA-CPMS NOT REQUIRED]
- (c) [NA-LFG NOT USED]
- (d) [NA NOT A MAJOR HAP SOURCE]

(e) If you own or operate any of the following stationary RICE, you must operate and maintain the stationary RICE and aftertreatment control device (if any) according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions:

- (1) [NA NOT A MAJOR HAP SOURCE]
- (2) [NA-NOT A MAJOR HAP SOURCE]

(3) An existing emergency or black start stationary RICE located at an area source of HAP emissions;

- (4) [NA-EMERGENCYENGINE(S)]
- (5) [NA-EMERGENCY ENGINE(S)]
- (6) [NA-EMERGENCY ENGINE(S)]
- (7) [NA-EMERGENCY ENGINE(S)]
- (8) [NA-EMERGENCY ENGINE(S)]
- (9) [NA-EMERGENCY ENGINE(S)]
- (10) [NA-EMERGENCYENGINE(S)]





(f) If you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing emergency stationary RICE located at an area source of HAP emissions, you must install a non-resettable hour meter if one is not already installed.

(g) [NA-EMERGENCY ENGINE(S)]

(h) If you operate a new, reconstructed, or existing stationary engine, you must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup in Tables 1a, 2a, 2c, and 2d to this subpart apply.

(i) If you own or operate a stationary CI engine that is subject to the work, operation or management practices in items 1 or 2 of Table 2c to this subpart or in items 1 or 4 of Table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

(j) If you own or operate a stationary SI engine that is subject to the work, operation or management practices in items 6, 7, or 8 of Table 2c to this subpart or in items 5, 6, 7, 9, or 11 of Table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Acid Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Acid Number increases by more than 3.0 milligrams of potassium hydroxide (KOH) per gram from Total Acid Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011; 78 FR 6703, Jan. 30, 2013]


§ 63.6630 How do I demonstrate initial compliance with the emission limitations, operating limitations, and other requirements?

(a) You must demonstrate initial compliance with each emission limitation, operating limitation, and other requirement that applies to you according to Table 5 of this subpart. [NA – NONE OF THE CATEGORIES IN TABLE 5 APPLY TO EMERGENCY ENGINES]

(b) [NA - PERFORMANCE TESTING NOT REQUIRED]

(c) [NA-NOCS NOT REQUIRED FOR EXISTING EMERGENCY RICE]

(d) [NA-EMERGENCY ENGINE(S)]





(e) [NA-EMERGENCYENGINE(S)]

[69 FR 33506, June 15, 2004, as amended at 78 FR 6704, Jan. 30, 2013]

Continuous Compliance Requirements

§ 63.6635 How do I monitor and collect data to demonstrate continuous compliance?

[NA-NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

§ 63.6640 How do I demonstrate continuous compliance with the emission limitations, operating limitations, and other requirements?

(a) You must demonstrate continuous compliance with each emission limitation, operating limitation, and other requirements in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you according to methods specified in Table 6 to this subpart.

TABLE 6 REQUIREMENTS

9. FOR EACH existing emergency and black start stationary RICE <=500 HP located at a major source of HAP, existing nonemergency stationary RICE <100 HP located at a major source of HAP, EXISTING EMERGENCY and black start STATIONARY RICE LOCATED AT AN AREA SOURCE OF HAP, existing non-emergency stationary CI RICE <=300 HP located at an area source of HAP, existing non-emergency 2SLB stationary RICE located at an area source of HAP, existing non-emergency stationary SI RICE located at an area source of HAP which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, existing non-emergency 4SLB and 4SRB stationary RICE <=500 HP located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE <=500 HP located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE <=500 HP located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE <=500 HP located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE <=500 HP located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE <=500 HP located at an area source of HAP, that operate 24 hours or less per calendar year, and existing non-emergency 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP that are remote stationary RICE, complying with the requirement to "Work or Management practices", you must demonstrate continuous compliance by:

i. Operating and maintaining the stationary RICE according to the manufacturer's emission-related operation and maintenance instructions; or

ii. Develop and follow your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.

[END OF TABLE 6 REQUIREMENTS]

(b) [NA-NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(c) [NA - ANNUAL COMPLIANCE DEMONSTRATION NOT REQUIRED]

(d) [NA-NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(e) You must also report each instance in which you did not meet the requirements in Table 8 to this subpart that apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing emergency stationary RICE, an existing limited use stationary RICE, or an existing stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart, except for the initial notification requirements: a new or reconstructed stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new or reconstructed emergency stationary RICE, or a new or





reconstructed limited use stationary RICE. [EXISTING EMERGENCY RICE AT AREA HAP SOURCES ARE NOT AMONG THOSE EXEMPTED FROM THIS SECTION]

(f) If you own or operate an emergency stationary RICE, you must operate the emergency stationary RICE according to the requirements in paragraphs (f)(1) through (4) of this section. In order for the engine to be considered an emergency stationary RICE under this subpart, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f)(1) through (4) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1) through (4) of this section, the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.

(1) There is no time limit on the use of emergency stationary RICE in emergency situations.

(2) You may operate your emergency stationary RICE for any combination of the purposes specified in paragraphs (f)(2)(i) through (iii) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraphs (f)(3) and (4) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (f)(2).

(i) Emergency stationary RICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency RICE beyond 100 hours per calendar year.

(ii)-(iii) [VACATED AS OF 5/2/16 PER COURT ORDER]

(3) [NA-NOT A MAJOR HAP SOURCE]

(4) Emergency stationary RICE located at area sources of HAP may be operated for up to 50 hours per calendar year in nonemergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in paragraph (f)(2) of this section. Except as provided in paragraphs (f)(4)(i) and (ii) of this section, the 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

(i) Prior to May 3, 2014, the 50 hours per year for non-emergency situations can be used for peak shaving or non-emergency demand response to generate income for a facility, or to otherwise supply power as part of a financial arrangement with another entity if the engine is operated as part of a peak shaving (load management program) with the local distribution system operator and the power is provided only to the facility itself or to support the local distribution system.

(ii) The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:

(A) The engine is dispatched by the local balancing authority or local transmission and distribution system operator.

(B) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.

(C) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.

(D) The power is provided only to the facility itself or to support the local transmission and distribution system.

(E) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine





owner or operator.

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006; 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010; 78 FR 6704, Jan. 30, 2013]

Notifications, Reports, and Records

§ 63.6645 What notifications must I submit and when?

(a) You must submit all of the notifications in \S 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) that apply to you by the dates specified if you own or operate any of the following;

(1) [NA - NOT A MAJOR HAP SOURCE]

(2) [NA PER (5) BELOW]

- (3) [NA NOT A MAJOR HAP SOURCE]
- (4) [NA-NOT A MAJOR HAP SOURCE]

(5) THIS REQUIREMENT DOES NOT APPLY IF YOU OWN OR OPERATE an existing stationary RICE less than 100 HP, AN EXISTING STATIONARY EMERGENCY RICE, OR AN EXISTING STATIONARY RICE THAT IS NOT SUBJECT TO ANY NUMERICAL EMISSION STANDARDS.

- (b) [NA NOT A MAJOR HAP SOURCE]
- (c) [NA-NOT A MAJOR HAP SOURCE]
- (d) [NA NOT A MAJOR HAP SOURCE]
- (e) [NA NOT A MAJOR HAP SOURCE]
- (f) [NA-63.6590(b) DOES NOT APPLY]
- (g) [NA PERFORMANCE TEST NOT REQUIRED]
- (h) [NA PERFORMANCE TEST NOT REQUIRED]
- (i) [NA-EMERGENCYENGINE(S)]

[73 FR 3606, Jan. 18, 2008, as amended at 75 FR 9677, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010; 78 FR 6705, Jan. 30, 2013]

§ 63.6650 What reports must I submit and when?

(a) You must submit each report in Table 7 of this subpart that applies to you.

TABLE 7 REQUIREMENTS

4. For each emergency stationary RICE that operate or are contractually obligated to be available for more than 15 hours per year for the purposes specified in § 63.6640(f)(2)(ii) and (iii) or that operate for the purposes specified in § 63.6640(f)(4)(ii), you must submit a Report. The report must contain the information in § 63.6650(h)(1). You must submit the report annually according to the requirements in § 63.6650(h)(2)-(3).

[END OF TABLE 7 REQUIREMENTS]

(b) Unless the Administrator has approved a different schedule for submission of reports under § 63.10(a), you must





submit each report by the date in Table 7 of this subpart and according to the requirements in paragraphs (b)(1) through (b)(9) of this section.

(1) [NA - ANNUAL REPORT REQUIRED, ONLY UNDER CERTAIN CONDITIONS]

(2) [NA - ANNUAL REPORT REQUIRED, ONLY UNDER CERTAIN CONDITIONS]

(3) [NA - ANNUAL REPORT REQUIRED, ONLY UNDER CERTAIN CONDITIONS]

(4) [NA - ANNUAL REPORT REQUIRED, ONLY UNDER CERTAIN CONDITIONS]

(5) [NA - ANNUAL REPORT REQUIRED, ONLY UNDER CERTAIN CONDITIONS]

(6) For annual Compliance reports, the first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.6595 and ending on December 31.

(7) For annual Compliance reports, the first Compliance report must be postmarked or delivered no later than January 31 following the end of the first calendar year after the compliance date that is specified for your affected source in § 63.6595.

(8) For annual Compliance reports, each subsequent Compliance report must cover the annual reporting period from January 1 through December 31.

(9) For annual Compliance reports, each subsequent Compliance report must be postmarked or delivered no later than January 31.

(c) [NA- "COMPLIANCE REPORT" NOT REQUIRED]

(d) [NA-NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(e) [NA-NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(f) [NA - NOT SUBJECT TO TITLE V PERMITTING]

(g) [NA-LFG NOT USED]

(h) If you own or operate an emergency stationary RICE with a site rating of more than 100 brake HP that operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii) or that operates for the purpose specified in § 63.6640(f)(4)(ii), you must submit an annual report according to the requirements in paragraphs (h)(1) through (3) of this section.

(1) The report must contain the following information:

(i) Company name and address where the engine is located.

(ii) Date of the report and beginning and ending dates of the reporting period.

(iii) Engine site rating and model year.

(iv) Latitude and longitude of the engine in decimal degrees reported to the fifth decimal place.

(v) Hours operated for the purposes specified in 63.6640(f)(2)(ii) and (iii), including the date, start time, and end time for engine operation for the purposes specified in 63.6640(f)(2)(ii) and (iii).

(vi) Number of hours the engine is contractually obligated to be available for the purposes specified in § 63.6640(f)(2)(ii) and (iii).

(vii) Hours spent for operation for the purpose specified in § 63.6640(f)(4)(ii), including the date, start time, and end time for





36-05152

engine operation for the purposes specified in 63.6640(f)(4)(ii). The report must also identify the entity that dispatched the engine and the situation that necessitated the dispatch of the engine.

(viii) If there were no deviations from the fuel requirements in § 63.6604 that apply to the engine (if any), a statement that there were no deviations from the fuel requirements during the reporting period.

(ix) If there were deviations from the fuel requirements in § 63.6604 that apply to the engine (if any), information on the number, duration, and cause of deviations, and the corrective action taken.

(2) The first annual report must cover the calendar year 2015 and must be submitted no later than March 31, 2016. Subsequent annual reports for each calendar year must be submitted no later than March 31 of the following calendar year.

(3) The annual report must be submitted electronically using the subpart specific reporting form in the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) (www.epa.gov/cdx). However, if the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the written report must be submitted to the Administrator at the appropriate address listed in § 63.13.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9677, Mar. 3, 2010; 78 FR 6705, Jan. 30, 2013]

§ 63.6655 What records must I keep?

(a) [NA-NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(b) [NA-NO CEMS OR CPMS]

(c) [NA-LFG NOT USED]

(d) [NA-NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(e) You must keep records of the maintenance conducted on the stationary RICE in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan if you own or operate any of the following stationary RICE;

(1) [NA – NOT A MAJOR HAP SOURCE]

(2) An existing stationary emergency RICE.

(3) An existing stationary RICE located at an area source of HAP emissions subject to management practices as shown in Table 2d to this subpart.

(f) If you own or operate any of the stationary RICE in paragraphs (f)(1) through (2) of this section, you must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The owner or operator must document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation. If the engine is used for the purposes specified in § 63.6640(f)(2)(ii) or (iii) or § 63.6640(f)(4)(ii), the owner or operator must keep records of the notification of the emergency situation, and the date, start time, and end time of engine operation for these purposes.

(1) [NA - NOT A MAJOR HAP SOURCE]

(2) An existing emergency stationary RICE located at an area source of HAP emissions that does not meet the standards applicable to non-emergency engines.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010; 75 FR 51592, Aug. 20, 2010; 78 FR 6706, Jan. 30, 2013]

§ 63.6660 In what form and how long must I keep my records?





(a) Your records must be in a form suitable and readily available for expeditious review according to § 63.10(b)(1).

(b) As specified in § 63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to § 63.10(b)(1).

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010]

Other Requirements and Information

§ 63.6665 What parts of the General Provisions apply to me?

Table 8 to this subpart shows which parts of the General Provisions in §§ 63.1 through 63.15 apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with any of the requirements of the General Provisions specified in Table 8: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing stationary RICE that combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, an existing emergency stationary RICE, or an existing limited use stationary RICE. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in the General Provisions specified in Table 8 except for the initial notification requirements: A new stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new emergency stationary RICE, or a new limited use stationary RICE. [EXISTING EMERGENCY RICE AT AREA HAP SOURCES ARE NOT AMONG THOSE EXEMPTED FROM THIS SECTION]

[75 FR 9678, Mar. 3, 2010]

Regulatory Changes:

Individual sources within this source group that are subject to 40 CFR Part 63 Subpart ZZZZ -National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines shall comply with all applicable requirements of the Subpart. 40 CFR 63.13(a) requires submission of copies of all requests, reports and other communications to both the Department and the EPA. The EPA copies shall be forwarded to:

Director Air Protection Division (3AP00) U.S. EPA Region III 1650 Arch Street Philadelphia, PA 19103-2029

The Department copies shall be forwarded to:

Regional Air Program Manager PA Department of Environmental Protection 909 Elmerton Avenue Harrisburg, PA 17110-8200

In the event that the Federal Subpart that is the subject of this Source Group is revised, the permittee shall comply with the revised version of the subpart, and shall not be required to comply with any provisions in this permit designated as having the subpart as their authority, to the extent that such permit provisions would be inconsistent with the applicable provisions of the revised subpart.





36-05152

SECTION E. Source Group Restrictions.

Group Name: 05

Group Description: Pa. 129.63a Control of VOC emissions from industrial cleaning solvents

Sources included in this group

ID	Name
201	VOC SOURCES

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

VII. ADDITIONAL REQUIREMENTS.

001 [25 Pa. Code §127.441]

Operating permit terms and conditions.

(a) Applicability. This section applies to the owner and the operator of a facility at which an industrial cleaning solvent is used or applied in a cleaning activity at a cleaning unit operation, a work production-related work area or a part, product, tool, machinery, equipment, vessel, floor or wall.

- (b) Definitions [INCLUDED BY REFERENCE]
- (c) Exceptions and exemptions.
- (1) This section does not apply to all of the following:
- (i) [NA CLEANING UNITS NOT SUBJECT TO PA.129.63 OR 40 CFR PART 63, SUBPART T]

(ii) An owner or operator of a cleaning unit operation associated with a following category: [NA - FACILITY IS NOT INCLUDED IN EXEMPT CATEGORIES]

(2) The VOC emission limitations in subsection (e) do not apply to the use or application of an industrial cleaning solvent by the owner or operator of a cleaning unit operation at a facility subject to subsection (a) under either of the following circumstances:





(i) [NA - NOT FEDERAL GOVERNMENT]

(ii) [NA - NO SCREEN PRINTING EQUIPMENT]

(3) The VOC emission limitations in subsection (e) and the work practice requirements in subsection (f) do not apply to the owner or operator of a facility subject to subsection (a) if the total combined actual VOC emissions from all subject cleaning unit operations at the facility are less than 2.7 tons (2,455 kilograms) per 12-month rolling period, before consideration of controls. An owner or operator claiming this exemption shall maintain records in accordance with subsection (h)(4).

(d) [NA - NO RACT PERMIT]

(e) Emissions limitations. Beginning August 11, 2018, the owner or operator of a facility at which the total combined actual VOC emissions from all subject cleaning unit operations at the facility are equal to or greater than 2.7 tons (2,455 kilograms) per 12-month rolling period, before consideration of controls, may not cause or permit the emission into the outdoor atmosphere of VOCs from an industrial cleaning solvent used or applied in a cleaning unit operation subject to this section at the facility, unless one of the following limitations is met:

(1) Compliant solvents. The industrial cleaning solvent meets one of the following VOC limits:

(i) A VOC content less than or equal to 0.42 lb VOC/gal (50 g VOC/l) as applied.

(ii) A VOC composite vapor pressure less than or equal to 8 mm mercury at 68°F (20°C) as applied.

(2) [NA - NO VOC CAPTURE AND CONTROL DEVICE]

(f) Work practice requirements for industrial cleaning solvents, used shop towels and waste materials. The owner or operator of a facility subject to subsection (e) shall comply with all of the following work practices for industrial cleaning solvents and shop towels used in the cleaning unit operation cleaning activity:

(1) Store all VOC-containing industrial cleaning solvents, used shop towels and related waste materials in closed containers.

(2) Ensure that mixing and storage containers used for VOC-containing industrial cleaning solvents and related waste materials are kept closed at all times except when depositing or removing these materials.

(3) Minimize spills of VOC-containing industrial cleaning solvents and related waste materials and clean up spills immediately.

(4) Convey VOC-containing industrial cleaning solvents and related waste materials from one location to another in closed containers or pipes.

(5) Minimize VOC emissions from cleaning of storage, mixing and conveying equipment.

(6) Minimize air circulation around cleaning unit operations.

(g) Compliance demonstration. The owner or operator of a cleaning unit operation subject to this section shall demonstrate compliance as follows:

(1) The owner or operator of a facility at which the total combined actual VOC emissions from all subject cleaning unit operations at the facility are equal to or greater than 2.7 tons (2,455 kilograms) per 12-month rolling period, before consideration of controls, shall do either of the following:

(i) Ensure that industrial cleaning solvents used or applied in the subject cleaning unit operations at the facility meet the applicable emissions limitation in subsection (e)(1) and maintain records in accordance with subsection (h)(1)(i).

(ii) [NA - NO VOC CAPTURE AND CONTROL DEVICE]





(2) The owner or operator of a cleaning unit operation subject to this section claiming exemption under:

(i) [NA - SUBSECTION (c)(2)(i) EXEMPTION NOT CLAIMED]

(ii) [NA - SUBSECTION (c)(2)(ii) EXEMPTION NOT CLAIMED]

(iii) Subsection (c)(3) shall maintain records in accordance with subsection (h)(4).

(3) The owner or operator of a cleaning unit operation subject to this section shall determine the VOC content of the industrial cleaning solvent as applied by conducting sampling and testing of the industrial cleaning solvent in accordance with the procedures and test methods specified in subsections (i) and (j) and Chapter 139.

(4) The owner or operator of a cleaning unit operation subject to paragraph (3) may use other test methods or documentation to demonstrate compliance with this section if approved in advance in writing by the Department and the EPA.

(h) Recordkeeping and reporting requirements. The owner or operator of a cleaning unit operation subject to this section shall comply with all of the following applicable recordkeeping and reporting requirements:

(1) The owner or operator of a facility at which the total combined actual VOC emissions from all subject cleaning unit operations at the facility are equal to or greater than 2.7 tons (2,455 kilograms) per 12-month rolling period, before consideration of controls, shall maintain all of the applicable records:

(i) For an owner or operator that complies with this section by using a complying industrial cleaning solvent under subsection (e)(1), records of all of the following parameters for each cleaning unit operation industrial cleaning solvent:

(A) The name and identification number.

(B) The weight percent of total volatiles, water and exempt solvents, as supplied.

(C) The VOC content or composite vapor pressure, as supplied. The composite vapor pressure as supplied shall be determined in accordance with subsections (i) and (j).

(D) The VOC content or composite vapor pressure, as applied. The composite vapor pressure as applied shall be determined in accordance with subsections (i) and (j).

(E) The volume used or applied on a monthly basis.

(ii) [NA - NO VOC CAPTURE AND CONTROL DEVICE]

(2) [NA - SUBSECTION (c)(2)(i) EXEMPTION NOT CLAIMED]

(3) [NA - SUBSECTION (c)(2)(ii) EXEMPTION NOT CLAIMED]

(4) The owner or operator of a facility claiming exemption under subsection (c)(3) shall maintain monthly records of the industrial cleaning solvents used or applied at the subject cleaning unit operations sufficient to demonstrate that the total combined actual VOC emissions from all subject cleaning unit operations at the facility are less than 2.7 tons (2,455 kilograms) per 12-month rolling period, before consideration of controls.

(5) Records shall be maintained onsite for 2 years, unless a longer period is required under Chapter 127 (relating to construction, modification, reactivation and operation of sources) or a plan approval, operating permit, consent decree or order issued by the Department.

(6) Records shall be submitted to the Department in an acceptable format upon receipt of a written request from the Department.

(i) Composite vapor pressure. The composite vapor pressure of organic compounds in cleaning unit operation industrial







36-05152

cleaning solvents shall be determined by one or more of the following procedures:

(1) Quantifying the amount of each compound in the blend using gas chromatographic analysis, using one or more of the following methods:

(i) An appropriate and current ASTM test method with prior written approval from the Department and the EPA.

(ii) Another test method demonstrated to provide results that are acceptable for purposes of determining compliance with this section if prior approval is obtained in writing from the Department and the EPA.

(2) Calculating the composite vapor pressure using the following equation:

[REFERENCE REGULATION FOR EQUATION]

(3) Providing documentation from the manufacturer of the industrial cleaning solvent that indicates the composite vapor pressure. The documentation may include an MSDS, CPDS or other data certified by the manufacturer.

(j) Vapor pressure of single component compound. The vapor pressure of each single component compound in a cleaning unit operation industrial cleaning solvent shall be determined from one or more of the following:

(1) An appropriate and current ASTM test method with prior written approval from the Department and the EPA.

- (2) The most recent edition of one or more of the following sources:
- (i) Vapour Pressures of Pure Substances, Boublik, Elsevier Scientific Publishing Company.
- (ii) Perry's Chemical Engineers' Handbook, Green and Perry, McGraw-Hill Book Company.
- (iii) CRC Handbook of Chemistry and Physics, CRC Press.
- (iv) Lange's Handbook of Chemistry, McGraw-Hill Book Company.

(3) Documentation provided by the manufacturer of the single component compound that indicates the vapor pressure of the single component compound. The documentation may include an MSDS, CPDS or other data certified by the manufacturer.

(k) ASTM method references. References to ASTM methods in this section pertain to test methods developed by ASTM International, 100 Barr Harbor Drive, Post Office Box C700, West Conshohocken, Pennsylvania 19428-2959, www.astm.org.





SECTION F. Alternative Operation Requirements.

No Alternative Operations exist for this State Only facility.





SECTION G. Emission Restriction Summary.

No emission restrictions listed in this section of the permit.





SECTION H. Miscellaneous.

36-05152

This administrative amendment for an ownership change supersedes operating permit 36-05152 amended May 3, 2023 for plan approval 36-05152F.

NOTE: The capacities listed in Section A, page 4, are for informational use only and should not be used as enforceable limitations.

The following sources and activities are not subject to any specific work practice standards, testing, monitoring, recordkeeping, or reporting requirements:

A) Biogas produced by the waste treatment plant and injected into the natural gas line B) WWTP natural gas fired water heater

Details of the sources and control devices in this permit are in the following plan approvals:

Bulk Handling Plan Approvals 36-317-101A 36-317-102A 36-317-103A 36-317-133 36-317-134 36-317-151 through 153 Flavor Making Plan Approval 36-317-112 Corn Line Plan Approvals 36-317-105 through 108 36-317-113 36-317-115 36-317-117 36-317-120 through 122 Bran Line Plan Approvals 36-317-110 36-317-111A 36-317-114 36-317-116 36-317-118 36-317-119 Vacuum Cleaning System Plan Approvals 36-317-130 36-317-131 36-317-132 36-317-178 36-317-149 36-317-150 36-317-169 36-317-170 Shred Line Plan Approvals 36-317-136 through 147 Combo Line Plan Approvals 36-317-155 36-317-156 36-317-158 36-317-159 36-317-161

36-317-164





SECTION H. Miscellaneous.

36-317-165 36-317-212

Crispix Line Plan Approvals 36-317-162 36-317-163 36-317-172 through 177 36-317-179 36-317-181 36-317-157

Coating Line Plan Approvals 36-317-182 36-317-125 36-03141A

Boiler Plan Approvals 36-03141B

VOC Sources: 36-05152A

Source 100, Miscellaneous Combustion Sources, is comprised of process combustion sources using natural gas and the waste water treatment plant process water heater.

Source 201, VOC Sources, is comprised of pesticides and sanitizers (including alcohol-based sanitizer and cleaning chemicals).

Source 801, Miscellaneous Sources, is comprised of flavor making materials utilized in the shred line (VOC emissions) and eight cooling towers.





****** End of Report ******