



# pennsylvania

DEPARTMENT OF ENVIRONMENTAL PROTECTION  
NORTHCENTRAL REGIONAL OFFICE

MAN

April 8, 2011

CERTIFIED MAIL NO. [REDACTED]

Re: Act 223, Section 208 Determination  
Complaint No. 273463  
Washington Township, Wyoming County

Dear [REDACTED]

The Department has investigated the possible degradation of your water supply well located at [REDACTED], in response to an 8/13/2010 complaint that recent gas well drilling activities may have affected your water well.

On 10/27/2010, the Department collected samples from your water supply. The samples were submitted to the Department's laboratory in Harrisburg for analysis. The analytical reports for the samples are included, as well as documents that will assist you with interpreting the sample results. The sample results showed methane is present at 1.4 mg/l in your water supply. Methane gas was also detected in the headspace of your water well. Combustible gas readings obtained by the Department ranged from 30 percent on 10/26/2010 to nondetect on 12/22/2010. The Department investigation indicates that gas well drilling has impacted your water supply.


Methane is the predominant component of natural gas. Drinking water standard limitations have not been established for methane gas and the Department is not aware of any associated health risks. The true level of concern begins above 28 mg/l methane, which is referred to as the saturation level. At this level, under normal atmospheric pressure, the water cannot hold additional methane in solution. The potential hazard occurs when the water is used for extended periods of time. This may allow the gas to come out of the water and concentrate in the air space of your home or building. There is a physical danger of fire or explosion due to the migration of natural gas into water wells or through soils into dwellings where it could be ignited by sources that are present in most homes/buildings. Due to the presence of free combustible gas detected in your well, it is recommended that the well be properly vented. Natural gas can also cause a threat of asphyxiation, although this is extremely rare.

It is the Department's recommendation that all water wells should be equipped with a working vent. This will help alleviate the possibility of concentrating these gases in areas where ignition would pose a threat to life or property. Please note that it is not possible to completely eliminate the hazards of having natural gas in your water supply by simply venting your well.

4/8/2011

The Department is continuing to work to permanently resolve this issue. Should you have any questions concerning this matter, please feel free to contact Eric Rooney at 570-346-5543.

Sincerely,



Jennifer W. Means  
Environmental Program Manager  
Oil and Gas Management

Enclosures: Laboratory Analytical Results  
"How to Interpret A Water Analysis Report"

cc: Jennifer Means  
Marc Cooley  
Eric Rooney  
William J. Kosmer, P.G.  
Complaint File



# pennsylvania

DEPARTMENT OF ENVIRONMENTAL PROTECTION  
DISTRICT OIL AND GAS OPERATIONS

September 5, 2012

[REDACTED]  
[REDACTED]  
[REDACTED]  
**CERTIFIED MAIL NO.** [REDACTED]

Re: 58 Pa. C.S § 3218 Determination  
Complaint No. 273463  
Washington Township, Wyoming County

Dear [REDACTED]

The Department has investigated the degradation of your home water supply well located on [REDACTED], in response to an August 13, 2010, complaint that gas well drilling activities may have affected your water well. The Department collected combustible gas readings and water samples from your well. The combustible gas readings indicated that gas well drilling had impacted your water supply, and on April 8, 2011, the Department issued a letter of positive determination describing this impact.

Subsequent to the issuance of the April 8, 2011, determination letter, additional combustible gas readings and water samples were collected from your water supply as part of an intensive investigation. The combustible gas readings and samples were collected by the Department and a qualified third party and samples were submitted to an independent accredited laboratory for analysis. The analytical reports for those samples were previously submitted to you. The Department's investigation indicates that the previous impact to your water supply appears to have been temporary, and that water quality has returned to background conditions.

Based on water quality sample results to date, the Department does not anticipate requiring any further action in relation to this matter. Should you have any questions, please feel free to contact Eric Rooney at 570-346-5543.

Sincerely,

Jennifer W. Means  
Eastern District Oil and Gas Manager  
Bureau of District Oil and Gas Operations

cc:

Jennifer Means  
William J. Kosmer, P.G.  
Marc Cooley  
Eric Rooney  
Complaint File 273463  
[REDACTED]