



December 14, 2015

CERTIFIED MAIL NO. [REDACTED]

[REDACTED]

Re: 58 Pa. C.S. § 3218 Determination  
Complaint No. 315337  
Eulalia Township, Potter County

Dear [REDACTED]

The Department initiated an investigation of the possible degradation (a reported turbidity increase/soapy water) of your water supply "Water Supply" located at the address above in Eulalia Township, Potter County in response to a 9/21/2015 complaint that recent gas well drilling activities may have affected your water supply well. Based on the sample results and other information obtained to date, the Department has determined that the Water Supply was adversely affected by the drilling, alteration, or operation of an oil or gas well. The information, upon which this determination is based, is summarized below.

[REDACTED] reported that the Water Supply's conditions had changed on 9/21/2015. No pre-drill water quality data was available for the Water Supply. Subsequently, water quality samples were collected from the Water Supply on several occasions by the Department and private consultants, and were submitted to the Department's laboratory or to an accredited third party laboratory for analysis. The analytical reports for the samples collected by the Department were previously submitted to you. Please see the attached documents, which include sampling results regarding the quality of the Water Supply, as well as information regarding interpreting those results.

On 9/29/2015 and 10/14/2015, Department staff observed that water from the Water Supply appeared clear, but had a slight soapy appearance during the 9/29/2015 sampling event. Water quality samples were collected on both dates for analysis by the Department's laboratory. After review of the data collected by the Department and others, the results reveal that the water quality observed is consistent with the issues reported to the Department and appears to be related to oil and gas drilling activities.

Specifically, analytical data collected over the investigation period reveal turbidity levels as high as 30.2 NTU during the initial sampling conducted on 9/23/2015 by [REDACTED] representatives, which has since subsided to 1.29 NTU during the 10/14/2015 split sampling conducted by the Department [REDACTED]. Additionally, concentrations of iron and aluminum were detected above their respective Secondary Maximum Contaminant Levels (SMCLs) during the September sampling events. Iron concentrations have since decreased to levels that are in compliance with

its respective SMCL, while aluminum has fluctuated above and below its respective SMCL. The entrainment of sediment in the samples, is the most likely cause of the observed increases in metals, which are common elements found in the soils and geology of the area. Isopropanol was not detected during any of the sampling events conducted on the Water Supply. Methylene Blue Active Substance (MBAS), an analysis for surfactants, was detected at 1.2 mg/L in the 9/23/2015 sampling event, but has been <0.0250 mg/L since the initial detection.

Acetone and bis(2-Ethylhexyl)phthalate were the only Volatile/Semi-volatile Organic Compounds (VOC/SVOCs) detected in the Water Supply during the investigation. Acetone is a degradation by-product of isopropanol in the aquifer. No VOCs or SVOCs were detected above applicable standards during the investigation, and recent analytical data indicate the absence of these compounds with the exception of bis(2-Ethylhexyl)phthalate. However, this compound was also detected in the trip blank collected during the sampling event at a similar concentration, and in the laboratory QA/QC blanks, and appears related to the vials used to store the hydrochloric acid used in sample preservation or from laboratory contamination, and therefore does not appear to be related to the release.

This is an ongoing investigation and a Department representative will be contacting you in the near future to schedule another round of sampling from the Water Supply. The Department will send you a follow-up letter when the Department determines that conditions in the Water Supply have returned to background conditions. Should you have any questions concerning this matter, please feel free to contact William J. Kosmer, P.G. at 570.974.2613.

Sincerely,



Jennifer Means  
Program Manager  
Eastern Oil and Gas District

Enclosures:

Laboratory Analytical Table  
"How to Interpret A Water Analysis Report"

cc:

William J. Kosmer, P.G.  
Terra Tokarz  
David Engle  
Matt Nuss  
Sharon Steinbacher  
Complaint File # 315337