

March 11, 2020

Mr. Matthew Gordon
Sunoco Logistics, L.P.
535 Fritztown Road
Sinking Spring, PA 19608

Re: Technical Deficiency Letter
ESCGP-3 Permit Application
Pennsylvania Pipeline Project (PPP)/Mariner East II
Major Modification – HDD 0620
Southeast Regional Office Submission
Construction Spread 6
DEP File No. ESG0100015001
Middletown Township
Delaware County

Dear Mr. Gordon:

The Department of Environmental Protection (DEP) and the Delaware County Conservation District (District) have reviewed the above-referenced application and has identified the technical deficiencies listed below. The *Pennsylvania Erosion and Sediment Pollution Control Program Manual* (E&S Manual) and the *Pennsylvania Stormwater Best Management Practices Manual* (BMP Manual) include information that may aid you in responding to some of the deficiencies listed below. The deficiencies are based on applicable laws and regulations, and the guidance sets forth DEP's established means of satisfying the applicable regulatory and statutory requirements.

Technical Deficiencies

1. The recent submission to address technical deficiencies only consisted of revised sheets. The original major permit modification was submitted April 26, 2019. We need three copies of the entire major permit amendment plan and calculation packages to process the permit.
2. Sheet ES-0.02 was not revised to reflect open cut of stream S-12. This table exists as a sheet and also in the Erosion Control Narrative.

3. Please clarify the rip-rap streambank symbol the entire width on length of S-12 through the L.O.D. on sheet ES-6.20. This was not part of the original permit. Was it added as part of the inadvertent return issues? Has it been done, or will it be done as part of the open cut?

You must submit a response fully addressing each of the technical deficiencies set forth above. Please note that this information must be received within 30 calendar days from the date of this letter, or DEP may deny the ESCGP-3 Permit application.

Please submit a response letter addressing the above comments and two copies of the revised information (one set should include **highlights** of all revisions) to the District at 1521 North Providence Road, Media, PA 19063, and two copies of the revised information (one set should include **highlights** of all revisions) to DEP at the address located in the first page footer.

Please coordinate with the District prior to resubmitting. The District may require a District application and/or additional fees associated with your resubmission.

If you believe that any of the stated deficiencies are not significant, instead of submitting a response to that deficiency, you have the option of requesting that DEP make a permit decision based on the information you have already provided regarding the subject matter of that deficiency. If you choose this option with regard to any deficiency, you should explain and justify how your current submission satisfies that deficiency.

If you have questions about your application, please contact me by e-mail at christopsm@pa.gov or by telephone at 484.250.5152 and refer to Application No. ESG0100015001 Major Modification HDD 0620, to discuss your concerns or to schedule a meeting. You must attempt to schedule any meeting within the 30 calendar days allotted for your reply.

Sincerely,



Christopher Smith, P.E.
Chief, Construction Permits Section
Waterways and Wetlands

cc: Mr. Simcik – Tetra Tech, Inc.
Ms. Wheeler - Delaware County Conservation District
Middletown Township (Delaware County)
Re 30 (GJS20WAW)71-10