

### Draft Geothermal Well Isolation Distance

The minimum horizontal isolation distances between the features named and treatment tanks, dosing tanks, holding tanks, lift pump tanks, filter tanks, chlorine contact tanks and evapotranspiration systems shall comply with the following:

50 feet	Geothermal heating system wells, except wells sealed in accordance with the Department's well abandonment guidelines
---------	--

The following minimum horizontal isolation distances shall be maintained between the features named and the perimeter of the aggregate in the absorption area:

100 feet	Geothermal heating system wells, except wells sealed in accordance with the Department's well abandonment guidelines
----------	--

The following minimum horizontal isolation distances shall be maintained between the features named and the wetted perimeter of the spray field:

100 feet	Geothermal heating system wells except wells sealed in accordance with the Department's well abandonment guidelines
----------	---

DRAFT

DRAFT