



# PA Electric Power Generating Industry TDS Issues

Presented to PADEP WRAC – TDS Subcommittee  
October 16, 2009

# PA Coal-Fired Electric Generation

- PA ranks 2<sup>nd</sup> in electric generation
- 26 coal-fired plants
  - 19,500 MW of generation capacity
  - 15 scrubbed (FGD) plants (52% of capacity)
- 15 waste-coal plants
  - 1,500 MW of generation capacity
- Represents 41% of PA generating capacity and 54% of generation

# Power Plant Sources of TDS & SO<sub>4</sub>

	<b>TDS Concentration (mg/L)</b>	<b>Sulfate Concentration (mg/L)</b>	<b>TDS Loading (lbs./day)</b>
<b>FGD Blowdown (~0.5 MGD)</b>	<b>15,000 - 30,000</b>	<b>&gt;1,000</b>	<b>62,600 – 125,000</b>
<b>Boiler Makeup Water Waste Stream (~0.040 MGD - Inter.)</b>	<b>&gt;20,000</b>	<b>&gt;11,000</b>	<b>~6,700</b>
<b>Coal Pile Runoff</b>	<b>&gt;500</b>	<b>&gt;250</b>	<b>Rainfall Dependent</b>
<b>CCB Landfills</b>	<b>1,200 - 2,500</b>	<b>&gt;250</b>	<b>Rainfall Dependent</b>
<b>Cooling Tower Blowdown (~3.6 MGD – 2500-gpm)</b>	<b>300 - 2500</b>	<b>&gt;250</b>	<b>9,000 – 75, 000</b>
<b>Waste Coal Plants (~0.25 MGD)</b>	<b>~2,000</b>		<b>1,600-4,000</b>

# TDS Treatment Options for FGD Bleed Stream

- Deep well injection
- Membrane treatment
- Filtration
- Evaporation
- Recycle and Solids Retention
- Emerging technologies

## Deep well injection

- Geologic and regulatory constraints


## Membrane treatment

### ● Reverse Osmosis (RO)

- Largely ineffective
- Higher TDS levels = higher reject water volume
- Severe scaling & fouling issues

### ● Electrodialysis (ED)

- Unproven with FGD bleed stream

  
Filtration – neither Micro-filtration (0.1 – 10  $\mu\text{m}$ ) nor Ultra-filtration (0.001 – 0.1  $\mu\text{m}$ ) effective for removal of TDS

<b>Parameter</b>	<b>Unfiltered*</b>	<b>Filtered*</b>
• TDS	18,867	18,867
• Sulfate	1,173	1,100
• Chloride	8,573	7,617

\*/ mg/l

## Recycle and Solids Retention

- Effective for TDS reduction
  - ✓ Depending on site, recycle can achieve >30% reductions
  - ✓ Solids retention has demonstrated 30% to 50% reductions
- But incapable of achieving PADEP proposed levels

# Evaporation

## Brine Concentrator & Crystallizer

- ✓ Used on cooling tower blowdown
- ✓ Rarely used for FGD bleed stream
  - Handful in operation worldwide
- ✓ Minimum 36 months to design, procure, construct, & commission
  - Longer for plant-wide treatment
  - Plus permitting time
- ✓ Significant transportation impacts (additives & waste)
- ✓ Significant capital, O&M, and energy costs



# Permitting Time

- ✦ E&SC (3-6 mos)
- ✦ NPDES modification (24 mos)
- ✦ WQM Part II (9-12 mos)
- ✦ Solid waste/landfill expansion (36-48 mos)
  - EPA designation of CCB will affect
- ✦ Air/material handling (6-12 mos)

# Evaporation (cont.)

- 400 GPM avg. flow rate
  - Power requirement = 4.0 MW/hour of operation
    - Equivalent to lighting 4000 homes
  - Solids production = 150 tpd
    - Landfill cost ~ \$2,175/day (\$14.50/ton)
      - ~ \$750,000/year (dispatch dependent)
  - Soda ash consumption = 2,000# per hour
    - Salt conversion
    - Est \$1.6 million/year (dispatch dependent)

# Evaporation Costs

- FGD only (assume 400 GPM Flow)
  - Capital costs of ~ \$60 million
  - Annual O&M costs ~ \$4-6 million
  - Annual solids ~ \$750,000
- All wastewater streams (assume 2 to 5 MGD flow)
  - Capital costs \$200-\$500 million
  - Annual O&M \$15-\$40 million
  - Power consumption 14 – 35 MW
  - Greater solids generation



**Table 3-2  
Evaporator System Cost Summary**

System Description	Basis	Estimated Capital Cost (2008 \$)	Estimated Operating Cost (2008 \$/yr)
1. Brine Concentrator (2 x 60%)	240 gpm	12,900,000	
2. Crystallizer (1 x 100%)	60 gpm	9,700,000	
3. Salt Conversion	400 gpm	5,000,000	
4. Storage Tank	250,000 gal	400,000	
5. Balance of Plant		4,000,000	
6. Pre-Engineered Building	9,000 ft <sup>2</sup>	2,800,000	
7. Site Development	32,000 ft <sup>2</sup>	750,000	
8. Electrical Equipment		7,700,000	
9. Operating Labor	3 FTE		344,000
10. Electrical Demand	4,000 kW		2,103,000
11. Trucking	150 tpd		219,000
12. Soda Ash	2,000 lb/hr		1,621,000
13. Other Chemicals			150,000
14. Indirect Cost Multiplier	30%	12,980,000	
15. Owner Costs	10%	5,700,000	
<b>Total Costs</b>		<b>61,930,000</b>	<b>4,437,000</b>

# Evaporation Costs (cont.)

- 15 PA plants FGD wastewater stream
  - Annual O&M costs \$70 million
  - Capital costs approach \$1 billion
  - Power needs 60 MW
  - 2250 tpd solids
- 15 PA plants all wastewater streams
  - Capital costs \$3 – \$7.5 billion
  - Annual O&M costs \$230 - \$600 million
  - Power needs 200 – 520 MW (a new plant)
  - Greater solids generation

# Caveats

- ☞ 11 PA non-scrubbed stations?
  - “New source” issue or
  - CAIR II, MACT, etc.
- ☞ Assumes limits similar to those currently being imposed in permits
- ☞ Assumes all plants have FGD bleed stream
  - Technology dependent
- ☞ Conceptual cost estimates

# Caveats (cont.)

- ☞ Non TDS/Sulfates permit requirements timelines (sooner) vs. TDS/Sulfates limits (later)
  - Need policy that is not economically wasteful
- ☞ Landfill capacity and technology
- ☞ Need nuclear cooling tower blowdown data

# Water Impairment Issues

- ☛ Significant problems with the Mon River “impairment” finding
  - Insufficient time period
  - No river segmentation
  - Missing data
  - Flawed statistics
- ☛ Statewide, the sources and relative contributions for TDS are still unknown; for the Mon, WV and PA contributions still unknown
- ☛ PA and WV should follow the approach taken in the Chesapeake Bay



# Conclusions

- ☞ There is no demonstrated, cost-effective technology to achieve the PADEP proposed levels
- ☞ However, electric generating stations can achieve significant reductions in TDS using recycle and entrainment methods
- ☞ A holistic assessment of the sources and relative contributions should be conducted **before** developing proposed solutions

# Questions

—