

SAMPLE INFORMATION							PARAMETER	TDS @ 180°C	CHLORIDE	SULFATE	BROMIDE
							(UNITS)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
RMI	SAMPLE LOCATION	LATITUDE	LONGITUDE	SAMPLE ID#	DATE COLLECTED	LAB ID#	CRITERIA (BASIS)	500 Avg 750 Max (PWS)	250 (PWS)	250 (PWS)	
5.6	Tunnelton Bridge- Left Bank	40°27' 14.814"	79°23' 25.994"	4034-320	9/17/2010	29464		796	158	328	1.2
5.6	Tunnelton Bridge- Right Bank	40°27' 14.814"	79°23' 25.994"	4034-321	9/17/2010	29465		786	139	328	0.9
5.6	Tunnelton Bridge- Mid Bridge	40°27' 14.814"	79°23' 25.994"	4034-322	9/17/2010	29466		896	193	333	1.4