

SAMPLE INFORMATION					PARAMETER (UNITS)	TDS @ 105°C (mg/L)	CHLORIDE (mg/L)	SULFATE (mg/L)	BROMIDE (mg/L)	TEMPERATURE FIELD (°C)	SPECIFIC CONDUCTANCE FIELD (umhos/c)	pH FIELD (s.u.)
RMI	SAMPLE LOCATION	SAMPLE ID#	DATE COLLECTED	LAB ID#	CRITERIA (BASIS)	500 Avg 750 Max (PWS)	250 (PWS)	250 (PWS)				6.0 - 9.0
0.44	Brownsville STP Outfall 001	0552-863	10/15/2008	37634		1214	391.4	326.4	NA	NA	1725	7.32
		0593-040	10/24/2008	39226		1568	510.6	381	4	NA	NA	NA
		0593-043	10/25/2008	39236		798	205.8	217	1.4	NA	NA	NA
		0592-200	10/26/2008	39249		698	130.1	239.4	0.8	16.76	891	7.46
		0592-214	10/27/2008	39221		810	134.7	251.2	0.6	15.85	1210	6.99
		0593-059	10/28/2008	39446		810	9.4	310.2	0.7	8.64	552	8.28
		0593-078	10/29/2008	39570		868	110.1	338.6	0.5	6.6	505	8.43

SAMPLE INFORMATION					DO FIELD (mg/L)	ALUMINUM (ug/L)	ANTIMONY (ug/L)	ARSENIC (ug/L)	BARIUM (ug/L)	BERYLLIUM (ug/L)	CADMIUM (ug/L)	CALCIUM (mg/L)	CHROMIUM (ug/L)
RMI	SAMPLE LOCATION	SAMPLE ID#	DATE COLLECTED	LAB ID#		750 (AFC)	5.6 (THH)	10 (THH)	2400 (THH)	NA	@H=10C 0.25		10 (CFC)
0.44	Brownsville STP Outfall 001	0552-863	10/15/2008	37634	NA	<200	<2.00	<3.0	74	<1.0	<10.0	108.0	<50
		0593-040	10/24/2008	39226	NA	NA	<2.00	<3.0	NA	NA	NA	NA	NA
		0593-043	10/25/2008	39236	NA	NA	<2.00	<3.0	NA	NA	NA	NA	NA
		0592-200	10/26/2008	39249	7.55	NA	<2.00	<3.0	NA	NA	NA	NA	NA
		0592-214	10/27/2008	39221	5.84	NA	NA	NA	NA	NA	NA	NA	NA
		0593-059	10/28/2008	39446	NA	NA	NA	NA	NA	NA	NA	NA	NA
		0593-078	10/29/2008	39570	11.62	NA	<2.00	<3.0	NA	NA	NA	NA	NA

SAMPLE INFORMATION					COBALT (ug/L)	COPPER (ug/L)	IRON (ug/L)	LEAD (ug/L)	MAGNESIUM (mg/L)	MANGANESE (ug/L)	MERCURY (ug/L)	NICKEL (ug/L)	POTASSIUM (mg/L)
RMI	SAMPLE LOCATION	SAMPLE ID#	DATE COLLECTED	LAB ID#	19 (CFC)	@H=100 9.0	1500 (AL)	@H=100 2.5		1000 (PWS)	0.05 (THH)	@H=100 52	
0.44	Brownsville STP Outfall 001	0552-863	10/15/2008	37634	<50	<10	210	<1.0	25.8	614	<0.2	<50	17.800
		0593-040	10/24/2008	39226	NA	NA	NA	<1.0	NA	NA	<0.2	NA	NA
		0593-043	10/25/2008	39236	NA	NA	NA	1.1	NA	NA	<0.2	NA	NA
		0592-200	10/26/2008	39249	NA	NA	NA	<1.0	NA	NA	<0.2	NA	NA
		0592-214	10/27/2008	39221	NA	NA	NA	NA	NA	NA	NA	NA	NA
		0593-059	10/28/2008	39446	NA	NA	NA	NA	NA	NA	NA	NA	NA
		0593-078	10/29/2008	39570	NA	NA	NA	<1.0	NA	NA	<0.2	NA	NA

SAMPLE INFORMATION					SELENIUM (ug/L)	SILVER (ug/L)	SODIUM (mg/L)	THALLIUM (ug/L)	VANADIUM (ug/L)	ZINC (ug/L)
					4.6 (CFC)	@H=100 3.2		0.24 (THH)	100 (CFC)	@H=100 120
0.44	Brownsville STP Outfall 001	0552-863	10/15/2008	37634	<7	<10	269.0	<2	<20	<10.0
		0593-040	10/24/2008	39226	<7	NA	NA	<2	NA	NA
		0593-043	10/25/2008	39236	<7	NA	NA	<2	NA	NA
		0592-200	10/26/2008	39249	<7	NA	NA	<2	NA	NA
		0592-214	10/27/2008	39221	NA	NA	NA	NA	NA	NA
		0593-059	10/28/2008	39446	NA	NA	NA	NA	NA	NA
		0593-078	10/29/2008	39570	<7	NA	NA	<2	NA	NA