

**2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)**

This index provides many of the Chapter 109 citations.

Those highlighted in green are new citations because of the RTCR regulation, effective September 24, 2016.

This is the hierarchy of names that are used in Chapter 109:

109 Chapter
A Subchapter
.1 Section
(a) Subsection
(1) Paragraph
(i) Subparagraph
(A) Clause
(V) Subclause
(-a-) Item
(-1-) Subitem

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

A GENERAL PROVISIONS	109-1
109.1 Definitions	109-2
Lead service line	109-7
Level 1 assessment	109-7
Level 2 assessment	109-7
Liquid from dewatering processes	109-7
SUVA.....	109-12
Sanitary defect.....	109-12
Sanitary survey.....	109-12
Seasonal system.....	109-12
Sedimentation	109-12
109.2 PURPOSE	109-15
109.3 Scope.....	109-16
109.4 General requirements	109-16
109.5 Organization of chapter	109-16
109.6 Inspection authorization	109-17
B MCLS, MRDLS, OR TREATMENT TECHNIQUE REQUIREMENTS	109-19
109.201 Authority.....	109-19
109.202 State MCLs, MRDLs and treatment technique requirements	109-19
109.202(a) Primary MCLs	109-19
109.202(b) Secondary MCLs	109-20
109.202(c) Treatment technique requirements for pathogenic bacteria, viruses and protozoan cysts	109-20
109.202(c)(1)(i)(A) Conventional or direct filtration	109-20
109.202(c)(1)(i)(B) Slow sand or diatomaceous earth filtration	109-21
109.202(c)(1)(i)(C) Other filtration technologies	109-21
109.202(c)(1)(ii) Combined total disinfection processes for filtration plants.....	109-21
109.202(c)(1)(iii) Unfiltered surface water treatment technique requirements	109-21
109.202(c)(1)(iv) Unfiltered SW experiencing turbidity, microbial violations, contamination or outbreak feasibility study and permit requirements.....	109-22
109.202(c)(1)(v) Subparagraph iv requirements do not impact compliance order requirements	109-23
109.202(c)(1)(vi) Springs, infiltration galleries and GUDI source treatment technique requirements	109-23
109.202(c)(2) PWS using SW or GUDI sources comply with Subchapter L (LT2ESWTR).....	109-24
109.202(c)(3) CWS shall provide continuous disinfection and comply with Subchapter M (GWR)	109-24
109.202(c)(4) PWS shall conduct assessments in accordance with 109.705(b).....	109-24
109.202(c)(4)(i) A Level 1 assessment is triggered if any of the following conditions occur:	109-24
109.202(c)(4)(i)(A) For systems taking 40 samples or more, the system exceeds 5.0% TC positive	109-24
109.202(c)(4)(i)(B) For systems taking fewer than 40 samples, the system has 2 or more TC positive	109-24
109.202(c)(4)(i)(C) The system fails to take every required check sample	109-24
109.202(c)(4)(ii) A Level 2 assessment is triggered if any of the following conditions occur:	109-24
109.202(c)(4)(ii)(A) A system fails to meet the <i>E. coli</i> MCL as specified under subsection (a)(2)	109-24
109.202(c)(4)(ii)(B) A system triggers another Level 1 assessment within a rolling 12-month period	109-24
109.202(c)(5) Failure by a seasonal water system to complete the approved start-up procedure prior to serving ..	109-24
109.202(d) Fluoride.....	109-25
109.202(e) Treatment technique requirements for acrylamide and epichlorohydrin	109-25
109.202(f) MRDLs	109-25
109.202(g) Treatment technique requirements for disinfection byproduct precursors	109-25

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.202(h) Recycling of waste stream	109-25
109.203 Unregulated contaminants.....	109-26
109.204 Disinfection profiling and benchmarking	109-27
109.204(a) Disinfection profiling and benchmarking requirements are incorporated by reference	109-27
109.204(b) PWs that serve 10,000 or more before 1/1/05 shall comply with this section	109-27
109.204(c) PWSs shall conduct disinfection profiling using EPA's guidance manual	109-27
C MONITORING REQUIREMENTS	109-28
109.301 General monitoring requirement.....	109-28
109.301(1) Performance monitoring for filtration and disinfection	109-28
109.301(1)(i)(A) Shall determine and record the turbidity level as follows:	109-28
109.301(1)(i)(A)(I) For systems that operate continuously, at least once every 4 hours that the system is in operation except provided in clause (B).....	109-28
109.301(1)(i)(A)(II) For systems that do not operate continuously, at start-up, at least once every 4 hours that the system is in operation and also prior to shutting down the plant, except as provided in clause (B).	109-28
109.301(1)(i)(B) May substitute continuous turbidity monitoring and recording...At a minimum, calibration with an EPA-approved primary standard shall be conducted at least quarterly	109-28
109.301(1)(i)(C) Shall continuously monitor and record the residual disinfectant concentration of the water being supplied to the distribution system	109-29
109.301(1)(i)(D) Shall measure and record the residual disinfectant concentration at representative points in the distribution system no less frequently than the frequency for total coliforms.....	109-29
109.301(1)(ii) For a PWS serving 3,300 or fewer people, the Department may reduce the residual disinfectant ...	109-29
109.301(1)(iii) For a PWS serving fewer than 500 people, the Department may reduce the filtered water turbidity monitoring to one grab sample per day	109-29
109.301(1)(iv) A PWS providing conventional filtration treatment or direct filtration and serving 10,000 or more people shall conduct individual filter monitoring and record results every 15 mins	109-30
109.301(1)(iv)(A) The water supplier shall calibrate turbidimeters with an EPA-approved primary standard at least quarterly	109-30
109.301(1)(iv)(B) If there is failure in the continuous turbidity monitoring or recording equipment, the system shall conduct grab sampling or manual recording every 4 hours	109-30
109.301(1)(iv)(C) A public water supplier serving fewer than 10,000 persons has a maximum of 14 days following the failure of the equipment to repair or replace the equipment before a violation is incurred.....	109-30
109.301(1)(iv)(D) A public water supplier serving 10,000 or more persons has a maximum of 5 working days following the failure of the equipment to repair or replace the equipment before a violation is incurred .	109-30
109.301(2) Performance monitoring for unfiltered surface water and GUDI.....	109-30
109.301(3) Monitoring requirements for coliforms.....	109-32
109.301(3)(i) Frequency	109-32
109.301(3)(i)(C) Prior to serving water to the public each season, a seasonal system shall collect one or more total coliform samples in accordance with the DEP-approved start-up procedure specified in 109.715 until coliforms are not detected in a set of samples. These samples are considered special purpose samples under subparagraph (v)	109-34
109.301(3)(ii) Repeat Monitoring	109-34
109.301(3)(iii) Invalidation of total coliform samples	109-34.1
109.301(3)(iv) Compliance determinations.....	109-34.2
109.301(3)(iv)(A) A system is in compliance with the MCL for <i>E. coli</i> for samples taken under this paragraph unless any of the following conditions occur:	109-34.2
109.301(3)(iv)(A)(I) The system has an <i>E. coli</i> -positive check sample following a total coliform-positive routine sample	109-34.2
109.301(3)(iv)(A)(II) The system has a total coliform-positive check sample following an <i>E. coli</i> -positive routine sample	109-34.3
109.301(3)(iv)(A)(III) The system fails to take all required check samples following an <i>E. coli</i> -positive routine sample	109-34.3
109.301(3)(iv)(A)(IV) The system fails to test for <i>E. coli</i> when any check sample tests positive for total coliform.....	109-34.3

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.301(3)(v)	Special purpose samples.....	109-34.3
109.301(4)	Exception.....	109-34.3
109.301(5)	Monitoring requirements for VOCs.....	109-34.3
109.301(5)(i)	Vinyl chloride	109-34.3
109.301(5)(ii)	Initial monitoring schedule.....	109-34.3
109.301(5)(iii)	Repeat monitoring for entry points at which a VOC is detected	109-34.4
109.301(5)(iv)	Repeat monitoring for entry points at which no VOC is detected	109-34.5
109.301(5)(v)	Repeat monitoring for VOCS with MCL exceedances	109-34.5
109.301(5)(vi)	Confirmation samples	109-34.5
109.301(5)(vii)	Reduced monitoring	109-34.5
109.301(5)(viii)	Waivers	109-35
109.301(5)(ix)	Invalidation of VOC samples	109-35
109.301(5)(x)	Compliance determinations.....	109-35
109.301(6)	Monitoring requirements for SOCs	109-36
109.301(6)(i)	Initial monitoring schedule.....	109-36
109.301(6)(ii)	Repeat monitoring for SOCs that are detected.....	109-36
109.301(6)(iii)	Repeat monitoring for SOCs that are not detected.....	109-37
109.301(6)(iv)	Repeat monitoring for SOCs with MCL exceedances.....	109-37
109.301(6)(v)	Confirmation samples	109-37
109.301(6)(vi)	Reduced monitoring	109-37
109.301(6)(vii)	Waivers	109-38
109.301(6)(vii)(A)	Vulnerability assessment area for SOCs except dioxin and PCBs	109-38
109.301(6)(vii)(B)	Use waivers	109-38
109.301(6)(vii)(C)	Susceptibility waivers	109-38
109.301(6)(vii)(D)	Waiver requests and renewals.....	109-39
109.301(6)(vii)(E)	Waivers for dioxin and PCBs	109-39
109.301(6)(viii)	Invalidation of SOC samples	109-39
109.301(6)(ix)	Compliance determinations.....	109-39
109.301(7)	Monitoring requirements for IOCs.....	109-39
109.301(7)(i)	Monitoring requirements for asbestos.....	109-40
109.301(7)(i)(A)	Waivers for asbestos monitoring	109-40
109.301(7)(i)(B)	Initial monitoring schedule.....	109-40
109.301(7)(i)(C)	Monitoring of new entry points.....	109-40
109.301(7)(i)(D)	Repeat monitoring for systems that exceed the asbestos MCL	109-40
109.301(7)(i)(E)	Confirmation samples	109-40
109.301(7)(ii)	Monitoring requirements for nitrate and nitrite	109-40
109.301(7)(ii)(A)	Initial monitoring schedule.....	109-40
109.301(7)(ii)(B)	Monitoring of new entry points.....	109-41
109.301(7)(ii)(C)	Repeat monitoring for systems with nitrate or nitrite levels equal to or greater than 50% of the MCL.....	109-41
109.301(7)(ii)(D)	Repeat monitoring for systems with nitrate or nitrite levels less than 50% of the MCL.....	109-42
109.301(7)(iii)	Monitoring requirements for antimony, arsenic, barium beryllium, cadmium, cyanide, chromium, fluoride, mercury, nickel, selenium and thallium	109-42
109.301(7)(iii)(A)	Initial monitoring schedule.....	109-42
109.301(7)(iii)(B)	Monitoring of new entry points.....	109-42
109.301(7)(iii)(C)	Repeat monitoring for entry points at which an IOC MCL is exceeded	109-42
109.301(7)(iii)(D)	Waivers for IOC monitoring	109-43
109.301(7)(iii)(E)	Waivers for cyanide monitoring	109-44
109.301(7)(iii)(F)	Operational monitoring for fluoride	109-44
109.301(7)(iv)	Invalidation of IOC samples	109-44
109.301(7)(v)	Compliance determinations.....	109-44
109.301(8)	Monitoring requirements for public water systems that obtain finished water from another public water system	109-45
109.301(8)(iii)	Consecutive water supplies may be exempt from conducting monitoring for the MCLS for VOCS, SOCs, and IOCs and rads if the PWS from which finished water is obtained complies with monitoring and is in compliance with the MCLs.....	109-45
109.301(9)	Monitoring requirements for POE devices	109-46
109.301(10)	Additional monitoring	109-46

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.301(11) Monitoring requirements for entry points that do not provide water continuously	109-46
109.301(12) Monitoring requirements for disinfection byproducts and disinfection byproduct precursors	109-46
109.301(12)(i) TTHMs and HAA5 Stage 1 DBP Rule	109-46
109.301(12)(i)(A) Routine monitoring	109-46
109.301(12)(i)(B) Reduced monitoring Systems serving at least 500 persons and that use SW or GUDI sources shall monitor source water TOC for at least 1 year prior to qualifying for reduced TTHM and HAA5 monitoring	109-48
109.301(12)(ii) TTHMs and HAA5 Stage 2 DBP Rule	109-49
109.301(12)(ii)(A) Applicability and schedule	109-50
109.301(12)(ii)(B) Routine monitoring	109-50
109.301(12)(ii)(C) Reduced monitoring	109-52
109.301(12)(ii)(D) Increased monitoring	109-55
109.301(12)(ii)(E) General monitoring and compliance requirements	109-55
109.301(12)(iii) Chlorite	109-56
109.301(12)(iii)(A) Routine monitoring	109-56
109.301(12)(iii)(A)(I) Daily monitoring	109-56
109.301(12)(iii)(A)(II) Monthly monitoring	109-56
109.301(12)(iii)(A)(III) Additional monitoring	109-57
109.301(12)(iii)(B) Reduced monitoring	109-57
109.301(12)(iv) Bromate	109-57
109.301(12)(iv)(A) Routine monitoring	109-57
109.301(12)(iv)(B) Reduced monitoring	109-57
109.301(12)(iv)(B)(II) Beginning April 1, 2009, a system required to analyze for bromate may reduce monitoring from monthly to quarterly, if the system's RAA bromate concentration computed quarterly is less than or equal to 0.0025 mg/l based on monthly measurements as prescribed in clause (A) for the most recent 4 quarters.	109-57
109.301(12)(v) Disinfection byproduct precursors	109-58
109.301(12)(v)(A) Routine monitoring	109-58
109.301(12)(v)(B) Reduced monitoring	109-58
109.301(12)(v)(C) Early monitoring	109-58
109.301(13) Monitoring requirements for disinfectant residuals	109-58
109.301(13)(i) Chlorine and chloramines	109-59
109.301(13)(ii) Chlorine dioxide.....	109-59
109.301(13)(ii)(A) Routine monitoring	109-59
109.301(13)(ii)(B) Additional monitoring	109-59
109.301(14) Monitoring requirements for radionuclides	109-59
109.301(14)(i) Monitoring requirements for gross alpha particle activity, radium-226, radium-228 and uranium	109-60
109.301(14)(i)(A) Initial monitoring schedule.....	109-60
109.301(14)(i)(A)(IV) Systems that add new entry points shall conduct monitoring beginning the first full quarter the entry point begins serving the public	109-60
109.301(14)(i)(A)(VI) Quarterly monitoring is required when the average of initial monitoring > MCL.....	109-60
109.301(14)(i)(B) Repeat monitoring	109-60
109.301(14)(i)(C) Gross alpha substitution	109-61
109.301(14)(i)(D) Grandfathering	109-61
109.301(14)(ii) Monitoring requirements for beta-particle and photon radioactivity	109-62
109.301(14)(iii) General monitoring and compliance requirements	109-63
109.302 Special monitoring requirements	109-64
109.302(a) Additional monitoring if PWS is not in compliance with MCL, MRDL or TT	109-64
109.302(b) Additional monitoring where potential health hazard may exist	109-65
109.302(c) Special monitoring of UCMR	109-65
109.302(d) Schedule for sampling for special monitoring	109-65
109.302(e) Special monitoring for experimental facilities	109-65
109.302(f) GUDI sampling requirements.....	109-65
109.302(g) DEP may reduce or eliminate GUDI sampling requirements.....	109-65
109.303 Sampling requirements	109-66
109.303(a) Sampling locations identified in 109.301 or 109.302 or as follows:	109-66

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.303(a)(1)	turbidity MCL at EP	109-66
109.303(a)(2)	<i>E. coli</i> MCL within distribution system according to a written sample siting plan as specified under 109.701(a)(5). Representative locations include the following:	
109.303(a)(2)(i)	Dead ends.	109-66
109.303(a)(2)(ii)	First service connections.	109-66
109.303(a)(2)(iii)	Finished water storage facilities.	109-66
109.303(a)(2)(iv)	Interconnections with other PWSs	109-66
109.303(a)(2)(v)	Areas of high water age.	109-66
109.303(a)(2)(vi)	Areas with previous coliform detections	109-66
109.303(a)(3)	fluoride MCL at EP	109-66
109.303(a)(4)	organics and inorganics MCLS and UCMR at EP	109-66
109.303(a)(5)	asbestos sampling points in distribution system with A/C pipe and EP	109-66
109.303(b)	TT performance monitoring locations.....	109-66
109.303(c)	PWSs assure that samples are properly collected and preserved	109-66
109.303(d)	Compliance monitoring for VOCs shall be collected by a trained person.....	109-67
109.303(e)	Samples may be composited.....	109-67
109.303(f)	POE free flowing tap location	109-67
109.303(g)	Rad samples may be composited.....	109-67
109.303(h)	Beta particle and photon radioactivity samples may be composited.....	109-67
109.304 Analytical requirements.....		109-68
109.304(a)	Analytical techniques adopted by EPA or methods approved by DEP	109-68
109.304(b)	Alternative analytical technique may be employed with the written approval from DEP	109-68
109.304(c)	For the purpose of determining compliance with the monitoring and analytical requirements established under this subchapter and Subchapters K, L and M ...Turbidity, fluoridation operation, residual disinfectants, WQPs, daily chlorite may be performed by:	109-68
109.304(c)(1)	certified operator.....	109-68
109.304(c)(2)	person using SOPs.....	109-68
109.304(c)(3)	environmental lab	109-68
109.304(d)	<i>Cryptosporidium</i> samples analyzed by EPA-approved lab	109-69
109.305 Fees		109-69
109.305(a)	Data management fees	109-69
109.305(b)	Waivers	109-69
D PUBLIC NOTIFICATION		109-70
109.407 General public notification requirements.....		109-72
109.407(a)	Violation categories and other situations requiring a public notice	109-72
109.407(a)(1)	Failure to comply with applicable State primary MCL or MRDL in Subchapter B	109-72
109.407(a)(2)	Failure to comply with a prescribed treatment technique requirement in Subchapter B, G, K, L or M	109-72
109.407(a)(3)	Failure to perform water quality monitoring, as required by Subchapter C or Subchapter K.....	109-72
109.407(a)(4)	Operation under a variance or an exemption Under Subchapter I.....	109-72
109.407(a)(5)	Failure to comply with the requirements of any schedule that has been set under a variance or exemption.....	109-72
109.407(a)(6)	Occurrence of a waterborne disease outbreak or other emergency situation as defined in 109.701(a)(3)(iii) that adversely affects the quality or quantity of finished water and has a significant potential to have serious adverse effects on human health as a result of short-term exposure.....	109-72
109.407(a)(7)	Availability of unregulated contaminant monitoring data.....	109-72
109.407(a)(8)	Exceedance of the nitrate MCL by noncommunity water systems, when permitted by DEP in writing to exceed the MCL	109-72
109.407(a)(9)	Other violations or situations determined by DEP to require a public notice under this subchapter	109-72
109.407(b)	Definition of public notice tiers	109-72
109.407(b)(1)	Tier 1 public notice.....	109-73
109.407(b)(2)	Tier 2 public notice.....	109-73

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.407(b)(3) Tier 3 public notice.....	109-73
109.407(c) Public notice recipients	109-73
109.407(c)(2) DEP may allow the water supplier to limit distribution of the PN to only persons served by that portion of the system which is out of compliance. Permission for limiting distribution of the notice will be granted in writing by DEP	109-73
109.407(d) Additional requirements.....	109-74
109.408 Tier 1 public notice - categories, timing and delivery of notice	109-74
109.408(a) General violation categories and other situations requiring a Tier 1 public notice	109-74
109.408(a)(1) Violation of the MCL for <i>E. coli</i> , as specified in 109.202(a)(2) or when the water supplier fails to test for <i>E. coli</i> when any check sample tests positive for coliforms, as specified in 109.301(3) ..	109-74
109.408(a)(2) Violation of the MCL for nitrate, nitrite or total nitrate and nitrite as defined in 109.202(a)(2) or when the water supplier fails to take a confirmation sample within 24 hours of the system's receipt of the first sample showing an exceedance of the nitrate or nitrite MCL, as specified in Exceedance of the nitrate MCL by noncommunity water systems, when permitted by DEP in writing to exceed the MCL in accordance with 40 CFR (i.e., alternate nitrate level)	109-74
109.408(a)(3) Violation of the MRDL for chlorine dioxide, as defined in 109.202(f)(2), when one or more samples taken in the distribution system the day following an exceedance of the MRDL at the EP, or when the system does not take the required samples in the distribution system, as specified in 109.301	109-75
109.408(a)(4) Violation of the turbidity MCL of 5 NTU based on an average for 2 consecutive days by a PWS using an unfiltered surface water sources, as specified in 109.202(a)(2).	109-75
109.408(a)(5) Violation of a TT requirement for pathogenic bacteria, viruses and protozoan cysts as defined in 109.202(c) resulting from a single exceedance of the maximum allowable turbidity limit	109-75
109.408(a)(6) Violation of a TT requirement for <i>Cryptosporidium</i> resulting from a failure to provide the bin level of treatment	109-75
109.408(a)(7) Detection of <i>E. coli</i> in source water samples for triggered or assessment monitoring.....	109-75
109.408(a)(8) A breakdown in treatment for GW sources as specified in 109.1307(a)(1)(ii)	109-75
109.408(a)(9) Occurrence of a waterborne disease outbreak or other emergency situation as defined in 109.701(a)(3)(iii) that adversely affects the quality or quantity of the finished water and has a significant potential to have serious adverse effects on human health as a result of short-term exposure.....	109-75
109.408(a)(10) Other violations or situations with significant potential to have serious adverse effects on human health as a result of short-term exposure, as determined by DEP on a case-by-case basis.	109-75
109.408(a)(11) Timing for a Tier 1 public notice.....	109-75
109.408(b) Provide a "Problem Corrected" PN	109-76
109.408(c) Form and manner of a Tier 1 public notice prior to May 10, 2010.....	109-76
109.408(d) Delivery of a Tier 1 public notice beginning on May 10, 2010	109-76
109.409 Tier 2 public notice - categories, timing and delivery of notice	109-77
109.409(a) General violation categories and other situations requiring a Tier 2 public notice	109-77
109.409(a)(1) All violations and failure to take corrective action in Subchapters B, G, K, L, or M...	109-77
109.409(a)(2) Violations of monitoring requirements In Subchapter C, K or M, lead and copper and additional requirements for groundwater sources	109-77
109.409(b) Timing for a Tier 2 public notice.....	109-78
109.409(c) Form and manner of a Tier 2 public notice	109-78
109.410 Tier 3 public notice - categories, timing and delivery of notice	109-79
109.410(a) General violation categories and other situations requiring a Tier 3 public notice	109-79
109.410(a)(1) Monitoring violations under Subchapter C, K, L or M.....	109-79
109.410(a)(2) Reporting and record maintenance violations under 109.701(h).....	109-80
109.410(a)(3) Operation under a variance or an exemption granted under Subchapter I.....	109-80
109.410(a)(4) Availability of unregulated contaminant monitoring results	109-80
109.410(a)(5) Failure to report an <i>E. coli</i> MCL violation or an <i>E. coli</i> -positive routine or check sample as required under 109.701(a)(3)(iv).....	109-80

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.410(a)(6) Failure to submit a completed assessment form in accordance with 109.701(a)(9)	109-80
109.410(a)(7) Failure to submit certification of completion of a DEP-approved start-up procedure by a seasonal system in accordance with 109.715(e)	109-80
109.410(b) Timing for a Tier 3 public notice.....	109-80
109.410(c) Delivery of a Tier 3 public notice	109-80
109.410(d) Use of a CCR to meet the Tier 3 public notice requirements.....	109-81
109.411 Content of a public notice	109-82
109.411(a) Elements of a public notice	109-82
109.411(b) Abbreviated notice	109-82
109.411(c) Elements of a public notice for public water systems operating under a variance or exemption	109-82
109.411(d) Presentation of a public notice	109-83
109.411(e) Standard language for a public notice	109-83
109.411(e)(1) Standard health effects language for primary MCL or MRDL violations, treatment technique violations, and violations of the condition of a variance or exemption.....	109-83
109.411(e)(2) Standard language for violations of monitoring requirements.....	109-84
109.411(e)(3) Standard language to encourage the distribution of the public notice to all persons served.....	109-84
109.412 Special notice of the availability of unregulated contaminant monitoring results	109-85
109.412(a) Timing for a special notice.....	109-85
109.412(b) Delivery of a special notice	109-85
109.413 Special notice for nitrate exceedances above MCL by noncommunity water systems, where granted permission by the Department.....	109-85
109.413(a) Timing for a special notice.....	109-85
109.413(b) Delivery of a special notice	109-86
109.414 Notice to new billing units or new customers	109-86
109.414(a) Requirements for community water systems	109-86
109.414(b) Requirements for noncommunity water systems.....	109-86
109.415 Notice by the Department on behalf of the public water system	109-86
109.415(a) Failure to give public notice	109-86
109.415(b) System responsibilities when public notice is given by the Department.....	109-87
109.416 CCR requirements	109-87
109.416(1) EPA definitions of "customer" and "detected" are incorporated by reference	109-87
109.416(2) Each CWS shall deliver to its customers an annual CCR on the dates established by EPA	109-87
109.416(3) Report contains EPA language except health effects language for fluoride MCL violation.....	109-87
109.416(4) Report delivery and recordkeeping.....	109-88
109.417 Special notice for significant deficiencies by NCWS	109-89
109.417(a) NCWS shall inform the public of an uncorrected significant deficiency	109-89
109.417(b) If directed by DEP, NCWS with corrected significant deficiency shall inform its customers	109-90
109.418 Special notice for failure to conduct source water <i>Cryptosporidium</i> monitoring or failure to determine bin classification	109-90
109.418(a) Special notice for repeated failure to conduct monitoring of the source water for <i>Cryptosporidium</i> and for failure to determine bin classification or <i>Cryptosporidium</i> level.	109-90
109.418(b) Delivery of the special notice for failure to determine bin classification or <i>Cryptosporidium</i> level..	109-90
109.418(c) Form and manner of the special notice.....	109-91
E PERMIT REQUIREMENTS.....	109-92
109.501 General permit requirements	109-92

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.502	Permitting of currently operating systems; compliance deadlines	109-93
109.503	Public water system construction permits	109-94
109.503(a)	Permit application requirements	109-94
109.503(a)(1)	General requirements	109-94
109.503(a)(1)(i)	Permit application signatures	109-94
109.503(a)(1)(ii)	Plans, specifications and engineer's report	109-95
109.503(a)(1)(iii)	Information describing new sources	109-95
109.503(a)(1)(iii)(B)(I)	VOCs for which MCLS have been established	109-95
109.503(a)(1)(iii)(B)(V)	Total coliform concentration and, if TC+, analyze for the presence of <i>E. coli</i>	109-96
109.503(a)(1)(iii)(B)(VI)(-a-)	Except for SOCs that have been granted a statewide waiver, SOCs.....	109-96
109.503(a)(1)(iii)(B)(VI)(-c-)	PCBs where there is a source of PCB contamination within 1000 feet.....	109-96
109.503(a)(1)(iii)(B)(XII)	For surface water or GUDI sources, <i>E. coli</i> or <i>Cryptosporidium</i> or both as specified in 109.1202	109-96
109.503(a)(1)(iv)	Chapter 102 requirements	109-97
109.503(a)(2)	Special requirements for public water suppliers proposing to use POE devices	109-97
109.503(a)(3)	Business plan requirements for new community water systems	109-97
109.503(a)(3)(i)	Facilities plan.....	109-98
109.503(a)(3)(ii)	Management plan	109-98
109.503(a)(3)(iii)	Financial plan.....	109-98
109.503(b)	Amendments.....	109-99
109.503(c)	Permit fees.....	109-99
109.503(d)	Department's review	109-100
109.503(e)	Issuance and conditions.....	109-100
109.504	Public water system operation permits.....	109-101
109.505	Requirements for noncommunity water systems.....	109-102
109.505(a)(3)(i)(B)	Total coliform concentration and, if TC+, analyze for the presence of <i>E. coli</i>	109-103
109.505(b)	A NCWS providing 4-log treatment shall obtain a NCWS 4-log treatment permit	109-103
109.506	Emergency permits	109-104
109.507	Permits for innovative technology	109-104
109.507	DEP may consider proposals for innovative water treatment processes...that the proposal will provide drinking water that complies with Subchapters B, L and M	109-104
F	DESIGN AND CONSTRUCTION STANDARDS	109-106
109.601	Application of standards	109-106
109.602	Acceptable design	109-106
109.602(a)	A PWS shall be designed to provide... and capable of providing water that complies with MCLs, MRDLs and TT established in Subchapters B, L and M.....	109-106
109.603	Source quality and quantity	109-107
109.604	Facilities siting	109-108
109.605	Minimum treatment design standards.....	109-109
109.605(2)	For surface water and GUDI sources, the minimum treatment design...except NCWs may propose and DEP may approve, an alternative to the <i>Giardia</i> design standard when 99.9% inactivation is not feasible.....	109-109
109.605(3)	For surface water and GUDI sources permitted after 12/26/09, that are determined to be bin 2 or higher, the minimum treatment design for filtration and disinfection must also meet requirements of 109.1203 and 109.1204...	109-109

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.605(4) For CWSs using groundwater, the minimum treatment design standard for disinfection is 99.99% treatment of viruses.	109-110
109.605(5) For NCWs using groundwater with an <i>E. coli</i> positive groundwater source, the minimum treatment design standard for disinfection is 99.99% treatment of viruses.	109-110
109.606 Chemicals, materials and equipment	109-110
109.607 Pressures	109-111
109.608 Cross-connections	109-112
109.609 Reserved capacity and finished water storage	109-112
109.611 Disinfection	109-113
109.611 Disinfection facilities shall be designed to provide the dosage rate and contact time... to provide water that complies with the microbiological MCL, MRDL and TT requirements under 109.202 and 109.1302	109-113
109.612 POE devices	109-113
G SYSTEM MANAGEMENT RESPONSIBILITIES.....	109-114
109.701 Reporting and recordkeeping	109-114
109.701(a) Reporting requirements for public water systems	109-114
109.701(a)(1) General reporting requirements	109-114
109.701(a)(2) Monthly reporting requirements for performance monitoring	109-115
109.701(a)(2)(i)(A) Turbidity performance monitoring.....	109-115
109.701(a)(2)(i)(B) Entry point residual disinfectant concentration	109-115
109.701(a)(2)(i)(B)(I) The date, time and lowest value each day the residual disinfectant remains equal to or greater than the required minimum.....	109-116
109.701(a)(2)(i)(B)(II) The initial date, time and value for each occurrence that the residual disinfectant concentration is less than the required minimum, and the subsequent date, time and value that the residual disinfect concentration is equal to or greater than the required minimum	109-116
109.701(a)(2)(i)(B)(III) The date the entry point is not in operation	109-116
109.701(a)(2)(i)(C) Distribution sites residual disinfectant concentration	109-115
109.701(a)(3) One-hour reporting requirements-.....	109-117
109.701(a)(3)(i) A primary MCL or MRDL has been exceeded or a treatment technique requirement has been violated under Subchapter B, K, L or M	109-117
109.701(a)(3)(ii) A sample result requires the collection of check samples under 109.301	109-117
109.701(a)(3)(iii) Circumstances exist which may adversely affect the quality or quantity of drinking water including, but not limited to:	109-117
109.701(a)(3)(iii)(A) The occurrence of a waterborne disease outbreak	109-117
109.701(a)(3)(iii)(B) A failure or significant interruption in key water treatment processes.....	109-117
109.701(a)(3)(iii)(C) A natural disaster that disrupts the water supply or distribution system	109-117
109.701(a)(3)(iii)(D) A chemical spill	109-117
109.701(a)(3)(iii)(E) An unexpected loading of possible pathogens into the source water that significantly increases the potential for drinking water contamination	109-117
109.701(a)(3)(iii)(F) An overfeed of a drinking water chemical that exceeds NSF maximum use value.....	109-117
109.701(a)(3)(iii)(G) A situation that causes a loss of positive water pressure in the distribution system where there is evidence of contamination or a water supplier suspects a high risk of contamination	109-117
109.701(a)(3)(iii)(H) A lack of resources that adversely affect operations, such as staff shortages, notification by the power utility of planned lengthy power outages or imminent depletion of treatment chemical inventory.....	109-117
109.701(a)(3)(iv) Any sample result is <i>E. coli</i>-positive:	109-117
109.701(a)(4) Notice	109-117
109.701(a)(5) Siting plan for routine and repeat coliform sampling	109-118

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.701(a)(5)(i)	A sample siting plant must include, at a minimum, the following:	109-118
109.701(a)(5)(i)(A)	A list of sample site locations as specified in 109.303(a)(2) in the distribution system .	109-118
109.701(a)(5)(i)(B)	The name of the company or individual collecting the samples	109-118
109.701(a)(5)(i)(C)	A sample collection schedule.....	109-117
109.701(a)(5)(i)(D)	Available repeat monitoring locations for each routine monitoring location	109-117
109.701(a)(5)(i)(E)	Triggered source water monitoring locations as specified under 109.1303	109-117
109.701(a)(5)(i)(F)	The population served by the system	109-117
109.701(a)(5)(i)(G)	A description of the accessibility of sample sites.....	109-117
109.701(a)(5)(i)(H)	The beginning and ending dates of each operating season for seasonal systems	109-117
109.701(a)(5)(ii)	A water supplier shall revise and resubmit its sample siting plan within 30 days of notification by DEP of a sample siting plan which fails to meet the criteria	109-118
109.701(a)(5)(iii)	The water supplier shall notify DEP of subsequent revisions to a coliform sample siting plan as they occur. Revisions to a coliform sample siting plan shall be submitted in written form to the DEP within 30 days of notifying DEP of the revisions	109-118
109.701(a)(6)	Records	109-118
109.701(a)(7)	Form.....	109-118
109.701(a)(8)	Reporting requirements for disinfectant residuals	109-118
109.701(a)(8)(i)	Systems monitoring for chlorine dioxide shall report the number of days chlorine dioxide was used at each entry point during the last month	109-118
109.701(a)(8)(ii)	Systems monitoring for either chlorine or chloramines shall report the following...	109-118
109.701(a)(9)	Level 1 and Level 2 assessments. A public water supplier shall:	109-118
109.701(a)(9)(i)	Submit an assessment form completed in accordance with 109.705(b) within 30 days after the system learns that it has exceeded a trigger under 109.202(c)(4).....	109-118
109.701(a)(9)(ii)	Submit a revised assessment form completed in accordance with 109.705(b) within 30 days of notification from DEP that revisions are necessary	109-119
109.701(a)(10)	Noncompliance report. Except where a different reporting period is specified in this chapter, the water supplier shall report to DEP within 48 hours the failure to comply with any NPDWR, including the failure to comply with any monitoring requirement set forth in this chapter.....	109-119
109.701(b)	Reporting requirements for community water systems	109-119
109.701(c)	Reporting requirements for nontransient noncommunity water systems.....	109-119
109.701(d)	Record maintenance	109-119
109.701(d)(9)	A copy of any assessment form and documentation of corrective actions completed as a result of those assessments or other available summary documentation of the sanitary defects and corrective actions taken under 109.705(b) shall be kept at least 5 years after completion of the assessment or corrective action	109-120
109.701(e)	Reporting requirements for public water systems required to perform individual filter monitoring under § 109.301(1)(iv)	109-120
109.701(f)	Alternative individual filter turbidity exceedance levels.....	109-121
109.701(g)	Monitoring plans for disinfectants, DBPS and DBP precursors	109-121
109.701(g)(1)	Stage 1 DBP Rule	109-121
109.701(g)(2)	Stage 2 DBP Rule	109-122
109.701(g)(2)(i)	IDSE requirements	109-122
109.701(g)(2)(ii)	Stage 2 DPB Rule monitoring plan	109-122
109.701(g)(2)(iii)	Operational evaluation levels	109-123
109.701(g)(2)(iv)	Reporting and recordkeeping requirements	109-124
109.701(h)	Reporting and record maintenance for systems recycling their waste streams	109-124
109.701(i)	Accuracy of data	109-125
109.701(j)	Electronic reporting	109-125
109.701(k)	Monitoring plan to determine of a source is directly influenced by surface water	109-126
109.701(l)	Additional reporting and recordkeeping requirements for systems using surface water or GUDI sources.....	109-126
109.701(m)	Additional reporting and recordkeeping requirements for systems using groundwater sources	109-126
109.702	Operation and maintenance plan	109-127
109.702(a)(9)	System evaluation program as required under 109.705(a) including the wellhead protection program for any water system that develops one under 109.713	109-127
109.703	Facilities operation	109-128

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.704 Operator certification	109-129
109.704(a) CWS and NCWS shall have personnel certified under Op Cert Act	109-129
109.704(b) TNCWS shall have competent personnel qualified to operate and maintain	109-129
109.705 System evaluations and assessments	109-130
109.705(b) PWS shall conduct Level 1 and 2 assessments required under 109.202(c)(4) The PWS shall also comply with any expedited actions or additional actions required by DEP in the case of an <i>E. coli</i> MCL violations	109-130
109.705(b)(1) A Level 1 or Level 2 assessment must include review and identification of the following elements, at a minimum:	109-130
109.705(b)(1)(i) Atypical events that could affect distributed water quality or indicate that distributed water quality was impaired.	109-130
109.705(b)(1)(ii) Changes in distribution system maintenance and operation that could affect distributed water quality including water storage.	109-130
109.705(b)(1)(iii) Sources and treatment processes that impact distributed water quality.	109-130
109.701(b)(1)(iv) Existing water quality monitoring data	109-130
109.701(b)(1)(v) Inadequacies in sample sites, sampling protocols and sample processing.....	109-130
109.705(b)(2) Within 30 days of triggering a Level 1 or Level 2 assessment under 109.202(c), a PWS shall complete the appropriate assessment and submit a report to DEP on forms acceptable to DEP	109-130
109.705(b)(3) A Level assessment shall be conducted by competent personal qualified to operate and maintain the water system's facilities:	109-130
109.705(b)(4) A Level 2 assessment shall be conducted by one or more individuals meeting the following criteria:.....	109-130
109.705(b)(4)(i) Holds a valid certificate issued under Chapter 302 to operate a water system.....	109-131
109.705(b)(4)(ii) Maintains certification in the appropriate class and subclassifications as defined in Chapter 302 for the size and treatment technologies for the water system being assessed.	109-131
109.705(b)(5) DEP may conduct a Level 1 or Level 2 assessment in addition to the assessment conducted by the PWS	109-131
109.705(b)(6) In the completed assessment report, the PWS shall describe all sanitary defects identified, corrective actions completed and a proposed timetable for any corrective actions not already completed. The assessment report may also note that no sanitary defects were identified ...	109-131
109.705(b)(7) If DEP determines that a Level 1 or Level 2 assessment is not sufficient, the PWS shall consult with DEP within 14 days of receiving written notification from DEP that the assessment is not sufficient. Following consultation, DEP may require a PWS to revise the assessment. A PWS shall submit a revised assessment form to DEP no later than 30 days from the date of consultation.....	109-131
109.705(b)(8) PWSs shall correct sanitary defects found through either a Level 1 or Level 2 assessment conducted in accordance with this subsection. For corrections not completed by the time of submission of the assessment report, the PWS shall complete the corrective actions in compliance with a timetable approved by DEP in consultation with the system. The system shall notify DEP when each scheduled corrective action is completed	109-131
109.705(b)(9) Any time during the assessment or corrective action phase, either the PWS or DEP may request a consultation with the other party to determine the appropriate actions to be taken. The PWS may consult with DEP on all relevant information that may impact its ability to comply with a requirement of this subsection.	109-131
109.705(c) The following apply to significant deficiencies identified at PWSs supplied by a SW source and PWSs supplied by a GUDI source	109-131
109.705(c)(1) For sanitary surveys by DEP, a system shall respond in writing to significant deficiencies identified in sanitary survey reports no later than 45 days after receipt of the report, indicating how and on what schedule the system will address significant deficiencies noted in the survey.....	109-131
109.705(c)(2) A system shall correct significant deficiencies identified in sanitary survey reports according to the schedule approved by DEP, or if there is no approved schedule, according to the schedule reported under paragraph (1) if the deficiencies are within the control of the system.....	109-131
109.705(d) Significant deficiencies identified at DEP at a PWSs using groundwater shall comply with 109.1302(c).....	109-131

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.706 System distribution map	109-132
109.707 Emergency response plan.....	109-132
109.707(a)(2) Communication procedures and contact information. For each probable emergency situation, including, but not limited to, those specified in 109.701(a)(3)(iii), a list of appropriate contact persons and phone numbers for the following group of people:	109-132
109.707(a)(2)(i) Emergency management agencies within a water system's jurisdiction	109-132
109.707(a)(2)(ii) Key public officials.	109-132
109.705(a)(2)(iii) Government agencies including, but not limited to, DEP, PUC, Dept. of Health, Dept. of Public Welfare and PA Dept. of Agriculture.....	109-132
109.705(a)(2)(iv) Facilities with a water supplier's service area, including, but not limited to, hospitals, schools, day-care facilities, nursing home, social service agencies, industrial and commercial users	109-133
109.705(a)(2)(v) Media.....	109-133
109.705(a)(2)(vi) Equipment and chemical suppliers	109-133
109.707(c) The CWS shall review and update the plan at least annually and as necessary to reflect changes to communication procedures and contact information under subsection(a)(2)	109-133
109.708 Planned service interruptions	109-134
109.709 Cross-connection control program.....	109-134
109.710 Disinfectant residual in the distribution system.....	109-134
109.711 Disinfection of facilities prior to placing them into service.....	109-135
109.712 Control of POE devices	109-136
109.713 Wellhead protection program.....	109-136
109.714 Filter profile, filter self-assessment and comprehensive performance evaluations	109-137
109.715 Seasonal systems	109-137
109.715(a) A new seasonal system shall submit a start-up procedure with the construction permit application or brief description as required under 109.505(a)	109-138
109.715(b) A seasonal system approved by DEP to operate prior to September 24, 2016, shall submit a start-up procedure to DEP by October 24, 2016	109-138
109.715(c) IF DEP determines that a start-up procedure is not sufficient, the PWS shall submit a revised start-up procedure within 30 days of receiving written notification from DEP	109-139
109.715(d) A seasonal system shall submit to DEP for approval any revisions to an approved start-up procedure prior to serving water to the public the next season.....	109-139
109.715(e) A seasonal system shall demonstrate completion of a DEP-approved start-up procedure by submitting written certification prior to serving water to the public each season	109-139
H LABORATORY CERTIFICATION.....	109.139
109.801 Certification requirement	109-138
109.801 A laboratory shall be accredited...demonstrating compliance with monitoring requirements established in Subchapters C, K, L and M	109-139
109.810 Reporting and notification requirements	109-141
109.810(a) Beginning November 13, 2009, a lab accredited shall electronically report	109-140
109.810(b) A lab accredited shall whenever an MCL, MRDL, TT or AL is exceeded or a sample requires a check	

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

	or confirmation sample or any check sample is total coliform-positive, or a sample collected by a seasonal system as part of a DEP-approved start-up procedure is total coliform positive or is <i>E. coli</i> -positive shall do the following.....	109-142
109.810(c)	A lab accredited under Chapter 252 shall meet the requirements under subsections (a) and (b), regarding the results of test measurements or analyses performed by the lab under this chapter, unless the lab assign in writing the responsibility for reporting and notification to another accredited lab	109-142
109.810(d)	A lab accredited shall be responsible for the accurate reporting of data	109-142

I VARIANCES AND EXEMPTIONS ISSUED BY THE DEPARTMENT 109-142

109.901 Requirements for a variance	109-144
109.901(a)(1) DEP may grant a variance from the MCL requirements if the PWS has installed and is using the best treatment technology, treatment methods or other means available to reduce the level of the contaminant, and has determined that alternate sources of water are not reasonably available	109-144
109.901(b) The MCL for <i>E. coli</i> established under 109.202(a) is not eligible for a variance	109-144
109.901(c) The TT requirements under 109.202(c), 109.1102(b), 109.1203 and 109.1302 are not eligible for a variance	109-144

109.902 Variance request..... 109-145

109.903 Requirements for an exemption.....	109-1456
109.903(a)(1) PWS is unable to comply with the contaminant level or treatment technique requirement, or to implement measures to develop an alternative source of water supply	109-146
109.903(a)(4) Management or restructuring changes or both cannot reasonably be made that will result in compliance with the applicable MCL or TT or, if compliance cannot be achieved, improve the quality of the drinking water	109-146
109.903(b) The MCL for <i>E. coli</i> established under 109.202(a) is not eligible for a variance	109-146
109.903(c) The TT requirements under 109.202(c), 109.1102(b), 109.1203 and 109.1302 are not eligible for an exemption.....	109-146

109.904 Exemption request 109-146

109.905 Public hearing on a variance or exemption..... 109-147

109.906 Consideration of a request for a variance or exemption	109-148
109.906(1) In its consideration of whether the PWS satisfies the requirements for a variance, DEP will, and whether the system has evaluated that alternative sources of water are not reasonably available ..	109-148
109.906(3)(iii) The availability of an alternative source of water, including the feasibility of partnerships with neighboring PWSs, as identified by the PWS or DEP	109-149

109.907 Disposition of a request for a variance or exemption 109-149

109.907(c) If DEP makes a determination to grant a variance or exemption request, it will document its findings for granting a variance or exemption.....	109-149
---	---------

109.908 Compliance schedules 109-150

109.908(e) In accordance with 40 CFR 142.20(b)(2), DEP may renew an exemption for a PWS that serves fewer than 3,300 persons and which needs financial assistance for the necessary improvements	109-150.1
--	-----------

J BOTTLED WATER AND VENDED WATER SYSTEMS, RETAIL WATER FACILITIES AND BULK WATER HAULING SYSTEMS..... 109-150.1

109.1001 Scope 109-150.1

109.1002 MCLs, MRDLs or treatment techniques 109-150.1

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.1002(a)	BRVB systems shall supply drinking water that complies with the MCLs, MRDLs and TTs under 109.202 and 109.203. BRVB systems shall provide continuous disinfection for groundwater sources. Water for bottling labeled as mineral water, under 109.1007 shall comply with the MCLs except that mineral water may exceed the MCL for total dissolved solids.....	109-150.2
109.1002(b)	BRVB systems shall supply drinking water that contains no more than 0.005 mg/L of lead and no more than 1.0 mg/L copper.....	109-150.2
109.1002(c)	BRVB systems shall comply with TTs under Subchapter L	109-150.2
109.1002(d)	BRVB systems shall comply with Subchapter M. For the purpose of determining compliance with Subchapter M, BRVBs shall comply with standards pertaining to NCWSs	109-150.2
109.1003 Monitoring requirements		109-150.2
109.1002(a)	General monitoring requirements. BVRB systems shall monitor for compliance with the MCLs and MRDLs in accordance with 109.301 and shall comply with 109.302. The monitoring requirements shall be applied as flows, except that systems which have installed treatment to comply with primary MCL shall conduct quarterly operational monitoring for the contaminant which the facility is designed to remove.....	109-150.2
109.903(a)(1)	Bottled, retail and bulk water hauling EP monitoring.....	109-150.2
109.1003(a)(1)(i)	Monitor weekly for the presence or absence of total coliform. For any total coliform positive routine or check sample, determine the presence or absence of <i>E. coli</i> . A system may forego <i>E. coli</i> testing on a total coliform-positive sample if the system assumes that any total coliform-positive sample is also <i>E. coli</i> -positive. A system which chooses to forego <i>E. coli</i> test shall, notify DEP within 1 hr after the water system learns of the violation or the situation, and shall provide PN in accordance with 109.1004.....	109-150.3
109.1003(a)(1)(ii)	Monitor for turbidity every 4 hours or continuously each day a surface water or GUDI source is in use	109-150.3
109.1003(a)(1)(iii)	Monitor for compliance with the MCLs for VOCs	109-150.3
109.1003(a)(1)(iv)	Conduct initial and repeat monitoring for compliance with the MCLs for SOCs-pesticides and PCBs- in accordance with 109.301(6)	109-150.4
109.1003(a)(1)(v)	Beginning in 1995, monitor for the primary IOCs, including lead and copper annually	109-150.5
109.1003(a)(1)(vi)	Conduct operation monitoring for fluoride at least once each day, if the system fluoridates its water.....	109-150.5
109.1003(a)(1)(vii)	Monitor for compliance with radiological MCLs once every 4 years.	109-150.5
109.1003(a)(1)(viii)	Stage 1 DBP Rule monitoring for TTHM and HAA5 beginning January 1, 2004	109-150.5
109.1003(a)(1)(ix)	Stage 2 DBP Rule monitoring for TTHM and HAA5 beginning October 1, 2013	109-150.6
109.1003(a)(1)(x)	Beginning January 1, 2004, monitor daily for chlorite if the system uses chlorine dioxide for disinfection or oxidation. Systems shall take at least one daily sample at the entry point. If a daily sample exceeds the chlorite MCL, the system shall take three additional samples within 24 hours from the same lot, batch, machine, carrier vehicle or point of delivery. The chlorite MCL is based on the average of the required daily sample plus any additional samples	109-150.7
109.1003(a)(1)(xi)	Beginning January 1, 2004, monitor monthly for bromate if the system uses ozone for disinfection or oxidation.	109-150.7
109.1003(a)(2)	Vended water systems shall monitor in accordance with paragraph (1) except that vended water systems qualifying for permit by rule under 109.1005(b) for each EP shall:	109-150.2
109.1003(a)(2)(i)	Monitor weekly for the presence or absence of total coliform. For any total coliform positive routine or check sample, determine the presence or absence of <i>E. coli</i> . A system may forego <i>E. coli</i> testing on a total coliform-positive sample if the system assumes that any total coliform-positive sample is also <i>E. coli</i> -positive. A system which chooses to forego <i>E. coli</i> test shall, notify DEP within 1 hr after the water system learns of the violation or the situation, and shall provide PN in accordance with 109.1004.....	109-150.3
109.1003(b)	Sampling requirements	109-150.8
109.1003(c)	Repeat monitoring for microbiological contaminants	109-150.9
109.1003(c)(1)	If a sample collected in accordance with subsection (a)(1)(i) or (2)(i) is found to be total coliform-positive:	109-150.9
109.1003(c)(1)(i)	The bottled water system shall collect a set of three additional samples (check) from the same lot or batch of the type of products	109-150.9
109.1003(c)(1)(ii)	The BVRB systems shall collect a set of three additional samples (check) from the same	

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

entry point (machine, point of delivery or carrier vehicle)	109-150.9
109.1003(c)(2) Samples shall be collected for analysis within 24 hours of being notified of the total coliform-positive sample.	109-150.9
109.1003(c)(3) At a minimum, the system shall collect one set of check samples for each total coliform-positive routine sample. If a check sample is total coliform-positive, the PWS shall collect additional check samples in the manner specified in the subsection. The system shall continue to collect check samples until either total coliforms are not detected in a set of checks samples, or the system determines that an assessment has been triggered under 109.202(c)(4).	109-150.9
109.1003(d) A bulk hauling system that serves at least 25 of the same persons year round	109-150.9
109.1003(e) A bulk hauling system or vended water system that serves at least 25 of the same persons over 6 months per year	109-150.9
109.1003(f) Additional monitoring requirements for SW and GUDI sources (comply with Subchapter L)	109-150.9
109.1003(g) Additional monitoring requirements for GW sources (comply with Subchapter M)	109-150.9
109.1004 Public notification.....	109-150.10
109.1004(a) General public notification requirements	109-150.10
109.1004(b) Description and content of notice	109-150.11
109.1004(c) Notice by the Department	109-150.12
109.1004(d) CCR Requirements	109-150.12
109.1005 Permit requirements	109-150.12
109.1005(a) General permit requirements.....	109-150.12
109.1005(b) Special permit by rule requirement for vended water systems	109-150.12
109.1005(c) Special permit by rule requirement for bottled water systems	109-150.13
109.1005(d) Permit amendments	109-150.14
109.1005(e) Permit applications.....	109-150.14
109.1005(f) Permit amendment applications	109-150.16
109.1005(g) Emergency permits	109-150.18
109.1005(h) Department's review	109-150.18
109.1005(i) Permit fees.....	109-150.19
109.1006 Design and construction standards.....	109-150.19
109.1006(a) Application of standards.....	109-150.19
109.1006(b) Acceptable design	109-150.19
109.1007 Labeling requirements for bottled water systems, vended water systems and retail water facilities	109-150.20
109.1007(a) General labeling requirements	109-150.20
109.1007(b) Corporate name and trade name	109-150.20
109.1007(c) Special vending machine label	109-150.21
109.1007(d) Special retail water facility label	109-150.21
109.1008 System management responsibilities	109-150.21
109.1008(a) Reporting and recordkeeping requirements for bottled water and vended water systems, retail water facilities and bulk water hauling systems	109-150.21
109.1008(a)(4) BVRB systems using surface water or GUDI sources shall also comply with Subchapter L	109-150.22
109.1008(a)(5) BVRB systems using groundwater sources, including purchasing groundwater shall also comply with Subchapter M	109-150.22
109.1008(b) Operation and maintenance plan requirements.....	109-150.23
109.1008(c) Operator requirements	109-150.23
109.1008(d) Annual system evaluation requirements. BVRB systems shall conduct an evaluation of the water system at least annually that includes the activities listed in paragraphs (1) - (4). A BVRB system obtaining finished water from a permitted PWS is not required to perform the activities in paragraphs (1) and (2) if DEP determines that there are no potential problems necessitating inspection and evaluation of the source.....	109-150.23

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.1008(d)(1)	Watershed surveillance consisting of an inspection of portions of the drainage area necessary to identify and evaluate actual and probable sources of contamination	109-150.23
109.1008(d)(2)	Evaluation of source construction and protection and, when appropriate, withdrawal and transmission facilities.....	109-150.23
109.1008(d)(3)	Treatment facilities inspection consisting of an evaluation of the effectiveness of the operation and maintenance procedures and the condition and operability of permitted facilities	109-150.23
109.1008(d)(4)	BVRB systems using surface water or GUDI sources shall also comply with Subchapter L ...	109-150.223
109.1008(e)	Emergency response requirements	109-150.23
109.1008(f)	Cross-connection control program	109-150.24
109.1008(g)	Level 1 and Level 2 assessments. BRVB systems shall comply with the requirements of 109.705(b). BRVR may use a Nationally-recognized organization which inspects bottled water system for compliance with 21 CFR Part 129, such as NSF, or another organization, state or country which utilizes an inspection protocol as stringent as NSF's protocols to conduct the Level 2 assessment.	109-150.24
109.1008(h)	Seasonal systems. A BVRB system that operates as a seasonal system shall comply with the requirements of 109.715	109-150.24

109.1009 System operational requirements	109-150.25	
109.1009(a)	General facilities operation.....	109-150.25
109.1009(b)	Special bottled water system requirements	109-150.25
109.1009(c)	Disinfectant residual requirements.....	109-150.25
109.1009(d)	Disinfection of facilities following construction, modification or repair	109-150.25
109.1009(e)	Dedicated equipment	109-150.26
109.1009(g)	Special operational requirements for water vending machine systems	109-150.26
109.1009(h)	Special operational requirements for bulk water hauling systems.....	109-150.26

K LEAD AND COPPER	109-150.27
--------------------------------	-------------------

109.1101 Scope.....	109-150.27
----------------------------	-------------------

109.1102 Action levels and treatment technique requirements	109-150.28
--	-------------------

109.1102(a)	Action levels for lead and copper.....	109-150.28
109.1102(a)(4)	The 90 th percentile lead and copper action level computation	109-150.28
109.1102(b)	Treatment technique requirement for corrosion control.....	109-150.28
109.1102(b)(1)	Optimal corrosion control treatment	109-150.28
109.1102(b)(1)(i)	A small or medium water system is deemed to have optimized CCT if the system does not exceed either the lead or copper action level during each of two consecutive 6-month monitoring periods conducted in accordance with 109.1103. If the system thereafter exceeds an action level during a monitoring period, the system shall complete application compliance activities under paragraph (2). DEP may require a system to repeat compliance activities previously completed when DEP determines that this is necessary to achieve optimal corrosion control treatment	109-150.28
109.1102(b)(1)(ii)	A water system deemed to have optimized CCT demonstrates to DEP that for 2 consecutive 6-month monitoring periods that the system does not exceed a lead or copper action level and the difference between the 90th percentile tap water lead level and the highest source water lead level is less than 0.005 mg/L which is the PQL for lead	109-151
109.1102(b)(1)(ii)(A)	To make this demonstration, the system shall collect 1 sample for lead from each entry point during a monitoring period prior to initiation of construction or modification of CCT facilities	109-151
109.1102(b)(1)(ii)(B)	A water system deemed to have optimized CCT in accordance with this subparagraph shall continue monitoring for lead and copper at the tap no less frequently than once every 3-calendar years using the reduced number of sites specified in 109.1103(e) and collecting the samples at times and locations specified in 109.1103(e)(1)(iii)	109-151
109.1102(b)(2)	Corrosion control treatment compliance schedule	109-151
109.1102(b)(3)	Corrosion control treatment feasibility study	109-152
109.1102(b)(4)	Source water treatment	109-153
109.1102(b)(5)	Water quality parameter performance requirements	109-154

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.1103 Monitoring requirements	109-155
109.1103(a) Initial monitoring	109-155
109.1103(a)(1) Initial lead and copper tap monitoring	109-155
109.1103(a)(2) Initial water quality parameter monitoring	109-156
109.1103(a)(3) Initial source water monitoring. A system which exceeds either the lead or copper action level shall collect one source water sample from each entry point within 6 months after the end of the monitoring period in which the action level was exceeded. Monitoring is required only for the parameter for which the action level was exceeded.	109-157
109.1103(b) Special lead and copper tap monitoring	109-157
109.1103(c) Follow-up monitoring after construction or modification of corrosion control treatment facilities..	109-157
109.1103(c)(1) Lead and copper tap monitoring	109-157
109.1103(c)(2) Water quality parameter monitoring.....	109-158
109.1103(c)(3) Source water monitoring. The source water monitoring begins within 6 months after the end of the monitoring period in which the action level was exceeded	109-159
109.1103(d) Monitoring after performance requirements are established.....	109-159
109.1103(d)(1) Lead and copper tap monitoring	109-159
109.1103(d)(2) Water quality parameter performance monitoring	109-159
109.1103(d)(3) Source water monitoring. The source water monitoring begins within 6 months after the end of the monitoring period in which the action level was exceeded	109-160
109.1103(e) Reduced monitoring	109-160
109.1103(e)(1) Reduced lead and copper tap monitoring	109-161
109.1103(e)(1)(i) Annual lead and copper tap monitoring	109-161
109.1103(e)(1)(i)(B) A system that installed CCT may reduce lead and copper sample sites and reduce the frequency to once per year if the following conditions are met:	109-161
109.1103(e)(1)(i)(B)(I) The system does not exceed the lead and copper action levels during each of 2 consecutive 6-month monitoring periods.....	109-161
109.1103(e)(1)(i)(B)(II) The system maintains the range of value for the WQP performance requirements during each of 2 consecutive 6-month monitoring periods in accordance with subsection (d)(2).	109-161
109.1103(e)(1)(i)(C) Annual monitoring shall begin during the calendar year immediately following the end of the second consecutive 6-month monitoring period.....	109-161
109.1103(e)(1)(ii) Triennial lead and copper tap monitoring.....	109-161
109.1103(e)(1)(ii)(B) A system that installed CCT may reduce the frequency of lead and copper tap monitoring from annual to once every 3 years if the following conditions are met:	109-161
109.1103(e)(1)(ii)(B)(I) The system does not exceed the lead and copper action levels during 3 consecutive years of 6-month or annual monitoring.	109-161
109.1103(e)(1)(ii)(B)(II) The system maintains the range of value for the WQP performance requirements during 3 consecutive years of monitoring.	109-161
109.1103(e)(1)(iii) Sample sites and timing	109-162
109.1103(e)(2) Reduced water quality parameter monitoring for large systems	109-162
109.1103(e)(2)(i) Reduced sites.....	109-162
109.1103(e)(2)(ii) Reduced water quality parameter monitoring.....	109-162
109.1103(e)(3) Reduced monitoring revocation	109-163
109.1103(e)(3)(i) Reduced monitoring revocation for large systems	109-163
109.1103(e)(3)(ii) Reduced monitoring revocation for small or medium water systems	109-163
109.1103(e)(3)(ii)(A) The water supplier shall conduct WQP monitoring during the monitoring period in which the action level is exceeded. The start of the 6-month monitoring period for WQP monitoring required must coincide with the start of the annual or triennial tap monitoring period in which the action level was exceeded.	109-164
109.1103(e)(3)(ii)(B) The water supplier shall collect one source water sample from each entry point within 6 months of the end of the monitoring period for which the action level was exceeded. Monitoring is required only for the parameter for which the action level was exceeded. For systems on annual or less frequent monitoring, the end of the monitoring period is September 30 of the calendar year in which sampling occurs, or, if DEP designated an alternative monitoring period, the end of the monitoring period is the last day of the 4-month period in which sampling occurs	109-164

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.1103(e)(3)(ii)(C) If a system has installed CCT in compliance with 109.1102(b)(2), the water supplier shall resume lead and copper tap monitoring in accordance with subsection (d)(1)	109-164
109.1103(f) Additional monitoring by systems.....	109-164
109.1103(g) Sample site location plan	109-164
109.1103(g)(1) Materials evaluation.....	109-165
109.1103(g)(2) Lead and copper tap sample site selection	109-165
109.1103(g)(2)(i) Site selection for community water systems	109-165
109.1103(g)(2)(ii) Site selection for nontransient noncommunity water systems	109-165
109.1103(g)(2)(iii) Site selection for community and nontransient noncommunity water systems that have fewer than five taps.....	109-166
109.1103(g)(2)(iv) Site selection for community and nontransient noncommunity water facilities that operate continuously.....	109-166
109.1103(g)(2)(v) Sample sites with lead service lines.....	109-166
109.1103(g)(2)(vi) Sample sites with point-of-use or point-of-entry devices	109-166
109.1103(g)(3) Water quality parameter sample site selection	109-166
109.1103(g)(3)(i) Water quality parameter distribution samples	109-166
109.1103(g)(3)(ii) Water quality parameter entry point samples.....	109-167
109.1103(g)(4) Sample procedure certification	109-167
109.1103(h) Sample collection methods	109-167
109.1103(h)(1) Lead and copper tap samples.....	109-167
109.1103(h)(2) Water quality parameter distribution samples	109-168
109.1103(h)(3) Water quality parameter entry point samples.....	109-168
109.1103(h)(4) Source water samples.....	109-168
109.1103(h)(5) Lead service line samples	109-168
109.1103(i) Analytical methods	109-169
109.1103(j) Invalidation of lead or copper tap water samples	109-169
109.1103(k) Monitoring waivers for small systems	109-169
109.1103(k)(1) Materials criteria.....	109-170
109.1103(k)(1)(i) Lead	109-170
109.1103(k)(1)(ii) Copper	109-170
109.1103(k)(2) Monitoring criteria for waiver issuance	109-170
109.1103(k)(2)(i) Lead levels	109-170
109.1103(k)(2)(ii) Copper levels	109-170
109.1103(k)(3) Department approval of waiver application	109-170
109.1103(k)(4) Monitoring frequency for systems with waivers	109-170
109.1103(k)(4)(i) Monitoring shall be conducted during the last year of each 9-year compliance cycle-for example 2010, 2019, 2028 and so forth.	109-170
109.1103(k)(5) Continued eligibility.....	109-171
109.1103(k)(6) Requirements following waiver revocation	109-171
109.1104 Public education and notification	190-171
109.1104(a) Public education program	190-171
109.1104(a)(1) Content	190-172
109.1104(a)(1)(i) Content of written materials	190-172
109.1104(a)(1)(ii) Information for non-English-speaking populations	190-172
109.1104(a)(1)(iii) Submission of written materials	190-172
109.1104(a)(2) Delivery.....	190-172
109.1104(a)(2)(i) Community water system requirements	190-172
109.1104(a)(2)(ii) Nontransient noncommunity water system requirements	190-174
109.1104(a)(2)(iii) Extension of 60-day delivery deadline	190-175
109.1104(a)(3) Discontinuation of public education program	190-175
109.1104(a)(4) Notification of customer monitoring	190-175
109.1104(b) Notification of results (consumer tap notice)	190-175
109.1104(b)(1) Content	190-175
109.1104(b)(2) Timing.....	190-175
109.1104(b)(3) Delivery.....	190-175
109.1104(c) Public notification requirements.....	190-175

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.1105 Permit requirements	109-176
109.1105(a) General permit requirements.....	190-176
109.1105(b) Construction permits and permit amendments.....	190-176
109.1105(b)(1) Community water system minor permit amendments	190-176
109.1105(b)(2) Nontransient noncommunity water system permits	190-176
109.1105(c) Operation permits	190-177
109.1106 Design standards.....	109-177
109.1106(1) A minimum pH in distribution samples of at least 7.0	109-177
109.1106(2) For systems that are exempt from submitting a construction permit application, a minimum alkalinity measured in all distribution samples of 20 mg/L	109-177
109.1107 System management responsibilities	109-178
109.1107(a) Reporting and recordkeeping	190-178
109.1107(a)(1) Sample site location plan maintain on file and submit to DEP prior to initial lead and copper monitoring or upon request	190-178
109.1107(a)(2) Reporting of monitoring results	190-178
109.1107(a)(2)(i) Lead and copper tap monitoring results	190-178
109.1107(a)(2)(ii) Water quality parameter monitoring results.....	190-178
109.1107(a)(2)(iii) Source water monitoring results	190-179
109.1107(a)(3) Corrosion control treatment reporting requirements	190-179
109.1107(a)(4) Public education reporting requirements	190-180
109.1107(a)(5) Consumer notice of lead tap monitoring results reporting requirements. The water supplier shall submit to DEP within 3 months of the end of the monitoring period in which lead tap monitoring was conducted a sample copy of the consumer notice of lead tap monitoring results along with a certification that the notices were distributed in accordance with 109.1104(b)	190-180
109.1107(a)(6) Lead service line replacement reporting	190-180
109.1107(a)(7) Record maintenance	190-181
109.1107(b) Operation and maintenance plan	190-181
109.1107(c) Operator certification.....	190-182
109.1107(d) Lead service line replacement	190-182
109.1107(d)(1) Initiation of lead service line replacement. The first year of LSL replacement begins on the first day following the end of the monitoring period in which the action level was exceeded. If monitoring is required annually or less frequently, the end of the monitoring period is September 30 of the calendar year in which sampling occurred.....	190-182
109.1107(d)(2) Replacement schedule	190-182
109.1107(d)(3) Lead service line sampling	190-182
109.1107(d)(4) Conditions of replacement	190-182
109.1107(d)(5) Discontinuation of lead service line replacement	190-182.1
109.1107(d)(6) Resumption of lead service line replacement. Water systems that resume a LSL replacement program shall update their LSL inventory to include those sites that were previously excluded under paragraph (3). Systems shall divide the updated number of remaining LSLs by the number of remaining years in the replacement program to determine the number that must be replaced each year. If the system has completed a 15-year LSL replacement program, DEP will determine a schedule for replacing or retesting LSLs that were previously tested out under the replacement program	190-182.1
109.1108 Fees	109-182.1
109.1108(1) Construction or permit amendment fee	109-182.2
109.1108(2) System not paying construction fee	109-182.2
L LONG-TERM 2 ENHANCED SURFACE WATER TREATMENT RULE	109-182.2
109.1201 Scope	109-182.3
109.1201(a) Scope.....	109-182.3
109.1201(b) Applicability	109-182.3

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.1202 Monitoring Requirements.....	109-183
109.1202(a) Initial round of source water monitoring	109-183
109.1202(b) Second round of source water monitoring	109-184
109.1202(c) Source water monitoring schedule	109-184
109.1202(d) Source water monitoring avoidance	109-185
109.1202(e) Plants operating only part of the year	109-185
109.1202(f) New sources	109-185
109.1202(g) Monitoring violations	109-186
109.1202(h) Source water sampling schedules	109-186
109.12020(i) Source water sample collection period	109-186
109.1202(j) Missed samples	109-187
109.1202(k) Source water sampling location	109-187
109.1202(l) Chemical treatment prior to sampling location	109-187
109.1202(m) Source water sample location for plants that recycle	109-187
109.1202(n) Bank filtration	109-187
109.1202(o) Multiple sources.....	109-188
109.1202(p) Additional requirements.....	109-188
 109.1203 Bin classification and treatment technique requirements.....	109-189
109.1203(a) Bin classification	109-189
109.1203(b) Procedures for calculating bin classifications	109-189
109.1203(c) <i>Cryptosporidium</i> bin concentration thresholds.....	109-189
109.1203(d) <i>Cryptosporidium</i> bin concentration recalculation requirements.....	109-190
109.1203(e) Filtered system additional <i>Cryptosporidium</i> treatment requirements.....	109-190
109.1203(f) Treatment and management options for filtered systems, microbial toolbox.....	109-191
109.1203(g) Failure to meet treatment credit.....	109-191
109.1203(h) Increased watershed contamination	109-191
109.1203(i) Unfiltered systems determination of <i>Cryptosporidium</i> bin level, initial round	109-191
109.1203(j) Unfiltered systems determination of <i>Cryptosporidium</i> bin level, second round	109-191
109.1203(k) Schedule for compliance with <i>Cryptosporidium</i> treatment requirements	109-192
109.1203(l) Treatment technique requirements for unfiltered systems	109-192
109.1203(m) <i>Cryptosporidium</i> treatment compliance dates	109-192
109.1203(n) Change in <i>Cryptosporidium</i> level for filtered system	109-192
109.1203(o) Change in <i>Cryptosporidium</i> level for unfiltered system	109-192
 109.1204 Requirements for microbial toolbox components.....	109-193
109.1204(a) System will receive Treatment credits listed in Appendix B	109-193
109.1204(b) Watershed control program.....	109-193
109.1204(c) Alternative source	109-195
109.1204(d) Presedimentation	109-195
109.1204(e) 2-stage lime softening	109-196
109.1204(f) Bank filtration	109-196
109.1204(g) Combined filter performance.....	109-197
109.1204(h) Individual filter performance.....	109-197
109.1204(i) Demonstration of performance.....	109-197
109.1204(j) Bag and cartridge filters.....	109-198
109.1204(k) Membrane filtration	109-199
109.1204(l) Second stage filtration.....	109-203
109.1204(m) Slow sand filtration (as secondary filter).....	109-203
109.1204(n) Inactivation toolbox components	109-204
109.1204(o) Chlorine dioxide.....	109-204
109.1204(p) Ozone	109-204
109.1204(q) Ultraviolet light	109-204
 109.1205 Grandfathering previously collected data	109-206
 109.1206 Reporting and recordkeeping requirements	109-206

2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)

109.1206(a)	Source water reporting time frame	109-206
109.1206(b)	Methods for reporting initial source water monitoring results to EPA	109-206
109.1206(c)	Methods for reporting initial source water monitoring results to DEP	109-206
109.1206(d)	Methods for reporting second round of source water monitoring results to DEP.....	109-206
109.1206(e)	Source water reporting data elements.....	109-206
109.1206(f)	Sampling schedule reporting.....	109-207
109.1206(g)	Bin classification reporting.....	109-207
109.1206(h)	Microbial toolbox reporting requirements.....	109-208
109.1206(i)	Reporting significant change in disinfection practices.....	109-208
109.1206(j)	Source water monitoring recordkeeping requirements	109-208
109.1206(k)	Notification retention	109-208
109.1206(l)	Results retention.....	109-208
M	ADDITIONAL REQUIREMENT FOR GROUNDWATER SOURCES	109-209
109.1301	Scope	109-209
109.1302	Treatment technique requirements	109-210
109.1302(a)	Community groundwater systems.....	109-210
109.1302(b)	Noncommunity groundwater systems including BVRBs	109-210
109.1302(c)	Groundwater systems with significant deficiencies or source water <i>E. coli</i> contamination.....	109-211
109.1303	Triggered monitoring requirements for groundwater sources	109-212
109.1303(a)	Source water sample for <i>E. coli</i> required within 24 hours of a TC+	109-212
109.1303(b)	DEP may extend 24 hours to 72 hours for logical problem	109-213
109.1303(c)	Source water samples that are representative of multiple sources	109-213
109.1303(d)	Source water sample collected prior to any treatment.....	109-213
109.1303(e)	Purchased water system notifies selling system of TC+ within 24 hours.....	109-213
109.1303(f)	Source water monitoring waived if 2 conditions apply.....	109-213
109.1303(g)	Invalidation criteria of <i>E. coli</i> + source water sample	109-213
109.1303(h)	Requirements following a <i>E. coli</i> + source water sample.....	109-214
109.1303(i)	Selling systems must comply with triggered monitoring requirements under (a).....	109-214
109.1304	Assessment source water monitoring.....	109-214
109.1304(a)	To determine if a noncommunity groundwater source contains fecal contamination	109-214
109.1304(b)	Invalidation criteria of <i>E. coli</i> TC+ source water sample	109-215
109.1305	Compliance monitoring	109-216
109.1305(a)	Chemical disinfection residual disinfection monitoring requirements	109-216
109.1305(b)	Alternative treatment compliance monitoring requirements	109-216
109.1306	Information describing 4-log treatment and compliance monitoring.....	109-217
109.1306(a)	CWS, BRVBs and NCWs with valid operations permits submit forms to evaluate treatment effectiveness	109-217
109.1306(b)	NCWs without permits demonstrating 4-log treatment submittal requirements	109-217
109.1306(c)	Plans, specifications and engineer report requirements	109-217
109.1307	System management responsibilities	109-218
109.1307(a)	Reporting	109-218
109.1307(b)	Recordkeeping.....	109-219
APPENDIX A TO SUBCHAPTER L (LT2ESWTR)	109-220	
Table 1	CT Values for <i>Cryptosporidium</i> inactivation by chlorine dioxide	109-220
Table 2	CT Values for <i>Cryptosporidium</i> inactivation by ozone	109-220
Table 3	UV Dose for <i>Cryptosporidium</i> , <i>Giardia lamblia</i> and virus inactivation credit	109-221

**2017 Chapter 109 Index - September 2017
(highlight = revised Total Coliform Rule citations)**

APPENDIX B TO SUBCHAPTER L (LT2ESWTR)	109-222
Microbial Toolbox Summary Table: Options, Treatment Credits and Criteria	109-222
APPENDIX C TO SUBCHAPTER L (LT2ESWTR)	109-225
Microbial Toolbox Reporting Requirements	109-225