



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
AIR QUALITY PROGRAM**

**STATE ONLY NATURAL MINOR OPERATING PERMIT**

Issue Date: October 2, 2024

Effective Date: December 1, 2024

Expiration Date: November 30, 2029

In accordance with the provisions of the Air Pollution Control Act, the Act of January 8, 1960, P.L. 2119, as amended, and 25 Pa. Code Chapter 127, the Owner, [and Operator if noted] (hereinafter referred to as permittee) identified below is authorized by the Department of Environmental Protection (Department) to operate the air emission source(s) more fully described in this permit. This Facility is subject to all terms and conditions specified in this permit. Nothing in this permit relieves the permittee from its obligations to comply with all applicable Federal, State and Local laws and regulations.

The regulatory or statutory authority for each permit condition is set forth in brackets. All terms and conditions in this permit are federally enforceable unless otherwise designated.

**State Only Permit No: 01-03007**

Natural Minor

Federal Tax Id - Plant Code: 30-0944504-1

**Owner Information**

Name: PCA CORRUGATED & DISPLAY LLC

Mailing Address: 104 COMMERCE ST  
NEW OXFORD, PA 17350-1702

**Plant Information**

Plant: PCA CORRUGATED & DISPLAY LLC/NEW OXFORD

Location: 01 Adams County 01926 New Oxford Borough

SIC Code: 2653 Manufacturing - Corrugated And Solid Fiber Boxes

**Responsible Official**

Name: JOHN RICE

Title: GENERAL MANAGER

Phone: (717) 624 - 6397

Email: johnrice@PACKAGINGCORP.COM

**Permit Contact Person**

Name: SCOTT BOLLINGER

Title: EHS MANAGER

Phone: (717) 624 - 6390

Email: SCOTTBOLLINGER@PACKAGINGCORP.COM

[Signature] \_\_\_\_\_

*WILLIAM R. WEAVER, SOUTH CENTRAL REGION AIR PROGRAM MANAGER*

**SECTION A. Table of Contents****Section A. Facility/Source Identification**

Table of Contents  
Site Inventory List

**Section B. General State Only Requirements**

- #001 Definitions.
- #002 Operating Permit Duration.
- #003 Permit Renewal.
- #004 Operating Permit Fees under Subchapter I.
- #005 Transfer of Operating Permits.
- #006 Inspection and Entry.
- #007 Compliance Requirements.
- #008 Need to Halt or Reduce Activity Not a Defense.
- #009 Duty to Provide Information.
- #010 Revising an Operating Permit for Cause.
- #011 Operating Permit Modifications
- #012 Severability Clause.
- #013 De Minimis Emission Increases.
- #014 Operational Flexibility.
- #015 Reactivation of Sources
- #016 Health Risk-based Emission Standards and Operating Practice Requirements.
- #017 Circumvention.
- #018 Reporting Requirements.
- #019 Sampling, Testing and Monitoring Procedures.
- #020 Recordkeeping.
- #021 Property Rights.
- #022 Alternative Operating Scenarios.
- #023 Reporting
- #024 Report Format

**Section C. Site Level State Only Requirements**

- C-I: Restrictions
- C-II: Testing Requirements
- C-III: Monitoring Requirements
- C-IV: Recordkeeping Requirements
- C-V: Reporting Requirements
- C-VI: Work Practice Standards
- C-VII: Additional Requirements
- C-VIII: Compliance Certification
- C-IX: Compliance Schedule

**Section D. Source Level State Only Requirements**

- D-I: Restrictions
- D-II: Testing Requirements
- D-III: Monitoring Requirements
- D-IV: Recordkeeping Requirements
- D-V: Reporting Requirements
- D-VI: Work Practice Standards
- D-VII: Additional Requirements

Note: These same sub-sections are repeated for each source!

**Section E. Source Group Restrictions**

- E-I: Restrictions



## SECTION A. Table of Contents

- E-II: Testing Requirements
- E-III: Monitoring Requirements
- E-IV: Recordkeeping Requirements
- E-V: Reporting Requirements
- E-VI: Work Practice Standards
- E-VII: Additional Requirements

### Section F. Alternative Operating Scenario(s)

- F-I: Restrictions
- F-II: Testing Requirements
- F-III: Monitoring Requirements
- F-IV: Recordkeeping Requirements
- F-V: Reporting Requirements
- F-VI: Work Practice Standards
- F-VII: Additional Requirements

### Section G. Emission Restriction Summary

### Section H. Miscellaneous

**SECTION A. Site Inventory List**

Source ID	Source Name	Capacity/Throughput	Fuel/Material
031	YORK SHIPLEY BOILER, 2012, 25.2 MMBTU/HR	25.200 MCF/HR	NATURAL GAS
101	OFFSET NONHEATSET LITHOGRAPHIC PRESSES (2)		
102	FLEXOGRAPHIC PRESSES (9)		
103	EMER GEN MACT 4Z, GEN.2(SI RICE),FIRE PP.(CI RICE)	1.000 MCF/HR	Natural Gas
		5.000 Gal/HR	#2 Oil
104	EMER GEN, NSPS 4J, GEN 1 (SI RICE), 2011, 62HP(40KW)	0.500 MCF/HR	NATURAL GAS
105	DEGREASERS		
FML01	FUEL MATERIAL, NATURAL GAS		
FML02	FUEL MATERIAL, #2 OIL FUEL		
S031	STACK, YS BOILER		
S103	STACK, 4Z SOURCES		
S104	STACK, SI RICE, NATURAL GAS		
Z00	FUGITIVES, PRESSES /DEGREASERS		

**PERMIT MAPS**

**SECTION B. General State Only Requirements****#001 [25 Pa. Code § 121.1]****Definitions.**

Words and terms that are not otherwise defined in this permit shall have the meanings set forth in Section 3 of the Air Pollution Control Act (35 P.S. § 4003) and in 25 Pa. Code § 121.1.

**#002 [25 Pa. Code § 127.446]****Operating Permit Duration.**

(a) This operating permit is issued for a fixed term of five (5) years and shall expire on the date specified on Page 1 of this permit.

(b) The terms and conditions of the expired permit shall automatically continue pending issuance of a new operating permit, provided the permittee has submitted a timely and complete application and paid applicable fees required under 25 Pa. Code Chapter 127, Subchapter I and the Department is unable, through no fault of the permittee, to issue or deny a new permit before the expiration of the previous permit.

**#003 [25 Pa. Code §§ 127.412, 127.413, 127.414, 127.446 & 127.703(b)]****Permit Renewal.**

(a) The permittee shall submit a timely and complete application for renewal of the operating permit to the appropriate Regional Air Program Manager. The application for renewal of the operating permit shall be submitted at least six (6) months and not more than 18 months before the expiration date of this permit.

(b) The application for permit renewal shall include the current permit number, a description of any permit revisions that occurred during the permit term, and any applicable requirements that were promulgated and not incorporated into the permit during the permit term. An application is complete if it contains sufficient information to begin processing the application, has the applicable sections completed and has been signed by a responsible official.

(c) The permittee shall submit with the renewal application a fee for the processing of the application as specified in 25 Pa. Code § 127.703(b). The fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" and submitted with the fee form to the respective regional office.

(d) The renewal application shall also include submission of proof that the local municipality and county, in which the facility is located, have been notified in accordance with 25 Pa. Code § 127.413.

(e) The application for renewal of the operating permit shall also include submission of supplemental compliance review forms in accordance with the requirements of 25 Pa. Code § 127.412(b) and § 127.412(j).

(f) The permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the permit application, shall promptly submit such supplementary facts or corrected information as necessary to address any requirements that become applicable to the source after the permittee submits a complete application, but prior to the date the Department takes action on the permit application.

**#004 [25 Pa. Code § 127.703]****Operating Permit Fees under Subchapter I.**

(a) The permittee shall pay the annual operating permit maintenance fee according to the following fee schedule in either paragraph (1) or (2) in accordance with 25 Pa. Code § 127.703(d) on or before December 31 of each year for the next calendar year.

(1) For a synthetic minor facility, a fee equal to:

(i) Four thousand dollars (\$4,000) for calendar years 2021—2025.

(ii) Five thousand dollars (\$5,000) for calendar years 2026—2030.

(iii) Six thousand three hundred dollars (\$6,300) for the calendar years beginning with 2031.

**SECTION B. General State Only Requirements**

(2) For a facility that is not a synthetic minor, a fee equal to:

- (i) Two thousand dollars (\$2,000) for calendar years 2021—2025.
- (ii) Two thousand five hundred dollars (\$2,500) for calendar years 2026—2030.
- (iii) Three thousand one hundred dollars (\$3,100) for the calendar years beginning with 2031.

(b) The applicable fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" with the permit number clearly indicated and submitted to the respective regional office.

**#005 [25 Pa. Code §§ 127.450 (a)(4) and 127.464]****Transfer of Operating Permits.**

(a) This operating permit may not be transferred to another person, except in cases of transfer-of-ownership that are documented and approved by the Department.

(b) In accordance with 25 Pa. Code § 127.450(a)(4), a change in ownership of the source shall be treated as an administrative amendment if the Department determines that no other change in the permit is required and a written agreement has been submitted to the Department identifying the specific date of the transfer of permit responsibility, coverage and liability between the current and the new permittee and a compliance review form has been submitted to, and the permit transfer has been approved by, the Department.

(c) This operating permit is valid only for those specific sources and the specific source locations described in this permit.

**#006 [25 Pa. Code § 127.441 and 35 P.S. § 4008]****Inspection and Entry.**

(a) Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Department or authorized representatives of the Department to perform the following:

(1) Enter at reasonable times upon the permittee's premises where a source is located or emissions related activity is conducted, or where records are kept under the conditions of this permit;

(2) Have access to and copy, at reasonable times, any records that are kept under the conditions of this permit;

(3) Inspect at reasonable times, any facilities, equipment including monitoring and air pollution control equipment, practices, or operations regulated or required under this permit;

(4) Sample or monitor, at reasonable times, any substances or parameters, for the purpose of assuring compliance with the permit or applicable requirements as authorized by the Clean Air Act, the Air Pollution Control Act, or the regulations promulgated under the Acts.

(b) Pursuant to 35 P.S. § 4008, no person shall hinder, obstruct, prevent or interfere with the Department or its personnel in the performance of any duty authorized under the Air Pollution Control Act or regulations adopted thereunder including denying the Department access to a source at this facility. Refusal of entry or access may constitute grounds for permit revocation and assessment of criminal and/or civil penalties.

(c) Nothing in this permit condition shall limit the ability of the EPA to inspect or enter the premises of the permittee in accordance with Section 114 or other applicable provisions of the Clean Air Act.

**#007 [25 Pa. Code §§ 127.441 & 127.444]****Compliance Requirements.**

(a) The permittee shall comply with the conditions of this operating permit. Noncompliance with this permit constitutes a violation of the Clean Air Act and the Air Pollution Control Act and is grounds for one or more of the following:

**SECTION B. General State Only Requirements**

- (1) Enforcement action
- (2) Permit termination, revocation and reissuance or modification
- (3) Denial of a permit renewal application

(b) A person may not cause or permit the operation of a source which is subject to 25 Pa. Code Article III unless the source(s) and air cleaning devices identified in the application for the plan approval and operating permit and the plan approval issued for the source is operated and maintained in accordance with specifications in the applications and the conditions in the plan approval and operating permit issued by the Department. A person may not cause or permit the operation of an air contamination source subject to 25 Pa. Code Chapter 127 in a manner inconsistent with good operating practices.

(c) For purposes of Sub-condition (b) of this permit condition, the specifications in applications for plan approvals and operating permits are the physical configurations and engineering design details which the Department determines are essential for the permittee's compliance with the applicable requirements in this State-Only permit. Nothing in this sub-condition shall be construed to create an independent affirmative duty upon the permittee to obtain a predetermination from the Department for physical configuration or engineering design detail changes made by the permittee.

**#008 [25 Pa. Code § 127.441]****Need to Halt or Reduce Activity Not a Defense.**

It shall not be a defense for the permittee in an enforcement action that it was necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

**#009 [25 Pa. Code §§ 127.442(a) & 127.461]****Duty to Provide Information.**

(a) The permittee shall submit reports to the Department containing information the Department may prescribe relative to the operation and maintenance of each source at the facility.

(b) The permittee shall furnish to the Department, in writing, information that the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. Upon request, the permittee shall also furnish to the Department copies of records that the permittee is required to maintain in accordance with this permit.

**#010 [25 Pa. Code § 127.461]****Revising an Operating Permit for Cause.**

This operating permit may be terminated, modified, suspended or revoked and reissued if one or more of the following applies:

- (1) The permittee constructs or operates the source subject to the operating permit so that it is in violation of the Air Pollution Control Act, the Clean Air Act, the regulations thereunder, a plan approval, a permit or in a manner that causes air pollution.
- (2) The permittee fails to properly or adequately maintain or repair an air pollution control device or equipment attached to or otherwise made a part of the source.
- (3) The permittee has failed to submit a report required by the operating permit or an applicable regulation.
- (4) The EPA determines that the permit is not in compliance with the Clean Air Act or the regulations thereunder.

**#011 [25 Pa. Code §§ 127.450, 127.462, 127.465 & 127.703]****Operating Permit Modifications**

(a) The permittee is authorized to make administrative amendments, minor operating permit modifications and significant operating permit modifications, under this permit, as outlined below:

**SECTION B. General State Only Requirements**

(b) Administrative Amendments. The permittee shall submit the application for administrative operating permit amendments (as defined in 25 Pa. Code § 127.450(a)), according to procedures specified in § 127.450 unless precluded by the Clean Air Act or its regulations.

(c) Minor Operating Permit Modifications. The permittee shall submit the application for minor operating permit modifications (as defined 25 Pa. Code § 121.1) in accordance with 25 Pa. Code § 127.462.

(d) Significant Operating Permit Modifications. The permittee shall submit the application for significant operating permit modifications in accordance with 25 Pa. Code § 127.465.

(e) The applicable fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" with the permit number clearly indicated and submitted to the respective regional office.

**#012 [25 Pa. Code § 127.441]****Severability Clause.**

The provisions of this permit are severable, and if any provision of this permit is determined by a court of competent jurisdiction to be invalid or unenforceable, such a determination will not affect the remaining provisions of this permit.

**#013 [25 Pa. Code § 127.449]****De Minimis Emission Increases.**

(a) This permit authorizes de minimis emission increases in accordance with 25 Pa. Code § 127.449 so long as the permittee provides the Department with seven (7) days prior written notice before commencing any de minimis emissions increase. The written notice shall:

(1) Identify and describe the pollutants that will be emitted as a result of the de minimis emissions increase.

(2) Provide emission rates expressed in tons per year and in terms necessary to establish compliance consistent with any applicable requirement.

(b) The Department may disapprove or condition de minimis emission increases at any time.

(c) Except as provided below in (d), the permittee is authorized to make de minimis emission increases (expressed in tons per year) up to the following amounts without the need for a plan approval or prior issuance of a permit modification:

(1) Four tons of carbon monoxide from a single source during the term of the permit and 20 tons of carbon monoxide at the facility during the term of the permit.

(2) One ton of NO<sub>x</sub> from a single source during the term of the permit and 5 tons of NO<sub>x</sub> at the facility during the term of the permit.

(3) One and six-tenths tons of the oxides of sulfur from a single source during the term of the permit and 8.0 tons of oxides of sulfur at the facility during the term of the permit.

(4) Six-tenths of a ton of PM<sub>10</sub> from a single source during the term of the permit and 3.0 tons of PM<sub>10</sub> at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act, the regulations thereunder or 25 Pa. Code Article III.

(5) One ton of VOCs from a single source during the term of the permit and 5.0 tons of VOCs at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act, the regulations thereunder or 25 Pa. Code Article III.

(6) Other sources and classes of sources determined to be of minor significance by the Department.

(d) In accordance with § 127.14, the permittee is authorized to install the following minor sources without the need for a plan approval or permit modification:



**SECTION B. General State Only Requirements**

- (1) Air conditioning or ventilation systems not designed to remove pollutants generated or released from other sources.
  - (2) Combustion units rated at 2,500,000 or less Btu per hour of heat input.
  - (3) Combustion units with a rated capacity of less than 10,000,000 Btu per hour heat input fueled by natural gas supplied by a public utility or by commercial fuel oils which are No. 2 or lighter, viscosity less than or equal to 5.82 c St, and which meet the sulfur content requirements of 25 Pa. Code §123.22 (relating to combustion units). For purposes of this permit, commercial fuel oil shall be virgin oil which has no reprocessed, recycled or waste material added.
  - (4) Space heaters which heat by direct heat transfer.
  - (5) Laboratory equipment used exclusively for chemical or physical analysis.
  - (6) Other sources and classes of sources determined to be of minor significance by the Department.
- (e) This permit does not authorize de minimis emission increases if the emissions increase would cause one or more of the following:
- (1) Increase the emissions of a pollutant regulated under Section 112 of the Clean Air Act except as authorized in Subparagraphs (c)(4) and (5) of this permit condition.
  - (2) Subject the facility to the prevention of significant deterioration requirements in 25 Pa. Code Chapter 127, Subchapter D and/or the new source review requirements in Subchapter E.
  - (3) Violate any applicable requirement of this permit, the Air Pollution Control Act, the Clean Air Act, or the regulations promulgated under either of the acts.
- (f) Emissions authorized under this permit condition shall be included in the monitoring, recordkeeping and reporting requirements of this permit.
- (g) Except for de minimis emission increases, installation of minor sources made pursuant to this permit condition and Plan Approval Exemptions under 25 Pa. Code § 127.14 (relating to exemptions), the permittee is prohibited from making changes or engaging in activities that are not specifically authorized under this permit without first applying for a plan approval. In accordance with § 127.14(b), a plan approval is not required for the construction, modification, reactivation, or installation of the sources creating the de minimis emissions increase.
- (h) The permittee may not meet de minimis emission threshold levels by offsetting emission increases or decreases at the same source.

**#014 [25 Pa. Code § 127.3]****Operational Flexibility.**

The permittee is authorized to make changes within the facility in accordance with the regulatory provisions outlined in 25 Pa. Code § 127.3 (relating to operational flexibility) to implement the operational flexibility requirements provisions authorized under Section 6.1(i) of the Air Pollution Control Act and the operational flexibility terms and conditions of this permit. The provisions in 25 Pa. Code Chapter 127 which implement the operational flexibility requirements include the following:

- (1) Section 127.14 (relating to exemptions)
- (2) Section 127.447 (relating to alternative operating scenarios)
- (3) Section 127.448 (relating to emissions trading at facilities with Federally enforceable emissions caps)
- (4) Section 127.449 (relating to de minimis emission increases)
- (5) Section 127.450 (relating to administrative operating permit amendments)

**SECTION B. General State Only Requirements**

(6) Section 127.462 (relating to minor operating permit modifications)

(7) Subchapter H (relating to general plan approvals and general operating permits)

**#015 [25 Pa. Code § 127.11a]****Reactivation of Sources**

(a) The permittee may not reactivate a source that has been out of operation or production for at least one year unless the reactivation is conducted in accordance with a plan approval granted by the Department or in accordance with reactivation and maintenance plans developed and approved by the Department in accordance with 25 Pa. Code § 127.11a(a).

(b) A source which has been out of operation or production for more than five (5) years but less than 10 years may be reactivated and will not be considered a new source if the permittee satisfies the conditions specified in 25 Pa. Code § 127.11a(b).

**#016 [25 Pa. Code § 127.36]****Health Risk-based Emission Standards and Operating Practice Requirements.**

(a) When needed to protect public health, welfare and the environment from emissions of hazardous air pollutants from new and existing sources, the permittee shall comply with the health risk-based emission standards or operating practice requirements imposed by the Department, except as precluded by §§ 6.6(d)(2) and (3) of the Air Pollution Control Act [35 P.S. § 4006.6(d)(2) and (3)].

(b) A person challenging a performance or emission standard established by the Department has the burden to demonstrate that performance or emission standard does not meet the requirements of Section 112 of the Clean Air Act.

**#017 [25 Pa. Code § 121.9]****Circumvention.**

No person may permit the use of a device, stack height which exceeds good engineering practice stack height, dispersion technique or other technique which, without resulting in reduction of the total amount of air contaminants emitted, conceals or dilutes an emission of air contaminants which would otherwise be in violation of 25 Pa. Code Article III, except that with prior approval of the Department, the device or technique may be used for control of malodors.

**#018 [25 Pa. Code §§ 127.402(d) & 127.442]****Reporting Requirements.**

(a) The permittee shall comply with the applicable reporting requirements of the Clean Air Act, the regulations thereunder, the Air Pollution Control Act and 25 Pa. Code Article III including Chapters 127, 135 and 139.

(b) The permittee shall submit reports to the Department containing information the Department may prescribe relative to the operation and maintenance of any air contamination source.

(c) Reports, test data, monitoring data, notifications and requests for renewal of the permit shall be submitted to the:

Regional Air Program Manager  
PA Department of Environmental Protection  
(At the address given in the permit transmittal letter, or otherwise notified)

(d) Any records or information including applications, forms, or reports submitted pursuant to this permit condition shall contain a certification by a responsible official as to truth, accuracy and completeness. The certifications submitted under this permit shall require a responsible official of the facility to certify that based on information and belief formed after reasonable inquiry, the statements and information in the documents are true, accurate and complete.

(e) Any records, reports or information submitted to the Department shall be available to the public except for such

**SECTION B. General State Only Requirements**

records, reports or information which meet the confidentiality requirements of § 4013.2 of the Air Pollution Control Act and §§ 112(d) and 114(c) of the Clean Air Act. The permittee may not request a claim of confidentiality for any emissions data generated for the facility.

**#019 [25 Pa. Code §§ 127.441(c) & 135.5]****Sampling, Testing and Monitoring Procedures.**

(a) The permittee shall comply with the monitoring, recordkeeping or reporting requirements of 25 Pa. Code Chapter 139 and the other applicable requirements of 25 Pa. Code Article III and additional requirements related to monitoring, reporting and recordkeeping required by the Clean Air Act and the regulations thereunder including the Compliance Assurance Monitoring requirements of 40 CFR Part 64, where applicable.

(b) Unless alternative methodology is required by the Clean Air Act and regulations adopted thereunder, sampling, testing and monitoring required by or used by the permittee to demonstrate compliance with any applicable regulation or permit condition shall be conducted in accordance with the requirements of 25 Pa. Code Chapter 139.

**#020 [25 Pa. Code §§ 127.441(c) and 135.5]****Recordkeeping.**

(a) The permittee shall maintain and make available, upon request by the Department, the following records of monitored information:

- (1) The date, place (as defined in the permit) and time of sampling or measurements.
- (2) The dates the analyses were performed.
- (3) The company or entity that performed the analyses.
- (4) The analytical techniques or methods used.
- (5) The results of the analyses.
- (6) The operating conditions as existing at the time of sampling or measurement.

(b) The permittee shall retain records of any required monitoring data and supporting information for at least five (5) years from the date of the monitoring, sample, measurement, report or application. Supporting information includes the calibration data and maintenance records and original strip-chart recordings for continuous monitoring instrumentation, and copies of reports required by the permit.

(c) The permittee shall maintain and make available to the Department upon request, records including computerized records that may be necessary to comply with the reporting, recordkeeping and emission statement requirements in 25 Pa. Code Chapter 135 (relating to reporting of sources). In accordance with 25 Pa. Code Chapter 135, § 135.5, such records may include records of production, fuel usage, maintenance of production or pollution control equipment or other information determined by the Department to be necessary for identification and quantification of potential and actual air contaminant emissions.

**#021 [25 Pa. Code § 127.441(a)]****Property Rights.**

This permit does not convey any property rights of any sort, or any exclusive privileges.

**#022 [25 Pa. Code § 127.447]****Alternative Operating Scenarios.**

The permittee is authorized to make changes at the facility to implement alternative operating scenarios identified in this permit in accordance with 25 Pa. Code § 127.447.

**SECTION B. General State Only Requirements****#023 [25 Pa. Code §135.3]****Reporting**

(a) If the facility is a Synthetic Minor Facility, the permittee shall submit by March 1 of each year an annual emissions report for the preceding calendar year. The report shall include information for all active previously reported sources, new sources which were first operated during the preceding calendar year, and sources modified during the same period which were not previously reported. All air emissions from the facility should be estimated and reported.

(b) A source owner or operator of a Synthetic Minor Facility may request an extension of time from the Department for the filing of an annual emissions report, and the Department may grant the extension for reasonable cause.

**#024 [25 Pa. Code §135.4]****Report Format**

If applicable, the emissions reports shall contain sufficient information to enable the Department to complete its emission inventory. Emissions reports shall be made by the source owner or operator in a format specified by the Department.

**SECTION C. Site Level Requirements****I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §123.1]****Prohibition of certain fugitive emissions**

The permittee shall not allow the emission into the outdoor atmosphere of a fugitive air contaminant from a source other than the following:

- (1) Construction or demolition of buildings or structures.
- (2) Grading, paving and maintenance of roads and streets.
- (3) Use of roads and streets. Emissions from material in or on trucks, railroad cars and other vehicular equipment are not considered as emissions from use of roads and streets.
- (4) Clearing of land.
- (5) Stockpiling of materials.
- (6) Open burning operations.
- (7) Blasting in open pit mines. Emissions from drilling are not considered as emissions from blasting.
- (8) Coke oven batteries, provided the fugitive air contaminants emitted from any coke oven battery comply with the standards for visible fugitive emissions in §§ 123.44 and 129.15 (relating to limitations of visible fugitive air contaminants from operation of any coke oven battery; and coke pushing operations).
- (9) Sources and classes of sources other than those identified in paragraphs (1)—(8), for which the operator has obtained a determination from the Department that fugitive emissions from the source, after appropriate control, meet the following requirements:
  - (i) The emissions are of minor significance with respect to causing air pollution.
  - (ii) The emissions are not preventing or interfering with the attainment or maintenance of an ambient air quality standard.

**# 002 [25 Pa. Code §123.2]****Fugitive particulate matter**

The permittee shall not allow the emission of fugitive particulate matter into the outdoor atmosphere from a source specified in Condition #001 of Section C if the emissions are visible at the point the emissions pass outside the permittee's property.

**# 003 [25 Pa. Code §123.31]****Limitations**

The permittee shall not allow the emission into the outdoor atmosphere of any malodorous air contaminants from any source in such a manner that the malodors are detectable outside the permittee's property.

**# 004 [25 Pa. Code §123.41]****Limitations**

The permittee shall not allow the emission into the outdoor atmosphere of visible air contaminants in such a manner that the opacity of the emission is either of the following:

- (1) Equal to or greater than 20% for a period or periods aggregating more than three minutes in any one hour.
- (2) Equal to or greater than 60% at any time.

**# 005 [25 Pa. Code §123.42]****Exceptions**

The emission limitations of Condition #004 of Section C shall not apply when:

**SECTION C. Site Level Requirements**

- (1) When the presence of uncombined water is the only reason for failure of the emission to meet the limitations.
- (2) When the emission results from the operation of equipment used solely to train and test persons in observing the opacity of visible emissions.
- (3) When the emission results from sources specified in § 123.1 (a)(1)—(9) (relating to prohibition of certain fugitive emissions).
- (4) When arising from the production of agricultural commodities in their unmanufactured state on the premises of the farm operation.

**II. TESTING REQUIREMENTS.****# 006 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The Department reserves the right to require exhaust stack testing of the sources referenced in this plan approval to measure emissions for purposes including verification of plan approval condition compliance and estimation of annual air emissions.

**# 007 [25 Pa. Code §139.1]****Sampling facilities.**

Upon the request of the Department, the permittee shall provide adequate sampling ports, safe sampling platforms and adequate utilities for the performance by the Department of tests on such source. In the request, the Department will set forth the time period in which the facilities shall be provided as well as the specifications for such facilities.

**III. MONITORING REQUIREMENTS.****# 008 [25 Pa. Code §123.43]****Measuring techniques**

Visible emissions may be measured using either of the following:

- (a) A device approved by the Department and maintained to provide accurate opacity measurements (e.g. Continuous Opacity Monitor).
- (b) Observers trained and certified in EPA Reference Method 9 to measure plume opacity with the naked eye; or with the aid of any device(s) approved by the Department.

**# 009 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall conduct a monthly inspection around the plant periphery during daylight hours when the plant is in production to detect visible emissions, fugitive visible emissions, and malodorous air contaminants. Monthly inspections are necessary to determine:

- (a) The presence of visible emissions as stated in Section C. Visible emissions may be measured according to the methods specified in Section C, Monitoring. Alternately, plant personnel who observe visible emissions may report the incident of visible emissions to the Department within two (2) hours of the incident and make arrangements for a certified observer to measure the visible emissions.
- (b) The presence of fugitive visible emissions beyond the plant property boundaries, as stated in Section C.
- (c) The presence of malodorous air contaminants beyond the plant property boundaries, as stated in Section C.

**IV. RECORDKEEPING REQUIREMENTS.****# 010 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall, monthly, unless another period is specified, record the quantities of all fuel usage, material

**SECTION C. Site Level Requirements**

throughputs, operating hours, and all VOC and HAP emissions. The list of VOC and HAP emissions shall be broken down on a source by source basis.

Additionally, the permittee shall keep appropriate records of all monitoring and testing requirements on a monthly basis, if any.

**# 011 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) The permittee shall maintain records of the monthly inspections referenced in Section C. The records shall include, at a minimum, the following information:

(1) The name of the company representative monitoring each inspection.

(2) The date and time of each inspection.

(3) The wind direction during each inspection.

(4) A description of the visible emissions, fugitive particulate matter emissions (beyond the plant property boundaries), and malodorous air contaminants (beyond the plant property boundaries) observed, if any, and actions taken to mitigate them. If no visible emissions or fugitive particulate matter emissions or malodors are observed, then document that none were observed.

(b) The permittee shall retain these records for a minimum of five (5) years. The records shall be made available to the Department upon its request.

**# 012 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

Unless otherwise specified, all records required shall be maintained on site for the most recent 5-year period, and make them available to the Department upon request.

**# 013 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

Emissions for VOC and HAPs shall be calculated and recorded each month and on a 12-month rolling total. These records shall be maintained on-site for the most recent five-year period and made available to Department representatives upon request.

**# 014 [25 Pa. Code §135.5]****Recordkeeping**

The permittee shall maintain and make available upon request by the Department, any records as may be necessary to demonstrate compliance with 25 Pa. Code § 135.3 and 135.21 (relating to reporting; and emission statements). These records may include records of production, fuel usage, maintenance of production or pollution control equipment or other information determined by the Department to be necessary for identification and quantification of potential and actual air contaminant emissions. If direct recordkeeping is not possible or practical, sufficient records shall be kept to provide the needed information by indirect means.

**V. REPORTING REQUIREMENTS.****# 015 [25 Pa. Code §127.442]****Reporting requirements.**

The permittee shall report malfunctions which occur at the facility to the Department. A malfunction is any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner that may result in an increase in air emissions above minor significance. Failures that are caused in part by poor maintenance or careless operation are not malfunctions. Malfunctions shall be reported as follows:

(a) Malfunctions which pose an imminent danger to public health, safety, welfare and the environment, shall be immediately reported to the Department by telephone. The telephone report of such malfunctions shall occur no later than two hours after discovery of the incident. Telephone reports can be made to the Air Quality Program at (717) 705-4702

**SECTION C. Site Level Requirements**

during normal business hours, or to the Department's Emergency Hotline 866-825-0208 at any time. The Emergency Hotline phone number is changed/updated periodically. The current Emergency Hotline phone number can be found at <https://www.dep.pa.gov/About/Regional/SouthcentralRegion/Pages/default.aspx>.

(1) The notice shall describe the:

- (i) name and location of the facility;
- (ii) nature and cause of the malfunction or breakdown;
- (iii) time when the malfunction or breakdown was first observed;
- (iv) expected duration of excess emissions; and
- (v) estimated rate of emissions.

(2) The owner or operator shall notify the Department immediately when corrective measures have been accomplished.

(3) The permittee shall submit a written report of instances of such malfunctions to the department, in writing, within three (3) days of the of the telephone report.

(4) The owner or operator shall submit reports on the operation and maintenance of the source to the Regional Air Program Manager at such intervals and in such form and detail as may be required by the Department. Information required in the reports may include, but is not limited to, process weight rates, firing rates, hours of operation, and maintenance schedules.

(b) Unless otherwise required by this permit, any other malfunction that is not subject to the reporting requirements of (a) above, shall be reported to the Department, in writing, within five (5) days of discovery of the malfunction.

(c) Unless otherwise approved by DEP, all malfunctions shall be reported through the Department's Greenport PUP system available through:

<https://greenport.pa.gov/ePermitPublicAccess/PublicSubmission/Home>

**# 016 [25 Pa. Code §135.3]**

**Reporting**

Unless otherwise approved in writing by DEP, an annual report containing monthly records of fuel usage and operating hours for the sources listed in this operating permit shall be submitted to the Air Quality District Supervisor. The report for January 1 through December 31 is due no later than March 1 of the following year for each operating year authorized by the operating permit or its renewal.

**VI. WORK PRACTICE REQUIREMENTS.**

**# 017 [25 Pa. Code §123.1]**

**Prohibition of certain fugitive emissions**

The permittee shall take all reasonable actions to prevent particulate matter from becoming airborne from any source specified in Condition #001(a)-(g) of Section C. These actions shall include, but not be limited to, the following:

(a) Use, where possible, of water or chemicals for control of dust in the demolition of buildings or structures, construction operations, the grading of roads, or the clearing of land.

(b) Application of asphalt, oil, water, or suitable chemicals on dirt roads, material stockpiles and other surfaces which may give rise to airborne dusts.

(c) Paving and maintenance of roadways.

(d) Prompt removal of earth or other material from paved streets onto which earth or other material has been transported by trucking or earth moving equipment, erosion by water, or other means.

**# 018 [25 Pa. Code §127.444]**

**Compliance requirements.**

The permittee shall operate and maintain all sources and any air cleaning devices identified in this operating permit in accordance with the manufacturer's recommendations/specifications, as well as in a manner consistent with good



**SECTION C. Site Level Requirements**

operating practices.

**# 019 [25 Pa. Code §129.77.]****Control of emissions from the use or application of adhesives, sealants, primers and solvents.**

The facility is not subject to 25 Pa. Code Section 129.77 for the application of the following compounds or products:

- (1) Adhesives and sealants that contain less than 20 grams of VOC per liter of adhesive or sealant, less water and less exempt compounds, as applied.
- (2) Adhesives, sealants, adhesive primers or sealant primers that are sold or supplied by the manufacturer or supplier in containers with a net volume of 16 fluid ounces or less, or a net weight of 1 pound or less, except plastic cement welding adhesives and contact adhesives.
- (3) Contact adhesives that are sold or supplied by the manufacturer or supplier in containers with a net volume of 1 gallon or less.

**VII. ADDITIONAL REQUIREMENTS.****# 020 [25 Pa. Code §129.14]****Open burning operations**

(a) No person shall conduct open burning of materials in such a manner that:

- (1) The emissions are visible, at any time, at the point such emissions pass outside the property of the person on whose land the open burning is being conducted.
- (2) Malodorous air contaminants from the open burning are detectable outside the property of the person on whose land the open burning is being conducted.
- (3) The emissions interfere with the reasonable enjoyment of life and property.
- (4) The emissions cause damage to vegetation or property.
- (5) The emissions are or may be deleterious to human or animal health.

(b) Exceptions. The requirements of Subsection (a) do not apply where the open burning operations result from:

- (1) A fire set to prevent or abate a fire hazard, when approved by the Department and set by or under the supervision of a public official.
- (2) Any fire set for the purpose of instructing personnel in fire fighting, when approved by the Department.
- (3) A fire set for the prevention and control of disease or pests, when approved by the Department.
- (4) A fire set solely for recreational or ceremonial purposes.
- (5) A fire set solely for cooking food.

(c) This permit does not constitute authorization to burn solid waste pursuant to section 610 (3) of the Solid Waste Management Act 35 P.S. Section 6018.610 (3), or any other provision of the Solid Waste Management Act.

**VIII. COMPLIANCE CERTIFICATION.**

No additional compliance certifications exist except as provided in other sections of this permit including Section B (relating to State Only General Requirements).

**IX. COMPLIANCE SCHEDULE.**



**SECTION C. Site Level Requirements**

No compliance milestones exist.


**SECTION D. Source Level Requirements**

Source ID: 031

Source Name: YORK SHIPLEY BOILER, 2012, 25.2 MMBTU/HR

Source Capacity/Throughput: 25.200 MCF/HR NATURAL GAS

Conditions for this source occur in the following groups: 01

**I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §123.22]****Combustion units**

(i) Except as specified in subparagraphs (ii) and (iii), a person may not offer for sale, deliver for use, exchange in trade or permit the use of commercial fuel oil in nonair basin areas if the commercial fuel oil contains sulfur in excess of the applicable maximum allowable sulfur content set forth in the following tables:

Maximum Allowable % Sulfur by Weight through August 31, 2020, based on Grades Commercial Fuel Oil:

No. 2 and Lighter (viscosity less than or equal to 5.820cSt): 500ppm (0.05%)

Maximum Allowable Sulfur Content Beginning September 1, 2020, Expressed as Parts per Million (ppm) by Weight or Percentage by Weight, based on Grades Commercial Fuel Oil (Consistent with ASTM D396):

No. 2 and lighter oil: 15 ppm (0.0015%)

(ii) Commercial fuel oil that was stored in this Commonwealth by the ultimate consumer prior to September 1, 2020, which met the applicable maximum allowable sulfur content for commercial fuel oil through August 31, 2020, in subparagraph (i) at the time it was stored, may be used by the ultimate consumer in this Commonwealth on and after September 1, 2020.

**# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this condition is derived from GP1-01-03027C, (PM, NO<sub>x</sub>, and CO)]

a. Source 031 may not emit particulate matter in excess of 0.4 pound per million Btu of heat input as specified in 25 Pa. Code §123.11 (relating to combustion units).

b. The permittee shall install and maintain the necessary meter(s) to determine and to record amount of fuel usage.

c. Source 031 may not emit greater than the following amounts of the following pollutants:

- i. 30 ppmdv NO<sub>x</sub> at 3% O<sub>2</sub> when firing gas;
- ii. 90 ppmdv NO<sub>x</sub> at 3% O<sub>2</sub> when firing No. 2 fuel oil; and
- iii. 300 ppmdv CO at 3% O<sub>2</sub>.

d. Source 031 shall be fired only on natural gas or No. 2 commercial fuel oil to which there has been no reclaimed or waste oil or other waste materials added.



## **SECTION D. Source Level Requirements**

### **II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

### **III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

### **IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

### **V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

### **VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

### **VII. ADDITIONAL REQUIREMENTS.**


No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**SECTION D. Source Level Requirements**

Source ID: 101

Source Name: OFFSET NONHEATSET LITHOGRAPHIC PRESSES (2)

Source Capacity/Throughput:

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VII. ADDITIONAL REQUIREMENTS.****# 001 [25 Pa. Code §129.67b]****Control of VOC emissions from offset lithographic printing presses and letterpress printing presses.**

(a) Applicability.

(1) Except as specified in paragraph (3), this section applies to the owner and operator of an offset lithographic printing press or a letterpress printing press, or both, if the press meets one or a combination of the following:

(i) [NA – NONE OF THE LITHO PRESSES AT THIS FACILITY HAVE PTE BEFORE CONTROL OF 25 TPY OR GREATER]

(ii) [NA – NO LETTERPRESS]

(iii) Offset lithographic printing. One or more offset lithographic printing presses if the total actual VOC emissions from all inks (including varnishes), coatings, adhesives and fountain solutions combined from all offset lithographic printing presses and all VOC emissions from related cleaning activities at the facility are equal to or greater than 450 pounds (204.1 kilograms) per month or 2.7 tons (2,455 kilograms) per 12-month rolling period, before consideration of add-on controls.

**SECTION D. Source Level Requirements**

(iv) [NA – NO LETTERPRESS]

(v) [NA – VOC NOT < 450 LB/MO; 2.7 TON/YR]

(2) The owner or operator of an offset lithographic printing press subject to paragraph (1) may use the VOC emission retention factors and capture efficiency factors specified in subsection (l) to determine the amount of potential or actual VOC emissions that is available for capture and control from the inks (including varnishes), fountain solutions and cleaning solutions used on the offset lithographic printing press.

(3) VOCs from adhesives used at a facility that are not used or applied on or with an offset lithographic printing press or a letterpress printing press are not subject to this section and may be regulated under § 129.77 or Chapter 130, Subchapter D (relating to control of emissions from the use or application of adhesives, sealants, primers and solvents; and adhesives, sealants, primers and solvents).

(b) [NA – NO EXISTING RACT PERMIT]

(c) Emission limits for cleaning solutions and fountain solutions used in or on printing presses subject to this section.

(1) Cleaning solutions. Beginning January 1, 2015, a person subject to subsection (a)(1)(i), (ii), (iii) or (iv) may not cause or permit the emission into the outdoor atmosphere of VOCs from cleaning solutions used in or on an offset lithographic printing press or a letterpress printing press unless the following conditions are met:

(i) The cleaning solutions used must meet one or both of the following VOC limits:

(A) A VOC composite partial vapor pressure less than 10 millimeters of mercury at 68°F (20°C).

(B) A VOC content less than 70% by weight.

(ii) The use of one or more cleaning solutions with a higher VOC composite partial vapor pressure or higher VOC content, or both, than is listed in subparagraph (i) is limited to 110 gallons per year, combined, of all cleaning solutions that exceed the limits in subparagraph (i).

(2) Fountain solutions. Except as specified in paragraph (3), beginning January 1, 2015, a person subject to subsection (a)(1)(i), (iii) or (iv) may not cause or permit the emission into the outdoor atmosphere of VOCs from a fountain solution used in an offset lithographic printing press unless the fountain solution meets one or more of the following VOC limits.

(i) [NA – UNITS ARE NON-HEATSET, AND ARE SHEETFED (NOT WEB)]

(ii) For each sheet-fed offset lithographic printing press, the press-ready (as applied) fountain solution must meet one of the following limits:

(A) A VOC content of 5% or less by weight.

(B) A VOC content of 8.5% or less by weight if the fountain solution is refrigerated below 60°F (15.5°C).

(C) A VOC content of 5% or less by weight and no alcohol in the fountain solution.

(D) Another method that achieves a level of control of VOC emissions from the press-ready (as applied) fountain solution equal to or better than the methods listed in clauses (A)–(C).

(iii) [NA – UNITS ARE SHEETFED (NOT WEB)]

(3) [NA – EXCEPTIONS DO NOT APPLY]

(d) [NA – UNITS ARE NON-HEATSET, AND ARE SHEETFED (NOT WEB)]

**SECTION D. Source Level Requirements**

(e) Compliance and monitoring requirements.

(1) [NA – UNITS ARE NON-HEATSET, AND ARE SHEETFED (NOT WEB)]

(2) Fountain solution. The owner or operator of an offset lithographic printing press subject to this section that is required to meet one of the fountain solution VOC limits of subsection (c)(2) shall demonstrate compliance by using one or more of the following methods:

(i) Analysis of a sample of the press-ready (as applied) fountain solution for VOC content using EPA Reference Method 24, Determination of Volatile Matter Content, Water Content, Density, Volume Solids, and Weight Solids of Surface Coatings, codified in 40 CFR Part 60, Appendix A, including updates and revisions.

(ii) Maintenance onsite of MSDS, CPDS or other data provided by the manufacturer of the fountain solution that indicates the VOC content of the press-ready (as applied) fountain solution.

(iii) Calculation of the VOC content of the press-ready (as applied) fountain solution that combines the EPA Reference Method 24 analytical VOC content data for each of the concentrated components or additives used to prepare the press-ready fountain solution.

(A) The VOC content data for each of the concentrated components or additives shall be combined in the proportions in which the concentrated components or additives are mixed to make the batch of press-ready (as applied) fountain solution.

(B) The VOC content shall be calculated one time for each recipe of press-ready (as applied) fountain solution. The recipe name, VOC content for each concentrated component or additive and fountain solution mix ratio shall be recorded in a logbook.

(C) The EPA Reference Method 24 analysis of the concentrated components or additives used to prepare the press-ready (as applied) fountain solution may be performed by the supplier of the components or additives and these results provided to the owner or operator of the affected press.

(iv) Measurement of the recirculating reservoir temperature of a refrigerated press-ready (as applied) fountain solution specified in subsection (c)(2)(i)(B) or (ii)(B) with a thermometer or other temperature detection device capable of reading to 0.5°F (0.28°C) to ensure that the temperature of the refrigerated fountain solution containing alcohol is maintained below 60°F (15.5°C) at all times. The temperature on the thermometer or other temperature detection device shall be continuously monitored. The temperature reading shall be recorded at least once per operating day to verify that the refrigeration system is operating properly.

(v) Monitoring of the press-ready (as applied) fountain solution for alcohol concentration or VOC content with one or more of the following instruments:

(A) A refractometer or a hydrometer to monitor the fountain solution alcohol concentration. The instrument must:

(I) Be corrected for temperature one time per 8-hour shift.

(II) Have a visual, analog or digital readout with an accuracy of 0.5%.

(III) Be calibrated with a standard solution for the type of alcohol used in the fountain solution.

(B) A conductivity meter to determine the fountain solution VOC content. Reading for the fountain solution must be referenced to the conductivity of the incoming water.

(vi) Another method to determine compliance with the VOC content limits for fountain solutions in subsection (c)(2) if the following requirements are met:

(A) The facility owner or operator submits a request, in writing, to the appropriate regional office of the Department for approval of the alternative method.

**SECTION D. Source Level Requirements**

(B) The request demonstrates that the alternative method provides results that accurately determine the fountain solution VOC content.

(C) The Department provides prior written approval of the alternative method.

(3) Cleaning solution. The owner or operator of an offset lithographic printing press or a letterpress printing press subject to this section shall demonstrate compliance with the VOC content limit or VOC composite partial vapor pressure limit for cleaning solutions in subsection (c)(1) by one or more of the following methods:

(i) Analysis of a sample of press-ready (as applied) cleaning solution for VOC content using EPA Reference Method 24.

(ii) Use of the equation in subsection (j) to calculate the composite partial vapor pressure of the press-ready (as applied) cleaning solution.

(iii) Use of the methods in subsection (k) to determine the VOC composite partial vapor pressure of a single concentrated component or additive used to prepare the press-ready (as applied) cleaning solution.

(iv) Maintenance onsite of MSDS, CPDS or other data provided by the manufacturer of the press-ready (as applied) cleaning solution that indicates the VOC content or the VOC composite partial vapor pressure, or both, of the press-ready (as applied) cleaning solution.

(v) Calculation of the VOC content or the VOC composite partial vapor pressure, or both, of the press-ready (as applied) cleaning solution that combines the EPA Reference Method 24 analytical VOC content data or analytical VOC composite partial vapor pressure data for each of the concentrated components or additives used to prepare the press-ready (as applied) cleaning solution.

(A) The VOC content data or VOC composite partial vapor pressure data for each of the concentrated components or additives shall be combined in the proportions in which the concentrated components or additives are mixed to make the batch of press-ready (as applied) cleaning solution.

(B) The VOC content or VOC composite partial vapor pressure shall be calculated one time for each recipe of press-ready (as applied) cleaning solution. The recipe name, VOC content or VOC composite partial vapor pressure for each concentrated component or additive and cleaning solution mix ratio shall be recorded in a log book.

(C) The EPA Reference Method 24 analysis of the concentrated components or additives used to prepare the press-ready (as applied) cleaning solution may be performed or the VOC composite partial vapor pressure data may be determined by the supplier of the components or additives and these results provided to the owner or operator of the affected press.

(vi) Another method to determine compliance with the VOC content limits for cleaning solutions in subsection (c)(1) if the following requirements are met:

(A) The facility owner or operator submits a request, in writing, to the appropriate regional office of the Department for approval of the alternative method.

(B) The request demonstrates that the alternative method provides results that accurately determine the cleaning solution VOC content or VOC composite partial vapor pressure.

(C) The Department provides prior written approval of the alternative method.

(f) Recordkeeping requirements. Beginning January 1, 2015, the owner or operator of a printing press subject to this section shall maintain records sufficient to demonstrate compliance with this section. Records maintained for compliance demonstrations may include purchase, use, production and other records.

(1) [NA – NO AIR POLLUTION CONTROL DEVICE REQUIRED]



**SECTION D. Source Level Requirements**

(2) An owner or operator subject to subsection (a)(1)(i), (ii), (iii) or (iv) shall maintain records of cleaning solutions and fountain solutions used at the facility, including:

(i) The following parameters for each press ready blanket, roller or other cleaning solution:

(A) The name and identification number for the blanket, roller or other cleaning solution.

(B) The VOC content (weight %) or VOC composite partial vapor pressure of each cleaning solution as applied.

(C) The volume used of each cleaning solution as applied, if the owner or operator is using cleaning solutions which exceed the limits in subsection (c)(1)(i).

(D) Records of cleaning solution monitoring as required under subsection (e)(3).

(ii) The following parameters for each press-ready (as applied) fountain solution:

(A) The VOC content (weight %).

(B) Records of fountain solution monitoring as required under subsection (e)(2).

(3) An owner or operator claiming exemption from a VOC control provision of this section based on potential or actual VOC emissions, as applicable, shall maintain records that demonstrate to the Department that the press or facility is exempt.

(4) The owner or operator may group materials into classes using the highest VOC content in any material in a class to represent that class of material.

(g) Reporting requirements. Beginning January 1, 2015, the owner or operator of an offset lithographic printing press or a letterpress printing press subject to this section shall meet the following reporting requirements:

(1) The records required under subsection (f) shall be maintained onsite for 2 years unless a longer period is required by a plan approval or operating permit issued under Chapter 127 (relating to construction, modification, reactivation and operation of sources). The records shall be submitted to the Department in an acceptable format upon receipt of a written request.

(2) [NA – NO AIR POLLUTION CONTROL DEVICE REQUIRED]

(h) Sampling and testing.

(1) Sampling and testing shall be performed as follows:

(i) Sampling of an ink, varnish, coating, fountain solution or cleaning solution and testing for the VOC content of the ink, varnish, coating, fountain solution or cleaning solution shall be performed in accordance with the procedures and test methods specified in Chapter 139.

(ii) [NA – NO AIR POLLUTION CONTROL DEVICE REQUIRED]

(2) [NA – NO AIR POLLUTION CONTROL DEVICE REQUIRED]

(3) Other test methods demonstrated to provide results that are acceptable for purposes of determining compliance with this section may be used if prior approval is obtained in writing from the Department and the EPA.

(i) Work practice requirements for cleaning activities.

(1) Except as specified in paragraph (3), beginning January 1, 2015, the owner or operator of an offset lithographic printing press or a letterpress printing press subject to subsection (a)(1)(i), (ii), (iii) or (iv) shall comply with the following work practices for cleaning activities at the facility:

**SECTION D. Source Level Requirements**

- (i) Store all VOC-containing cleaning solutions, waste cleaning solutions and used shop towels in closed containers.
  - (ii) Ensure that mixing vessels and storage containers used for VOC-containing cleaning solutions, waste cleaning solutions and used shop towels are kept closed at all times, except when depositing or removing these solutions or shop towels.
  - (iii) Minimize spills of VOC-containing cleaning solutions and waste cleaning solutions and clean up spills immediately.
  - (iv) Convey VOC-containing cleaning solutions, waste cleaning solutions and used shop towels from one location to another in closed containers or pipes.
- (2) The requirements in paragraph (1) apply to the following activities:
- (i) Cleaning of a press, including blanket washing, roller washing, plate cleaners, metering roller cleaners, impression cylinder cleaners and rubber rejuvenators.
  - (ii) Cleaning of press parts, including press parts that have been removed from the press for cleaning.
  - (iii) Cleaning of ink, coating or adhesive from areas around a press.
- (3) The requirements in paragraph (1) do not apply to the following activities:
- (i) Cleaning electronic components of a press.
  - (ii) Cleaning in pre-press (for example, platemaking) operations.
  - (iii) Cleaning in post-press (for example, binding) operations.
  - (iv) Using janitorial supplies (for example, detergents or floor cleaners) for general cleaning around a press.
  - (v) The use of parts washers or cold cleaners at an offset lithographic printing or a letterpress printing facility. The use of parts washers and cold cleaners is regulated under § 129.63 (relating to degreasing operations).
- (j) Composite partial vapor pressure. The composite partial vapor pressure of organic compounds in cleaning solutions shall be determined by one of the following procedures:
- (1) Quantifying the amount of each compound in the blend using gas chromatographic analysis, using an appropriate and current ASTM test method with prior written approval by the Department.
  - (2) Calculating the composite partial vapor pressure using the following equation: [SEE REGULATION FOR EQUATION]
- (k) Determination of vapor pressure of single organic compounds in cleaning solutions. The vapor pressure of each single component compound shall be determined from one or more of the following: [SEE REGULATION FOR REFERENCES]
- (l) VOC retention factors and capture efficiency factors. As specified in subsection (a)(2), if:
- (1) A portion of the VOCs contained in the ink or cleaning solution, or both, is retained in the printed web substrate or in the shop towels used for cleaning, the following VOC emission retention factors shall be used, as applicable:
    - (i) A 20% VOC emission retention factor for a petroleum ink oil-based heatset ink printed on an absorptive substrate, meaning 80% of the petroleum ink oil content is emitted as VOC during the printing process and is available for capture and control by an add-on air pollution control device. The petroleum ink oil content of a heatset ink may be determined from formulation data included on a CPDS or MSDS.
    - (ii) A 95% VOC emission retention factor for a petroleum ink oil-based non-heatset web or non-heatset sheet-fed ink, meaning 5% of the petroleum ink oil content is emitted as VOC during the printing process and is available for capture and

**SECTION D. Source Level Requirements**

control by an add-on air pollution control device. The petroleum ink oil content of a non-heatset web or non-heatset sheet-fed ink may be determined from formulation data included on a CPDS or MSDS.

(iii) A 100% VOC emission retention factor for vegetable ink oil-based heatset and non-heatset inks.

(iv) A 50% VOC emission retention factor for low VOC composite vapor pressure cleaning solutions in shop towels if both of the following conditions are met:

(A) The VOC composite vapor pressure of the cleaning solution is less than 10mm Hg at 20°C (68°F).

(B) The cleaning solutions and used shop towels are kept in closed containers.

(2) A portion of the VOCs contained in one or more of the ink, fountain solution or automatic blanket wash materials is captured in the press dryer for control by the add-on air pollution control device, the following capture efficiency factors shall be used, as applicable:

(i) A 100% VOC emission capture efficiency for volatilized ink oils for oil-based heatset paste inks and varnishes as specified in paragraph (1) if both of the following conditions are met:

(A) The press dryer is operating at negative pressure relative to the surrounding pressroom.

(B) The air flow is into the press dryer.

(ii) A 70% VOC emission capture efficiency for a fountain solution that contains an alcohol substitute.


(iii) A 40% VOC emission capture efficiency for an automatic blanket wash if the VOC composite vapor pressure of the cleaning solution is less than 10mm Hg at 20°C (68°F).

**SECTION D. Source Level Requirements**

Source ID: 102

Source Name: FLEXOGRAPHIC PRESSES (9)

Source Capacity/Throughput:

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VII. ADDITIONAL REQUIREMENTS.****# 001 [25 Pa. Code §129.67a]****Control of VOC emissions from flexible packaging printing presses.**

§ 129.67a. Control of VOC emissions from flexible packaging printing presses.

(a) Applicability.

(1) Except as specified in paragraph (3) or (4), this section applies to the owner and operator of a flexible packaging printing press if one or more of the following apply:

(i) [NA – NONE OF THE FLEX PRESSES HAVE 25 TPY VOC PTE]

(ii) Actual VOC emissions at or above threshold. The total actual VOC emissions from all inks, coatings and adhesives combined from all flexible packaging printing presses and all VOC emissions from related cleaning activities at the facility are equal to or greater than 450 pounds (204.1 kilograms) per month or 2.7 tons (2,455 kilograms) per 12-month rolling period, before consideration of add-on controls.

**SECTION D. Source Level Requirements**

(iii) [NA – FLEX PRESSES EACH HAVE >2.7 TPY VOC ACTUAL]

(2) [NA – CONTROL DEVICE NOT REQUIRED]

(3) VOCs from adhesives used at a facility that are not used or applied on or with a flexible packaging printing press are not subject to this section and may be regulated under § 129.52b, § 129.77 or Chapter 130, Subchapter D (relating to control of VOC emissions from paper, film and foil surface coating processes; control of emissions from the use or application of adhesives, sealants, primers and solvents; and adhesives, sealants, primers and solvents).

(4) Surface coating of flexible packaging substrates that is not done with a flexible packaging printing press is regulated under § 129.52b.

(b) [NA – NO EXISTING RACT PERMIT]

(c) – (d) [NA – NOT SUBJECT TO (a)(1)(i)]

(e) Recordkeeping and reporting requirements. Beginning January 1, 2015, the owner or operator of a flexible packaging printing press subject to this section shall maintain records sufficient to demonstrate compliance with the requirements of this section. Records maintained for compliance demonstrations may include purchase, use, production and other records.

(1) – (2) [NA – NOT SUBJECT TO (a)(1)(i)]

(3) An owner or operator claiming exemption from a VOC control provision of this section based on potential or actual VOC emissions, as applicable, shall maintain records that demonstrate to the Department that the press or facility is exempt.

(4) The owner or operator may group materials into classes using the highest VOC content in any material in a class to represent that class of material.

(5) The records required under paragraphs (1)—(4) shall be maintained for 2 years, unless a longer period is required by a plan approval or operating permit issued under Chapter 127 (relating to construction, modification, reactivation and operation of sources). The records shall be submitted to the Department in an acceptable format upon receipt of a written request.

(6) [NA – NOT SUBJECT TO (a)(1)(i)]

(f) Sampling and testing.

(1) Sampling and testing shall be performed as follows:

(i) Sampling of an ink or coating and testing for the VOC content of the ink or coating shall be performed in accordance with the procedures and test methods specified in Chapter 139.

(ii) [NA – CONTROL DEVICE NOT REQUIRED]

(2) [NA – CONTROL DEVICE NOT REQUIRED]

(3) Other test methods demonstrated to provide results that are acceptable for purposes of determining compliance with this section may be used if prior approval is obtained in writing from the Department and the EPA.

(g) Work practice requirements for cleaning activities.

(1) Except as specified in paragraph (3), beginning January 1, 2015, the owner or operator of a flexible packaging printing press subject to subsection (a)(1)(i), (1)(ii) or (2) shall comply with the following work practices for cleaning activities at the facility:

(i) Store all VOC-containing cleaning solutions, waste cleaning solutions and used shop towels in closed containers.

**SECTION D. Source Level Requirements**

(ii) Ensure that mixing vessels and storage containers used for VOC-containing cleaning solutions, waste cleaning solutions and used shop towels are kept closed at all times, except when depositing or removing these solutions or shop towels.

(iii) Minimize spills of VOC-containing cleaning solutions and waste cleaning solutions and clean up spills immediately.

(iv) Convey VOC-containing cleaning solutions, waste cleaning solutions and used shop towels from one location to another in closed containers or pipes.

(2) The requirements in paragraph (1) apply to the following activities:

(i) Cleaning of ink, coating or adhesive from a press.

(ii) Cleaning of ink, coating or adhesive from press parts, including press parts that have been removed from the press for cleaning.

(iii) Cleaning of ink, coating or adhesive from areas around a press.

(3) The requirements in paragraph (1) do not apply to the following activities:

(i) Cleaning electronic components of a press.

(ii) Cleaning in pre-press (for example, platemaking) operations.

(iii) Cleaning in post-press (for example, binding) operations.

(iv) Using janitorial supplies (for example, detergents or floor cleaners) for general cleaning around a press.

(v) The use of parts washers or cold cleaners at a flexible packaging printing facility. The use of parts washers and cold cleaners is regulated under § 129.63 (relating to degreasing operations).

**# 002 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.820]**

**Subpart KK--National Emission Standards for the Printing and Publishing Industry Applicability.**

§63.820 Applicability.

(a) The provisions of this subpart apply to:

(3) Each facility for which the owner or operator chooses to commit to and meets the criteria stated in paragraph (a)(2) of this section shall be considered an area source, and is subject only to the provisions of §§63.829(d) and 63.830(b)(1) of this subpart.

§63.829 Recordkeeping requirements.

(d) The owner or operator of each facility which commits to the criteria of §63.820(a)(2) shall maintain records of all required measurements and calculations needed to demonstrate compliance with these criteria, including the mass of all HAP containing materials used and the mass fraction of HAP present in each HAP containing material used, on a monthly basis.

§63.830 Reporting requirements.

(b) Each owner or operator of an affected source subject to this subpart shall submit the reports specified in paragraphs (b)(1) through (b)(6) of this section to the Administrator:

(1) An initial notification required in §63.9(b).

(i) Initial notifications for existing sources shall be submitted no later than one year before the compliance date

**SECTION D. Source Level Requirements**

specified in §63.826(a).

(ii) Initial notifications for new and reconstructed sources shall be submitted as required by §63.9(b).



**SECTION D. Source Level Requirements**

Source ID: 103

Source Name: EMER GEN MACT 4Z, GEN.2(SI RICE),FIRE PP.(CI RICE)

Source Capacity/Throughput:	1.000 MCF/HR	Natural Gas
	5.000 Gal/HR	#2 Oil

Conditions for this source occur in the following groups: 03



**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).



**SECTION D. Source Level Requirements**

Source ID: 104

Source Name: EMER GEN, NSPS 4J, GEN 1 (SI RICE), 2011, 62HP(40KW)

Source Capacity/Throughput: 0.500 MCF/HR NATURAL GAS

Conditions for this source occur in the following groups: 02

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**VII. ADDITIONAL REQUIREMENTS.**


No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements) and/or Section E (Source Group Restrictions).

**SECTION D. Source Level Requirements**

Source ID: 105

Source Name: DEGREASERS

Source Capacity/Throughput:

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**IV. RECORDKEEPING REQUIREMENTS.****# 001 [25 Pa. Code §129.63]****Degreasing operations**

(a) As per Section 129.63(a)(5), the permittee shall maintain the following records for each parts washer /degreaser:

- (i) The name and address of the solvent supplier.
- (ii) The type of solvent including the product or vendor identification number.
- (iii) The vapor pressure of the solvent measured in mm Hg at 20°C (68°F).

(b) An invoice, bill of sale, certificate that corresponds to a number of sales, Material Safety Data Sheet (MSDS), or other appropriate documentation acceptable to the Department may be used to comply with this section, as per Section 129.63(a)(5).

(c) The permittee shall retain these records for a minimum of five (5) years and shall make them available to the Department upon its request.

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VI. WORK PRACTICE REQUIREMENTS.****# 002 [25 Pa. Code §129.63]****Degreasing operations**

As per Section 129.63(a)(1), the immersion cold cleaning machines shall have a freeboard ratio of 0.50 or greater.

[NOTE: As defined at 25 Pa. Code Section 121.1, the freeboard ratio is defined as the distance from the liquid solvent in the idling mode to the top edge of the cleaning machine divided by the smaller dimension (length or width) of the cleaning machine.]

**# 003 [25 Pa. Code §129.63]****Degreasing operations**

**SECTION D. Source Level Requirements**

As per Section (a)(2)(ii), each Source ID 105 machine shall be equipped with one of the following:

- (a) A cover that shall be closed at all times except during cleaning of parts or the addition or removal of solvent.
- (b) A perforated drain with a diameter of not more than six (6) inches, if the machine drains directly into the solvent storage reservoir.

**# 004 [25 Pa. Code §129.63]****Degreasing operations**

As per Section 129.63(a)(3), the permittee shall operate each Source ID 105 machine in accordance with the following procedures:

- (i) Waste solvent shall be collected and stored in closed containers. The closed containers may contain a device that allows pressure relief, but does not allow liquid solvent to drain from the container.
- (ii) Flushing of parts using a flexible hose or other flushing device shall be performed only within the machine. The solvent spray shall be a solid fluid stream, not an atomized or shower spray.
- (iii) Sponges, fabric, wood, leather, paper products and other absorbent materials may not be cleaned in any Source ID 105 machine.
- (iv) Air-agitated solvent baths may not be used.
- (v) Spills during solvent transfer and use of any Source ID 105 machine shall be cleaned up immediately.

**# 005 [25 Pa. Code §129.63]****Degreasing operations**

As per Section 129.63(a)(2)(i):

- (A) Cleaned parts should be drained at least 15 seconds or until dripping ceases, whichever is longer. Parts having cavities or blind holes shall be tipped or rotated while the part is draining. During the draining, tipping or rotating, the parts should be positioned so that solvent drains directly back to the Source ID 104 machine.
- (B) When a pump-agitated solvent bath is used, the agitator should be operated to produce a rolling motion of the solvent with no observable splashing of the solvent against the tank walls or the parts being cleaned.
- (C) Work area fans should be located and positioned so that they do not blow across the opening of the degreaser unit.

**VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**SECTION E. Source Group Restrictions.**

Group Name: 01

Group Description: NSPS Subpart Dc, Combustion Unit, Natural Gas Only

**Sources included in this group**

ID	Name
031	YORK SHIPLEY BOILER, 2012, 25.2 MMBTU/HR

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VII. ADDITIONAL REQUIREMENTS.**

**# 001 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.40c]  
Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units  
Applicability and delegation of authority.**

§ 60.40c Applicability and delegation of authority.

(a) Except as provided in paragraphs (d), (e), (f), and (g) of this section, the affected facility to which this subpart applies is each steam generating unit for which construction, modification, or reconstruction is commenced after June 9, 1989 and that has a maximum design heat input capacity of 29 megawatts (MW) (100 million British thermal units per hour (MMBtu/h)) or less, but greater than or equal to 2.9 MW (10 MMBtu/h).

(b) [NA - NOT SUBJECT TO PM OR SO2 STANDARDS]

(c) [NA - NOT SUBJECT TO PM OR SO2 STANDARDS]

(d) Any temporary change to an existing steam generating unit for the purpose of conducting combustion research is not considered a modification under § 60.14.

(e) [NA - SOURCES NOT ASSOCIATED WITH TURBINES]

(f) [NA - 4A AND 4C NOT APPLICABLE]

**SECTION E. Source Group Restrictions.**

(g) [NA - 4B NOT APPLICABLE]

(h) [NA - J AND Ja NOT APPLICABLE]

(i) [NA - UNIT(S) NOT TEMPORARY]

[72 FR 32759, June 13, 2007, as amended at 74 FR 5090, Jan. 28, 2009; 77 FR 9461, Feb. 16, 2012]

§ 60.42c Standard for sulfur dioxide (SO<sub>2</sub>).

(a) - (j) [NA - UNIT(S) DO NOT BURN COAL OR OIL]

[72 FR 32759, June 13, 2007, as amended at 74 FR 5090, Jan. 28, 2009; 77 FR 9462, Feb. 16, 2012]

§ 60.43c Standard for particulate matter (PM).

(a) - (e) [NA - UNIT(S) DO NOT BURN COAL, OIL OR WOOD]

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009; 77 FR 9462, Feb. 16, 2012]

§ 60.44c Compliance and performance test methods and procedures for sulfur dioxide.

[NA - NOT SUBJECT TO SO<sub>2</sub> STANDARD]

§ 60.45c Compliance and performance test methods and procedures for particulate matter.

[NA - NOT SUBJECT TO PM STANDARD]

§ 60.46c Emission monitoring for sulfur dioxide.

[NA - NOT SUBJECT TO SO<sub>2</sub> STANDARD]

§ 60.47c Emission monitoring for particulate matter.

[NA - NOT SUBJECT TO PM STANDARD]

§ 60.48c Reporting and recordkeeping requirements.

(a) [NA - REQUIREMENT IS IN THE PAST]

(b) - (f) [NA - NOT SUBJECT TO PM OR SO<sub>2</sub> STANDARDS]

(g)(1) Except as provided under paragraphs (g)(2) and (g)(3) of this section, the owner or operator of each affected facility shall record and maintain records of the amount of each fuel combusted during each operating day.

(2) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility that combusts only natural gas, wood, fuels using fuel certification in § 60.48c(f) to demonstrate compliance with the SO<sub>2</sub> standard, fuels not subject to an emissions standard (excluding opacity), or a mixture of these fuels may elect to record and maintain records of the amount of each fuel COMBUSTED during each calendar month.

(3) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility or multiple affected facilities located on a contiguous property unit where the only fuels combusted in any steam generating unit (including steam generating units not subject to this subpart) at that property are natural gas, wood, distillate oil meeting the most current requirements in § 60.42C to use fuel certification to demonstrate compliance with the SO<sub>2</sub> standard, and/or fuels, excluding coal and residual oil, not subject to an emissions standard (excluding opacity) may elect to record and maintain records of the total amount of each steam generating unit fuel DELIVERED to that property during each calendar month.

**SECTION E. Source Group Restrictions.**

(h) [NA – NO CAPACITY FACTOR REQUIREMENT]

(i) All records required under this section shall be maintained by the owner or operator of the affected facility for a period of two years following the date of such record.

(j) [NA – NO REPORTS REQUIRED]

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009]

**Regulatory Changes**

Individual sources within this source group that are subject to 40 CFR Part 60 Subpart Dc shall comply with all applicable requirements of the Subpart. 40 CFR 60.8 requires submission of copies of all requests, reports and other communications to both the Department and the EPA. The EPA copies shall be forwarded to:

Director  
United States Environmental Protection Agency  
Region III, Air and Radiation Division  
Permits branch (3AD10)  
Four Penn Center  
U.S. EPA Region III  
1600 John F. Kennedy Boulevard  
Philadelphia, PA 19103-2852

Unless otherwise approved by DEP, the DEP copies shall be reported through the Department's Greenport PUP system available through:

<https://greenport.pa.gov/ePermitPublicAccess/PublicSubmission/Home>

In the event that the Federal Subpart that is the subject of this Source Group is revised, the permittee shall comply with the revised version of the subpart, and shall not be required to comply with any provisions in this permit designated as having the subpart as their authority, to the extent that such permit provisions would be inconsistent with the applicable provisions of the revised subpart.

**SECTION E. Source Group Restrictions.**

Group Name: 02

Group Description: NSPS Subpart JJJJ, SI RICE, Natural Gas Fired, Generator No. 1

**Sources included in this group**

ID	Name
104	EMER GEN, NSPS 4J, GEN 1 (SI RICE), 2011, 62HP(40KW)

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VII. ADDITIONAL REQUIREMENTS.**

**# 001 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4230]  
Subpart JJJJ - Standards of Performance for Stationary Spark Ignition Internal Combustion Engines  
Am I subject to this subpart?**

§ 60.4230 Am I subject to this subpart?

(a) The provisions of this subpart are applicable to manufacturers, owners, and operators of stationary spark ignition (SI) internal combustion engines (ICE) as specified in paragraphs (a)(1) through (6) of this section. For the purposes of this subpart, the date that construction commences is the date the engine is ordered by the owner or operator.

(1) [NA - UNIT(S) >19 KW]

(2) [NA - NOT UNITS DO NO NOT USE GASOLINE OR RICH BURN LPG]

(3) [NA - NOT AN ENGINE MANUFACTURER]

(4) Owners and operators of stationary SI ICE that commence construction after June 12, 2006, where the stationary SI ICE are manufactured:

(i) [NA - UNIT(S) < 500 HP]

(ii) [NA - UNIT(S) < 500 HP]

**SECTION E. Source Group Restrictions.**

(iii) on or after July 1, 2008, for engines with a maximum engine power less than 500 HP; or

(iv) on or after January 1, 2009, for emergency engines with a maximum engine power greater than 19 KW (25 HP).

(5) [NA - UNIT(S) NOT MODIFIED OR RECONSTRUCTED]

(6) The provisions of § 60.4236 of this subpart are applicable to all owners and operators of stationary SI ICE that commence construction after June 12, 2006.

(b) [NA - ENGINE TEST CELL NOT RELEVANT HERE]

(c) If you are an owner or operator of an area source subject to this subpart, you are exempt from the obligation to obtain a permit under 40 CFR part 70 or 40 CFR part 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart as applicable.

(d) [NA - UNIT(S) DO NOT USE ALCOHOL-BASED FUELS]

(e) [NA - NO NATIONAL SECURITY EXEMPTION]

(f) [NA - NOT TEMPORARY REPLACEMENT UNITS]

[73 FR 3591, Jan. 18, 2008, as amended at 76 FR 37972, June 28, 2011; 86 FR 34360, June 29, 2021]

#### Emission Standards for Owners and Operators

§ 60.4233 What emission standards must I meet if I am an owner or operator of a stationary SI internal combustion engine?

(a) [NA - UNIT(S) >19 KW]

(b) [NA - UNIT(S) DO NOT BURN GASOLINE]

(c) [NA - UNIT(S) ARE NOT RICH BURN LPG]

(d) OWNERS AND OPERATORS OF STATIONARY SI ICE WITH A MAXIMUM ENGINE POWER GREATER THAN 19 KW (25 HP) AND LESS THAN 75 KW (100 HP) (except gasoline and rich burn engines that use LPG) MUST COMPLY with the emission standards for field testing in 40 CFR 1048.101(c) for their non-emergency stationary SI ICE and WITH THE EMISSION STANDARDS IN TABLE 1 TO THIS SUBPART FOR THEIR EMERGENCY STATIONARY SI ICE. Owners and operators of stationary SI ICE with a maximum engine power greater than 19 KW (25 HP) and less than 75 KW (100 HP) manufactured prior to January 1, 2011, that were certified to the standards in Table 1 to this subpart applicable to engines with a maximum engine power greater than or equal to 100 HP and less than 500 HP, may optionally choose to meet those standards.

#### TABLE 1 REQUIREMENTS:

Maximum engine power: 25<HP<130 [SOURCE 104 is 62 HP]

Manufacture date: 2012 [SOURCE 104 HAS ENGINE CERTIFICATE BGNXB04.221.3, and was installed in 2011]

NO<sub>x</sub> + HC limit (g/hp-hr): 10

CO limit (g/hp-hr): 387

VOC limit (g/hp-hr): N/A

#### END OF TABLE 1 REQUIREMENTS:

(e) [NA - UNIT(S) < 75 KW]



**SECTION E. Source Group Restrictions.**

(f) [NA - UNIT(S) NOT MODIFIED OR RECONSTRUCTED]

(g) [NA - STATIONARY WELLHEAD GAS NOT USED]

[73 FR 3591, Jan. 18, 2008, as amended at 76 FR 37973, June 28, 2011]

§ 60.4234 How long must I meet the emission standards if I am an owner or operator of a stationary SI internal combustion engine?

Owners and operators of stationary SI ICE must operate and maintain stationary SI ICE that achieve the emission standards as required in § 60.4233 over the entire life of the engine.

Other Requirements for Owners and Operators

§ 60.4235 What fuel requirements must I meet if I am an owner or operator of a stationary SI gasoline fired internal combustion engine subject to this subpart?

[NA - UNIT(S) DO NOT USE GASOLINE]

§ 60.4236 What is the deadline for importing or installing stationary SI ICE produced in previous model years?

(a) After July 1, 2010, owners and operators may not install stationary SI ICE with a maximum engine power of less than 500 HP that do not meet the applicable requirements in § 60.4233.

(b) [NA - UNIT(S) < 500 HP]

(c) For emergency stationary SI ICE with a maximum engine power of greater than 19 KW (25 HP), owners and operators may not install engines that do not meet the applicable requirements in § 60.4233 after January 1, 2011.

(d) [NA - IMPORTATION NOT RELEVANT IN THIS CASE]

(e) The requirements of this section do not apply to owners and operators of stationary SI ICE that have been modified or reconstructed, and they do not apply to engines that were removed from one existing location and reinstalled at a new location.

§ 60.4237 What are the monitoring requirements if I am an owner or operator of an emergency stationary SI internal combustion engine?

(a) [NA - UNIT(S) < 500 HP]

(b) [NA - UNIT(S) < 130 HP]

(c) If you are an owner or operator of an emergency stationary SI internal combustion engine that is less than 130 HP, was built on or after July 1, 2008, and does not meet the standards applicable to non-emergency engines, you must install a non-resettable hour meter upon startup of your emergency engine.

Compliance Requirements for Owners and Operators

§ 60.4243 What are my compliance requirements if I am an owner or operator of a stationary SI internal combustion engine?

(a) [NA - UNIT(S) NOT SUBJECT TO § 60.4233(a) through (c); NEVERTHELESS, THIS SECTION IS REFERENCED FROM (b)]

If you are an owner or operator of a stationary SI internal combustion engine that is manufactured after July 1, 2008, and must comply with the emission standards specified in § 60.4233(a) through (c), you must comply by purchasing an engine certified to the emission standards in § 60.4231(a) through (c), as applicable, for the same engine class and maximum

**SECTION E. Source Group Restrictions.**

engine power. [THE FACILITY HAS PROVIDED THE EPA EMISSION CERTIFICATE FOR THIS UNIT] In addition, you must meet one of the requirements specified in (a)(1) and (2) of this section.

(1) If you operate and maintain the certified stationary SI internal combustion engine and control device according to the manufacturer's emission-related written instructions, you must keep records of conducted maintenance to demonstrate compliance, but no performance testing is required if you are an owner or operator. You must also meet the requirements as specified in 40 CFR part 1068, subparts A through D, as they apply to you. If you adjust engine settings according to and consistent with the manufacturer's instructions, your stationary SI internal combustion engine will not be considered out of compliance.

(2) If you do not operate and maintain the certified stationary SI internal combustion engine and control device according to the manufacturer's emission-related written instructions, your engine will be considered a non-certified engine, and you must demonstrate compliance according to (a)(2)(i) through (iii) of this section, as appropriate.

(i) If you are an owner or operator of a stationary SI internal combustion engine less than 100 HP, you must keep a maintenance plan and records of conducted maintenance to demonstrate compliance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions, but no performance testing is required if you are an owner or operator.

(ii) [NA - UNIT(S) <100 HP]

(iii) [NA - UNIT(S) <500 HP]

(b) If you are an owner or operator of a stationary SI internal combustion engine and must comply with the emission standards specified in § 60.4233(d) or (e), you must demonstrate compliance according to one of the methods specified in paragraphs (b)(1) and (2) of this section.

(1) Purchasing an engine certified according to procedures specified in this subpart, for the same model year and demonstrating compliance according to one of the methods specified in paragraph (a) of this section.

(2) [NA - UNIT(S) ARE CERTIFIED]

(c) [NA - UNIT(S) NOT MODIFIED OR RECONSTRUCTED]

(d) If you own or operate an emergency stationary ICE, you must operate the emergency stationary ICE according to the requirements in paragraphs (d)(1) through (3) of this section. In order for the engine to be considered an emergency stationary ICE under this subpart, any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (d)(1) through (3), is prohibited. If you do not operate the engine according to the requirements in paragraphs (d)(1) through (3), the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.

(1) There is no time limit on the use of emergency stationary ICE in emergency situations.

(2) You may operate your emergency stationary ICE for the purpose specified in paragraph (d)(2)(i) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraph (d)(3) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (d)(2).

(i) Emergency stationary ICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE beyond 100 hours per calendar year.

(ii)-(iii) [Reserved]

(3) Emergency stationary ICE may be operated for up to 50 hours per calendar year in non-emergency situations. The 50

**SECTION E. Source Group Restrictions.**

hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing provided in paragraph (d)(2) of this section. Except as provided in paragraph (d)(3)(i) of this section, the 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

(i) The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:

(A) The engine is dispatched by the local balancing authority or local transmission and distribution system operator;

(B) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.

(C) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.

(D) The power is provided only to the facility itself or to support the local transmission and distribution system.

(E) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.

(ii) [Reserved]

(e) Owners and operators of stationary SI natural gas fired engines may operate their engines using propane for a maximum of 100 hours per year as an alternative fuel solely during emergency operations, but must keep records of such use. If propane is used for more than 100 hours per year in an engine that is not certified to the emission standards when using propane, the owners and operators are required to conduct a performance test to demonstrate compliance with the emission standards of § 60.4233.

(f) If you are an owner or operator of a stationary SI internal combustion engine that is less than or equal to 500 HP and you purchase a non-certified engine or you do not operate and maintain your certified stationary SI internal combustion engine and control device according to the manufacturer's written emission-related instructions, you are required to perform initial performance testing as indicated in this section, but you are not required to conduct subsequent performance testing unless the stationary engine undergoes rebuild, major repair or maintenance. Engine rebuilding means to overhaul an engine or to otherwise perform extensive service on the engine (or on a portion of the engine or engine system). For the purpose of this paragraph (f), perform extensive service means to disassemble the engine (or portion of the engine or engine system), inspect and/or replace many of the parts, and reassemble the engine (or portion of the engine or engine system) in such a manner that significantly increases the service life of the resultant engine.

(g) [NA - CATALYSTS NOT USED]

(h) [NA- UNIT(S) <500 HP]

(i) [NA - UNIT(S) NOT MODIFIED OR RECONSTRUCTED]

[73 FR 3591, Jan. 18, 2008, as amended at 76 FR 37974, June 28, 2011; 78 FR 6697, Jan. 30, 2013; 86 Fr 34362, June 29, 2021; 87 Fr 48606, Aug.10, 2022]

Testing Requirements for Owners and Operators

§ 60.4244 What test methods and other procedures must I use if I am an owner or operator of a stationary SI internal combustion engine?

[NA – TESTING NOT REQUIRED FOR CERTIFIED UNITS WHICH ARE NOT ALTERED PER 60.4243(f)]

**SECTION E. Source Group Restrictions.**

## Notification, Reports, and Records for Owners and Operators

§ 60.4245 What are my notification, reporting, and recordkeeping requirements if I am an owner or operator of a stationary SI internal combustion engine?

Owners or operators of stationary SI ICE must meet the following notification, reporting and recordkeeping requirements.

(a) Owners and operators of all stationary SI ICE must keep records of the information in paragraphs (a)(1) through (4) of this section.

(1) All notifications submitted to comply with this subpart and all documentation supporting any notification.

(2) Maintenance conducted on the engine.

(3) If the stationary SI internal combustion engine is a certified engine, documentation from the manufacturer that the engine is certified to meet the emission standards and information as required in 40 CFR parts 1048, 1054, and 1060, as applicable.

(4) If the stationary SI internal combustion engine is not a certified engine or is a certified engine operating in a non-certified manner and subject to § 60.4243(a)(2), documentation that the engine meets the emission standards.

(b) For all stationary SI emergency ICE greater than or equal to 500 HP manufactured on or after July 1, 2010, that do not meet the standards applicable to non-emergency engines, the owner or operator of must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. For all stationary SI emergency ICE greater than or equal to 130 HP and less than 500 HP manufactured on or after July 1, 2011 that do not meet the standards applicable to non-emergency engines, the owner or operator of must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. For all stationary SI emergency ICE greater than 25 HP and less than 130 HP manufactured on or after July 1, 2008, that do not meet the standards applicable to non-emergency engines, the owner or operator of must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The owner or operator must document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation.

(c) [NA - UNIT(S) <500 HP]

(d) [NA – TESTING NOT REQUIRED FOR CERTIFIED UNITS WHICH ARE NOT ALTERED PER 60.4243(f)]

(e) [NA - UNITS) < 100 HP]

[73 FR 3591, Jan. 18, 2008, as amended at 73 FR 59177, Oct. 8, 2008; 78 FR 6697, Jan. 30, 2013; 86 FR 34362, June 29, 2021; 87 FR 48606, Aug.10, 2022]

## General Provisions

§ 60.4246 What General Provisions and confidential information provisions apply to me?

(a) Table 3 to this subpart shows which parts of the General Provisions in §§ 60.1 through 60.19 apply to you.

(b) The provisions of 40 CFR 1068.10 and 1068.11 apply for engine manufacturers. For others, the general confidential business information (CBI) provisions apply as described in 40 CFR part 2.

[88 FR 4471, Jan. 24, 2023]

## Regulatory Changes

Individual sources within this source group that are subject to 40 CFR Part 60 Subpart JJJJ shall comply with all applicable requirements of the Subpart. 40 CFR Part 60.4 requires submission of copies of all requests, reports and other communications to both the Department and the EPA. The EPA copies shall be forwarded to:

**SECTION E. Source Group Restrictions.**

Director  
United States Environmental Protection Agency  
Region III, Air and Radiation Division  
Permits branch (3AD10)  
Four Penn Center  
U.S. EPA Region III  
1600 John F. Kennedy Boulevard  
Philadelphia, PA 19103-2852

Unless otherwise approved by DEP, the DEP copies shall be reported through the Department's Greenport PUP system available through:

<https://greenport.pa.gov/ePermitPublicAccess/PublicSubmission/Home>

In the event that the Federal Subpart that is the subject of this Source Group is revised, the permittee shall comply with the revised version of the subpart, and shall not be required to comply with any provisions in this permit designated as having the subpart as their authority, to the extent that such permit provisions would be inconsistent with the applicable provisions of the revised subpart.

**SECTION E. Source Group Restrictions.**

Group Name: 03

Group Description: EMERGENCY GENERATORS (CI OR SI) AT AREA HAP SOURCES

Sources included in this group

ID	Name
103	EMER GEN MACT 4Z, GEN.2(SI RICE),FIRE PP.(CI RICE)

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VII. ADDITIONAL REQUIREMENTS.****# 001 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6585]****Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines****Am I subject to this subpart?**

§ 63.6585 Am I subject to this subpart?

You are subject to this subpart if you own or operate a stationary RICE at a major or area source of HAP emissions, except if the stationary RICE is being tested at a stationary RICE test cell/stand.

(a) A stationary RICE is any internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.

(b) A major source of HAP emissions is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons (9.07 megagrams) or more per year or any combination of HAP at a rate of 25 tons (22.68 megagrams) or more per year, except that for oil and gas production facilities, a major source of HAP emissions is determined for each surface site.

(c) An area source of HAP emissions is a source that is not a major source.

(d) If you are an owner or operator of an area source subject to this subpart, your status as an entity subject to a standard or

**SECTION E. Source Group Restrictions.**

other requirements under this subpart does not subject you to the obligation to obtain a permit under 40 CFR part 70 or 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart as applicable.

(e) [NA – NOT USED FOR NATIONAL SECURITY PURPOSES]

(f) [NA – RICE NOT RESIDENTIAL, COMMERCIAL OR INSTITUTIONAL]

[69 FR 33506, June 15, 2004, as amended at 73 FR 3603, Jan. 18, 2008; 78 FR 6700, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022]

§ 63.6590 What parts of my plant does this subpart cover?

This subpart applies to each affected source.

(a) Affected source. An affected source is any existing, new, or reconstructed stationary RICE located at a major or area source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand.

(1) Existing stationary RICE.

(i) [NA – NOT A MAJOR HAP SOURCE]

(ii) [NA – NOT A MAJOR HAP SOURCE]

(iii) For stationary RICE located at an area source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

(iv) A change in ownership of an existing stationary RICE does not make that stationary RICE a new or reconstructed stationary RICE.

(2) New stationary RICE.

(i) [NA – NOT A MAJOR HAP SOURCE]

(ii) [NA – NOT A MAJOR HAP SOURCE]

(iii) [NA – NOT A NEW SOURCE]

(3) [NA – NOT A RECONSTRUCTED SOURCE]

(b) Stationary RICE subject to limited requirements. (1) An affected source which meets either of the criteria in paragraphs (b)(1)(i) through (ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of § 63.6645(f).

(i) [NA – NOT A MAJOR HAP SOURCE]

(ii) [NA – NOT A MAJOR HAP SOURCE]

(2) [NA – NOT A MAJOR HAP SOURCE AND DOES NOT COMBUST LFG]

(3) The following stationary RICE do not have to meet the requirements of this subpart and of subpart A of this part, including initial notification requirements:

(i) [NA – NOT A MAJOR HAP SOURCE]

(ii) [NA – NOT A MAJOR HAP SOURCE]

**SECTION E. Source Group Restrictions.**

(iii) [NA – NOT A MAJOR HAP SOURCE]

(iv) [NA – NOT A MAJOR HAP SOURCE]

(v) [NA – NOT A MAJOR HAP SOURCE AND DOES NOT COMBUST LFG]

(c) [NA – NOT SUBJECT TO SUBPARTS IIII OR JJJJ]

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9674, Mar. 3, 2010; 75 FR 37733, June 30, 2010; 75 FR 51588, Aug. 20, 2010; 78 FR 6700, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022]

§ 63.6595 When do I have to comply with this subpart?

(a) Affected sources. (1) If you have an existing stationary RICE, excluding existing non-emergency CI stationary RICE, with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the applicable emission limitations, operating limitations and other requirements no later than June 15, 2007. IF YOU HAVE an existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, an existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or AN EXISTING STATIONARY CI RICE LOCATED AT AN AREA SOURCE OF HAP EMISSIONS, YOU MUST COMPLY WITH THE APPLICABLE EMISSION LIMITATIONS, OPERATING LIMITATIONS, AND OTHER REQUIREMENTS NO LATER THAN MAY 3, 2013.

IF YOU HAVE an existing stationary SI RICE with a site rating of less than or equal to 500 brake HP located at a major source of hap emissions, or AN EXISTING STATIONARY SI RICE LOCATED AT AN AREA SOURCE OF HAP EMISSIONS, YOU MUST COMPLY WITH THE APPLICABLE EMISSION LIMITATIONS, OPERATING LIMITATIONS, AND OTHER REQUIREMENTS NO LATER THAN OCTOBER 19, 2013.

(2) [NA – NOT A MAJOR HAP SOURCE]

(3) [NA – NOT A MAJOR HAP SOURCE]

(4) [NA – NOT A MAJOR HAP SOURCE]

(5) [NA – NOT A MAJOR HAP SOURCE]

(6) [NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(7) [NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(b) Area sources that become major sources. If you have an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP, the compliance dates in paragraphs (b)(1) and (2) of this section apply to you.

(1) Any stationary RICE for which construction or reconstruction is commenced after the date when your area source becomes a major source of HAP must be in compliance with this subpart upon startup of your affected source.

(2) Any stationary RICE for which construction or reconstruction is commenced before your area source becomes a major source of HAP must be in compliance with the provisions of this subpart that are applicable to RICE located at major sources within 3 years after your area source becomes a major source of HAP.

(c) If you own or operate an affected source, you must meet the applicable notification requirements in § 63.6645 and in 40 CFR part 63, subpart A.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9675, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010; 78 FR 6701, Jan. 30, 2013]

Emission and Operating Limitations



**SECTION E. Source Group Restrictions.**

§ 63.6600 What emission limitations and operating limitations must I meet if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?

[NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

§ 63.6601 What emission limitations must I meet if I own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 brake HP and less than or equal to 500 brake HP located at a major source of HAP emissions?

[NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

§ 63.6602 What emission limitations and other requirements must I meet if I own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions?

[NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

§ 63.6603 What emission limitations, operating limitations, and other requirements must I meet if I own or operate an existing stationary RICE located at an area source of HAP emissions?

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart.

(a) If you own or operate an existing stationary RICE located at an area source of HAP emissions, YOU MUST COMPLY WITH THE REQUIREMENTS IN TABLE 2d to this subpart and the operating limitations in Table 2b to this subpart that apply to you.

**TABLE 2d REQUIREMENTS:**

4. For each EMERGENCY STATIONARY CI RICE and black start stationary CI RICE\*\*, you must meet the following requirement, except during periods of startup:

- a. Change oil and filter every 500 hours of operation or annually, whichever comes first\*;
- b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and
- c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.

5. For each EMERGENCY STATIONARY SI RICE; black start stationary SI RICE; non-emergency, non-black start 4SLB stationary RICE >500 HP that operate 24 hours or less per calendar year; non-emergency, non-black start 4SRB stationary RICE >500 HP that operate 24 hours or less per calendar year\*\*, you must meet the following requirement, except during periods of startup:

- a. Change oil and filter every 500 hours of operation or annually, whichever comes first\*;
- b. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and
- c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.

\*Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in Table 2d of this subpart.

\*\*If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in Table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has

**SECTION E. Source Group Restrictions.**

ended or the unacceptable risk under federal, state, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the federal, state or local law under which the risk was deemed unacceptable.

[END OF TABLE 2d REQUIREMENTS]

(b) [NA – EMERGENCY ENGINE(S)]

(c) [NA – EMERGENCY ENGINE(S)]

(d) [NA – EMERGENCY ENGINE(S)]

(e) [NA – EMERGENCY ENGINE(S)]

(f) [NA – EMERGENCY ENGINE(S)]

[75 FR 9675, Mar. 3, 2010, as amended at 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011; 78 FR 6701, Jan. 30, 2013]

§ 63.6604 What fuel requirements must I meet if I own or operate a stationary CI RICE?

(a) [NA – EMERGENCY ENGINE(S)]

(b) Beginning January 1, 2015, if you own or operate an existing emergency CI stationary RICE with a site rating of more than 100 brake HP and a displacement of less than 30 liters per cylinder that uses diesel fuel and operates the purpose specified in § 63.6640(f)(4)(ii), you must use diesel fuel that meets the requirements in 40 CFR 1090.305 for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to January 1, 2015, may be used until depleted.

(c) [Reserved]

(d) [NA – NOT IN SPECIFIED GEOGRAPHIC LOCATIONS]

[78 FR 6702, Jan. 30, 2013, as amended at 85 FR 78463, Dec. 4, 2020; 87 FR 48607, Aug. 10, 2022]

General Compliance Requirements

§ 63.6605 What are my general requirements for complying with this subpart?

(a) You must be in compliance with the emission limitations, operating limitations, and other requirements in this subpart that apply to you at all times.

(b) At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

[75 FR 9675, Mar. 3, 2010, as amended at 78 FR 6702, Jan. 30, 2013]

Testing and Initial Compliance Requirements

§ 63.6610 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?

**SECTION E. Source Group Restrictions.**

[NA – NOT A MAJOR HAP SOURCE]

§ 63.6611 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a new or reconstructed 4SLB SI stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions?

[NA – NOT A MAJOR HAP SOURCE]

§ 63.6612 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions?

[NA – NO PERFORMANCE TESTING REQUIRED]

§ 63.6615 When must I conduct subsequent performance tests?

[NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

§ 63.6620 What performance tests and other procedures must I use?

[NA – NO PERFORMANCE TESTING REQUIRED]

§ 63.6625 What are my monitoring, installation, collection, operation, and maintenance requirements?

(a) [NA – CEMS NOT REQUIRED]

(b) [NA – CPMS NOT REQUIRED]

(c) [NA – LFG NOT USED]

(d) [NA – NOT A MAJOR HAP SOURCE]

(e) If you own or operate any of the following stationary RICE, you must operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions:

(1) [NA – NOT A MAJOR HAP SOURCE]

(2) [NA – NOT A MAJOR HAP SOURCE]

(3) An existing emergency or black start stationary RICE located at an area source of HAP emissions;

(4) [NA – EMERGENCY ENGINE(S)]

(5) [NA – EMERGENCY ENGINE(S)]

(6) [NA – EMERGENCY ENGINE(S)]

(7) [NA – EMERGENCY ENGINE(S)]

(8) [NA – EMERGENCY ENGINE(S)]

(9) [NA – EMERGENCY ENGINE(S)]

(10) [NA – EMERGENCY ENGINE(S)]

**SECTION E. Source Group Restrictions.**

(f) If you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing emergency stationary RICE located at an area source of HAP emissions, you must install a non-resettable hour meter if one is not already installed.

(g) [NA – EMERGENCY ENGINE(S)]

(h) If you operate a new, reconstructed, or existing stationary engine, you must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup in Tables 1a, 2a, 2c, and 2d to this subpart apply.

(i) If you own or operate a stationary CI engine that is subject to the work, operation or management practices in items 1 or 2 of Table 2c to this subpart or in items 1 or 4 of Table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

(j) If you own or operate a stationary SI engine that is subject to the work, operation or management practices in items 6, 7, or 8 of Table 2c to this subpart or in items 5, 6, 7, 9, or 11 of Table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Acid Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Acid Number increases by more than 3.0 milligrams of potassium hydroxide (KOH) per gram from Total Acid Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011; 78 FR 6703, Jan. 30, 2013]

§ 63.6630 How do I demonstrate initial compliance with the emission limitations, operating limitations, and other requirements?

(a) You must demonstrate initial compliance with each emission limitation, operating limitation, and other requirement that applies to you according to Table 5 of this subpart. [NA – NONE OF THE CATEGORIES IN TABLE 5 APPLY TO EMERGENCY ENGINES]

(b) [NA – PERFORMANCE TESTING NOT REQUIRED]

(c) [NA – NOCS NOT REQUIRED FOR EXISTING EMERGENCY RICE]

(d) [NA – EMERGENCY ENGINE(S)]

**SECTION E. Source Group Restrictions.**

(e) [NA – EMERGENCY ENGINE(S)]

[69 FR 33506, June 15, 2004, as amended at 78 FR 6704, Jan. 30, 2013]

Continuous Compliance Requirements

§ 63.6635 How do I monitor and collect data to demonstrate continuous compliance?

[NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

§ 63.6640 How do I demonstrate continuous compliance with the emission limitations, operating limitations, and other requirements?

(a) You must demonstrate continuous compliance with each emission limitation, operating limitation, and other requirements in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you according to methods specified in Table 6 to this subpart.

TABLE 6 REQUIREMENTS

9. FOR EACH existing emergency and black start stationary RICE  $\leq 500$  HP located at a major source of HAP, existing non-emergency stationary RICE  $< 100$  HP located at a major source of HAP, EXISTING EMERGENCY and black start STATIONARY RICE LOCATED AT AN AREA SOURCE OF HAP, existing non-emergency stationary CI RICE  $\leq 300$  HP located at an area source of HAP, existing non-emergency 2SLB stationary RICE located at an area source of HAP, existing non-emergency stationary SI RICE located at an area source of HAP which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, existing non-emergency 4SLB and 4SRB stationary RICE  $\leq 500$  HP located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE  $> 500$  HP located at an area source of HAP that operate 24 hours or less per calendar year, and existing non-emergency 4SLB and 4SRB stationary RICE  $> 500$  HP located at an area source of HAP that are remote stationary RICE, complying with the requirement to "Work or Management practices", you must demonstrate continuous compliance by:

i. Operating and maintaining the stationary RICE according to the manufacturer's emission-related operation and maintenance instructions; or

ii. Develop and follow your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.

[END OF TABLE 6 REQUIREMENTS]

(b) [NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(c) [NA – ANNUAL COMPLIANCE DEMONSTRATION NOT REQUIRED]

(d) [NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(e) You must also report each instance in which you did not meet the requirements in Table 8 to this subpart that apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing emergency stationary RICE, an existing limited use stationary RICE, or an existing stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart, except for the initial notification requirements: a new or reconstructed stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new or reconstructed emergency stationary RICE, or a new or

**SECTION E. Source Group Restrictions.**

reconstructed limited use stationary RICE. [EXISTING EMERGENCY RICE AT AREA HAP SOURCES ARE NOT AMONG THOSE EXEMPTED FROM THIS SECTION]

(f) If you own or operate an emergency stationary RICE, you must operate the emergency stationary RICE according to the requirements in paragraphs (f)(1) through (4) of this section. In order for the engine to be considered an emergency stationary RICE under this subpart, any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f)(1) through (4), is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1) through (4), the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.

(1) There is no time limit on the use of emergency stationary RICE in emergency situations.

(2) You may operate your emergency stationary RICE for the purpose specified in paragraph (f)(2)(i) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraphs (f)(3) and (4) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (f)(2).

(i) Emergency stationary RICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency RICE beyond 100 hours per calendar year.

(ii)-(iii) [Reserved]

(3) [NA – NOT A MAJOR HAP SOURCE]

(4) Emergency stationary RICE located at area sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing provided in paragraph (f)(2) of this section. Except as provided in paragraphs (f)(4)(i) and (ii) of this section, the 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

(i) Prior to May 3, 2014, the 50 hours per year for non-emergency situations can be used for peak shaving or non-emergency demand response to generate income for a facility, or to otherwise supply power as part of a financial arrangement with another entity if the engine is operated as part of a peak shaving (load management program) with the local distribution system operator and the power is provided only to the facility itself or to support the local distribution system.

(ii) The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:

(A) The engine is dispatched by the local balancing authority or local transmission and distribution system operator.

(B) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.

(C) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.

(D) The power is provided only to the facility itself or to support the local transmission and distribution system.

(E) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.

**SECTION E. Source Group Restrictions.**

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006; 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010; 78 FR 6704, Jan. 30, 2013; 87 FR 48607, Aug.10, 2022]

Notifications, Reports, and Records

§ 63.6645 What notifications must I submit and when?

(a) You must submit all of the notifications in §§ 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) that apply to you by the dates specified if you own or operate any of the following;

(1) [NA – NOT A MAJOR HAP SOURCE]

(2) [NA PER (5) BELOW]

(3) [NA – NOT A MAJOR HAP SOURCE]

(4) [NA – NOT A MAJOR HAP SOURCE]

(5) THIS REQUIREMENT DOES NOT APPLY IF YOU OWN OR OPERATE an existing stationary RICE less than 100 HP, AN EXISTING STATIONARY EMERGENCY RICE, OR AN EXISTING STATIONARY RICE THAT IS NOT SUBJECT TO ANY NUMERICAL EMISSION STANDARDS.

(b) [NA – NOT A MAJOR HAP SOURCE]

(c) [NA – NOT A MAJOR HAP SOURCE]

(d) [NA – NOT A MAJOR HAP SOURCE]

(e) [NA – NOT A MAJOR HAP SOURCE]

(f) [NA – 63.6590(b) DOES NOT APPLY]

(g) [NA – PERFORMANCE TEST NOT REQUIRED]

(h) [NA – PERFORMANCE TEST NOT REQUIRED]

(i) [NA – EMERGENCY ENGINE(S)]

[73 FR 3606, Jan. 18, 2008, as amended at 75 FR 9677, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010; 78 FR 6705, Jan. 30, 2013; 85 FR 73912, Nov. 19, 2020]

§ 63.6650 What reports must I submit and when?

(a) You must submit each report in Table 7 of this subpart that applies to you.

TABLE 7 REQUIREMENTS

4. For each emergency stationary RICE that operate or are contractually obligated to be available for more than 15 hours per year for the purposes specified in § 63.6640(f)(2)(ii) and (iii) or that operate for the purposes specified in § 63.6640(f)(4)(ii), you must submit a Report. The report must contain the information in § 63.6650(h)(1). You must submit the report annually according to the requirements in § 63.6650(h)(2)-(3).

[END OF TABLE 7 REQUIREMENTS]

(b) Unless the Administrator has approved a different schedule for submission of reports under § 63.10(a), you must submit each report by the date in Table 7 of this subpart and according to the requirements in paragraphs (b)(1) through (b)(9) of this section.

**SECTION E. Source Group Restrictions.**

- (1) [NA – ANNUAL REPORT REQUIRED, ONLY UNDER CERTAIN CONDITIONS]
- (2) [NA – ANNUAL REPORT REQUIRED, ONLY UNDER CERTAIN CONDITIONS]
- (3) [NA – ANNUAL REPORT REQUIRED, ONLY UNDER CERTAIN CONDITIONS]
- (4) [NA – ANNUAL REPORT REQUIRED, ONLY UNDER CERTAIN CONDITIONS]
- (5) [NA – ANNUAL REPORT REQUIRED, ONLY UNDER CERTAIN CONDITIONS]
- (6) For annual Compliance reports, the first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.6595 and ending on December 31.
- (7) For annual Compliance reports, the first Compliance report must be postmarked or delivered no later than January 31 following the end of the first calendar year after the compliance date that is specified for your affected source in § 63.6595.
- (8) For annual Compliance reports, each subsequent Compliance report must cover the annual reporting period from January 1 through December 31.
- (9) For annual Compliance reports, each subsequent Compliance report must be postmarked or delivered no later than January 31.
- (c) [NA – “COMPLIANCE REPORT” NOT REQUIRED]
- (d) [NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]
- (e) [NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]
- (f) [NA – NOT SUBJECT TO TITLE V PERMITTING]
- (g) [NA – LFG NOT USED]
- (h) If you own or operate an emergency stationary RICE with a site rating of more than 100 brake HP that operates for the purpose specified in § 63.6640(f)(4)(ii), you must submit an annual report according to the requirements in paragraphs (h)(1) through (3) of this section.
- (1) The report must contain the following information:
- (i) Company name and address where the engine is located.
- (ii) Date of the report and beginning and ending dates of the reporting period.
- (iii) Engine site rating and model year.
- (iv) Latitude and longitude of the engine in decimal degrees reported to the fifth decimal place.
- (v)-(vi) [Reserved]
- (vii) Hours spent for operation for the purpose specified in § 63.6640(f)(4)(ii), including the date, start time, and end time for engine operation for the purposes specified in § 63.6640(f)(4)(ii). The report must also identify the entity that dispatched the engine and the situation that necessitated the dispatch of the engine.
- (viii) If there were no deviations from the fuel requirements in § 63.6604 that apply to the engine (if any), a statement that there were no deviations from the fuel requirements during the reporting period.
- (ix) If there were deviations from the fuel requirements in § 63.6604 that apply to the engine (if any), information on the number, duration, and cause of deviations, and the corrective action taken.



**SECTION E. Source Group Restrictions.**

(2) The first annual report must cover the calendar year 2015 and must be submitted no later than March 31, 2016. Subsequent annual reports for each calendar year must be submitted no later than March 31 of the following calendar year.

(3) The annual report must be submitted electronically using the subpart specific reporting form in the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) ([www.epa.gov/cdx](http://www.epa.gov/cdx)). However, if the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the written report must be submitted to the Administrator at the appropriate address listed in § 63.13.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9677, Mar. 3, 2010; 78 FR 6705, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022]

§ 63.6655 What records must I keep?

(a) [NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(b) [NA – NO CEMS OR CPMS]

(c) [NA – LFG NOT USED]

(d) [NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(e) You must keep records of the maintenance conducted on the stationary RICE in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan if you own or operate any of the following stationary RICE;

(1) [NA – NOT A MAJOR HAP SOURCE]

(2) An existing stationary emergency RICE.

(3) An existing stationary RICE located at an area source of HAP emissions subject to management practices as shown in Table 2d to this subpart.

(f) If you own or operate any of the stationary RICE in paragraphs (f)(1) through (2) of this section, you must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The owner or operator must document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation. If the engine is used for the purpose specified in § 63.6640(f)(4)(ii), the owner or operator must keep records of the notification of the emergency situation, and the date, start time, and end time of engine operation for these purposes.

(1) [NA – NOT A MAJOR HAP SOURCE]

(2) An existing emergency stationary RICE located at an area source of HAP emissions that does not meet the standards applicable to non-emergency engines.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010; 75 FR 51592, Aug. 20, 2010; 78 FR 6706, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022]

§ 63.6660 In what form and how long must I keep my records?

(a) Your records must be in a form suitable and readily available for expeditious review according to § 63.10(b)(1).

(b) As specified in § 63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to § 63.10(b)(1).

**SECTION E. Source Group Restrictions.**

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010]

**Other Requirements and Information**

§ 63.6665 What parts of the General Provisions apply to me?

Table 8 to this subpart shows which parts of the General Provisions in §§ 63.1 through 63.15 apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with any of the requirements of the General Provisions specified in Table 8: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing stationary RICE that combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, an existing emergency stationary RICE, or an existing limited use stationary RICE. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in the General Provisions specified in Table 8 except for the initial notification requirements: A new stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new emergency stationary RICE, or a new limited use stationary RICE. [EXISTING EMERGENCY RICE AT AREA HAP SOURCES ARE NOT AMONG THOSE EXEMPTED FROM THIS SECTION]

[75 FR 9678, Mar. 3, 2010]

**Regulatory Changes:**

Individual sources within this source group that are subject to 40 CFR Part 63 Subpart ZZZZ -National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines shall comply with all applicable requirements of the Subpart. 40 CFR 63.13(a) requires submission of copies of all requests, reports and other communications to both the Department and the EPA. The EPA copies shall be forwarded to:

Director  
United States Environmental Protection Agency  
Region III, Air and Radiation Division  
Permits branch (3AD10)  
Four Penn Center  
U.S. EPA Region III  
1600 John F. Kennedy Boulevard  
Philadelphia, PA 19103-2852

Unless otherwise approved by DEP, the DEP copies shall be reported through the Department's Greenport PUP system available through:

<https://greenport.pa.gov/ePermitPublicAccess/PublicSubmission/Home>

In the event that the Federal Subpart that is the subject of this Source Group is revised, the permittee shall comply with the revised version of the subpart, and shall not be required to comply with any provisions in this permit designated as having the subpart as their authority, to the extent that such permit provisions would be inconsistent with the applicable provisions of the revised subpart.



**SECTION F. Alternative Operation Requirements.**

No Alternative Operations exist for this State Only facility.



**SECTION G. Emission Restriction Summary.**

No emission restrictions listed in this section of the permit.

**SECTION H. Miscellaneous.**

#001. New Oxford Container (NOC) and Point-of-Purchase (POP).

#002. NOC Division has a Corrugator with a throughput up to 1,000 lineal feet/min (750 lb/min), installed in 2002

Notes: 1. Corrugator uses a glue made by mixing Polybond adhesive and corn starch, exempt by 25 PA Code Section 129.77 requirements

2. Cardboards are punched on presses. Waste cardboard material is conveyed, shredded, and bailed for disposal. They are controlled by an 80,000 cfm cyclone approved by RFD #6949 on 4/12/18 and installed in 2019, which replaced existing two cyclones.

#003. Source 101

Model	Facility ID	Equip. Type	Size/Capacity	Installed
KBA model 162A w/IR & UV	POP131	Litho. Press	95.8 MSF/hr	2004
7-color KBA press w/IR	POP125	Litho. Press	125.5 MSF/hr	2019

Notes: 1. 7-color KBA press was installed as per plan approval 01-03007A issued on January 7, 2019. The 7-color KBA press replaced the press POP 120, Planeta 64/7, 7-color with IR (installed 1998).

#004. Source 102

Model	Facility ID	Equip. Type	Size/Capacity	Installed
Bobst 924 NT	NOC317	Flexo. Folder Gluer	89.6 MSF/hr	2013
Martin 1228	NOC321	Flexo. Folder Gluer	76.9 MSF/hr	2002
EMBA	NOC318	Flexo. Folder Gluer	51.1 MSF/hr	2000
Ward 16000	NOC329	Flexo. Folder Gluer	86.4 MSF/hr	2006
Apstar HG 1624	NOC 284	Rotary Die Cutter	5,206 MSF/hr	2024
MWU ServoGrafix	NOC273	Rotary Die Cutter	68.1 MSF/hr	2010
Bobst 1624 NT	NOC274	Rotary Die Cutter	130.6 MSF/hr	2019
Ward 15000	POP276	Flexo. Printer	23.5 MSF/hr	1992
Ward 1300	POP260	Flexo. Printer	21.7 MSF/hr	1995
Bobst	POP415	Folder Gluer	12.6 MSF/hr	2020
J&L	POP416	Folder Gluer	15.8 MSF/hr	2010
Jagenberg	POP417	Folder Gluer	11.4 MSF/hr	2010
J&L	POP434	Folder Gluer	11.1 MSF/hr	2012
Bobst	POP210	Flatbed die cutter	10.2 MSF/hr	2010
Bobst	POP216	Flatbed die cutter	15.4 MSF/hr	2010
Bobst	POP217	Flatbed die cutter	31.0 MSF/hr	2013
Bobst	POP220	Flatbed die cutter	37.2 MSF/hr	2019
Clayton Boiler	-	Boiler	7.876 mmBTU/hr	2013
Clayton Boiler	-	Boiler	7.876 mmBTU/hr	2013

Notes: 1. Source 102 NOC274 was installed as a replacement for NOC253 and NOC310 as per RFD #7521 authorized on 1/25/19.  
 2. Only one Clayton boiler is operated for process steam heat, at any time, and the other unit is standby.  
 3. Source 102 NOC284 will be installed as a replacement for NOC262 as per RFD #10674 authorized on 6/10/24. The replacement of the NOC262 with the NOC284 will result in a PTE increase of 0.69 tons of VOCs and 0.01 tons of HAPs.  
 4. MSF=million square feet.

#005. The engines descriptions are as follows:

- Source 103 subject to MACT Subpart ZZZZ:

- SI RICE (POP): Generator No. 2: Cummins Onan model GGHE-4482443, 97 hp and 60 kw, installed 2000, natural gas fired.

- CI RICE (POP): Diesel Fire Pump Engine: Caterpillar model 3208, 235 hp and 175 kw, installed in 1999

- Source 104 subject to NSPS Subpart JJJJ:

- SI RICE (NOC): Source 104: Emergency Generator No. 1: Generac model SG040, 62 hp/40 kw, EPA engine family BGNXB04. 221.3, installed 2011. The engine is natural gas fired.

#006. Insignificant Source List, the following sources do not require any restrictions, or monitoring and recordkeeping requirements, and work practice standards:

- 1. Corrugators with cyclones (NOTE: RFD #6949, Cyclones replaced by 80,000 cfm cyclone)

**SECTION H. Miscellaneous.**

- 2. POP Division: four folder gluers and three flatbed die cutters
- 3. POP Division: Two natural gas fired Clayton Boilers, each 7.876 mmBTU/hr
- 4. Corn Starch Silo controlled by a bin vent filter.
- 5. Space heaters, natural gas fired.
- 6. No. 2 oil fuel storage tank, capacity 12,000 gallons, UST [NOTE: 2,500 gallons filled on 6/6/16, total 2,700 gallons of the pre 7/1/16 blend of sulfur in fuel].



\*\*\*\*\* End of Report \*\*\*\*\*

---