



**COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
AIR QUALITY PROGRAM**

TITLE V/STATE OPERATING PERMIT

Issue Date:	February 16, 2024	Effective Date:	December 19, 2024
Revision Date:	December 19, 2024	Expiration Date:	March 20, 2029
Revision Type:	Amendment		

In accordance with the provisions of the Air Pollution Control Act, the Act of January 8, 1960, P.L. 2119, as amended, and 25 Pa. Code Chapter 127, the Owner, [and Operator if noted] (hereinafter referred to as permittee) identified below is authorized by the Department of Environmental Protection (Department) to operate the air emission source(s) more fully described in this permit. This Facility is subject to all terms and conditions specified in this permit. Nothing in this permit relieves the permittee from its obligations to comply with all applicable Federal, State and Local laws and regulations.

The regulatory or statutory authority for each permit condition is set forth in brackets. All terms and conditions in this permit are federally enforceable applicable requirements unless otherwise designated as "State-Only" or "non-applicable" requirements.

TITLE V Permit No: 46-00298

Federal Tax Id - Plant Code: 23-1099050-6

Owner Information

Name: GLAXOSMITHKLINE LLC
Mailing Address: 709 SWEDELAND RD
KING OF PRUSSIA, PA 19406-2711

Plant Information

Plant: GLAXOSMITHKLINE/UPPER MERION EAST
Location: 46 Montgomery County 46955 Upper Merion Township
SIC Code: 2834 Manufacturing - Pharmaceutical Preparations

Responsible Official

Name: STU GOLD
Title: SITE OPERATIONS DIRECTOR
Phone: (610) 637 - 8359 Email: stu.j.gold@gsk.com

Permit Contact Person

Name: JESSICA BRANCH
Title: EHS MANAGER
Phone: (610) 832 - 8074 Email: jessica.k.branch@gsk.com

[Signature] _____
JAMES D. REBARCHAK, SOUTHEAST REGION AIR PROGRAM MANAGER



SECTION A. Table of Contents

Section A. Facility/Source Identification

Table of Contents
Site Inventory List

Section B. General Title V Requirements

- #001 Definitions
- #002 Prohibition of Air Pollution
- #003 Property Rights
- #004 Permit Expiration
- #005 Permit Renewal
- #006 Transfer of Ownership or Operational Control
- #007 Inspection and Entry
- #008 Compliance Requirements
- #009 Need to Halt or Reduce Activity Not a Defense
- #010 Duty to Provide Information
- #011 Reopening and Revising the Title V Permit for Cause
- #012 Reopening a Title V Permit for Cause by EPA
- #013 Operating Permit Application Review by the EPA
- #014 Significant Operating Permit Modifications
- #015 Minor Operating Permit Modifications
- #016 Administrative Operating Permit Amendments
- #017 Severability Clause
- #018 Fee Payment
- #019 Authorization for De Minimis Emission Increases
- #020 Reactivation of Sources
- #021 Circumvention
- #022 Submissions
- #023 Sampling, Testing and Monitoring Procedures
- #024 Recordkeeping Requirements
- #025 Reporting Requirements
- #026 Compliance Certification
- #027 Operational Flexibility
- #028 Risk Management
- #029 Approved Economic Incentives and Emission Trading Programs
- #030 Permit Shield
- #031 Reporting
- #032 Report Format

Section C. Site Level Title V Requirements

- C-I: Restrictions
- C-II: Testing Requirements
- C-III: Monitoring Requirements
- C-IV: Recordkeeping Requirements
- C-V: Reporting Requirements
- C-VI: Work Practice Standards
- C-VII: Additional Requirements
- C-VIII: Compliance Certification
- C-IX: Compliance Schedule

Section D. Source Level Title V Requirements

- D-I: Restrictions
- D-II: Testing Requirements
- D-III: Monitoring Requirements
- D-IV: Recordkeeping Requirements
- D-V: Reporting Requirements



SECTION A. Table of Contents

D-VI: Work Practice Standards
D-VII: Additional Requirements

Note: These same sub-sections are repeated for each source!

Section E. Source Group Restrictions

E-I: Restrictions
E-II: Testing Requirements
E-III: Monitoring Requirements
E-IV: Recordkeeping Requirements
E-V: Reporting Requirements
E-VI: Work Practice Standards
E-VII: Additional Requirements

Section F. Alternative Operating Scenario(s)


F-I: Restrictions
F-II: Testing Requirements
F-III: Monitoring Requirements
F-IV: Recordkeeping Requirements
F-V: Reporting Requirements
F-VI: Work Practice Standards
F-VII: Additional Requirements

Section G. Emission Restriction Summary

Section H. Miscellaneous









**SECTION A. Site Inventory List**

Source ID	Source Name	Capacity/Throughput	Fuel/Material
054	BOILER NO. 1 (CENTRAL UTILITY PLANT)	48.988 MMBTU/HR	
		46,655.000 CF/HR	Natural Gas
		349.900 Gal/HR	#2 Oil
055	BOILER NO. 2 (CENTRAL UTILITY PLANT)	48.988 MMBTU/HR	
		46,655.000 CF/HR	Natural Gas
		349.900 Gal/HR	#2 Oil
056	BOILER NO. 3 (CENTRAL UTILITY PLANT)	24.494 MMBTU/HR	
		23,327.600 CF/HR	Natural Gas
		175.000 Gal/HR	#2 Oil
057	BOILER NO. 4 (CENTRAL UTILITY PLANT)	24.494 MMBTU/HR	
		23,327.600 CF/HR	Natural Gas
		175.000 Gal/HR	#2 Oil
102	180 KW KOHLER EGEN 10-2 (CUMMINS ENGINE)	N/A	#2 Oil
103	510 KW MARATHON EGEN 11-1 (DETROIT DIESEL ENGINE)	N/A	#2 Oil
104	1,200 KW DETROIT EGEN 4-1A (DETROIT DIESEL ENGINE)	N/A	#2 Oil
106	1,500 KW MTU EGEN 38-3 (DETROIT DIESEL ENGINE)	N/A	#2 Oil
107	2,500 KW CATERPILLAR EGEN 3-3 (CATERPILLAR ENGINE)	N/A	#2 Oil
108	150 KW TAYLOR EGEN 17-1 (PERKINS ENGINE)	N/A	#2 Oil
109	2,000 KW MTU EGEN 56-1 (CUP)	147.300 Gal/HR	Diesel Fuel
110	600 KW GENERAC EGEN (PERKINS ENGINE)	41.400 Gal/HR	Diesel Fuel
205	NO. 2 OIL STORAGE TANK (CENTRAL UTILITY PLANT)		
FML01	NATURAL GAS		
FML02	NO. 2 FUEL OIL		
FML03	ULTRA LOW SULFUR DIESEL FUEL		
S054	BOILER NO. 1 STACK (CUP)		
S055	BOILER NO. 2 STACK (CUP)		
S056	BOILER NO. 3 STACK (CUP)		
S057	BOILER NO. 4 STACK (CUP)		
S058	GENERATOR ENGINE STACKS (CUP)		
S110	GENERAC EGEN STACK		
Z01	ENGINE EXHAUST POINT		

PERMIT MAPS




PERMIT MAPS





PERMIT MAPS



**SECTION B. General Title V Requirements****#001 [25 Pa. Code § 121.1]****Definitions**

Words and terms that are not otherwise defined in this permit shall have the meanings set forth in Section 3 of the Air Pollution Control Act (35 P.S. § 4003) and 25 Pa. Code § 121.1.

#002 [25 Pa. Code § 121.7]**Prohibition of Air Pollution**

No person may permit air pollution as that term is defined in the act.

#003 [25 Pa. Code § 127.512(c)(4)]**Property Rights**

This permit does not convey property rights of any sort, or any exclusive privileges.

#004 [25 Pa. Code § 127.446(a) and (c)]**Permit Expiration**

This operating permit is issued for a fixed term of five (5) years and shall expire on the date specified on Page 1 of this permit. The terms and conditions of the expired permit shall automatically continue pending issuance of a new Title V permit, provided the permittee has submitted a timely and complete application and paid applicable fees required under 25 Pa. Code Chapter 127, Subchapter I and the Department is unable, through no fault of the permittee, to issue or deny a new permit before the expiration of the previous permit. An application is complete if it contains sufficient information to begin processing the application, has the applicable sections completed and has been signed by a responsible official.

#005 [25 Pa. Code §§ 127.412, 127.413, 127.414, 127.446(e), 127.503 & 127.704(b)]**Permit Renewal**

(a) An application for the renewal of the Title V permit shall be submitted to the Department at least six (6) months, and not more than 18 months, before the expiration date of this permit. The renewal application is timely if a complete application is submitted to the Department's Regional Air Manager within the timeframe specified in this permit condition.

(b) The application for permit renewal shall include the current permit number, the appropriate permit renewal fee, a description of any permit revisions and off-permit changes that occurred during the permit term, and any applicable requirements that were promulgated and not incorporated into the permit during the permit term. The fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" and submitted with the fee form to the respective regional office.

(c) The renewal application shall also include submission of proof that the local municipality and county, in which the facility is located, have been notified in accordance with 25 Pa. Code § 127.413. The application for renewal of the Title V permit shall also include submission of compliance review forms which have been used by the permittee to update information submitted in accordance with either 25 Pa. Code § 127.412(b) or § 127.412(j).

(d) The permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the permit application, shall promptly submit such supplementary facts or corrected information during the permit renewal process. The permittee shall also promptly provide additional information as necessary to address any requirements that become applicable to the source after the date a complete renewal application was submitted but prior to release of a draft permit.

#006 [25 Pa. Code §§ 127.450(a)(4) & 127.464(a)]**Transfer of Ownership or Operational Control**

(a) In accordance with 25 Pa. Code § 127.450(a)(4), a change in ownership or operational control of the source shall be treated as an administrative amendment if:

- (1) The Department determines that no other change in the permit is necessary;
- (2) A written agreement has been submitted to the Department identifying the specific date of the transfer of permit responsibility, coverage and liability between the current and the new permittee; and,
- (3) A compliance review form has been submitted to the Department and the permit transfer has been approved by

**SECTION B. General Title V Requirements**

the Department.

(b) In accordance with 25 Pa. Code § 127.464(a), this permit may not be transferred to another person except in cases of transfer-of-ownership which are documented and approved to the satisfaction of the Department.

#007 [25 Pa. Code § 127.513, 35 P.S. § 4008 and § 114 of the CAA]**Inspection and Entry**

(a) Upon presentation of credentials and other documents as may be required by law for inspection and entry purposes, the permittee shall allow the Department of Environmental Protection or authorized representatives of the Department to perform the following:

- (1) Enter at reasonable times upon the permittee's premises where a Title V source is located or emissions related activity is conducted, or where records are kept under the conditions of this permit;
- (2) Have access to and copy or remove, at reasonable times, records that are kept under the conditions of this permit;
- (3) Inspect at reasonable times, facilities, equipment including monitoring and air pollution control equipment, practices, or operations regulated or required under this permit;
- (4) Sample or monitor, at reasonable times, substances or parameters, for the purpose of assuring compliance with the permit or applicable requirements as authorized by the Clean Air Act, the Air Pollution Control Act, or the regulations promulgated under the Acts.

(b) Pursuant to 35 P.S. § 4008, no person shall hinder, obstruct, prevent or interfere with the Department or its personnel in the performance of any duty authorized under the Air Pollution Control Act.

(c) Nothing in this permit condition shall limit the ability of the EPA to inspect or enter the premises of the permittee in accordance with Section 114 or other applicable provisions of the Clean Air Act.

#008 [25 Pa. Code §§ 127.25, 127.444, & 127.512(c)(1)]**Compliance Requirements**

(a) The permittee shall comply with the conditions of this permit. Noncompliance with this permit constitutes a violation of the Clean Air Act and the Air Pollution Control Act and is grounds for one (1) or more of the following:

- (1) Enforcement action
- (2) Permit termination, revocation and reissuance or modification
- (3) Denial of a permit renewal application

(b) A person may not cause or permit the operation of a source, which is subject to 25 Pa. Code Article III, unless the source(s) and air cleaning devices identified in the application for the plan approval and operating permit and the plan approval issued to the source are operated and maintained in accordance with specifications in the applications and the conditions in the plan approval and operating permit issued by the Department. A person may not cause or permit the operation of an air contamination source subject to 25 Pa. Code Chapter 127 in a manner inconsistent with good operating practices.

(c) For purposes of Sub-condition (b) of this permit condition, the specifications in applications for plan approvals and operating permits are the physical configurations and engineering design details which the Department determines are essential for the permittee's compliance with the applicable requirements in this Title V permit.

#009 [25 Pa. Code § 127.512(c)(2)]**Need to Halt or Reduce Activity Not a Defense**

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

**SECTION B. General Title V Requirements****#010 [25 Pa. Code §§ 127.411(d) & 127.512(c)(5)]****Duty to Provide Information**

(a) The permittee shall furnish to the Department, within a reasonable time, information that the Department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit, or to determine compliance with the permit.

(b) Upon request, the permittee shall also furnish to the Department copies of records that the permittee is required to keep by this permit, or for information claimed to be confidential, the permittee may furnish such records directly to the Administrator of EPA along with a claim of confidentiality.

#011 [25 Pa. Code §§ 127.463, 127.512(c)(3) & 127.542]**Reopening and Revising the Title V Permit for Cause**

(a) This Title V permit may be modified, revoked, reopened and reissued or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay a permit condition.

(b) This permit may be reopened, revised and reissued prior to expiration of the permit under one or more of the following circumstances:

(1) Additional applicable requirements under the Clean Air Act or the Air Pollution Control Act become applicable to a Title V facility with a remaining permit term of three (3) or more years prior to the expiration date of this permit. The Department will revise the permit as expeditiously as practicable but not later than 18 months after promulgation of the applicable standards or regulations. No such revision is required if the effective date of the requirement is later than the expiration date of this permit, unless the original permit or its terms and conditions has been extended.

(2) Additional requirements, including excess emissions requirements, become applicable to an affected source under the acid rain program. Upon approval by the Administrator of EPA, excess emissions offset plans for an affected source shall be incorporated into the permit.

(3) The Department or the EPA determines that this permit contains a material mistake or inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.

(4) The Department or the Administrator of EPA determines that the permit must be revised or revoked to assure compliance with the applicable requirements.

(c) Proceedings to revise this permit shall follow the same procedures which apply to initial permit issuance and shall affect only those parts of this permit for which cause to revise exists. The revision shall be made as expeditiously as practicable.

(d) Regardless of whether a revision is made in accordance with (b)(1) above, the permittee shall meet the applicable standards or regulations promulgated under the Clean Air Act within the time frame required by standards or regulations.

#012 [25 Pa. Code § 127.543]**Reopening a Title V Permit for Cause by EPA**

As required by the Clean Air Act and regulations adopted thereunder, this permit may be modified, reopened and reissued, revoked or terminated for cause by EPA in accordance with procedures specified in 25 Pa. Code § 127.543.

#013 [25 Pa. Code § 127.522(a)]**Operating Permit Application Review by the EPA**

The applicant may be required by the Department to provide a copy of the permit application, including the compliance plan, directly to the Administrator of the EPA. Copies of title V permit applications to EPA, pursuant to 25 PA Code §127.522(a), shall be submitted, if required, to the following EPA e-mail box:

R3_Air_Apps_and_Notices@epa.gov

Please place the following in the subject line: TV [permit number], [Facility Name].

**SECTION B. General Title V Requirements****#014 [25 Pa. Code § 127.541]****Significant Operating Permit Modifications**

When permit modifications during the term of this permit do not qualify as minor permit modifications or administrative amendments, the permittee shall submit an application for significant Title V permit modifications in accordance with 25 Pa. Code § 127.541. Notifications to EPA, pursuant to 25 PA Code §127.522(a), if required, shall be submitted, to the following EPA e-mail box:

R3_Air_Apps_and_Notices@epa.gov

Please place the following in the subject line: TV [permit number], [Facility Name].

#015 [25 Pa. Code §§ 121.1 & 127.462]**Minor Operating Permit Modifications**

The permittee may make minor operating permit modifications (as defined in 25 Pa. Code §121.1), on an expedited basis, in accordance with 25 Pa. Code §127.462 (relating to minor operating permit modifications). Notifications to EPA, pursuant to 25 PA Code §127.462(c), if required, shall be submitted, to the following EPA e-mail box:

R3_Air_Apps_and_Notices@epa.gov

Please place the following in the subject line: TV [permit number], [Facility Name].

#016 [25 Pa. Code § 127.450]**Administrative Operating Permit Amendments**

(a) The permittee may request administrative operating permit amendments, as defined in 25 Pa. Code §127.450(a). Copies of request for administrative permit amendment to EPA, pursuant to 25 PA Code §127.450(c)(1), if required, shall be submitted to the following EPA e-mail box:

R3_Air_Apps_and_Notices@epa.gov

Please place the following in the subject line: TV [permit number], [Facility Name].

(b) Upon final action by the Department granting a request for an administrative operating permit amendment covered under §127.450(a)(5), the permit shield provisions in 25 Pa. Code § 127.516 (relating to permit shield) shall apply to administrative permit amendments incorporated in this Title V Permit in accordance with §127.450(c), unless precluded by the Clean Air Act or the regulations thereunder.

#017 [25 Pa. Code § 127.512(b)]**Severability Clause**

The provisions of this permit are severable, and if any provision of this permit is determined by the Environmental Hearing Board or a court of competent jurisdiction, or US EPA to be invalid or unenforceable, such a determination will not affect the remaining provisions of this permit.

#018 [25 Pa. Code §§ 127.704, 127.705 & 127.707]**Fee Payment**

(a) The permittee shall pay fees to the Department in accordance with the applicable fee schedules in 25 Pa. Code Chapter 127, Subchapter I (relating to plan approval and operating permit fees). The applicable fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" with the permit number clearly indicated and submitted to the respective regional office.

(b) Emission Fees. The permittee shall, on or before September 1st of each year, pay applicable annual Title V emission fees for emissions occurring in the previous calendar year as specified in 25 Pa. Code § 127.705. The permittee is not required to pay an emission fee for emissions of more than 4,000 tons of each regulated pollutant emitted from the facility.

(c) As used in this permit condition, the term "regulated pollutant" is defined as a VOC, each pollutant regulated under Sections 111 and 112 of the Clean Air Act and each pollutant for which a National Ambient Air Quality Standard has been promulgated, except that carbon monoxide is excluded.

**SECTION B. General Title V Requirements**

(d) Late Payment. Late payment of emission fees will subject the permittee to the penalties prescribed in 25 Pa. Code § 127.707 and may result in the suspension or termination of the Title V permit. The permittee shall pay a penalty of fifty percent (50%) of the fee amount, plus interest on the fee amount computed in accordance with 26 U.S.C.A. § 6621(a)(2) from the date the emission fee should have been paid in accordance with the time frame specified in 25 Pa. Code § 127.705(c).

(e) The permittee shall pay an annual operating permit maintenance fee according to the following fee schedule established in 25 Pa. Code § 127.704(d) on or before December 31 of each year for the next calendar year.

(1) Eight thousand dollars (\$8,000) for calendar years 2021—2025.

(2) Ten thousand dollars (\$10,000) for calendar years 2026—2030.

(3) Twelve thousand five hundred dollars (\$12,500) for the calendar years beginning with 2031.

#019 [25 Pa. Code §§ 127.14(b) & 127.449]**Authorization for De Minimis Emission Increases**

(a) This permit authorizes de minimis emission increases from a new or existing source in accordance with 25 Pa. Code §§ 127.14 and 127.449 without the need for a plan approval or prior issuance of a permit modification. The permittee shall provide the Department with seven (7) days prior written notice before commencing any de minimis emissions increase that would result from either: (1) a physical change of minor significance under § 127.14(c)(1); or (2) the construction, installation, modification or reactivation of an air contamination source. The written notice shall:

(1) Identify and describe the pollutants that will be emitted as a result of the de minimis emissions increase.

(2) Provide emission rates expressed in tons per year and in terms necessary to establish compliance consistent with any applicable requirement.

The Department may disapprove or condition de minimis emission increases at any time.

(b) Except as provided below in (c) and (d) of this permit condition, the permittee is authorized during the term of this permit to make de minimis emission increases (expressed in tons per year) up to the following amounts without the need for a plan approval or prior issuance of a permit modification:

(1) Four tons of carbon monoxide from a single source during the term of the permit and 20 tons of carbon monoxide at the facility during the term of the permit.

(2) One ton of NO_x from a single source during the term of the permit and 5 tons of NO_x at the facility during the term of the permit.

(3) One and six-tenths tons of the oxides of sulfur from a single source during the term of the permit and 8.0 tons of oxides of sulfur at the facility during the term of the permit.

(4) Six-tenths of a ton of PM₁₀ from a single source during the term of the permit and 3.0 tons of PM₁₀ at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act or 25 Pa. Code Article III.

(5) One ton of VOCs from a single source during the term of the permit and 5.0 tons of VOCs at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act or 25 Pa. Code Article III.

(c) In accordance with § 127.14, the permittee may install the following minor sources without the need for a plan approval:

(1) Air conditioning or ventilation systems not designed to remove pollutants generated or released from other sources.

(2) Combustion units rated at 2,500,000 or less Btu per hour of heat input.

**SECTION B. General Title V Requirements**

(3) Combustion units with a rated capacity of less than 10,000,000 Btu per hour heat input fueled by natural gas supplied by a public utility, liquefied petroleum gas or by commercial fuel oils which are No. 2 or lighter, viscosity less than or equal to 5.82 c St, and which meet the sulfur content requirements of 25 Pa. Code § 123.22 (relating to combustion units). For purposes of this permit, commercial fuel oil shall be virgin oil which has no reprocessed, recycled or waste material added.

(4) Space heaters which heat by direct heat transfer.

(5) Laboratory equipment used exclusively for chemical or physical analysis.

(6) Other sources and classes of sources determined to be of minor significance by the Department.

(d) This permit does not authorize de minimis emission increases if the emissions increase would cause one or more of the following:

(1) Increase the emissions of a pollutant regulated under Section 112 of the Clean Air Act except as authorized in Subparagraphs (b)(4) and (5) of this permit condition.

(2) Subject the facility to the prevention of significant deterioration requirements in 25 Pa. Code Chapter 127, Subchapter D and/or the new source review requirements in Subchapter E.

(3) Violate any applicable requirement of the Air Pollution Control Act, the Clean Air Act, or the regulations promulgated under either of the acts.

(4) Changes which are modifications under any provision of Title I of the Clean Air Act and emission increases which would exceed the allowable emissions level (expressed as a rate of emissions or in terms of total emissions) under the Title V permit.

(e) Unless precluded by the Clean Air Act or the regulations thereunder, the permit shield described in 25 Pa. Code § 127.516 (relating to permit shield) shall extend to the changes made under 25 Pa. Code § 127.449 (relating to de minimis emission increases).

(f) Emissions authorized under this permit condition shall be included in the monitoring, recordkeeping and reporting requirements of this permit.

(g) Except for de minimis emission increases allowed under this permit, 25 Pa. Code § 127.449, or sources and physical changes meeting the requirements of 25 Pa. Code § 127.14, the permittee is prohibited from making physical changes or engaging in activities that are not specifically authorized under this permit without first applying for a plan approval. In accordance with § 127.14(b), a plan approval is not required for the construction, modification, reactivation, or installation of the sources creating the de minimis emissions increase.

(h) The permittee may not meet de minimis emission threshold levels by offsetting emission increases or decreases at the same source.

#020 [25 Pa. Code §§ 127.11a & 127.215]**Reactivation of Sources**

(a) The permittee may reactivate a source at the facility that has been out of operation or production for at least one year, but less than or equal to five (5) years, if the source is reactivated in accordance with the requirements of 25 Pa. Code §§ 127.11a and 127.215. The reactivated source will not be considered a new source.

(b) A source which has been out of operation or production for more than five (5) years but less than 10 years may be reactivated and will not be considered a new source if the permittee satisfies the conditions specified in 25 Pa. Code § 127.11a(b).

#021 [25 Pa. Code §§ 121.9 & 127.216]**Circumvention**

(a) The owner of this Title V facility, or any other person, may not circumvent the new source review requirements of 25 Pa. Code Chapter 127, Subchapter E by causing or allowing a pattern of ownership or development, including the

**SECTION B. General Title V Requirements**

phasing, staging, delaying or engaging in incremental construction, over a geographic area of a facility which, except for the pattern of ownership or development, would otherwise require a permit or submission of a plan approval application.

(b) No person may permit the use of a device, stack height which exceeds good engineering practice stack height, dispersion technique or other technique which, without resulting in reduction of the total amount of air contaminants emitted, conceals or dilutes an emission of air contaminants which would otherwise be in violation of this permit, the Air Pollution Control Act or the regulations promulgated thereunder, except that with prior approval of the Department, the device or technique may be used for control of malodors.

#022 [25 Pa. Code §§ 127.402(d) & 127.513(1)]**Submissions**

(a) Reports, test data, monitoring data, notifications and requests for renewal of the permit shall be submitted to the:

Regional Air Program Manager
PA Department of Environmental Protection
(At the address given on the permit transmittal letter, or otherwise notified)

(b) Any report or notification for the EPA Administrator or EPA Region III should be addressed to:

Enforcement & Compliance Assurance Division
Air, RCRA and Toxics Branch (3ED21)
Four Penn Center
1600 John F. Kennedy Boulevard
Philadelphia, PA 19103-2852

The Title V compliance certification shall be emailed to EPA at R3_APD_Permits@epa.gov.

(c) An application, form, report or compliance certification submitted pursuant to this permit condition shall contain certification by a responsible official as to truth, accuracy, and completeness as required under 25 Pa. Code § 127.402(d). Unless otherwise required by the Clean Air Act or regulations adopted thereunder, this certification and any other certification required pursuant to this permit shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.

#023 [25 Pa. Code §§ 127.441(c) & 127.463(e); Chapter 139; & 114(a)(3), 504(b) of the CAA]**Sampling, Testing and Monitoring Procedures**

(a) The permittee shall perform the emissions monitoring and analysis procedures or test methods for applicable requirements of this Title V permit. In addition to the sampling, testing and monitoring procedures specified in this permit, the Permittee shall comply with any additional applicable requirements promulgated under the Clean Air Act after permit issuance regardless of whether the permit is revised.

(b) The sampling, testing and monitoring required under the applicable requirements of this permit, shall be conducted in accordance with the requirements of 25 Pa. Code Chapter 139 unless alternative methodology is required by the Clean Air Act (including §§ 114(a)(3) and 504(b)) and regulations adopted thereunder.

#024 [25 Pa. Code §§ 127.511 & Chapter 135]**Recordkeeping Requirements**

(a) The permittee shall maintain and make available, upon request by the Department, records of required monitoring information that include the following:

- (1) The date, place (as defined in the permit) and time of sampling or measurements.
- (2) The dates the analyses were performed.
- (3) The company or entity that performed the analyses.
- (4) The analytical techniques or methods used.

**SECTION B. General Title V Requirements**

(5) The results of the analyses.

(6) The operating conditions as existing at the time of sampling or measurement.

(b) The permittee shall retain records of the required monitoring data and supporting information for at least five (5) years from the date of the monitoring sample, measurement, report or application. Supporting information includes the calibration data and maintenance records and original strip-chart recordings for continuous monitoring instrumentation, and copies of reports required by the permit.

(c) The permittee shall maintain and make available to the Department upon request, records including computerized records that may be necessary to comply with the reporting, recordkeeping and emission statement requirements in 25 Pa. Code Chapter 135 (relating to reporting of sources). In accordance with 25 Pa. Code Chapter 135, § 135.5, such records may include records of production, fuel usage, maintenance of production or pollution control equipment or other information determined by the Department to be necessary for identification and quantification of potential and actual air contaminant emissions. If direct recordkeeping is not possible or practical, sufficient records shall be kept to provide the needed information by indirect means.

#025 [25 Pa. Code §§ 127.411(d), 127.442, 127.463(e) & 127.511(c)]**Reporting Requirements**

(a) The permittee shall comply with the reporting requirements for the applicable requirements specified in this Title V permit. In addition to the reporting requirements specified herein, the permittee shall comply with any additional applicable reporting requirements promulgated under the Clean Air Act after permit issuance regardless of whether the permit is revised.

(b) Pursuant to 25 Pa. Code § 127.511(c), the permittee shall submit reports of required monitoring at least every six (6) months unless otherwise specified in this permit. Instances of deviations (as defined in 25 Pa. Code § 121.1) from permit requirements shall be clearly identified in the reports. The reporting of deviations shall include the probable cause of the deviations and corrective actions or preventative measures taken, except that sources with continuous emission monitoring systems shall report according to the protocol established and approved by the Department for the source. The required reports shall be certified by a responsible official.

(c) Every report submitted to the Department under this permit condition shall comply with the submission procedures specified in Section B, Condition #022(c) of this permit.

(d) Any records, reports or information obtained by the Department or referred to in a public hearing shall be made available to the public by the Department except for such records, reports or information for which the permittee has shown cause that the documents should be considered confidential and protected from disclosure to the public under Section 4013.2 of the Air Pollution Control Act and consistent with Sections 112(d) and 114(c) of the Clean Air Act and 25 Pa. Code § 127.411(d). The permittee may not request a claim of confidentiality for any emissions data generated for the Title V facility.

#026 [25 Pa. Code § 127.513]**Compliance Certification**

(a) One year after the date of issuance of the Title V permit, and each year thereafter, unless specified elsewhere in the permit, the permittee shall submit to the Department and EPA Region III a certificate of compliance with the terms and conditions in this permit, for the previous year, including the emission limitations, standards or work practices. This certification shall include:

- (1) The identification of each term or condition of the permit that is the basis of the certification.
- (2) The compliance status.
- (3) The methods used for determining the compliance status of the source, currently and over the reporting period.
- (4) Whether compliance was continuous or intermittent.

(b) The compliance certification shall be postmarked or hand-delivered no later than thirty days after each anniversary of the date of issuance of this Title V Operating Permit, or on the submittal date specified elsewhere in the permit, to the Department in accordance with the submission requirements specified in Section B, Condition #022 of this permit. The Title V compliance certification shall be emailed to EPA at R3_APD_Permits@epa.gov.

**SECTION B. General Title V Requirements****#027 [25 Pa. Code § 127.3]****Operational Flexibility**

The permittee is authorized to make changes within the Title V facility in accordance with the following provisions in 25 Pa. Code Chapter 127 which implement the operational flexibility requirements of Section 502(b)(10) of the Clean Air Act and Section 6.1(i) of the Air Pollution Control Act:

- (1) Section 127.14 (relating to exemptions)
- (2) Section 127.447 (relating to alternative operating scenarios)
- (3) Section 127.448 (relating to emissions trading at facilities with federally enforceable emissions caps)
- (4) Section 127.449 (relating to de minimis emission increases)
- (5) Section 127.450 (relating to administrative operating permit amendments)
- (6) Section 127.462 (relating to minor operating permit amendments)
- (7) Subchapter H (relating to general plan approvals and operating permits)

#028 [25 Pa. Code §§ 127.441(d), 127.512(i) and 40 CFR Part 68]**Risk Management**

(a) If required by Section 112(r) of the Clean Air Act, the permittee shall develop and implement an accidental release program consistent with requirements of the Clean Air Act, 40 CFR Part 68 (relating to chemical accident prevention provisions) and the Federal Chemical Safety Information, Site Security and Fuels Regulatory Relief Act (P.L. 106-40).

(b) The permittee shall prepare and implement a Risk Management Plan (RMP) which meets the requirements of Section 112(r) of the Clean Air Act, 40 CFR Part 68 and the Federal Chemical Safety Information, Site Security and Fuels Regulatory Relief Act when a regulated substance listed in 40 CFR § 68.130 is present in a process in more than the listed threshold quantity at the Title V facility. The permittee shall submit the RMP to the federal Environmental Protection Agency according to the following schedule and requirements:

- (1) The permittee shall submit the first RMP to a central point specified by EPA no later than the latest of the following:
 - (i) Three years after the date on which a regulated substance is first listed under § 68.130; or,
 - (ii) The date on which a regulated substance is first present above a threshold quantity in a process.

(2) The permittee shall submit any additional relevant information requested by the Department or EPA concerning the RMP and shall make subsequent submissions of RMPs in accordance with 40 CFR § 68.190.

(3) The permittee shall certify that the RMP is accurate and complete in accordance with the requirements of 40 CFR Part 68, including a checklist addressing the required elements of a complete RMP.

(c) As used in this permit condition, the term "process" shall be as defined in 40 CFR § 68.3. The term "process" means any activity involving a regulated substance including any use, storage, manufacturing, handling, or on-site movement of such substances or any combination of these activities. For purposes of this definition, any group of vessels that are interconnected, or separate vessels that are located such that a regulated substance could be involved in a potential release, shall be considered a single process.

(d) If the Title V facility is subject to 40 CFR Part 68, as part of the certification required under this permit, the permittee shall:

- (1) Submit a compliance schedule for satisfying the requirements of 40 CFR Part 68 by the date specified in 40 CFR § 68.10(a); or,
- (2) Certify that the Title V facility is in compliance with all requirements of 40 CFR Part 68 including the registration and submission of the RMP.

**SECTION B. General Title V Requirements**

(e) If the Title V facility is subject to 40 CFR Part 68, the permittee shall maintain records supporting the implementation of an accidental release program for five (5) years in accordance with 40 CFR § 68.200.

(f) When the Title V facility is subject to the accidental release program requirements of Section 112(r) of the Clean Air Act and 40 CFR Part 68, appropriate enforcement action will be taken by the Department if:

(1) The permittee fails to register and submit the RMP or a revised plan pursuant to 40 CFR Part 68.

(2) The permittee fails to submit a compliance schedule or include a statement in the compliance certification required under Section B, Condition #026 of this permit that the Title V facility is in compliance with the requirements of Section 112(r) of the Clean Air Act, 40 CFR Part 68, and 25 Pa. Code § 127.512(i).

#029 [25 Pa. Code § 127.512(e)]**Approved Economic Incentives and Emission Trading Programs**

No permit revision shall be required under approved economic incentives, marketable permits, emissions trading and other similar programs or processes for changes that are provided for in this Title V permit.

#030 [25 Pa. Code §§ 127.516, 127.450(d), 127.449(f) & 127.462(g)]**Permit Shield**

(a) The permittee's compliance with the conditions of this permit shall be deemed in compliance with applicable requirements (as defined in 25 Pa. Code § 121.1) as of the date of permit issuance if either of the following applies:

(1) The applicable requirements are included and are specifically identified in this permit.

(2) The Department specifically identifies in the permit other requirements that are not applicable to the permitted facility or source.

(b) Nothing in 25 Pa. Code § 127.516 or the Title V permit shall alter or affect the following:

(1) The provisions of Section 303 of the Clean Air Act, including the authority of the Administrator of the EPA provided thereunder.

(2) The liability of the permittee for a violation of an applicable requirement prior to the time of permit issuance.

(3) The applicable requirements of the acid rain program, consistent with Section 408(a) of the Clean Air Act.

(4) The ability of the EPA to obtain information from the permittee under Section 114 of the Clean Air Act.

(c) Unless precluded by the Clean Air Act or regulations thereunder, final action by the Department incorporating a significant permit modification in this Title V Permit shall be covered by the permit shield at the time that the permit containing the significant modification is issued.

#031 [25 Pa. Code §135.3]**Reporting**

(a) The permittee shall submit by March 1 of each year an annual emissions report for the preceding calendar year. The report shall include information for all active previously reported sources, new sources which were first operated during the preceding calendar year, and sources modified during the same period which were not previously reported. All air emissions from the facility should be estimated and reported.

(b) A source owner or operator may request an extension of time from the Department for the filing of an annual emissions report, and the Department may grant the extension for reasonable cause.

#032 [25 Pa. Code §135.4]**Report Format**

Emissions reports shall contain sufficient information to enable the Department to complete its emission inventory. Emissions reports shall be made by the source owner or operator in a format specified by the Department.

**SECTION C. Site Level Requirements****I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §123.1]****Prohibition of certain fugitive emissions**

(a) No person may permit the emission into the outdoor atmosphere of fugitive air contaminant from a source other than the following:

- (1) Construction or demolition of buildings or structures;
- (2) Grading, paving and maintenance of roads and streets;
- (3) Use of roads and streets. Emissions from material in or on trucks, railroad cars and other vehicular equipment are not considered as emissions from use of roads and streets;
- (4) Clearing of land;
- (5) Stockpiling of materials;
- (6) Open burning operations, as specified in 25 Pa. Code § 129.14;
- (7) - (8) N/A
- (9) Sources and classes of sources other than those identified in (1)-(8) above, for which the permittee has obtained a determination from the Department that fugitive emissions from the source, after appropriate control, meet the following requirements:
 - (i) The emissions are of minor significance with respect to causing air pollution; and
 - (ii) The emissions are not preventing or interfering with the attainment or maintenance of any ambient air quality standard.

002 [25 Pa. Code §123.2]**Fugitive particulate matter**

A person may not permit fugitive particulate matter to be emitted into the outdoor atmosphere from a source specified in 25 Pa. Code § 123.1 (a) if such emissions are visible at the point the emissions pass outside the person's property.

003 [25 Pa. Code §123.31]**Limitations**

A person may not permit the emission into the outdoor atmosphere of any malodorous air contaminants from any source in such a manner that the malodors are detectable outside the property of the person on whose land the source is being operated.

004 [25 Pa. Code §123.41]**Limitations**

A person may not permit the emission into the outdoor atmosphere of visible air contaminants in such a manner that the opacity of the emission is either of the following:

- (a) Equal to or greater than 20% for a period or periods aggregating more than three (3) minutes in any one (1) hour.
- (b) Equal to or greater than 60% at any time.

005 [25 Pa. Code §123.42]**Exceptions**

The opacity limitations of 25 Pa. Code § 123.41 shall not apply to a visible emission in any of the following instances:

- (a) When the presence of uncombined water is the only reason for failure of the emission to meet the limitations.
- (b) When the emission results from the operation of equipment used solely to train and test persons in observing the opacity of visible emissions.
- (c) When the emission results from sources specified in 25 Pa. Code § 123.1(a) (relating to prohibition of certain fugitive emissions).

**SECTION C. Site Level Requirements****# 006 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall limit facility-wide HAP emissions as follows:

- (a) less than 25 tons per year any combination HAP, based on a 12-month rolling sum, and
- (b) less than 10 tons per year any individual HAP, based on a 12-month rolling sum.

007 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall limit facility-wide NOx emissions to less than 99.9 tons per year, based on a 12-month rolling sum.

008 [25 Pa. Code §129.14]**Open burning operations**

No person may permit the open burning of material in the Southeast Air Basin except when the open burning operations result from:

- (a) A fire set to prevent or abate a fire hazard, when approved by the Department and set by or under the supervision of a public officer.
- (b) A fire set for the purpose of instructing personnel in fire-fighting, when approved by the Department.
- (c) A fire set for the prevention and control of disease or pests, when approved by the Department.
- (d) A fire set solely for recreational or ceremonial purposes.
- (e) A fire set solely for cooking food.

II. TESTING REQUIREMENTS.**# 009 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) If at any time the Department has cause to believe that air contaminant emissions from any source may be in excess of the limitations specified in this operating permit, or established pursuant to any applicable rule or regulation contained in 25 Pa. Code Article III, the permittee shall be required to conduct whatever tests are deemed necessary by the Department to determine the actual emission rate(s).

(b) Such testing shall be conducted in accordance with the provisions of 25 Pa. Code Chapter 139 and the most current version of the DEP Source Testing Manual, and the EPA Clean Air Act National Stack Testing Guidance, when applicable, and in accordance with any restrictions or limitations established by DEP at such time as it notifies the permittee that testing is required.

III. MONITORING REQUIREMENTS.**# 010 [25 Pa. Code §123.43]****Measuring techniques**

Visible emissions may be measured using either of the following:

- (a) A device approved by the Department and maintained to provide accurate opacity measurements.
- (b) Observers trained and qualified to measure plume opacity with the naked eye or with the aid of any devices approved by the Department.

011 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

(a) The permittee shall monitor the facility, once per operating day, for the following:

- (1) Odors which may be objectionable (as per 25 Pa. Code § 123.31).
- (2) Visible Emissions (as per 25 Pa. Code §§ 123.41 and 123.42).
- (3) Fugitive Particulate Matter (as per 25 Pa. Code §§ 123.1 and 123.2).

(b) Objectionable odors, fugitive particulate emissions, and visible emissions that are caused or may be caused by

**SECTION C. Site Level Requirements**

operations at the site shall:

- (1) Be investigated;
 - (2) Be reported to the facility management, or individual(s) designated by the permittee;
 - (3) Have appropriate corrective action taken (for emissions that originate on-site); and
 - (4) Be recorded in a permanent written log.
- (c) After six (6) months of daily monitoring, and upon the permittee's request, the Department will determine the feasibility of decreasing the monitoring frequency to weekly.
- (d) After six (6) months of weekly monitoring, and upon the permittee's request, the Department will determine the feasibility of decreasing the monitoring frequency to monthly.
- (e) The Department reserves the right to change the above monitoring requirements at any time, based on but not limited to: the review of the compliance certification, complaints, monitoring results, and/or Department findings.

IV. RECORDKEEPING REQUIREMENTS.**# 012 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall maintain records of all the facility's increases of emissions from the following categories:

- (a) De minimis increases without notification to the Department.
- (b) De minimis increases with notification to the Department, via letter.
- (c) Increases resulting from a Request for Determination (RFD) to the Department.
- (d) Increases resulting from the issuance of a plan approval and subsequent operating permit.

013 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall maintain a record of all monitoring of fugitive emissions, visible emissions and odors, including those that deviate from the conditions found in this permit. The record of deviations shall contain, at a minimum, the following items:

- (a) Date, time, and location of the incident(s).
- (b) The cause of the event.
- (c) The corrective action taken, if necessary to abate the situation and prevent future occurrences.

014 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

- (a) The permittee shall maintain records of facility-wide NOx emissions on a monthly basis, including 12-month rolling sums.
- (b) The permittee shall maintain records of facility-wide individual HAP emissions on a monthly basis, including 12-month rolling sums.
- (c) The permittee shall maintain records of facility-wide total HAP emissions on a monthly basis, including 12-month rolling sums.

015 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall maintain records of the facility-wide amount of natural gas consumed on a monthly and 12-month rolling basis.

V. REPORTING REQUIREMENTS.**# 016 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

- (a) The permittee shall report malfunctions, emergencies or incidents of excess emissions to the Department at 484-250-

**SECTION C. Site Level Requirements**

5920. A malfunction is any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner. An emergency is any situation arising from sudden and reasonably unforeseeable events beyond the control of the owner or operator of a facility which requires immediate corrective action to restore normal operation and which causes the emission source to exceed emissions, due to unavoidable increases in emissions attributable to the situation. An emergency shall not include situations caused by improperly designed equipment, lack of preventive maintenance, careless or improper operation, or operator error.

(b) When the malfunction, emergency or incident of excess emissions poses an imminent danger to the public health, safety, welfare, or environment, it shall be reported to the Department and the County Emergency Management Agency by telephone within one (1) hour after the discovery of the malfunction, emergency or incident of excess emissions. The owner or operator shall submit a written or emailed report of instances of such malfunctions, emergencies or incidents of excess emissions to the Department within three (3) business days of the telephone report.

(c) The report shall describe the following:

- (1) Name, permit or authorization number, and location of the facility;
- (2) Nature and cause of the malfunction, emergency or incident;
- (3) Date and time when the malfunction, emergency or incident was first observed;
- (4) Expected duration of excess emissions;
- (5) Estimated rate of emissions; and
- (6) Corrective actions or preventative measures taken.

(d) Any malfunction, emergency or incident of excess emissions that is not subject to the notice requirements of paragraph (b) of this condition shall be reported to the Department by telephone within 24 hours (or by 4:00 PM of the next business day, whichever is later) of discovery and in writing or by e-mail within five (5) business days of discovery. The report shall contain the same information required by paragraph (c), and any permit specific malfunction reporting requirements.

(e) During an emergency an owner or operator may continue to operate the source at their discretion provided they submit justification for continued operation of a source during the emergency and follow all the notification and reporting requirements in accordance with paragraphs (b)-(d), as applicable, including any permit specific malfunction reporting requirements.

(f) Reports regarding malfunctions, emergencies or incidents of excess emissions shall be submitted to the appropriate DEP Regional Office Air Program Manager.

(g) Any emissions resulted from malfunction or emergency are to be reported in the annual emissions inventory report, if the annual emissions inventory report is required by permit or authorization.

017 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code §§ 127.511(c)(1)-(2) and 127.513(5)(i)-(v).]

The permittee shall submit the following reports:

(a) An annual certificate of compliance, due by April 1st of each year, for the period covering January 1 through December 31 of the previous year. This certificate of compliance shall document compliance with all permit terms and conditions set forth in this Title V Permit as required under 25 Pa. Code § 127.513. The annual certificate of compliance shall be submitted to DEP electronically and to EPA Region III in electronic form at the following email address: R3_APD_Permits@epa.gov. The subject line shall read: "TVOP No. 46-00298, GlaxoSmithKline - Upper Merion - East."

(b) A semi-annual deviation report to DEP by October 1 of each year, for the period covering January 1–June 30, of the same year. [Note: The annual certificate of compliance in (a)(1), above, fulfills the obligation for the second deviation reporting period (i.e., July 1–December 31, of the previous year).]

018 [25 Pa. Code §135.21]**Emission statements**

**SECTION C. Site Level Requirements**

The permittee shall submit by March 1, of each year, an annual emission statement summarizing actual facility-wide NO_x and VOC emissions for the preceding calendar year. Additionally, a description of the method used to calculate the emissions shall be included. The statement shall contain a certification by a company official or plant manager that the information contained in the statement is true and accurate.

VI. WORK PRACTICE REQUIREMENTS.**# 019 [25 Pa. Code §123.1]****Prohibition of certain fugitive emissions**

A person responsible for any source specified in 25 Pa. Code § 123.1 shall take all reasonable actions to prevent particulate matter from becoming airborne. These actions shall include, but not be limited to, the following:

- (a) Use, where possible, of water or suitable chemicals, for control of dust in the demolition of buildings or structures, construction operations, the grading of roads, or the clearing of land;
- (b) Application of asphalt, water, or other suitable chemicals, on dirt roads, material stockpiles and other surfaces which may give rise to airborne dusts;
- (c) Paving and maintenance of roadways; and
- (d) Prompt removal of earth or other material from paved streets onto which earth or other material has been transported by trucking or earth moving equipment, erosion by water, or by other means.

020 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall immediately, upon discovery, implement measures which may include the application for the installation of air cleaning device(s), if necessary, to reduce the air contaminant emissions to within applicable limitations, if at any time the operation of the source(s) identified in Section A of this operating permit is causing the emission of air contaminants in excess of the limitations specified in, or established pursuant to 25 Pa. Code Article III or any other applicable rule promulgated under the Clean Air Act.

021 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall ensure that all sources are operated and maintained in accordance with manufacturer's specifications and good engineering and air pollution control practices.

022 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.512.]

The permittee may not modify any air contaminant system identified in this permit prior to obtaining Department approval except those modifications authorized by Condition #019(g) of Section B of this permit.

023 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6]**Subpart A--General Provisions****Compliance with standards and maintenance requirements.**

Operation and maintenance requirements.

- (a) At all times, including periods of startup, shutdown, and malfunction, owners or operators shall operate and maintain any affected source, including associated air pollution control equipment, in a manner consistent with good air pollution control practices for minimizing emissions at least to the levels required by all relevant standards.
- (b) Malfunctions shall be corrected as soon as practicable after their occurrence in accordance with the startup, shutdown, and malfunction plan required.
- (c) Operation and maintenance requirements established pursuant to Section 112 of the Clean Air Act are enforceable independent of emissions limitations or other requirements in relevant standards.

**SECTION C. Site Level Requirements****VII. ADDITIONAL REQUIREMENTS.****# 024 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The air contaminant sources located at the two (2) facilities listed below which are permitted respectively under Title V Operating Permit No. 46-00298 and 46-00300, shall be considered as a single facility for New Source Review (NSR), Prevention of Deterioration (PSD), and Title V applicability purposes:

- (1) TVOP No. 46-00298 GSK - East
- (2) TVOP No. 46-00300 GSK - BioPharm.

VIII. COMPLIANCE CERTIFICATION.

No additional compliance certifications exist except as provided in other sections of this permit including Section B (relating to Title V General Requirements).

IX. COMPLIANCE SCHEDULE.

No compliance milestones exist.

***** Permit Shield In Effect *****

**SECTION D. Source Level Requirements**

Source ID: 054

Source Name: BOILER NO. 1 (CENTRAL UTILITY PLANT)

Source Capacity/Throughput: 48.988 MMBTU/HR


46,655.000 CF/HR

Natural Gas

349.900 Gal/HR

#2 Oil

Conditions for this source occur in the following groups: GROUP 1A
 GROUP 1B
 GROUP 1C
 GROUP 1D

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

001 [25 Pa. Code §127.441]

Operating permit terms and conditions.

This boiler is manufactured by Cleaver Brooks; it has a maximum heat input of 48.988 MMBtu/hr and is equipped with a low-

**SECTION D. Source Level Requirements**

NOx burner, flue gas recirculation, and an oxygen trim system.

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

NOx burner, flue gas recirculation, and an oxygen trim system.

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 056

Source Name: BOILER NO. 3 (CENTRAL UTILITY PLANT)

Source Capacity/Throughput: 24.494 MMBTU/HR

23,327.600 CF/HR

Natural Gas


175.000 Gal/HR

#2 Oil

Conditions for this source occur in the following groups: GROUP 1A

GROUP 1B

GROUP 1D

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

001 [25 Pa. Code §127.441]

Operating permit terms and conditions.

This boiler is manufactured by Cleaver Brooks; it has a maximum heat input of 24.494 MMBtu/hr and is equipped with a low-NOx burner, flue gas recirculation, and an oxygen trim system.



SECTION D. Source Level Requirements

***** Permit Shield in Effect. *****



SECTION D. Source Level Requirements

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 102


Source Name: 180 KW KOHLER EGEN 10-2 (CUMMINS ENGINE)

Source Capacity/Throughput:

N/A

#2 Oil

Conditions for this source occur in the following groups: GROUP 3A
GROUP 3B
GROUP 4

**I. RESTRICTIONS.****Operation Hours Restriction(s).****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall limit the hours of operation for this source to 500 hours per year, based on a 12-month rolling sum.

[Note: The 500 hours per 12-month rolling period includes the hours of operation as per the compliance requirements for emergency engines in accordance with 40 CFR § 63.6640(f).]

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

**SECTION D. Source Level Requirements****VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 103


Source Name: 510 KW MARATHON EGEN 11-1 (DETROIT DIESEL ENGINE)

Source Capacity/Throughput:

N/A

#2 Oil

Conditions for this source occur in the following groups: GROUP 3A
GROUP 3B

**I. RESTRICTIONS.****Operation Hours Restriction(s).****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 129.91-95.]

The permittee shall limit the hours of operation for this source to 500 hours per year, based on a 12-month rolling sum.

[Note: The 500 hours per 12-month rolling period includes the hours of operation as per the compliance requirements for emergency engines in accordance with 40 CFR § 60.4211(f).]

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

**SECTION D. Source Level Requirements****VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 104


Source Name: 1,200 KW DETROIT EGEN 4-1A (DETROIT DIESEL ENGINE)

Source Capacity/Throughput:

N/A

#2 Oil

Conditions for this source occur in the following groups: GROUP 3A
GROUP 3B
GROUP 5

**I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 129.91-95.]

The permittee shall limit NO_x emissions from this source to 4.0 tons per year, based on a 12-month rolling sum.**Operation Hours Restriction(s).****# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 129.91-95.]

The permittee shall limit the hours of operation for this source to 500 hours per year, based on a 12-month rolling sum.

[Note: The 500 hours per 12-month rolling period includes the hours of operation as per the compliance requirements for emergency engines in accordance with 40 CFR § 63.6640(f).]

Throughput Restriction(s).**# 003 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 129.91-95.]

The permittee shall limit the amount of fuel oil consumed by this engine to 17,000 gallons per year, based on a 12-month rolling sum.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

**SECTION D. Source Level Requirements****IV. RECORDKEEPING REQUIREMENTS.****# 004 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall maintain monthly and 12-month rolling sums of NOx emissions for this engine.

005 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall record the amount of fuel used by this source on a monthly and 12-month rolling sum.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 106


Source Name: 1,500 KW MTU EGEN 38-3 (DETROIT DIESEL ENGINE)

Source Capacity/Throughput:

N/A

#2 Oil

Conditions for this source occur in the following groups: GROUP 3A
 GROUP 3B
 GROUP 4
 GROUP 5

**I. RESTRICTIONS.****Throughput Restriction(s).****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall limit the amount of fuel used by this EGEN to 10,290 gallons per year, based on a 12-month rolling sum.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.**# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall maintain records of the amount of fuel used by the EGEN on a monthly basis and 12-month rolling sum.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).



SECTION D. Source Level Requirements

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 107

Source Name: 2,500 KW CATERPILLAR EGEN 3-3 (CATERPILLAR ENGINE)

Source Capacity/Throughput:

N/A

#2 Oil

Conditions for this source occur in the following groups: GROUP 2A
 GROUP 2B
 GROUP 2C
 GROUP 4
 GROUP 5

**I. RESTRICTIONS.****Throughput Restriction(s).****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall limit the amount of fuel used by this EGEN to 17,330 gallons per year, based on a 12-month rolling sum.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.**# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall maintain records of the amount of fuel used by this EGEN on a monthly basis and 12-month rolling sum.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.**# 003 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4205]****Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines****What emission standards must I meet for emergency engines if I am an owner or operator of a stationary CI internal combustion engine?**

[Additional authority for this permit condition is also derived from 25 Pa. Code Chapter 122, 40 CFR § 60.4202(b)(1), and 40 CFR § 60.4205(b).]

**SECTION D. Source Level Requirements**

The emergency stationary CI internal combustion engine shall be certified to meet the Tier 2 emission standards specified in Table 1 of 40 CFR Part 60 Subpart IIII for 2007 model year and later engines with a maximum engine power greater than 560 kW:

- (a) HC: 1.0 g/hp-hr
- (b) NO_x: 6.9 g/hp-hr
- (c) CO: 8.5 g/hp-hr
- (d) PM: 0.40 g/hp-hr

[Compliance with the emission standards of 40 CFR Part 60 Subpart IIII Table 1 is demonstrated through the engine certification for emissions for this engine: i.e. Tier 2 Technical Data by Caterpillar.]

VII. ADDITIONAL REQUIREMENTS.

004 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The 2008 Caterpillar Diesel Generator Set is powered by a EPA Tier 2 CAT 3516C-HD TA diesel engine manufactured by Caterpillar, Model Year 2007 Family 7CPXL78.1T2E, rated at 2701 kW (3622 HP).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 108


Source Name: 150 KW TAYLOR EGEN 17-1 (PERKINS ENGINE)

Source Capacity/Throughput:

N/A

#2 Oil

Conditions for this source occur in the following groups: GROUP 2A
GROUP 2C
GROUP 4

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

**# 001 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4205]
Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
What emission standards must I meet for emergency engines if I am an owner or operator of a stationary CI internal combustion engine?**

[Additional authority for this permit condition is also derived from 25 Pa. Code Chapter 122, 40 CFR § 60.4202(a)(2), 40 CFR § 60.4205(b), and 40 CFR § 89.112.]

The emergency stationary CI internal combustion engine shall be certified to meet the emission standards specified in Table 1 of 40 CFR § 89.112 for Model Year 2006 and later engines with a maximum engine power greater than 130 kW and less than 225 kW:

- (a) NMHC+NO_x: 4.0 g/kW-hr
- (b) CO: 3.5 g/kW-hr

**SECTION D. Source Level Requirements**

(c) PM: 0.20 g/kW-hr

[Compliance with the emission standards of 40 CFR Part 60 Subpart IIII and 40 CFR § 89.112 Table 1 is demonstrated through the engine certification for emissions for this engine: i.e. Certificate of Conformity for 2011 Model Year Perkins Engine Family BPKXL06.6PJ1, Certificate No. PKX-NRCI-11-10.]

002 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4211]

Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines

What are my compliance requirements if I am an owner or operator of a stationary CI internal combustion engine?

[Additional authority for this permit condition is also derived from 25 Pa. Code Chapter 122 and 40 CFR § 60.4211(g)(2).]

If the permittee does not install, configure, operate, and maintain the engine according to the manufacturer's emission related written instructions, or the permittee changes emission-related settings in a way that is not permitted by the manufacturer, the permittee shall demonstrate compliance as follows:

For the engine which is greater than or equal to 100 HP and less than or equal to 500 HP, the permittee shall keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, the permittee shall conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of startup, or within 1 year after an engine and control device is no longer installed, configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after you change emission-related settings in a way that is not permitted by the manufacturer.

VII. ADDITIONAL REQUIREMENTS.

003 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The Taylor Generator Set is powered by a 2011 Model Year 274 HP diesel engine manufactured by Perkins Engine Co. Engine Family: BPKXL06.6PJ1, Certification No. PKX-NRCI-11-10.

***** Permit Shield in Effect. *****


**SECTION D. Source Level Requirements**

Source ID: 109

Source Name: 2,000 KW MTU EGEN 56-1 (CUP)

Source Capacity/Throughput: 147.300 Gal/HR Diesel Fuel

Conditions for this source occur in the following groups: GROUP 2A
 GROUP 2B
 GROUP 2C
 GROUP 5

**I. RESTRICTIONS.****Throughput Restriction(s).****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall limit the fuel usage for the stationary CI ICE to less than 27,600 gallons per year based on a 12-month rolling sum.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.**# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall monitor the amount of fuel consumed in the engine on a monthly basis using a fuel meter.

IV. RECORDKEEPING REQUIREMENTS.**# 003 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall maintain records of the amount of fuel consumed in the engine on a monthly basis, including 12-month rolling sums.

004 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall maintain records of NO_x, VOC, PM, SO₂, CO, and HAP emissions from the engine on a monthly basis, including 12-month rolling sums.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

**SECTION D. Source Level Requirements****VI. WORK PRACTICE REQUIREMENTS.****# 005 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4205]****Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines****What emission standards must I meet for emergency engines if I am an owner or operator of a stationary CI internal combustion engine?**

[Additional authority for this permit condition is also derived from 25 Pa. Code Chapter 122, 40 CFR § 60.4202(a)(2), 40 CFR § 60.4205(b), and 40 CFR § 89.112.]

The emergency stationary CI internal combustion engine shall be certified to meet the Tier 2 emission standards specified in Table 1 of 40 CFR Part 89 Subpart B for 2006 model year engines with a maximum engine power greater than 560 kW:

- (a) NMHC + NO_x: 6.4 g/kW-hr
- (b) PM: 0.20 g/kW-hr
- (c) CO: 3.5 g/kW-hr

[Compliance with the emission standards of 40 CFR Part 60 Subpart IIII and 40 CFR Part 89 Subpart B, Table 1 is demonstrated through the engine certification for emissions for this engine: i.e. Tier 2 Emission Data Sheet.]

VII. ADDITIONAL REQUIREMENTS.**# 006 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The stationary CI ICE associated with this Source ID is an MTU Tier 2- certified, 16-cylinder unit rated at 3,058 brake horsepower, with a displacement of 76.3 liters per cylinder; MTU 16V4000 DS2000 45°C.

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 110

Source Name: 600 KW GENERAC EGEN (PERKINS ENGINE)

Source Capacity/Throughput:

41.400 Gal/HR

Diesel Fuel

Conditions for this source occur in the following groups: GROUP 2A
GROUP 2B
GROUP 2C

**I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from BAT standards, BAQ-GPA/GP-9, Condition No. 7(b) for diesel-fired engines 750<hp<1,000, operating more than 100 hours per year.]

The permittee shall comply with the CO emission standard of 2.7 g/kW-hr (2.0 g/bhp-hr).

[Compliance with the CO emission standard of this condition is demonstrated through the engine certification for emissions for this engine: i.e. Tier 2, Engine Family NCPXL18.1NYS, Certificate No. NCPXL18.1NYS-003.]

[The CO emission standard of this condition is more stringent and streamlines compliance with the CO emission standard of 40 CFR Part 60 Subpart IIII and 40 CFR Part 1039 applicable to this engine.]

Throughput Restriction(s).**# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall limit the amount of diesel fuel oil used in the engine to 8,280 gallons per year, based on a 12-month rolling sum.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.**# 003 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall maintain monthly and 12-month rolling sums of the amount of diesel fuel used in the engine.

**SECTION D. Source Level Requirements****V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.**# 004 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 40 CFR Part 60 Subpart III.]

The permittee shall certify the 909-hp Perkins engine is compliant with Tier 2 emission standards specified in Table 2 of Appendix 1, 40 CFR Part 1039 for Model Year 2006 and later emergency, nonroad, stationary CI internal combustion engines with a maximum engine power greater than or equal to 37 kW and less than or equal to 2,237 kW with a displacement of less than 10 liters per cylinder that are not fire pump engines.

005 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4205]**Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines****What emission standards must I meet for emergency engines if I am an owner or operator of a stationary CI internal combustion engine?**

[Additional authority for this permit condition is also derived from 25 Pa. Code Chapter 122, 40 CFR § 60.4202(a)(2), 40 CFR § 60.4205(b), and 40 CFR Part 1039 Appendix I, Table 2.]

The emergency stationary CI internal combustion engine shall be certified to meet the Tier 2 emission standards specified in Table 2 of Appendix 1 of 40 CFR Part 1039 for Model Year 2006 emergency, nonroad, stationary CI internal combustion engines with a maximum engine power greater than or equal to 37 kW and less than or equal to 2,237 kW with a displacement of less than 10 liters per cylinder that are not fire pump engines:

- (a) NO_x + NMHC: 6.4 g/kW-hr (4.8 g/hp-hr)
- (b) PM: 0.20 g/kW-hr (0.15 g/hp-hr)

[Compliance with the emission standards of 40 CFR Part 60 Subpart III and 40 CFR Part 1039 is demonstrated through the engine certification for emissions for this engine: i.e. Tier 2, Engine Family NCPXL18.1NYS, Certificate No. NCPXL18.1NYS-003.]

[The PM emission standard of 40 CFR Part 60 Subpart III and 40 CFR Part 1039 is more stringent and streamlines compliance with the PM emission standard of 25 Pa. Code § 123.13(c)(1)(i).]

VII. ADDITIONAL REQUIREMENTS.**# 006 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The 600-kw electric generator (EGEN) powered by a Tier 2 909-hp diesel-fired engine is located in Building 4.

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 205

Source Name: NO. 2 OIL STORAGE TANK (CENTRAL UTILITY PLANT)

Source Capacity/Throughput:

I. RESTRICTIONS.**Fuel Restriction(s).****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall store only No. 2 fuel oil or equivalent in this above ground storage tank (AST).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.**# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) The permittee shall monitor and calculate the fuel throughput, in gallons, through the AST on a monthly basis and a 12-month rolling sum.

(b) The permittee shall monitor and calculate the amount of VOC emissions emitted from the AST on a monthly basis and 12-month rolling sum.

IV. RECORDKEEPING REQUIREMENTS.**# 003 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) The permittee shall maintain records of the fuel throughput, in gallons, through the AST on a monthly basis and a 12-month rolling sum.

(b) The permittee shall maintain records of the amount of VOC emissions emitted from the AST on a monthly basis and 12-month rolling sum.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: GROUP 1A

Group Description: General Combustion Unit Regs

Sources included in this group

ID	Name
054	BOILER NO. 1 (CENTRAL UTILITY PLANT)
055	BOILER NO. 2 (CENTRAL UTILITY PLANT)
056	BOILER NO. 3 (CENTRAL UTILITY PLANT)
057	BOILER NO. 4 (CENTRAL UTILITY PLANT)

I. RESTRICTIONS.**Emission Restriction(s).****# 001 [25 Pa. Code §123.11]****Combustion units**

A person may not permit the emission into the outdoor atmosphere of particulate matter from a combustion unit in excess of 0.4 pounds per million Btu of heat input, pursuant to 25 Pa. Code § 123.11(a)(1).

[The method of compliance for this condition is the use of compliant fuels as required herein.]

002 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

For the purposes of demonstrating compliance with Best Available Technology (BAT), as codified in 25 Pa. Code § 127.12, the permittee shall maintain the boiler manufacturer's emission data on file in order to demonstrate that the boiler meets the following emission limits.

- (1) 30 ppm_{dv} NO_x at 3% O₂ when firing natural gas
- (2) 90 ppm_{dv} NO_x at 3% O₂ when firing No. 2 fuel oil
- (3) 300 ppm_{dv} CO at 3% O₂.

003 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

(a) The permittee shall limit emissions from this boiler when firing No. 2 fuel oil as follows:

- (1) NO_x emissions are limited to 0.0140 lb/gal,
- (2) CO emissions are limited to 0.0106 lb/gal.

(b) The permittee shall limit emissions from this boiler when firing natural gas as follows:

- (1) NO_x emissions are limited to 0.015 lb/1.00E+03 scf,
- (2) CO emissions are limited to 0.077 lb/1.00E+03 scf.

Fuel Restriction(s).**# 004 [25 Pa. Code §123.22]****Combustion units**

A person may not offer for sale, deliver for use, exchange in trade or permit the use of commercial fuel oil in a combustion unit in the Southeast Pennsylvania Air Basin if the commercial fuel oil contains sulfur in excess of 15 ppm (0.0015%) by weight sulfur content for No. 2 fuel oil, in accordance with 25 Pa. Code § 123.22(e)(2)(i), except as allowable in 25 Pa. Code § 123.22(e)(2)(ii) and (iii).

[Compliance with this condition assures compliance with the sulfur emission rate of 1.0 lb SO₂/MMBtu as found in 25 Pa. Code § 123.22(e)(1) for the inner zone, while firing No. 2 fuel oil.]

[Compliance with this condition assures compliance with the sulfur content of fuel oil requirement of 0.5% sulfur by weight as found in 40 CFR § 60.42c(d).]

**SECTION E. Source Group Restrictions.****# 005 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall burn natural gas or No. 2 fuel oil only in this boiler.

Throughput Restriction(s).**# 006 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The following fuel throughput limits have been established for the four boilers:

- (a) The total amount of No. 2 fuel oil fired in the four boilers, combined, Source IDs 054, 055, 056 and 057, shall not exceed 1,029,022 gallons in a 12-month rolling period.
- (b) The total amount of natural gas fired in the four boilers, combined, Source IDs 054, 055, 056 and 057, shall not exceed 702.58 million cubic feet in a 12-month rolling period.
- (c) This emissions cap does not provide any relief from obtaining a plan approval for any future physical change or change in the method of operation of any of the boilers, or the addition or modification of any steam-consuming processes at the facility. Future applicability determinations must consider the baseline actual emissions of the emissions units and not the cap. The latter is true even if the company does not request a change in the compliance cap. Furthermore, by accepting this cap and agreeing to consider the four boilers as one emissions unit for NSR/PSD purposes, any future applicability determinations must involve all four boilers, e.g. should major NSR/PSD be triggered for any one boiler or process change, BACT/LAER is required for all four boilers.

II. TESTING REQUIREMENTS.**# 007 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

- (a) The permittee shall demonstrate compliance with the NO_x and CO emission limitations as established in Condition #003 for this boiler by conducting a stack test for this source using Department-approved procedures once within the life of the permit, then once every five (5) calendar years thereafter, where five (5) calendar years is defined as beginning with the calendar year the latest stack test was performed and ending on December 31, five (5) years later. The stack test shall be conducted as follows:
- (1) The permittee may test one of the following boilers on a rotational basis: Source ID 054, 055, 056, or 057, to demonstrate compliance with the emission limits for all boilers Source ID 054, 055, 056, and 057.
 - (2) Performance tests shall be conducted while the source is operating at maximum routine operating conditions or under other such conditions, within the capacity of the equipment, as may be requested by the Department.
 - (3) The stack test shall be performed for each fuel that has been consumed in the boiler for thirty (30) cumulative days or more during a 12-month rolling period. Justification for not testing the boiler while firing any of the fuels approved for use shall be provided in the protocol; documenting the number of operating days the boiler ran on any fuel not tested shall be included in the protocol, as applicable.
 - (4) Refer to PADEP Source Testing Program website online for further information related to source testing including Source Testing FAQ and the PADEP Source Testing Manual.
 - (5) The stack test shall, at a minimum, test for Nitrogen Oxides and Carbon Monoxide emissions. The permittee shall measure the stack volume exhaust rate during testing in order to calculate NO_x and CO emission factors (lb/CF or lb/gal, as applicable) to be used in emission calculations for this boiler. Tests shall be conducted in accordance with the provisions Department-approved EPA Test Methods or other Department-approved methodology and 25 Pa. Code Chapter 139, including the procedures of the most recent DEP Source Testing Manual.
- (b) At least ninety (90) days prior to the test, the permittee shall submit to the Department for approval the procedures for the test and a sketch with dimensions indicating the location of sampling ports and other data to ensure the collection of

**SECTION E. Source Group Restrictions.**

representative samples.

(c) At least thirty (30) days prior to the test, the Regional Air Quality Manager shall be informed of the date and time of the test.

(d) Within sixty (60) days after the source test(s), one electronic copy of the complete test report, including all operating conditions, shall be submitted to the Regional Air Quality Manager for approval.

(e) In the event that any of the above deadlines cannot be met, the permittee may request an extension for the due date(s) in writing and include a justification for the extension. The Department may grant an extension for a reasonable cause.

008 [25 Pa. Code §139.16]**Sulfur in fuel oil.**

(a) The following are applicable to tests for the analysis of commercial fuel oil:

(1) The fuel oil sample for chemical analysis shall be collected in a manner that provides a representative sample. Upon the request of a Department official, the person responsible for the operation of the source shall collect the sample employing the procedures and equipment specified in 25 Pa. Code § 139.4(10) (relating to references).

(2) Test methods and procedures for the determination of viscosity shall be that specified in 25 Pa. Code § 139.4(11) (relating to references). The viscosity shall be determined at 100°F.

(3) Tests methods and procedures for the determination of sulfur shall be those specified in 25 Pa. Code § 139.4(12)--(15) and (20).

(4) Results shall be reported in accordance with the units specified in 25 Pa. Code § 123.22 (relating to combustion units).

(b) The testing requirements in subpart (a) above shall be waived in the event that a delivery receipt from the supplier, showing the percentage sulfur in the fuel, is obtained each time a fuel oil delivery is made.

[Compliance with this streamlined permit condition assures compliance with 40 CFR § 60.42c(h)(1), 40 CFR §§ 60.46c(e) and § 60.48c(f)(1), referring to sulfur dioxide standard, emission monitoring for sulfur dioxide, and testing fuel oil for sulfur content, respectively.]

III. MONITORING REQUIREMENTS.**# 009 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall calculate NO_x and CO emissions from this boiler on a monthly basis and 12-month rolling sum using the emission factors determined during the latest source test, as applicable.

IV. RECORDKEEPING REQUIREMENTS.**# 010 [25 Pa. Code §123.22]****Combustion units**

(a) The permittee shall maintain in electronic or paper format the record provided by the transferor for the shipment of commercial fuel oil as it changed hands to the permittee (ultimate consumer). This record must legibly and conspicuously contain the following information, in accordance with 25 Pa. Code § 123.22(g)(1) and (5):

(1) The date of the sale or transfer.

(2) The name and address of the transferor.

(3) The name and address of the transferee.

(4) The volume of commercial fuel oil being sold or transferred.

(5) The identification of the sulfur content of the shipment of commercial fuel oil, determined using the sampling and

**SECTION E. Source Group Restrictions.**

testing methods specified in 25 Pa. Code § 123.22(f)(1) and § 139.16, expressed as the following statement for a shipment of No. 2 commercial fuel oil: "The sulfur content of this shipment is 15 ppm or below."

(6) The location of the commercial fuel oil at the time of transfer.

(b) The permittee shall maintain the applicable records in electronic or paper format for 5 years, in accordance with 25 Pa. Code § 123.22(g)(4)(i).

011 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall maintain records of NO_x, CO, VOC, PM, SO₂, and HAP emissions for this boiler on a monthly basis and 12-month rolling sum.

012 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

(a) The permittee shall maintain records of the hours of operation for this boiler on a monthly basis and 12-month rolling sum.

(b) The permittee shall maintain records of the aggregate amount of each fuel type (No. 2 and natural gas) consumed in the boilers listed as Source ID 054, 055, 056, and 057 on a monthly basis and 12-month rolling sum.

V. REPORTING REQUIREMENTS.**# 013 [25 Pa. Code §123.22]****Combustion units**

The permittee shall provide an electronic or written copy of the commercial fuel oil shipment record to the Department upon request, in accordance with 25 Pa. Code § 123.22(g)(4)(ii).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.**# 014 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

This boiler is equipped with low NO_x burners and flue gas recirculation.

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: GROUP 1B

Group Description: Subpart Dc - All Boilers

Sources included in this group

ID	Name
054	BOILER NO. 1 (CENTRAL UTILITY PLANT)
055	BOILER NO. 2 (CENTRAL UTILITY PLANT)
056	BOILER NO. 3 (CENTRAL UTILITY PLANT)
057	BOILER NO. 4 (CENTRAL UTILITY PLANT)

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

**# 001 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.48c]
Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units
Reporting and recordkeeping requirements.**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.441]

The permittee shall monitor the amounts of each fuel combusted in this boiler during each month, pursuant to 40 CFR § 60.48c(g).

IV. RECORDKEEPING REQUIREMENTS.

**# 002 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.48c]
Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units
Reporting and recordkeeping requirements.**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.441]

The permittee shall record and maintain records of the amounts of each fuel combusted in this boiler during each month, pursuant to 40 CFR § 60.48c(g).

V. REPORTING REQUIREMENTS.

**# 003 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.48c]
Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units
Reporting and recordkeeping requirements.**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.441]

(a) The permittee shall submit fuel oil sulfur reports required in 40 CFR § 60.48c(d) to DEP, pursuant to 40 CFR § 60.48c(d) (fuel oil sulfur limit reports) and 40 CFR § 60.4.

(b) The reporting period for the reports required is each six-month period. All reports shall be postmarked by the 30th day following the end of the reporting period, pursuant to 40 CFR § 60.48c(j).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).



SECTION E. Source Group Restrictions.

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: GROUP 1C

Group Description: Subpart Dc - Boilers greater than 30 MMBtu/hr

Sources included in this group

ID	Name
054	BOILER NO. 1 (CENTRAL UTILITY PLANT)
055	BOILER NO. 2 (CENTRAL UTILITY PLANT)

I. RESTRICTIONS.**Emission Restriction(s).****# 001 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.43c]****Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Standard for particulate matter.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Chapter 122 and 40 CFR § 60.43c(c) and (b).]

(a) When firing fuel oil in the boiler, the permittee shall not cause to be discharged into the atmosphere from the boiler any gases that exhibit greater than 20 percent opacity (6-minute average), except for one 6-minute period per hour of not more than 27 percent opacity.

(b) When firing fuel oil in the boiler, the opacity standard applies at all times, except during periods of startup, shutdown, or malfunction.

[Note: The initial Method 9 performance test was conducted on April 2, 2020.]

II. TESTING REQUIREMENTS.**# 002 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.45c]****Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Compliance and performance test methods and procedures for particulate matter.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Chapter 122 and 40 CFR § 60.45c(a).]

The permittee shall conduct subsequent performance tests as requested by the Administrator, to determine compliance with the opacity standard of 40 CFR § 60.43c using the procedures of Method 9 of Appendix A-4.

003 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.47c]**Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Emission monitoring for particulate matter.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Chapter 122 and 40 CFR § 60.47c(1)]

As an alternative to performing subsequent Method 9 performance tests, the permittee may elect to perform subsequent monitoring using Method 22 of Appendix A-7 of Part 60 according to the following procedures:

(a) The permittee shall conduct 10 minute observations (during normal operation) each operating day the affected facility fires fuel for which an opacity standard is applicable using Method 22 of appendix A-7 of this part and demonstrate that the sum of the occurrences of any visible emissions is not in excess of 5 percent of the observation period (i.e., 30 seconds per 10 minute period). If the sum of the occurrence of any visible emissions is greater than 30 seconds during the initial 10 minute observation, immediately conduct a 30 minute observation. If the sum of the occurrence of visible emissions is greater than 5 percent of the observation period (i.e., 90 seconds per 30 minute period), the owner or operator shall either document and adjust the operation of the facility and demonstrate within 24 hours that the sum of the occurrence of visible emissions is equal to or less than 5 percent during a 30 minute observation (i.e., 90 seconds) or conduct a new Method 9 of appendix A-4 of this part performance test using the procedures in paragraph (a) of this section within 45 calendar days according to the requirements in §60.45c(a)(8).

(b) If no visible emissions are observed for 10 operating days during which an opacity standard is applicable, observations can be reduced to once every 7 operating days during which an opacity standard is applicable. If any visible emissions are observed, daily observations shall be resumed.

**SECTION E. Source Group Restrictions.****III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

**# 004 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.48c]
Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units
Reporting and recordkeeping requirements.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Chapter 122 and 40 CFR § 60.48c(c).]

The permittee shall prepare excess emission reports for any excess emissions from the boiler that occur during the reporting period and maintain records according to the requirements as follows, as applicable to the visible emissions monitoring method used:

(a) For each performance test conducted using Method 9, the permittee shall keep the records including the following information:

- (1) Dates and time intervals of all opacity observation periods;
- (2) Name, affiliation, and copy of current visible emission reading certification for each visible emission observer participating in the performance test; and
- (3) Copies of all visible emission observer opacity field data sheets;

(b) For each performance test conducted using Method 22, the permittee shall keep the records including the following information:

- (1) Dates and time intervals of all visible emissions observation periods;
- (2) Name and affiliation for each visible emission observer participating in the performance test;
- (3) Copies of all visible emission observer opacity field data sheets; and
- (4) Documentation of any adjustments made and the time the adjustments were completed to the affected facility operation by the owner or operator to demonstrate compliance with the applicable monitoring requirements.

V. REPORTING REQUIREMENTS.

**# 005 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.48c]
Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units
Reporting and recordkeeping requirements.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Chapter 122 and 40 CFR § 60.48c(b).]

The permittee shall submit to the Administrator the performance test data from the initial and any subsequent performance tests.

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: GROUP 1D

Group Description: Area Boiler MACT Subpart JJJJJ

Sources included in this group

ID	Name
054	BOILER NO. 1 (CENTRAL UTILITY PLANT)
055	BOILER NO. 2 (CENTRAL UTILITY PLANT)
056	BOILER NO. 3 (CENTRAL UTILITY PLANT)
057	BOILER NO. 4 (CENTRAL UTILITY PLANT)

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.**# 001 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11210]****SUBPART JJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources****What are my initial compliance requirements and by what date must I conduct them?**

[Additional authority for this permit condition is derived from 25 Pa. Code § 127.35 and 40 CFR § 63.11210(f).]

The permittee shall monitor on a monthly basis the type of fuel combusted in the boiler.

If a fuel other than ultra-low-sulfur liquid fuel or gaseous fuels is fired in the boiler, the permittee shall conduct a performance test for filterable particulate matter within 60 days of burning the new fuel.

[Note: The boiler combusts only ultra-low-sulfur liquid fuel as defined in 40 CFR § 63.11237; therefore, the PM emission limit in Table 1 of Subpart JJJJJ does not apply.]

IV. RECORDKEEPING REQUIREMENTS.**# 002 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11210]****SUBPART JJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources****What are my initial compliance requirements and by what date must I conduct them?**

[Additional authority for this permit condition is derived from 25 Pa. Code § 127.35 and 40 CFR § 63.11210(f).]

The permittee shall record on a monthly basis the type of fuel combusted in the boiler.

If a fuel other than ultra-low-sulfur liquid fuel or gaseous fuels is fired in the boiler, the permittee shall conduct a performance test within 60 days of burning the new fuel.

[Note: The boiler combusts only ultra-low-sulfur liquid fuel as defined in 40 CFR § 63.11237; therefore, the PM emission limit in Table 1 of Subpart JJJJJ does not apply.]

003 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11223]**SUBPART JJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources****How do I demonstrate continuous compliance with the work practice and management practice standards?**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35 and 40 CFR § 63.11223(b)(6).]

The permittee shall maintain on-site and submit, if requested by the Administrator, a report containing the following information:

**SECTION E. Source Group Restrictions.**

(a) The concentrations of CO in the effluent stream in parts per million, by volume, and oxygen in volume percent, measured at high fire or typical operating load, before and after the tune-up of the boiler.

(b) A description of any corrective actions taken as a part of the tune-up of the boiler.

(c) The type and amount of fuel used over the 12 months prior to the tune-up of the boiler, but only if the unit was physically and legally capable of using more than one type of fuel during that period. Units sharing a fuel meter may estimate the fuel use by each unit.

004 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11225]**SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources****What are my notification, reporting, and recordkeeping requirements?**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35 and 40 CFR § 63.11225(c).]

The permittee shall maintain the records specified in this condition:

(a) As required in 40 CFR § 63.10(b)(2)(xiv), the permittee shall keep a copy of each notification and report that is submitted to comply with this subpart and all documentation supporting any Initial Notification or Notification of Compliance Status that are submitted.

(b) The permittee shall keep records to document conformance with the work practices, emission reduction measures, and management practices required by 40 CFR § 63.11214 and § 63.11223 as specified in this condition:

(1) Records must identify each boiler, the date of tune-up, the procedures followed for tune-up, and the manufacturer's specifications to which the boiler was tuned.

(2) For operating units that combusts non-hazardous secondary materials that have been determined not to be solid waste pursuant to 40 CFR § 241.3(b)(1), the permittee shall keep a record which documents how the secondary material meets each of the legitimacy criteria under 40 CFR § 241.3(d)(1). If the permittee combusts a fuel that has been processed from a discarded non-hazardous secondary material pursuant to 40 CFR § 241.3(b)(4), the permittee shall keep records as to how the operations that produced the fuel satisfies the definition of processing in 40 CFR § 241.2 and each of the legitimacy criteria in 40 CFR § 241.3(d)(1). If the fuel received a non-waste determination pursuant to the petition process submitted under 40 CFR § 241.3(c), the permittee shall keep a record that documents how the fuel satisfies the requirements of the petition process. For operating units that combust non-hazardous secondary materials as fuel per 40 CFR § 241.4, the permittee shall keep records documenting that the material is a listed non-waste under 40 CFR § 241.4(a).

(3) For each boiler required to conduct an energy assessment, the permittee shall keep a copy of the energy assessment report.

(c) Records of the occurrence and duration of each malfunction of the boiler, or of the associated air pollution control and monitoring equipment.

(d) Records of actions taken during periods of malfunction to minimize emissions in accordance with the general duty to minimize emissions in 40 CFR § 63.11205(a), including corrective actions to restore the malfunctioning boiler, air pollution control, or monitoring equipment to its normal or usual manner of operation.

005 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11225]**SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources****What are my notification, reporting, and recordkeeping requirements?**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35 and 40 CFR § 63.11225(d).]

(a) The permittee shall keep records in a form suitable and readily available for expeditious review. The permittee shall keep each record for 5 years following the date of each recorded action. The permittee shall keep each record on-site or be accessible from a central location by computer or other means that instantly provide access at the site for at least 2 years after the date of each recorded action. The permittee may keep the records off site for the remaining 3 years.

**SECTION E. Source Group Restrictions.**

(b) The permittee shall maintain copies of reports prepared pursuant to 40 CFR Part 63 Subpart JJJJJJ.

V. REPORTING REQUIREMENTS.**# 006 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11214]****SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources****How do I demonstrate initial compliance with the work practice standard, emission reduction measures, and management practice?**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35 and 40 CFR § 63.11214(d).]

The permittee shall submit a signed statement in the Notification of Compliance Status report that indicates that startups and shutdowns were conducted according to the manufacturer's recommended procedures or procedures specified for a boiler of similar design if manufacturer's recommended procedures are not available.

[Initial Notification of Compliance Status report received by DEP on 02/26/2021 for Boilers 054, 055, 056, and 057.]

007 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11225]**SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources****What are my notification, reporting, and recordkeeping requirements?**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35 and 40 CFR § 63.11210.]

(a) The permittee shall submit to the Administrator an Initial Notification within 120 days after the fuel switch to liquid fuels becomes effective.

(b) The permittee shall submit to the Administrator the Notification of Compliance Status no later than 180 days after the fuel switch to liquid fuels becomes effective. [Report received by DEP 02/26/2021]

(c) The Notification of Compliance Status must include the following information and certification(s) of compliance and signed by a responsible official:

(1) The permittee shall submit the information required in 40 CFR § 63.9(h)(2), except the information listed in 40 CFR § 63.9(h)(2)(i)(B), (D), (E), and (F). If the permittee conducts any opacity or visible emission observations, or other monitoring procedures or methods, the permittee shall submit that data to the Administrator at the appropriate address listed in 40 CFR § 63.13.

(2) "This facility complies with the requirements in 40 CFR § 63.11214(b) to conduct an initial tune-up of the boiler."

(3) For units that do not qualify for a statutory exemption as provided in section 129(g)(1) of the Clean Air Act: "No secondary materials that are solid waste were combusted in any affected unit."

(4) The notification must be submitted electronically using the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) (www.epa.gov/cdx). However, if the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the written Notification of Compliance Status must be submitted to the Administrator at the appropriate address listed in 40 CFR § 63.13.

008 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11225]**SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources****What are my notification, reporting, and recordkeeping requirements?**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35, 40 CFR § 63.11210(h), and 40 CFR § 63.11225(g).]

If the permittee has switched fuels or made a physical change to the boiler and the fuel switch or change resulted in the applicability of a different subcategory within subpart JJJJJJ, in the boiler becoming subject to subpart JJJJJJ, or in the boiler switching out of subpart JJJJJJ due to a change to 100 percent natural gas, or the permittee has taken a permit limit

**SECTION E. Source Group Restrictions.**

that resulted in being subject to subpart JJJJJJ, the permittee shall provide notice of the date upon which fuels are switched, made the physical change, or took a permit limit within 30 days of the change. The notification must identify:

(a) The name of the owner or operator of the affected source, the location of the source, the boiler(s) that have switched fuels, were physically changed, or took a permit limit, and the date of the notice.

(b) The date upon which the fuel switch, physical change, or permit limit occurred.

009 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11225]**SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources****What are my notification, reporting, and recordkeeping requirements?**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35 and 40 CFR § 63.11225(b).]

The permittee shall prepare and submit to the delegated authority upon request, a 5-year compliance report containing the following information:

(a) Company name and address.

(b) Statement by a responsible official, with the official's name, title, phone number, email address, and signature, certifying the truth, accuracy and completeness of the notification and a statement of whether the source has complied with all the relevant standards and other requirements of this subpart. The notification must include the following certification(s) of compliance, as applicable, and signed by a responsible official:

(1) "This facility complies with the requirements in 40 CFR § 63.11223 to conduct a 5-year tune-up, as applicable, of each boiler."

(2) For units that do not qualify for a statutory exemption as provided in section 129(g)(1) of the Clean Air Act: "No secondary materials that are solid waste were combusted in any affected unit."

(3) "This facility complies with the requirement in 40 CFR §§ 63.11214(d) and 63.11223(g) to minimize the boiler's time spent during startup and shutdown and to conduct startups and shutdowns according to the manufacturer's recommended procedures or procedures specified for a boiler of similar design if manufacturer's recommended procedures are not available."

VI. WORK PRACTICE REQUIREMENTS.**# 010 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11201]****SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources****What standards must I meet?**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35, 40 CFR § 63.11201(b), 40 CFR § 63.11210(g), 40 CFR § 63.11214(b), 40 CFR § 63.11223(a), (b) and (c) and Item No. 15 of Table 2 of Subpart JJJJJJ.]

(a) The permittee shall conduct a tune-up of the boiler every 5 years as specified in this condition.

(1) As applicable, inspect the burner, and clean or replace any components of the burner as necessary.

(2) Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern. The adjustment should be consistent with the manufacturer's specifications, if available.

(3) Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure that it is correctly calibrated and functioning properly.

(4) Optimize total emissions of CO. This optimization should be consistent with the manufacturer's specifications, if available, and with any nitrogen oxide requirement to which the unit is subject.

(5) Measure the concentrations in the effluent stream of CO in parts per million, by volume, and oxygen in volume percent,

**SECTION E. Source Group Restrictions.**

before and after the adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken using a portable CO analyzer.

(6) Maintain on-site and submit, if requested by the Administrator, a report containing the information in paragraphs (a)(6)(i) through (iii) of this condition.

(i) The concentrations of CO in the effluent stream in parts per million, by volume, and oxygen in volume percent, measured at high fire or typical operating load, before and after the tune-up of the boiler.

(ii) A description of any corrective actions taken as a part of the tune-up of the boiler.

(iii) The type and amount of fuel used over the 12 months prior to the tune-up of the boiler, but only if the unit was physically and legally capable of using more than one type of fuel during that period. Units sharing a fuel meter may estimate the fuel use by each unit.

(7) If the unit is not operating on the required date for a tune-up, the tune-up must be conducted within 30 days of startup.

(b) The tune-up must be conducted while burning the type of fuel (or fuels in the case of boilers that routinely burn two types of fuels at the same time) that provided the majority of the heat input to the boiler over the 12 months prior to the tune-up.

(c) Each 5-year tune-up must be conducted no more than 61 months after the previous tune-up. The first 5-year tune-up must be no later than 61 months after the initial startup. The burner inspection and inspection of the system controlling the air-to-fuel ratio may be delayed until the next scheduled unit shutdown, but each burner and system controlling the air-to-fuel ratio must be inspected at least once every 72 months. If an oxygen trim system is utilized on a unit without emission standards to reduce the tune-up frequency to once every 5 years, set the oxygen level no lower than the oxygen concentration measured during the most recent tune-up.

[Note: This boiler is equipped with an oxygen trim system which maintains an optimum air-to-fuel ratio.]

011 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11201]

SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources

What standards must I meet?

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35, 40 CFR § 63.11201(b) and Item No. 1 of Table 2 of Subpart JJJJJJ.]

The permittee shall minimize the boiler's startup and shutdown periods and conduct startups and shutdowns according to the manufacturer's recommended procedures. If manufacturer's recommended procedures are not available, the permittee must follow recommended procedures for a unit of similar design for which manufacturer's recommended procedures are available.

012 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11205]

SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources

What are my general requirements for complying with this subpart?

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35, 40 CFR § 63.11205(a).]

The permittee shall operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions at all times. The general duty to minimize emissions does not require the permittee to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator that may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

**SECTION E. Source Group Restrictions.****VII. ADDITIONAL REQUIREMENTS.****# 013 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional Authority for this permit condition is also derived from 40 C.F.R. § 63.11237.]

According to 40 CFR Part 63 Subpart JJJJJJ, for the purpose of fuel, this boiler is categorized as a boiler greater than 10 MMBTU/HR and uses fuel defined under oil subcategory of Subpart JJJJJJ.

014 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11235]**SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources****What parts of the General Provisions apply to me?**

The permittee must comply with the applicable General Provisions according to Table 8 in 40 CFR Part 63, Subpart JJJJJJ.

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: GROUP 2A

Group Description: Subpart IIII - New Engines (Post-July 11, 2005)

Sources included in this group

ID	Name
107	2,500 KW CATERPILLAR EGEN 3-3 (CATERPILLAR ENGINE)
108	150 KW TAYLOR EGEN 17-1 (PERKINS ENGINE)
109	2,000 KW MTU EGEN 56-1 (CUP)
110	600 KW GENERAC EGEN (PERKINS ENGINE)

I. RESTRICTIONS.**Fuel Restriction(s).****# 001 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4207]****Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines****What fuel requirements must I meet if I am an owner or operator of a stationary CI internal combustion engine subject to**

[Additional authority for this permit condition is also derived from 40 CFR §§ 60.4207(b) and 40 CFR § 1090.305.]

The permittee shall use diesel fuel that meets ULSD per-gallon standards as follows:

- (a) Sulfur content: 15 ppm maximum.
- (b) Cetane index or aromatic content, as follows:
 - (1) A minimum cetane index of 40; or
 - (2) A maximum aromatic content of 35 volume percent.

[Compliance with this streamlined condition assures compliance with 25 Pa. Code § 123.21(b).]

Operation Hours Restriction(s).**# 002 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4211]****Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines****What are my compliance requirements if I am an owner or operator of a stationary CI internal combustion engine?**

[Additional authority for this permit condition is also derived from 25 Pa. Code Chapter 122 and 40 CFR § 60.4211(f).]

The permittee shall operate the emergency stationary ICE according to the requirements in paragraphs (a) and (b) of this condition. In order for the engine to be considered an emergency stationary ICE under 40 CFR Part 60 Subpart IIII, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (a) and (b) of this condition, is prohibited. If the permittee does not operate the engine according to the requirements in paragraphs (a) and (b) of this condition, the engine will not be considered an emergency engine under Subpart IIII and must meet all requirements for non-emergency engines.

(a) The permittee may operate the emergency stationary ICE for any combination of the purposes of maintenance checks and readiness testing for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraph (b) of this condition counts as part of the 100 hours per calendar year allowed by this paragraph (a). Emergency stationary ICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE beyond 100 hours per calendar year.

(b) Emergency stationary ICE may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing provided in paragraph (a) of this condition.

**SECTION E. Source Group Restrictions.****II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

**# 003 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4209]
Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
What are the monitoring requirements if I am an owner or operator of a stationary CI internal combustion engine?**

[Additional authority for this permit condition is also derived from 40 CFR § 60.4209(a)]

The permittee shall monitor the hours of operation of the engine through the use of a non-resettable hour meter.

IV. RECORDKEEPING REQUIREMENTS.

**# 004 [25 Pa. Code §127.441]
Operating permit terms and conditions.**

The permittee shall maintain records of the following information, for each shipment of diesel fuel received, obtained either by laboratory analysis or from the fuel supplier's certification:

- (a) Sulfur content,
- (b) Cetane index or aromatic content.

**# 005 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4214]
Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
What are my notification, reporting, and recordkeeping requirements if I am an owner or operator of a stationary CI internal combustion engine?**

[Additional authority for this permit condition is also derived from 25 Pa. Code Chapter 122, and 40 CFR § 60.4202(b) and § 60.4214(a)(2).]

The permittee shall maintain records of:

- (a) All notifications submitted to DEP and EPA to comply with 40 CFR Part 60 Subpart III and all documentation supporting any notification.
- (b) Maintenance conducted on the engine.
- (c) Documentation from the manufacturer that the engine is certified to meet the emission standards (i.e. certificate of conformity or Tier certification, etc.).

**# 006 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4214]
Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
What are my notification, reporting, and recordkeeping requirements if I am an owner or operator of a stationary CI internal combustion engine?**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.12b and 40 CFR § 60.4214(b).]

- (a) The permittee shall maintain monthly and annual records of the operation time of the engine in emergency and nonemergency service that are recorded through the non-resettable hour meter.
- (b) The permittee shall record the time of operation of the engine and the reason the engine was in operation during that time.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

**SECTION E. Source Group Restrictions.****VI. WORK PRACTICE REQUIREMENTS.**

**# 007 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4211]
Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
What are my compliance requirements if I am an owner or operator of a stationary CI internal combustion engine?**

[Additional authority for this permit condition is also derived from 25 Pa. Code Chapter 122 and 40 CFR § 60.4211.]

- (a) The permittee shall install and configure the engine in accordance with the manufacturer specifications.
- (b) The permittee shall operate and maintain the engine in accordance with one of the following:
 - (1) The manufacturers' written instructions and/or specifications, or
 - (2) Permittee-developed procedures that are approved by the manufacturer. Only those settings that are permitted to be changed by the manufacturer may be changed.

VII. ADDITIONAL REQUIREMENTS.

**# 008 [25 Pa. Code §127.441]
Operating permit terms and conditions.**

This engine is subject to the Standards of Performance for New Stationary Sources Subpart III and shall comply with all applicable requirements of this Subpart. In accordance with 40 CFR § 60.4, copies of all requests, reports, applications, submittals, and other communications are required to be submitted to both the EPA and the Department. NSPS reports may be submitted electronically to EPA's Central Data Exchange: <https://cdx.epa.gov/>.

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: GROUP 2B

Group Description: Subpart IIII - New Engines Greater than 500 HP

Sources included in this group

ID	Name
107	2,500 KW CATERPILLAR EGEN 3-3 (CATERPILLAR ENGINE)
109	2,000 KW MTU EGEN 56-1 (CUP)
110	600 KW GENERAC EGEN (PERKINS ENGINE)

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

**# 001 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4211]
Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
What are my compliance requirements if I am an owner or operator of a stationary CI internal combustion engine?**
[Additional authority for this permit condition is also derived from 25 Pa. Code Chapter 122 and 40 CFR § 60.4211(g)(3).]

If the permittee does not install, configure, operate, and maintain the engine according to the manufacturer's emission related written instructions, or the permittee changes emission-related settings in a way that is not permitted by the manufacturer, the permittee shall demonstrate compliance as follows:

For the engine which is greater than 500 HP, the permittee shall keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, the permittee shall conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of startup, or within 1 year after an engine is no longer installed, configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after the emission-related settings are changed in a way that is not permitted by the manufacturer. The permittee shall conduct subsequent performance testing every 8,760 hours of engine operation or 3 years, whichever comes first, thereafter to demonstrate compliance with the applicable emission standards.

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: GROUP 2C

Group Description: General Engine Regs for New Engines (PM, SO_x)

Sources included in this group

ID	Name
107	2,500 KW CATERPILLAR EGEN 3-3 (CATERPILLAR ENGINE)
108	150 KW TAYLOR EGEN 17-1 (PERKINS ENGINE)
109	2,000 KW MTU EGEN 56-1 (CUP)
110	600 KW GENERAC EGEN (PERKINS ENGINE)

I. RESTRICTIONS.**Emission Restriction(s).****# 001 [25 Pa. Code §123.13]****Processes**

The permittee shall ensure that emission into the outdoor atmosphere of particulate matter from the emergency generator occurs in such a manner that the concentration of particulate matter in the effluent gas does not exceed 0.04 gr/dscf, according to 25 Pa. Code § 123.13(c)(1)(i).

[The method of compliance for this permit condition is using proper fuels as approved herein.]

002 [25 Pa. Code §123.21]**General**

No person may permit the emission into the outdoor atmosphere of sulfur oxides from a source in a manner that the concentration of the sulfur oxides, expressed as SO₂, in the effluent gas exceeds 500 parts per million, by volume, dry basis.

[Compliance with this condition is streamlined in 40 CFR § 60.4207(b) and § 80.510(b), by using diesel fuel oil with a sulfur content of 15ppm maximum.]

II. TESTING REQUIREMENTS.**# 003 [25 Pa. Code §139.16]****Sulfur in fuel oil.**

(a) The following are applicable to tests for the analysis of commercial fuel oil:

(1) The fuel oil sample for chemical analysis shall be collected in a manner that provides a representative sample. Upon the request of a Department official, the person responsible for the operation of the source shall collect the sample employing the procedures and equipment specified in 25 Pa. Code § 139.4(10) (relating to references).

(2) Test methods and procedures for the determination of viscosity shall be that specified in 25 Pa. Code § 139.4(11) (relating to references). The viscosity shall be determined at 100°F.

(3) Tests methods and procedures for the determination of sulfur shall be those specified in 25 Pa. Code § 139.4(12)--(15).

(4) Results shall be reported in accordance with the units specified in 25 Pa. Code § 123.22 (relating to combustion units).

(b) The testing requirements in subpart (a) above, shall be waived in the event that a delivery receipt from the supplier, showing the percentage sulfur in the fuel, is obtained each time a fuel oil delivery is made.

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

**SECTION E. Source Group Restrictions.****IV. RECORDKEEPING REQUIREMENTS.**

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: GROUP 3A

Group Description: Subpart ZZZZ - Existing Engines (Pre-June 12, 2006)

Sources included in this group

ID	Name
102	180 KW KOHLER EGEN 10-2 (CUMMINS ENGINE)
103	510 KW MARATHON EGEN 11-1 (DETROIT DIESEL ENGINE)
104	1,200 KW DETROIT EGEN 4-1A (DETROIT DIESEL ENGINE)
106	1,500 KW MTU EGEN 38-3 (DETROIT DIESEL ENGINE)

I. RESTRICTIONS.**Operation Hours Restriction(s).****# 001 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6625]****Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines****What are my monitoring, installation, operation, and maintenance requirements?**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35, 40 CFR § 63.6603(a), and 40 CFR § 63.6625(h).]

The permittee shall minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes.

002 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6640]**Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines****How do I demonstrate continuous compliance with the emission limitations, operating limitations, and other requiremer**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35]

The permittee shall limit the hours of operation for each emergency engine as follows, according to 40 CFR § 63.6640(f):

(a) No more than one hundred (100) hours per year for maintenance checks and readiness testing as required by the manufacturer, insurance company, or government agency; and

(b) No more than fifty (50) hours in non-emergency situations, but these fifty must be counted toward the 100 hours for maintenance and readiness testing. These 50 hours cannot be used for peak shaving or to generate income by supplying power as part of a financial arrangement with another entity.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.**# 003 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6655]****Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines****What records must I keep?**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35]

The following recordkeeping requirements apply to each engine, according to 40 CFR § 63.6655(f)(1):

**SECTION E. Source Group Restrictions.**

(a) The permittee shall keep records of the hours of operation of each engine that is recorded through a non-resettable hour meter.

(b) The permittee shall document how many hours are spent for emergency operation (12-month rolling), including what classified the operation as emergency and how many hours are spent for non-emergency operation (12-month rolling).

004 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6655]**Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines****What records must I keep?**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35]

The permittee shall keep records of the maintenance conducted on each emergency generator in order to demonstrate that each engine is operated and maintained according to a maintenance plan, according to 40 CFR § 63.6655(e)(2).

005 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6660]**Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines****In what form and how long must I keep my records?**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35.]

(a) The permittee shall maintain records in a form suitable and readily available for expeditious review according to 40 CFR § 63.10(b)(1).

(b) As specified in 40 CFR § 63.10(b)(1), the permittee shall keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) The permittee shall keep each record readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to 40 CFR § 63.10(b)(1).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.**# 006 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6603]****Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines****What emission limitations, operating limitations, and other requirements must I meet if I own or operate an existing stationary RICE located at an area source of HAP emissions?**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35]

The permittee shall perform the following work practice standards on this stationary RICE, according to 40 CFR § 63.6603(a) and Table 2d (Item 4) of Subpart ZZZZ:

(a) Change oil and filter every 500 hours of operation or annually, whichever comes first,

(b) Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and

(c) Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.

The permittee has the option to utilize an oil analysis program as described in 40 CFR § 63.6625(i) in order to extend the specified oil change requirement in (a) above.

007 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6605]**Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines**

**SECTION E. Source Group Restrictions.****What are my general requirements for complying with this subpart?**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35]

- (a) The permittee shall be in compliance with the applicable requirements of 40 CFR Part 63 Subpart ZZZZ at all times.
- (b) At all times the permittee shall operate and maintain the affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require the permittee to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Department which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

008 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6625]**Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines****What are my monitoring, installation, operation, and maintenance requirements?**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 127.35]

The permittee shall operate and maintain each stationary RICE according to the manufacturer's emission-related written instructions or facility-developed maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions, according to 40 CFR § 63.6625(e)(3).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: GROUP 3B

Group Description: General Engine Regs for Existing Engines (PM, SOx)

Sources included in this group

ID	Name
102	180 KW KOHLER EGEN 10-2 (CUMMINS ENGINE)
103	510 KW MARATHON EGEN 11-1 (DETROIT DIESEL ENGINE)
104	1,200 KW DETROIT EGEN 4-1A (DETROIT DIESEL ENGINE)
106	1,500 KW MTU EGEN 38-3 (DETROIT DIESEL ENGINE)

I. RESTRICTIONS.**Emission Restriction(s).****# 001 [25 Pa. Code §123.13]****Processes**

The permittee shall ensure that emission into the outdoor atmosphere of particulate matter from the emergency generator occurs in such a manner that the concentration of particulate matter in the effluent gas does not exceed 0.04 gr/dscf, according to 25 Pa. Code § 123.13(c)(1)(i).

[The method of compliance for this permit condition is using proper fuels as approved herein.]

002 [25 Pa. Code §123.21]**General**

No person may permit the emission into the outdoor atmosphere of sulfur oxides from a source in a manner that the concentration of the sulfur oxides, expressed as SO₂, in the effluent gas exceeds 500 parts per million, by volume, dry basis.

[The method of compliance for this permit condition may be verified through the use of commercial grade fuel oil containing 0.05% or less sulfur content by weight.]

Fuel Restriction(s).**# 003 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall burn No. 2 fuel oil only in the engine.

II. TESTING REQUIREMENTS.**# 004 [25 Pa. Code §139.16]****Sulfur in fuel oil.**

(a) The following are applicable to tests for the analysis of commercial fuel oil:

(1) The fuel oil sample for chemical analysis shall be collected in a manner that provides a representative sample. Upon the request of a Department official, the person responsible for the operation of the source shall collect the sample employing the procedures and equipment specified in 25 Pa. Code § 139.4(10) (relating to references).

(2) Test methods and procedures for the determination of viscosity shall be that specified in 25 Pa. Code § 139.4(11) (relating to references). The viscosity shall be determined at 100°F.

(3) Tests methods and procedures for the determination of sulfur shall be those specified in 25 Pa. Code § 139.4(12)--(15).

(4) Results shall be reported in accordance with the units specified in 25 Pa. Code § 123.22 (relating to combustion units).

(b) The testing requirements in subpart (a) above, shall be waived in the event that a delivery receipt from the supplier, showing the percentage sulfur in the fuel, is obtained each time a fuel oil delivery is made.

**SECTION E. Source Group Restrictions.****III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: GROUP 4

Group Description: Exempt Engine Conditions

Sources included in this group

ID	Name
102	180 KW KOHLER EGEN 10-2 (CUMMINS ENGINE)
106	1,500 KW MTU EGEN 38-3 (DETROIT DIESEL ENGINE)
107	2,500 KW CATERPILLAR EGEN 3-3 (CATERPILLAR ENGINE)
108	150 KW TAYLOR EGEN 17-1 (PERKINS ENGINE)

I. RESTRICTIONS.**Emission Restriction(s).**

001 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall limit the aggregate NOx emissions from all exempt engines on site to less than 100 lbs/hr, 1000 lbs/day, 2.75 tons per ozone season and 6.6 tons per year on a 12-month rolling basis.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

002 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall maintain monthly records of the aggregate NOx emissions from all exempt engines on site including pounds per hour, pounds per day, ozone season (i.e., the period from May 1 through September 30 of each year) sums, and 12-month rolling sums to demonstrate compliance with the NOx emission limits applicable to this source.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: GROUP 5

Group Description: Small NOx Regulation 129.203-204 (> 1,000 hp)

Sources included in this group

ID	Name
104	1,200 KW DETROIT EGEN 4-1A (DETROIT DIESEL ENGINE)
106	1,500 KW MTU EGEN 38-3 (DETROIT DIESEL ENGINE)
107	2,500 KW CATERPILLAR EGEN 3-3 (CATERPILLAR ENGINE)
109	2,000 KW MTU EGEN 56-1 (CUP)

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.**# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code § 129.203]

The permittee shall maintain a record of the May through September NOx emission calculations performed for this source.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.**# 002 [25 Pa. Code §129.203]****Stationary internal combustion engines.**

(a) The permittee shall, by October 31, 2005 and each year thereafter, calculate the difference between the actual emissions from the unit during the period from May 1 through September 30 and the allowable emissions for that period.

(b) The permittee shall calculate allowable emissions by multiplying the cumulative hours of operations for the unit for the period by the horsepower rating of the unit and by 2.3 grams of NOx per brake horsepower-hour.

003 [25 Pa. Code §129.204]**Emission accountability.**

(a) The permittee shall surrender to the Department one CAIR NOx allowance and one CAIR NOx Ozone Season allowance, as defined in 40 CFR § 96.102 and 96.302 (relating to definitions), for each ton of NOx by which the combined actual emissions exceed the allowable emissions for this engine from May 1 through September 30. The surrendered NOx allowances shall be of current year vintage. For the purpose of determining the amount of allowances to surrender, any remaining fraction of a ton equal to or greater than 0.50 ton is deemed to equal 1 ton and any fraction of a ton less than 0.50 ton is deemed to equal zero tons.

(b) If the combined allowable emissions from sources subject to 25 Pa. Code Chapter 129 (Additional NOx Requirements) at a facility from May 1 through September 30 exceed the combined actual emissions from units subject to this section at the facility during the same period, the permittee may deduct the difference or any portion of the difference from the amount of actual emissions from sources subject to 25 Pa. Code Chapter 129 (Additional NOx Requirements) at the permittee's other facilities.

**SECTION E. Source Group Restrictions.**

(c) By November 1, 2005, and by November 1 of each year thereafter, the permittee shall surrender the required NOx allowances to the Department's designated NOx allowance tracking system account and provide to the Department, in writing, the following:

- (1) The serial number of each NOx allowance surrendered.
- (2) The calculations used to determine the quantity of NOx allowances required to be surrendered.

(d) If a permittee fails to comply with subcondition (c), the permittee shall by December 31, surrender three (3) NOx allowances of the current or later year vintage for each NOx allowance that was required to be surrendered by November 1 of that year.

(e) The surrender of NOx allowances under subcondition (d) does not affect the liability of the permittee of the unit for any fine, penalty or assessment, or an obligation to comply with any other remedy for the same violation, under the CAA or the act.

(1) For purposes of determining the number of days of violation, if a facility has excess emissions for the period May 1 through September 30, each day in that period (153 days) constitutes a day in violation unless the permittee demonstrates that a lesser number of days should be considered.

- (2) Each ton of excess emissions is a separate violation.

[Note: On July 6, 2011, EPA promulgated the Cross-State Air Pollution Rule (CSAPR) to replace CAIR. The CSAPR provisions of 40 CFR Part 97, Subpart AAAAA (relating to CSAPR NOx Annual Trading Program), replaced the provisions of 40 CFR Part 96, Subpart AA (relating to CAIR NOx Annual Trading Program General Provisions), and remain in effect. On October 26, 2016, EPA promulgated the CSAPR Update to establish the provisions of 40 CFR Part 97, Subpart EEEEE (relating to CSAPR NOx Ozone Season Group 2 Trading Program), to replace the previously-established CAIR NOx Ozone Season Trading Program and CSAPR NOx Ozone Season Group 1 Trading Program for certain states, including Pennsylvania, beginning with the 2017 ozone season. On April 30, 2021, EPA promulgated the Revised CSAPR Update to establish the provisions of 40 CFR Part 97, Subpart GGGGG (relating to CSAPR NOx Ozone Season Group 3 Trading Program), to replace the provisions of 40 CFR Part 97, Subpart EEEEE, for certain states, including Pennsylvania, beginning with the 2021 ozone season (though DEP will accept CSAPR NOx Ozone Season Group 2 allowances of current year vintage from other states, if available). Accordingly, the permittee shall surrender CSAPR NOx Annual allowances and either CSAPR NOx Ozone Season Group 2 allowances or CSAPR NOx Ozone Season Group 3 allowances, as defined in 40 CFR §§ 97.402, 97.802, and 97.1002, respectively, instead of the CAIR NOx allowances and CAIR NOx Ozone Season allowances indicated in 25 Pa. Code § 129.204(c), as the latter are no longer available.]

004 [25 Pa. Code §129.204]**Emission accountability.**

The permittee shall determine actual emissions of NOx by one of the following:

(a) The 1-year average emission rate calculated from the most recent permit emission limit compliance demonstration test data for NOx.

(b) The maximum hourly allowable NOx emission rate contained in the permit or the higher of the following:

(1) The highest rate determined by use of the emission factor for the unit class contained in the most up-to date version of the EPA publication, "AP-42 Compilation of Air Pollution Emission Factors."

(2) The highest rate determined by use of the emission factor for the unit class contained in the most up-to date version of EPA's "Factor Information Retrieval (FIRE)" data system.

(c) CEMS data, if the permittee elects to monitor NOx emissions with a CEMS. The permittee shall monitor emissions and report the data from the CEMS in accordance with Chapter 139 or Chapter 145 (relating to interstate pollution transport reduction). Any data invalidated under Chapter 139 shall be substituted with data calculated using the potential emission rate for the unit or, if approved by the Department in writing, an alternative amount of emissions that is more representative of actual emissions that occurred during the period of invalid data.

**SECTION E. Source Group Restrictions.**

(d) An alternative calculation and recordkeeping procedure based upon emissions testing and correlations with operating parameters. The permittee shall demonstrate that the alternate procedure does not underestimate actual emissions throughout the allowable range of operating conditions. The alternate calculation and recordkeeping procedures must be approved by the Department in writing prior to implementation.

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****

**SECTION F. Alternative Operation Requirements.**

No Alternative Operations exist for this Title V facility.

**SECTION G. Emission Restriction Summary.**

Source Id	Source Descriptor		
054	BOILER NO. 1 (CENTRAL UTILITY PLANT)		
Emission Limit		Pollutant	
300.000	PPMV	at 3% oxygen	CO
30.000	PPMV	at 3% oxygen when firing natural gas	NOX
90.000	PPMV	at 3% oxygen when firing No. 2 fuel oil	NOX
0.400	Lbs/MMBTU		PM10
055	BOILER NO. 2 (CENTRAL UTILITY PLANT)		
Emission Limit		Pollutant	
300.000	PPMV	at 3% oxygen	CO
30.000	PPMV	at 3% oxygen when firing natural gas	NOX
90.000	PPMV	at 3% oxygen when firing No. 2 fuel oil	NOX
0.400	Lbs/MMBTU		PM10
056	BOILER NO. 3 (CENTRAL UTILITY PLANT)		
Emission Limit		Pollutant	
300.000	PPMV	at 3% oxygen	CO
30.000	PPMV	at 3% oxygen when firing natural gas	NOX
90.000	PPMV	at 3% oxygen when firing No. 2 fuel oil	NOX
0.400	Lbs/MMBTU		PM10
057	BOILER NO. 4 (CENTRAL UTILITY PLANT)		
Emission Limit		Pollutant	
300.000	PPMV	at 3% oxygen	CO
30.000	PPMV	at 3% oxygen when firing natural gas	NOX
90.000	PPMV	at 3% oxygen when firing No. 2 fuel oil	NOX
0.400	Lbs/MMBTU		PM10
102	180 KW KOHLER EGEN 10-2 (CUMMINS ENGINE)		
Emission Limit		Pollutant	
2.750	Tons/OZNESEAS	aggregate for all exempt engines	NOX
6.600	Tons/Yr	aggregate for all exempt engines	NOX
100.000	Lbs/Hr	aggregate for all exempt engines	NOX
1,000.000	Lbs/Day	aggregate for all exempt engines	NOX
0.040	gr/DRY FT3		PM10
500.000	PPMV		SOX
103	510 KW MARATHON EGEN 11-1 (DETROIT DIESEL ENGINE)		
Emission Limit		Pollutant	
0.040	gr/DRY FT3		PM10
500.000	PPMV		SOX
104	1,200 KW DETROIT EGEN 4-1A (DETROIT DIESEL ENGINE)		
Emission Limit		Pollutant	
4.000	Tons/Yr	12-month rolling sum	NOX
0.040	gr/DRY FT3		PM10

**SECTION G. Emission Restriction Summary.**

Source Id	Source Descriptor		
500.000	PPMV		SOX
106	1,500 KW MTU EGEN 38-3 (DETROIT DIESEL ENGINE)		
Emission Limit		Pollutant	
2.750	Tons/OZNESEAS	aggregate for all exempt engines	NOX
6.600	Tons/Yr	aggregate for all exempt engines	NOX
100.000	Lbs/Hr	aggregate for all exempt engines	NOX
1,000.000	Lbs/Day	aggregate for all exempt engines	NOX
0.040	gr/DRY FT3		PM10
500.000	PPMV		SOX
107	2,500 KW CATERPILLAR EGEN 3-3 (CATERPILLAR ENGINE)		
Emission Limit		Pollutant	
2.750	Tons/OZNESEAS	aggregate for all exempt engines	NOX
6.600	Tons/Yr	aggregate for all exempt engines	NOX
100.000	Lbs/Hr	aggregate for all exempt engines	NOX
1,000.000	Lbs/Day	aggregate for all exempt engines	NOX
0.040	gr/DRY FT3		PM10
500.000	PPMV		SOX
108	150 KW TAYLOR EGEN 17-1 (PERKINS ENGINE)		
Emission Limit		Pollutant	
2.750	Tons/OZNESEAS	aggregate for all exempt engines	NOX
6.600	Tons/Yr	aggregate for all exempt engines	NOX
100.000	Lbs/Hr	aggregate for all exempt engines	NOX
1,000.000	Lbs/Day	aggregate for all exempt engines	NOX
0.040	gr/DRY FT3		PM10
500.000	PPMV		SOX
109	2,000 KW MTU EGEN 56-1 (CUP)		
Emission Limit		Pollutant	
0.040	gr/DRY FT3		PM10
500.000	PPMV		SOX
110	600 KW GENERAC EGEN (PERKINS ENGINE)		
Emission Limit		Pollutant	
0.040	gr/DRY FT3		PM10
500.000	PPMV		SOX

Site Emission Restriction Summary

Emission Limit		Pollutant
24.900	Tons/Yr	any combination HAP, based on a 12-month rolling sum
9.900	Tons/Yr	any individual HAP, based on a 12-month rolling sum



SECTION G. Emission Restriction Summary.

99.900 Tons/Yr

based on a 12-month rolling sum

NOX

**SECTION H. Miscellaneous.**

 Initial November 2018

(1) The following previously issued Plan Approval serves as the basis for certain terms and conditions set forth in this Operating Permit:

RACT OP No. 46-0035 (Source ID 037, 038, 039, 103, 104, 200)
 TVOP No. 46-00035 (Source ID 037, 038, 039, 101, 102, 103, 104, 105, 106, 107, 200)
 Plan Approval No. 46-00351 (Source ID 054, 055, 056, 057, 109, 205)

(2) GSK Upper Merion is split into three permits:

East TVOP No. 46-00298
 West TVOP No. 46-00299 (now owned by Merion Innovation I & III LLC)
 BioPharm TVOP No. 46-00300

(3) The following RFDs have been reviewed for this site (GSK - Upper Merion East):

RFD No. 1834 - Source ID 106 - 1,500 kW MTU EGEN 38-3 Detroit Diesel Engine
 RFD No. 1245 - Source ID 107 - 2,500 kW Caterpillar EGEN 3-3 Caterpillar Engine
 RFD No. 2390 - Source ID 108 - 150 kW Taylor EGEN 17-1 Perkins Engine
 RFD No. 7549 - four (4) natural gas direct heaters, eight (8) natural gas indirect heaters, and three (3) natural gas indirect preheat furnaces, total for all units is 8.1 MMBtu/hr.

 Amendment January 2021

(4) AUTH ID 1334418 - The administrative amendment incorporates terms and conditions of Plan Approval No. 46-00351. The following sources have been decommissioned and removed from the permit:

- (a) Source ID 037 - 34.5 MMBtu/hr natural gas and No. 6 fuel oil Cleaver Brooks Boiler 9 located in Building 3
- (b) Source ID 038 - 34.5 MMBtu/hr natural gas and No. 6 fuel oil Cleaver Brooks Boiler 10 located in Building 3
- (c) Source ID 039 - 34.5 MMBtu/hr natural gas and No. 6 fuel oil Cleaver Brooks Boiler 11 located in Building 3
- (d) Source ID 200 - 30,000 gallon No. 6 fuel oil storage tank.

The following sources have been added to the permit with this amendment:

- (a) Source ID 054 - 48.988 MMBtu/hr natural gas and No. 2 fuel oil Cleaver Brooks Boiler 1 located in the Central Utility Plant
- (b) Source ID 055 - 48.988 MMBtu/hr natural gas and No. 2 fuel oil Cleaver Brooks Boiler 2 located in the Central Utility Plant
- (c) Source ID 056 - 24.494 MMBtu/hr natural gas and No. 2 fuel oil Cleaver Brooks Boiler 3 located in the Central Utility Plant
- (d) Source ID 057 - 24.494 MMBtu/hr natural gas and No. 2 fuel oil Cleaver Brooks Boiler 4 located in the Central Utility Plant
- (e) Source ID 109 - 2,000 kW MTU EGEN located in the Central Utility Plant
- (f) Source ID 205 - 29,800 gallon No. 2 Fuel Oil Tank located in the Central Utility Plant.

 Amendment February 2022

(5) AUTH ID 1384397 - The administrative amendment addresses a change in Responsible Official from Mr. John DaCosta to Mr. Stu Gold, Director of Site Operations. With the amendment, boiler source testing condition which appears in Section E, Source Group 1A has been revised for clarity.

 Renewal February 2024

(6) AUTH ID 1447298 - With this renewal action, the following sources have been removed from the permit:

- (a) Source ID 101 - 250-kW Onan EGEN 4-3 with Cummins Engine - the emergency generator is no longer onsite
- (b) Source ID 105 - 80-kW Onan EGEN 10-1 with Cummins Engine - the emergency generator is no longer onsite



SECTION H. Miscellaneous.

The following RFDs were reviewed and approved for the temporary operation of sources:

- RFD No. 9450: Two (2) temporary EGENs at Building 4 (275-kW and 1,500-kW)
- RFD No. 9695: Two (2) temporary EGENs at Building 29 (800-kW and 1,500-kW)
- RFD No. 10290: One (1) temporary EGEN at Building 11 (275-kW)
- RFD No. 10405: One (1) temporary engine powering an air compressor at Building 3 (560-hp)
- RFD No. 10414: Two (2) temporary EGENs at Building 4 (275-kW each)
- RFD No. 10426: One (1) temporary EGEN at Building 5 (563-kW)
- RFD No. 10447: One (1) temporary engine powering a chilled water pump at Bldg. 5 (275-kW).

Amendment August 2024

(7) AUTH ID 1494912 - Administrative amendment to incorporate terms and conditions of Plan Approval No. 46-0298 which is for the installation of Source ID 110 (600 kW Generac EGEN (Perkins Engine)).

Amendment December 2024

(8) AUTH ID 1509051 - Administrative amendment to update the permit contact from Lindsay Griffiths to Jessica Branch.



***** End of Report *****
