



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
AIR QUALITY PROGRAM

PLAN APPROVAL

Issue Date: November 4, 2025

Effective Date: November 4, 2025

Expiration Date: November 4, 2026

In accordance with the provisions of the Air Pollution Control Act, the Act of January 8, 1960, P.L. 2119, as amended, and 25 Pa. Code Chapter 127, the Owner, [and Operator if noted] (hereinafter referred to as permittee) identified below is authorized by the Department of Environmental Protection (Department) to construct, install, modify or reactivate the air emission source(s) more fully described in the site inventory list. This Facility is subject to all terms and conditions specified in this plan approval. Nothing in this plan approval relieves the permittee from its obligations to comply with all applicable Federal, State and Local laws and regulations.

The regulatory or statutory authority for each plan approval condition is set forth in brackets. All terms and conditions in this permit are federally enforceable unless otherwise designated as "State-Only" requirements.

Plan Approval No. 27-00015B

Federal Tax Id - Plant Code: 74-1056569-3

Owner Information

Name: KINDER MORGAN INC
Mailing Address: 1001 LOUISIANA ST STE 1000
HOUSTON, TX 77002-5089

Plant Information

Plant: TENNESSEE GAS PIPELINE/MARIENVILLE STA 307
Location: 27 Forest County 27905 Howe Township
SIC Code: 4922 Trans. & Utilities - Natural Gas Transmission

Responsible Official

Name: RONALD F MILLER
Title: DIRECTOR - OPERATIONS
Phone: (724) 662 - 6422 Email: Ron_Miller@kindermorgan.com

Plan Approval Contact Person

Name: SAMANTHA HON
Title: AIR PERMIT & COMPL SPEC
Phone: (713) 420 - 6318 Email: Samantha_Hon@kindermorgan.com

[Signature] _____
LORI L. MCNABB, NORTHWEST REGION AIR PROGRAM MANAGER



Plan Approval Description

The Department hereby authorizes plan approval 27-00015B to Tennessee Gas Pipeline LLC (TGP) for authorization to install and initially operate emissions control equipment (fuel injection system and oxidation catalyst) at their Marienville Compressor Station 307 facility.



SECTION A. Table of Contents

Section A. Facility/Source Identification

Table of Contents
Plan Approval Inventory List

Section B. General Plan Approval Requirements

- #001 Definitions
- #002 Future Adoption of Requirements
- #003 Plan Approval Temporary Operation
- #004 Content of Applications
- #005 Public Records and Confidential Information
- #006 Plan Approval Terms and Conditions
- #007 Transfer of Plan Approvals
- #008 Inspection and Entry
- #009 Plan Approval Changes for Cause
- #010 Circumvention
- #011 Submissions
- #012 Risk Management
- #013 Prohibition of Air Pollution
- #014 Compliance Requirement

Section C. Site Level Plan Approval Requirements

- C-I: Restrictions
- C-II: Testing Requirements
- C-III: Monitoring Requirements
- C-IV: Recordkeeping Requirements
- C-V: Reporting Requirements
- C-VI: Work Practice Standards
- C-VII: Additional Requirements
- C-VIII: Compliance Certification
- C-IX: Compliance Schedule

Section D. Source Level Plan Approval Requirements

- D-I: Restrictions
- D-II: Testing Requirements
- D-III: Monitoring Requirements
- D-IV: Recordkeeping Requirements
- D-V: Reporting Requirements
- D-VI: Work Practice Standards
- D-VII: Additional Requirements

Note: These same sub-sections are repeated for each source!

Section E. Source Group Restrictions

- E-I: Restrictions
- E-II: Testing Requirements
- E-III: Monitoring Requirements
- E-IV: Recordkeeping Requirements
- E-V: Reporting Requirements
- E-VI: Work Practice Standards
- E-VII: Additional Requirements

Section F. Alternative Operating Scenario(s)

- F-I: Restrictions
- F-II: Testing Requirements



SECTION A. Table of Contents


F-III: Monitoring Requirements
F-IV: Recordkeeping Requirements
F-V: Reporting Requirements
F-VI: Work Practice Standards
F-VII: Additional Requirements

Section G. Emission Restriction Summary

Section H. Miscellaneous

**SECTION A. Plan Approval Inventory List**

Source ID	Source Name	Capacity/Throughput	Fuel/Material
136	4000 BHP, CLARK TVC-10C, ENG NO 6, SN 107038		
C136	OXIDATION CATALYST		
FM001	TENNESSEE GAS PIPELINE CO LLC/MARIENVILLE STA 307		
S06	A6C		

PERMIT MAPS

**SECTION B. General Plan Approval Requirements****#001 [25 Pa. Code § 121.1]****Definitions**

Words and terms that are not otherwise defined in this plan approval shall have the meanings set forth in Section 3 of the Air Pollution Control Act (35 P.S. § 4003) and 25 Pa. Code § 121.1.

#002 [25 Pa. Code § 127.12b (a) (b)]**Future Adoption of Requirements**

The issuance of this plan approval does not prevent the future adoption by the Department of any rules, regulations or standards, or the issuance of orders necessary to comply with the requirements of the Federal Clean Air Act or the Pennsylvania Air Pollution Control Act, or to achieve or maintain ambient air quality standards. The issuance of this plan approval shall not be construed to limit the Department's enforcement authority.

#003 [25 Pa. Code § 127.12b]**Plan Approval Temporary Operation**

This plan approval authorizes temporary operation of the source(s) covered by this plan approval provided the following conditions are met.

(a) When construction, installation, modification, or reactivation is being conducted, the permittee shall provide written notice to the Department of the completion of the activity approved by this plan approval and the permittee's intent to commence operation at least five (5) working days prior to the completion of said activity. The notice shall state when the activity will be completed and when the permittee expects to commence operation. When the activity involves multiple sources on different time schedules, notice is required for the commencement of operation of each source.

(b) Pursuant to 25 Pa. Code § 127.12b (d), temporary operation of the source(s) is authorized to facilitate the shakedown of sources and air cleaning devices, to permit operations pending the issuance of a permit under 25 Pa. Code Chapter 127, Subchapter F (relating to operating permits) or Subchapter G (relating to Title V operating permits) or to permit the evaluation of the air contaminant aspects of the source.

(c) This plan approval authorizes a temporary operation period not to exceed 180 days from the date of commencement of operation, provided the Department receives notice from the permittee pursuant to paragraph (a), above.

(d) The permittee may request an extension of the 180-day shakedown period if further evaluation of the air contamination aspects of the source(s) is necessary. The request for an extension shall be submitted, in writing, to the Department at least 30 days prior to the end of the initial 180-day shakedown period and shall provide a description of the compliance status of the source, a detailed schedule for establishing compliance, and the reasons compliance has not been established. This temporary operation period will be valid for a limited time and may be extended for additional limited periods, each not to exceed 180 days.

(e) The notice submitted by the permittee pursuant to subpart (a) above, prior to the expiration of the plan approval, shall modify the plan approval expiration date on Page 1 of this plan approval. The new plan approval expiration date shall be 180 days from the date of commencement of operation.

#004 [25 Pa. Code § 127.12(a) (10)]**Content of Applications**

The permittee shall maintain and operate the sources and associated air cleaning devices in accordance with good engineering practice as described in the plan approval application submitted to the Department.

#005 [25 Pa. Code §§ 127.12(c) and (d) & 35 P.S. § 4013.2]**Public Records and Confidential Information**

(a) The records, reports or information obtained by the Department or referred to at public hearings shall be available to the public, except as provided in paragraph (b) of this condition.

(b) Upon cause shown by the permittee that the records, reports or information, or a particular portion thereof, but not emission data, to which the Department has access under the act, if made public, would divulge production or sales figures or methods, processes or production unique to that person or would otherwise tend to affect adversely the

**SECTION B. General Plan Approval Requirements**

competitive position of that person by revealing trade secrets, including intellectual property rights, the Department will consider the record, report or information, or particular portion thereof confidential in the administration of the act. The Department will implement this section consistent with sections 112(d) and 114(c) of the Clean Air Act (42 U.S.C.A. § 7412(d) and 7414(c)). Nothing in this section prevents disclosure of the report, record or information to Federal, State or local representatives as necessary for purposes of administration of Federal, State or local air pollution control laws, or when relevant in a proceeding under the act.

#006 [25 Pa. Code § 127.12b]**Plan Approval Terms and Conditions**

[Additional authority for this condition is derived from 25 Pa. Code Section 127.13]

(a) This plan approval will be valid for a limited time, as specified by the expiration date contained on Page 1 of this plan approval. Except as provided in § 127.11a and 127.215 (relating to reactivation of sources; and reactivation), at the end of the time, if the construction, modification, reactivation or installation has not been completed, a new plan approval application or an extension of the previous approval will be required.

(b) If construction has commenced, but cannot be completed before the expiration of this plan approval, an extension of the plan approval must be obtained to continue construction. To allow adequate time for departmental action, a request for the extension shall be postmarked at least thirty (30) days prior to the expiration date. The request for an extension shall include the following:

- (i) A justification for the extension,
- (ii) A schedule for the completion of the construction

If construction has not commenced before the expiration of this plan approval, then a new plan approval application must be submitted and approval obtained before construction can commence.

(c) If the construction, modification or installation is not commenced within 18 months of the issuance of this plan approval or if there is more than an 18-month lapse in construction, modification or installation, a new plan approval application that meets the requirements of 25 Pa. Code Chapter 127, Subchapter B (related to plan approval requirements), Subchapter D (related to prevention of significant deterioration of air quality), and Subchapter E (related to new source review) shall be submitted. The Department may extend the 18-month period upon a satisfactory showing that an extension is justified.

#007 [25 Pa. Code § 127.32]**Transfer of Plan Approvals**

(a) This plan approval may not be transferred from one person to another except when a change of ownership is demonstrated to the satisfaction of the Department and the Department approves the transfer of the plan approval in writing.

(b) Section 127.12a (relating to compliance review) applies to a request for transfer of a plan approval. A compliance review form shall accompany the request.

(c) This plan approval is valid only for the specific source and the specific location of the source as described in the application.

#008 [25 Pa. Code § 127.12(a)(4) & 35 P.S. § 4008 & § 114 of the CAA]**Inspection and Entry**

(a) Pursuant to 35 P.S. § 4008, no person shall hinder, obstruct, prevent or interfere with the Department or its personnel in the performance of any duty authorized under the Air Pollution Control Act.

(b) The permittee shall also allow the Department to have access at reasonable times to said sources and associated air cleaning devices with such measuring and recording equipment, including equipment recording visual observations, as the Department deems necessary and proper for performing its duties and for the effective enforcement of the Air Pollution Control Act and regulations adopted under the act.

**SECTION B. General Plan Approval Requirements**

(c) Nothing in this plan approval condition shall limit the ability of the Environmental Protection Agency to inspect or enter the premises of the permittee in accordance with Section 114 or other applicable provisions of the Clean Air Act.

#009 [25 Pa. Code 127.13a]**Plan Approval Changes for Cause**

This plan approval may be terminated, modified, suspended or revoked and reissued if one or more of the following applies:

(a) The permittee constructs or operates the source subject to the plan approval in violation of the act, the Clean Air Act, the regulations promulgated under the act or the Clean Air Act, a plan approval or permit or in a manner that causes air pollution.

(b) The permittee fails to properly or adequately maintain or repair an air pollution control device or equipment attached to or otherwise made a part of the source.

(c) The permittee fails to submit a report required by this plan approval.

(d) The Environmental Protection Agency determines that this plan approval is not in compliance with the Clean Air Act or the regulations thereunder.

#010 [25 Pa. Code §§ 121.9 & 127.216]**Circumvention**

(a) The permittee, or any other person, may not circumvent the new source review requirements of 25 Pa. Code Chapter 127, Subchapter E by causing or allowing a pattern of ownership or development, including the phasing, staging, delaying or engaging in incremental construction, over a geographic area of a facility which, except for the pattern of ownership or development, would otherwise require a permit or submission of a plan approval application.

(b) No person may permit the use of a device, stack height which exceeds good engineering practice stack height, dispersion technique or other technique which, without resulting in reduction of the total amount of air contaminants emitted, conceals or dilutes an emission of air contaminants which would otherwise be in violation of this plan approval, the Air Pollution Control Act or the regulations promulgated thereunder, except that with prior approval of the Department, the device or technique may be used for control of malodors.

#011 [25 Pa. Code § 127.12c]**Submissions**

Reports, test data, monitoring data, notifications shall be submitted to the:

Regional Air Program Manager

PA Department of Environmental Protection

(At the address given on the plan approval transmittal letter or otherwise notified)

#012 [25 Pa. Code § 127.12(a)(9) & 40 CFR Part 68]**Risk Management**

(a) If required by Section 112(r) of the Clean Air Act, the permittee shall develop and implement an accidental release program consistent with requirements of the Clean Air Act, 40 CFR Part 68 (relating to chemical accident prevention provisions) and the Federal Chemical Safety Information, Site Security and Fuels Regulatory Relief Act (P.L. 106-40).

(b) The permittee shall prepare and implement a Risk Management Plan (RMP) which meets the requirements of Section 112(r) of the Clean Air Act, 40 CFR Part 68 and the Federal Chemical Safety Information, Site Security and Fuels Regulatory Relief Act when a regulated substance listed in 40 CFR § 68.130 is present in a process in more than the listed threshold quantity at the facility. The permittee shall submit the RMP to the Environmental Protection Agency according to the following schedule and requirements:

(1) The permittee shall submit the first RMP to a central point specified by the Environmental Protection Agency no later than the latest of the following:

**SECTION B. General Plan Approval Requirements**

- (i) Three years after the date on which a regulated substance is first listed under § 68.130; or,
- (ii) The date on which a regulated substance is first present above a threshold quantity in a process.

(2) The permittee shall submit any additional relevant information requested by the Department or the Environmental Protection Agency concerning the RMP and shall make subsequent submissions of RMPs in accordance with 40 CFR § 68.190.

(3) The permittee shall certify that the RMP is accurate and complete in accordance with the requirements of 40 CFR Part 68, including a checklist addressing the required elements of a complete RMP.

(c) As used in this plan approval condition, the term "process" shall be as defined in 40 CFR § 68.3. The term "process" means any activity involving a regulated substance including any use, storage, manufacturing, handling, or on-site movement of such substances or any combination of these activities. For purposes of this definition, any group of vessels that are interconnected, or separate vessels that are located such that a regulated substance could be involved in a potential release, shall be considered a single process.

#013 [25 Pa. Code § 121.7]**Prohibition of Air Pollution**

No person may permit air pollution as that term is defined in the Air Pollution Control Act (35 P.S. §§ 4001-4015).

#014 [25 Pa. Code § 127.25]**Compliance Requirement**

A person may not cause or permit the operation of a source subject to § 127.11 (relating to plan approval requirements), unless the source and air cleaning devices identified in the application for the plan approval and the plan approval issued to the source, are operated and maintained in accordance with specifications in the application and conditions in the plan approval issued by the Department. A person may not cause or permit the operation of an air contamination source subject to this chapter in a manner inconsistent with good operating practices.



SECTION C. Site Level Plan Approval Requirements

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this plan approval including Section B (Plan Approval General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this plan approval including Section B (Plan Approval General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this plan approval including Section B (Plan Approval General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

001 [25 Pa. Code §127.12b]

Plan approval terms and conditions.

- a) All records required must be maintained onsite for a minimum of 5 years and may be maintained in electronic format.
- b) The owner or operator of the facility shall generate and maintain records that clearly demonstrate to the Department that the facility is in compliance with all emission limitations. The Department reserves the right to request additional information necessary to determine compliance with the plan approval.
- c) All manually generated log entries used to comply with the recordkeeping requirements of this plan approval shall include the following:
 - 1) Time and date of observation
 - 2) Name, title, and signature of the person making the observation
 - 3) Any corrective action taken as result of the observation
- d) The permittee shall maintain records of all preventative maintenance, repairs, and inspections performed on monitoring equipment, sources, and control devices. These records shall contain the following at a minimum:
 - 1) Time and date of the task
 - 2) Name, title, and initials of the person performing the task
 - 3) A detailed description of any maintenance / inspection / repair performed
 - 4) Any problems or defects found
 - 5) Any corrective action taken as result of the task

V. REPORTING REQUIREMENTS.

002 [25 Pa. Code §127.12b]

Plan approval terms and conditions.

Malfunction reporting shall be conducted as follows:

- (a) The owner or operator shall report each malfunction that occurs at this facility that poses an imminent and substantial danger to the public health and safety or the environment. Malfunction reports are only required by this permit where such malfunctions would affect air emissions from the facility.

For purpose of this condition, a malfunction is defined as any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment or source to operate in a normal or usual manner that may result in an increase in the emission of air contaminants. Examples of malfunctions include, but are not limited to, large dust plumes, heavy smoke, or a spill or release that may result in an odor detectable outside the property of the person on whose land the source is being operated.

- (b) When the malfunction poses an imminent and substantial danger to the public health and safety or the environment, the incident shall be reported by telephone to the County Emergency Management Agency (911 Center), and to the 24-hour DEP Emergency Hotline (800-541-2050) no later than 1 hour after the incident.

**SECTION C. Site Level Plan Approval Requirements**

(c) All other malfunctions that must be reported under subsection (a) shall be reported to the DEP at the Regional Office listed below no later than the next business day.

Pennsylvania Department of Environmental Protection
Northwest Regional Office
814-332-6945
Office Hours 8 a.m. - 4 p.m.

(d) The report shall describe the:

- (i) Name and location of the facility;
- (ii) Nature and cause of the malfunction or breakdown;
- (iii) Time when the malfunction or breakdown was first observed;
- (iv) Expected duration of excess emissions; and
- (v) Estimated rate of emissions.

(e) The owner or operator shall notify the DEP immediately when containment measures and corrective actions have been completed.

(f) Subsequent to the malfunction, the owner/operator shall submit a full written report to the DEP including the items identified in (d) and including containment measures and corrective actions taken on the malfunction within 15 days of the incident.

(g) Written Malfunction Reports shall be submitted to the DEP electronically via the following web address.

<https://greenport.pa.gov/ePermitPublicAccess/PublicSubmission/Home>

VI. WORK PRACTICE REQUIREMENTS.**# 003 [25 Pa. Code §127.12b]****Plan approval terms and conditions.**

- a) The permittee shall install, maintain, and operate sufficient instrumentation and monitoring equipment in order to comply with the recordkeeping requirements of this plan approval.
- b) A source may not operate without the full operational capacity of its associated control device(s).
- c) Sources operating on backup power must also have their associated control device(s) operating on backup power.

VII. ADDITIONAL REQUIREMENTS.**# 004 [25 Pa. Code §127.12b]****Plan approval terms and conditions.**

- a) Any information required to be submitted as part of this plan approval should be submitted to the attention of New Source Review Section Chief, Air Quality Program, Northwest Regional Office, 230 Chestnut Street, Meadville, PA 16335.
- b) Issuance of an Operating Permit or incorporation of a plan approval into a current Operating Permit is contingent upon satisfactory compliance with the plan approval conditions, upon the source and control device being installed and operated as stated within the application, and upon satisfactory demonstration that the emissions from the source will not be in violation of applicable Rules and Regulations of the Department.
- c) If at any time the Department has reason to believe that the air contaminant emissions are, or may be, in excess of any applicable air contaminant emission limitation, the owner or operator shall conduct such stack tests or source tests requested by the Department to determine the actual air contaminant emission rate. The owner or operator shall perform



SECTION C. Site Level Plan Approval Requirements

any such testing in accordance with the applicable provisions of 25 Pa. Code, Chapter 139 (relating to sampling and testing) as well as in accordance with any additional requirements or conditions established by the Department at the time the owner or operator is notified, in writing, of the need to conduct testing.

d) The permittee will perform additional testing via a third party when the Department conducts an inspection of the facility and subsequently determines that additional testing is warranted.

e) All requirements of the current operating permit (27-00015 originally issued by the Department on June 23, 2021, Significant Modification Issued June 26, 2025, Expiration May 31, 2026) remain in effect, as applicable, unless modified by this plan approval. The conditions of this plan approval supersede the conditions of previous authorizations.

f) Some monitoring, work practice, and record keeping requirements of this plan approval necessitate the control device/source to be in operation and are therefore applicable only when the control device/source are in operation.

VIII. COMPLIANCE CERTIFICATION.

No additional compliance certifications exist except as provided in other sections of this plan approval including Section B (relating to Plan Approval General Requirements).

IX. COMPLIANCE SCHEDULE.

No compliance milestones exist.

**SECTION D. Source Level Plan Approval Requirements**

Source ID: 136

Source Name: 4000 BHP, CLARK TVC-10C, ENG NO 6, SN 107038

Source Capacity/Throughput:

**I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §127.12b]****Plan approval terms and conditions.**

a) Emissions from the source shall not exceed:

- (1) NO_x: 0.60 g/bhp-hr, 5.29 lbs/hr, 23.17 tpy (12 month rolling total)
- (2) CO: 1.00 g/bhp-hr, 8.82 lbs/hr, 38.62 tpy (12 month rolling total)
- (3) VOC: 0.50 g/bhp-hr, 4.41 lbs/hr, 19.31 tpy (12 month rolling total)

b) Visible emissions from the exhaust stack shall not exceed 10% opacity.

II. TESTING REQUIREMENTS.**# 002 [25 Pa. Code §127.12b]****Plan approval terms and conditions.**

a) Within one hundred and eighty (180) days of plan approval issuance, the permittee shall perform stack testing of the source/control device to determine the following emission rates:

- (1) NO_x (g/bhp-hr, lbs/hr)
- (2) CO (g/bhp-hr, lbs/hr)
- (3) VOC (g/bhp-hr, lbs/hr)

Testing shall occur when the source is operating at its maximum achievable production rate. Stack testing shall be performed in accordance with the provisions of Chapter 139 of the Rules and Regulations of the Department of Environmental Protection.

b) One electronic copy of all source test submissions (except notifications), such as protocols, reports, supplemental information, etc. shall be sent to both PSIMS Administration in Central Office and to Regional Office AQ Program Manager.

Electronic copies shall be sent to the following e-mail addresses:

CENTRAL OFFICE:

RA-EPstacktesting@pa.gov

NORTHWEST REGIONAL OFFICE:

RA-EPNWstacktesting@pa.gov

Testing notifications shall be submitted through OnBase at the following link:

<https://www.dep.pa.gov/DataandTools/Pages/Application-Form-Upload.aspx>

c) At least 90 days prior to performing a stack test, a protocol shall be submitted in accordance with the provisions of Chapter 139 of the Rules and Regulations of the Department of Environmental Protection. Submit the protocol via the instructions in b). The protocol shall contain, at a minimum, location of sampling ports, planned production rates, and any other information applicable to the stack testing. Performing a stack test prior to Department approval of the protocol may invalidate the results.

**SECTION D. Source Level Plan Approval Requirements**

d) At least 2 weeks prior to the test, the Department shall be informed, in writing, of the date and time of the test. Submit this notice via the instructions in b).

e) Within 30 days after completion of the test, the complete test report, including, but not limited to, production rates during testing, calculation methods and results, and any other applicable testing information that will allow for a complete review of the test and results, shall be submitted to the Department for approval. Submit the report via the instructions in b).

f) Actions Related to Noncompliance Demonstrated by a Stack Test:

(1) When the results of a stack test performed in conformance with this Condition exceed the level specified in any condition of this approval, the Permittee shall take appropriate corrective actions. The Permittee shall submit a description of these corrective actions to the Department, within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize emissions from the affected facility while the corrective actions are being implemented. The Department shall notify the Permittee within thirty (30) days, if the corrective actions taken are deficient. The Permittee shall submit a description of additional corrective actions taken to the Department within thirty (30) days of receipt of the notice of deficiency. The Department reserves the authority to use enforcement activities to resolve noncompliant stack tests.

(2) A retest to demonstrate compliance shall be performed within one hundred twenty (120) days of receipt of the original test results. Should the Permittee demonstrate to the Department that retesting in one hundred and twenty (120) days is not practicable, the Department may extend the retesting deadline. Failure of the second test to demonstrate compliance with the appropriate approval conditions may be grounds for immediate revocation of the approval to operate the affected facility.

g) If, at any time, the Department has reason to believe that the air contaminant emissions from the source are, or may be, in excess of any applicable air contaminant emission limitation, the owner or operator shall conduct stack tests as are deemed necessary by the Department to determine the actual air contaminant emission rate. The owner or operator shall perform any such testing in accordance with the applicable provisions of 25 Pa. Code, Chapter 139 (relating to sampling and testing) as well as in accordance with any additional requirements or conditions established by the Department at the time the owner or operator is notified, in writing, of the need to conduct testing.

h) This stack testing program shall be repeated every 8,760 hours of operation, but no less often than every 3 years. The testing shall be performed in accordance with the provisions of Chapter 139 of the Rules and Regulations of the Department of Environmental Protection and Conditions (a)-(g) above.

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this plan approval including Section B (Plan Approval General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

003 [25 Pa. Code §127.12b]

Plan approval terms and conditions.

a) The permittee shall maintain records of all preventative maintenance, repairs, and inspections performed on the sources, monitoring equipment, and control devices. These records shall contain the following at a minimum:

- (1) Time and date of the task
- (2) Name, title, and initials of the person performing the task
- (3) A detailed description any maintenance / inspection / repair performed
- (4) Any problems or defects found
- (5) Any corrective action taken as result of the task

**SECTION D. Source Level Plan Approval Requirements****V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this plan approval including Section B (Plan Approval General Requirements).

VI. WORK PRACTICE REQUIREMENTS.**# 004 [25 Pa. Code §127.12b]****Plan approval terms and conditions.**

- a) All gauges employed shall have a scale such that the expected normal reading shall be no less than twenty percent (20%) of full scale and be accurate within plus or minus two percent (+/- 2%) of full scale reading.
- b) The permittee shall maintain and operate the source and control device in accordance with the manufacturer's specifications, the requirements of this plan approval, and in accordance with good air pollution control practices.
- c) All manufacturer recommended maintenance activities shall be performed on the source and control device at the frequency recommended by the manufacturer.
- d) A copy of the source and control device manufacturer's operational and maintenance literature shall be maintained onsite at all times and shall be readily available.

VII. ADDITIONAL REQUIREMENTS.**# 005 [25 Pa. Code §127.12b]****Plan approval terms and conditions.**

This Plan Approval 27-00015B authorizes the following equipment to be installed on Source ID 136 (4000 BHP engine, CLARK TVC-10C, ENG NO 6, SN 107038), as described in the February 4, 2025 Plan Approval Application:

- a) a high-pressure fuel injection system (a type of Low Emissions Combustion [LEC] technology);
- b) new pre-combustion chambers;
- c) modifications to the existing turbocharger;
- d) new intercoolers, and a new auxiliary water cooler;
- e) new exhaust with oxidation catalyst to mitigate any potential increase in carbon monoxide emissions from the LEC technology.



SECTION E. Source Group Plan Approval Restrictions.

**SECTION F. Alternative Operation Requirements.**

No Alternative Operations exist for this Plan Approval facility.

**SECTION G. Emission Restriction Summary.**

Source Id	Source Description		
136	4000 BHP, CLARK TVC-10C, ENG NO 6, SN 107038		
Emission Limit		Pollutant	
1.000	gr/HP-Hr		CO
8.820	Lbs/Hr		CO
38.620	Tons/Yr	12 month rolling total	CO
0.600	gr/HP-Hr		NOX
5.290	Lbs/Hr		NOX
23.170	Tons/Yr	12 month rolling total	NOX
0.500	gr/HP-Hr		VOC
4.410	Lbs/Hr		VOC
19.310	Tons/Yr	12 month rolling total	VOC

Site Emission Restriction Summary

Emission Limit	Pollutant
----------------	-----------



SECTION H. Miscellaneous.



***** End of Report *****
