



**COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
AIR QUALITY PROGRAM**

TITLE V/STATE OPERATING PERMIT

Issue Date:	July 21, 2025	Effective Date:	May 20, 2026
Revision Date:	May 20, 2026	Expiration Date:	July 20, 2030
Revision Type:	Amendment		

In accordance with the provisions of the Air Pollution Control Act, the Act of January 8, 1960, P.L. 2119, as amended, and 25 Pa. Code Chapter 127, the Owner, [and Operator if noted] (hereinafter referred to as permittee) identified below is authorized by the Department of Environmental Protection (Department) to operate the air emission source(s) more fully described in this permit. This Facility is subject to all terms and conditions specified in this permit. Nothing in this permit relieves the permittee from its obligations to comply with all applicable Federal, State and Local laws and regulations.

The regulatory or statutory authority for each permit condition is set forth in brackets. All terms and conditions in this permit are federally enforceable applicable requirements unless otherwise designated as "State-Only" or "non-applicable" requirements.

TITLE V Permit No: 59-00002

Federal Tax Id - Plant Code: 55-0629203-9

Owner Information

Name: EASTERN GAS TRANS & STORAGE INC
Mailing Address: 10700 ENERGY WAY
GLEN ALLEN, VA 23060-9243

Plant Information

Plant: EASTERN GAS TRANS & STORAGE INC/TIOGA STA
Location: 59 Tioga County 59916 Farmington Township
SIC Code: 4922 Trans. & Utilities - Natural Gas Transmission

Responsible Official

Name: JOHN M. LAMB
Title: VP EASTERN PIPELINE OPR
Phone: (804) 273 - 4327 Email: Matt.Lamb@bhegts.com

Permit Contact Person

Name: SARAH JEAN CRANE
Title: ENV SPCST II
Phone: (804) 965 - 3360 Email: Sarah.Crane@bhegts.com

[Signature] _____
MUHAMMAD Q. ZAMAN, ENVIRONMENTAL PROGRAM MANAGER, NORTHCENTRAL REGION



SECTION A. Table of Contents

Section A. Facility/Source Identification

Table of Contents
Site Inventory List

Section B. General Title V Requirements

- #001 Definitions
- #002 Prohibition of Air Pollution
- #003 Property Rights
- #004 Permit Expiration
- #005 Permit Renewal
- #006 Transfer of Ownership or Operational Control
- #007 Inspection and Entry
- #008 Compliance Requirements
- #009 Need to Halt or Reduce Activity Not a Defense
- #010 Duty to Provide Information
- #011 Reopening and Revising the Title V Permit for Cause
- #012 Reopening a Title V Permit for Cause by EPA
- #013 Operating Permit Application Review by the EPA
- #014 Significant Operating Permit Modifications
- #015 Minor Operating Permit Modifications
- #016 Administrative Operating Permit Amendments
- #017 Severability Clause
- #018 Fee Payment
- #019 Authorization for De Minimis Emission Increases
- #020 Reactivation of Sources
- #021 Circumvention
- #022 Submissions
- #023 Sampling, Testing and Monitoring Procedures
- #024 Compliance Certification
- #025 Recordkeeping Requirements
- #026 Reporting Requirements
- #027 Operational Flexibility
- #028 Risk Management
- #029 Approved Economic Incentives and Emission Trading Programs
- #030 Permit Shield
- #031 Reporting
- #032 Report Format

Section C. Site Level Title V Requirements

- C-I: Restrictions
- C-II: Testing Requirements
- C-III: Monitoring Requirements
- C-IV: Recordkeeping Requirements
- C-V: Reporting Requirements
- C-VI: Work Practice Standards
- C-VII: Additional Requirements
- C-VIII: Compliance Certification
- C-IX: Compliance Schedule

Section D. Source Level Title V Requirements

- D-I: Restrictions
- D-II: Testing Requirements
- D-III: Monitoring Requirements
- D-IV: Recordkeeping Requirements
- D-V: Reporting Requirements



SECTION A. Table of Contents

D-VI: Work Practice Standards
D-VII: Additional Requirements

Note: These same sub-sections are repeated for each source!

Section E. Source Group Restrictions

E-I: Restrictions
E-II: Testing Requirements
E-III: Monitoring Requirements
E-IV: Recordkeeping Requirements
E-V: Reporting Requirements
E-VI: Work Practice Standards
E-VII: Additional Requirements

Section F. Alternative Operating Scenario(s)


F-I: Restrictions
F-II: Testing Requirements
F-III: Monitoring Requirements
F-IV: Recordkeeping Requirements
F-V: Reporting Requirements
F-VI: Work Practice Standards
F-VII: Additional Requirements

Section G. Emission Restriction Summary

Section H. Miscellaneous


**SECTION A. Site Inventory List**

Source ID	Source Name	Capacity/Throughput	Fuel/Material
033	TULPRO HEATER 2 (18.6 MMBTU/HR)	18.600 MMBTU/HR	
036	CLEAVER BROOKS BOILER (2.93 MMBTU/HR)	2.930 MMBTU/HR	
038	ETI REGEN HEATER	5.250 MMBTU/HR	
P01	FACILITY FUGITIVE EMISSIONS		
P101	4200 HP DRESSER RAND TCV-10 ENGINE 1		
P102	4200 HP DRESSER RAND TCV-10 ENGINE 2		
P201	596 BHP WAUKESHA GENERATOR ENGINE		
P204	7 STORAGE TANKS (VP < 1.5 PSI)		
P205	2 STORAGE TANKS (VP > 1.5 PSI)		
P213	GAS BLOWDOWNS		
C101A	OXIDATION CATALYST		
C101B	SCR		
C102A	OXIDATION CATALYST		
C102B	SCR		
FM01	NATURAL GAS PIPELINE		
S033	HEATER 2 STACK		
S036	BOILER STACK		
S038	ETI REGEN HEATER STACK		
S101	ENGINE 1 STACK		
S102	ENGINE 2 STACK		
S201	GENERATOR STACK		
Z01	FACILITY FUGITIVES		
Z204	TANK EMISSIONS		
Z205	TANK EMISSIONS		

PERMIT MAPS



PERMIT MAPS



**SECTION B. General Title V Requirements****#001 [25 Pa. Code § 121.1]****Definitions**

Words and terms that are not otherwise defined in this permit shall have the meanings set forth in Section 3 of the Air Pollution Control Act (35 P.S. § 4003) and 25 Pa. Code § 121.1.

#002 [25 Pa. Code § 121.7]**Prohibition of Air Pollution**

No person may permit air pollution as that term is defined in the Air Pollution Control Act (35 P.S. §§ 4001-4015).

#003 [25 Pa. Code § 127.512(c)(4)]**Property Rights**

This permit does not convey property rights of any sort, or any exclusive privileges.

#004 [25 Pa. Code § 127.446(a) and (c)]**Permit Expiration**

This operating permit is issued for a fixed term of five (5) years and shall expire on the date specified on Page 1 of this permit. The terms and conditions of the expired permit shall automatically continue pending issuance of a new Title V permit, provided the permittee has submitted a timely and complete application and paid applicable fees required under 25 Pa. Code Chapter 127, Subchapter I and the Department is unable, through no fault of the permittee, to issue or deny a new permit before the expiration of the previous permit. An application is complete if it contains sufficient information to begin processing the application, has the applicable sections completed and has been signed by a responsible official.

#005 [25 Pa. Code §§ 127.412, 127.413, 127.414, 127.446(e), 127.503 & 127.704(b)]**Permit Renewal**

(a) An application for the renewal of the Title V permit shall be submitted to the Department at least six (6) months, and not more than 18 months, before the expiration date of this permit. The renewal application is timely if a complete application is submitted to the Department's Regional Air Manager within the timeframe specified in this permit condition.

(b) The application for permit renewal shall include the current permit number, the appropriate permit renewal fee, a description of any permit revisions and off-permit changes that occurred during the permit term, and any applicable requirements that were promulgated and not incorporated into the permit during the permit term. The fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" and submitted with the fee form to the respective regional office.

(c) The renewal application shall also include submission of proof that the local municipality and county, in which the facility is located, have been notified in accordance with 25 Pa. Code § 127.413. The application for renewal of the Title V permit shall also include submission of compliance review forms which have been used by the permittee to update information submitted in accordance with either 25 Pa. Code § 127.412(b) or § 127.412(j).

(d) The permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the permit application, shall promptly submit such supplementary facts or corrected information during the permit renewal process. The permittee shall also promptly provide additional information as necessary to address any requirements that become applicable to the source after the date a complete renewal application was submitted but prior to release of a draft permit.

#006 [25 Pa. Code §§ 127.450(a)(4) & 127.464(a)]**Transfer of Ownership or Operational Control**

(a) In accordance with 25 Pa. Code § 127.450(a)(4), a change in ownership or operational control of the source shall be treated as an administrative amendment if:

(1) The Department determines that no other change in the permit is necessary;

(2) A written agreement has been submitted to the Department identifying the specific date of the transfer of permit

**SECTION B. General Title V Requirements**

responsibility, coverage and liability between the current and the new permittee; and,

(3) A compliance review form has been submitted to the Department and the permit transfer has been approved by the Department.

(b) In accordance with 25 Pa. Code § 127.464(a), this permit may not be transferred to another person except in cases of transfer-of-ownership which are documented and approved to the satisfaction of the Department.

#007 [25 Pa. Code § 127.513, 35 P.S. § 4008 and § 114 of the CAA]**Inspection and Entry**

(a) Upon presentation of credentials and other documents as may be required by law for inspection and entry purposes, the permittee shall allow the Department of Environmental Protection or authorized representatives of the Department to perform the following:

- (1) Enter at reasonable times upon the permittee's premises where a Title V source is located or emissions related activity is conducted, or where records are kept under the conditions of this permit;
- (2) Have access to and copy or remove, at reasonable times, records that are kept under the conditions of this permit;
- (3) Inspect at reasonable times, facilities, equipment including monitoring and air pollution control equipment, practices, or operations regulated or required under this permit;
- (4) Sample or monitor, at reasonable times, substances or parameters, for the purpose of assuring compliance with the permit or applicable requirements as authorized by the Clean Air Act, the Air Pollution Control Act, or the regulations promulgated under the Acts.

(b) Pursuant to 35 P.S. § 4008, no person shall hinder, obstruct, prevent or interfere with the Department or its personnel in the performance of any duty authorized under the Air Pollution Control Act.

(c) Nothing in this permit condition shall limit the ability of the EPA to inspect or enter the premises of the permittee in accordance with Section 114 or other applicable provisions of the Clean Air Act.

#008 [25 Pa. Code §§ 127.25, 127.444, & 127.512(c)(1)]**Compliance Requirements**

(a) The permittee shall comply with the conditions of this permit. Noncompliance with this permit constitutes a violation of the Clean Air Act and the Air Pollution Control Act and is grounds for one (1) or more of the following:

- (1) Enforcement action
- (2) Permit termination, revocation and reissuance or modification
- (3) Denial of a permit renewal application

(b) A person may not cause or permit the operation of a source, which is subject to 25 Pa. Code Article III, unless the source(s) and air cleaning devices identified in the application for the plan approval and operating permit and the plan approval issued to the source are operated and maintained in accordance with specifications in the applications and the conditions in the plan approval and operating permit issued by the Department. A person may not cause or permit the operation of an air contamination source subject to 25 Pa. Code Chapter 127 in a manner inconsistent with good operating practices.

(c) For purposes of Sub-condition (b) of this permit condition, the specifications in applications for plan approvals and operating permits are the physical configurations and engineering design details which the Department determines are essential for the permittee's compliance with the applicable requirements in this Title V permit.

**SECTION B. General Title V Requirements****#009 [25 Pa. Code § 127.512(c)(2)]****Need to Halt or Reduce Activity Not a Defense**

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

#010 [25 Pa. Code §§ 127.411(d) & 127.512(c)(5)]**Duty to Provide Information**

(a) The permittee shall furnish to the Department, within a reasonable time, information that the Department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit, or to determine compliance with the permit.

(b) Upon request, the permittee shall also furnish to the Department copies of records that the permittee is required to keep by this permit, or for information claimed to be confidential, the permittee may furnish such records directly to the Administrator of EPA along with a claim of confidentiality.

#011 [25 Pa. Code §§ 127.463, 127.512(c)(3) & 127.542]**Reopening and Revising the Title V Permit for Cause**

(a) This Title V permit may be modified, revoked, reopened and reissued or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay a permit condition.

(b) This permit may be reopened, revised and reissued prior to expiration of the permit under one or more of the following circumstances:

(1) Additional applicable requirements under the Clean Air Act or the Air Pollution Control Act become applicable to a Title V facility with a remaining permit term of three (3) or more years prior to the expiration date of this permit. The Department will revise the permit as expeditiously as practicable but not later than 18 months after promulgation of the applicable standards or regulations. No such revision is required if the effective date of the requirement is later than the expiration date of this permit, unless the original permit or its terms and conditions has been extended.

(2) Additional requirements, including excess emissions requirements, become applicable to an affected source under the acid rain program. Upon approval by the Administrator of EPA, excess emissions offset plans for an affected source shall be incorporated into the permit.

(3) The Department or the EPA determines that this permit contains a material mistake or inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.

(4) The Department or the Administrator of EPA determines that the permit must be revised or revoked to assure compliance with the applicable requirements.

(c) Proceedings to revise this permit shall follow the same procedures which apply to initial permit issuance and shall affect only those parts of this permit for which cause to revise exists. The revision shall be made as expeditiously as practicable.

(d) Regardless of whether a revision is made in accordance with (b)(1) above, the permittee shall meet the applicable standards or regulations promulgated under the Clean Air Act within the time frame required by standards or regulations.

#012 [25 Pa. Code § 127.543]**Reopening a Title V Permit for Cause by EPA**

As required by the Clean Air Act and regulations adopted thereunder, this permit may be modified, reopened and reissued, revoked or terminated for cause by EPA in accordance with procedures specified in 25 Pa. Code § 127.543.

**SECTION B. General Title V Requirements****#013 [25 Pa. Code § 127.522(a)]****Operating Permit Application Review by the EPA**

The applicant may be required by the Department to provide a copy of the permit application, including the compliance plan, directly to the Administrator of the EPA. Copies of title V permit applications to EPA, pursuant to 25 PA Code §127.522(a), shall be submitted, if required, to the following EPA e-mail box:

R3_Air_Apps_and_Notices@epa.gov

Please place the following in the subject line: TV [permit number], [Facility Name].

#014 [25 Pa. Code § 127.541]**Significant Operating Permit Modifications**

When permit modifications during the term of this permit do not qualify as minor permit modifications or administrative amendments, the permittee shall submit an application for significant Title V permit modifications in accordance with 25 Pa. Code § 127.541. Notifications to EPA, pursuant to 25 PA Code §127.522(a), if required, shall be submitted, to the following EPA e-mail box:

R3_Air_Apps_and_Notices@epa.gov

Please place the following in the subject line: TV [permit number], [Facility Name].

#015 [25 Pa. Code §§ 121.1 & 127.462]**Minor Operating Permit Modifications**

The permittee may make minor operating permit modifications (as defined in 25 Pa. Code §121.1), on an expedited basis, in accordance with 25 Pa. Code §127.462 (relating to minor operating permit modifications). Notifications to EPA, pursuant to 25 PA Code §127.462(c), if required, shall be submitted, to the following EPA e-mail box:

R3_Air_Apps_and_Notices@epa.gov

Please place the following in the subject line: TV [permit number], [Facility Name].

#016 [25 Pa. Code § 127.450]**Administrative Operating Permit Amendments**

(a) The permittee may request administrative operating permit amendments, as defined in 25 Pa. Code §127.450(a). Copies of request for administrative permit amendment to EPA, pursuant to 25 PA Code §127.450(c)(1), if required, shall be submitted to the following EPA e-mail box:

R3_Air_Apps_and_Notices@epa.gov

Please place the following in the subject line: TV [permit number], [Facility Name].

(b) Upon final action by the Department granting a request for an administrative operating permit amendment covered under §127.450(a)(5), the permit shield provisions in 25 Pa. Code § 127.516 (relating to permit shield) shall apply to administrative permit amendments incorporated in this Title V Permit in accordance with §127.450(c), unless precluded by the Clean Air Act or the regulations thereunder.

#017 [25 Pa. Code § 127.512(b)]**Severability Clause**

The provisions of this permit are severable, and if any provision of this permit is determined by the Environmental Hearing Board or a court of competent jurisdiction, or US EPA to be invalid or unenforceable, such a determination will not affect the remaining provisions of this permit.

**SECTION B. General Title V Requirements****#018 [25 Pa. Code §§ 127.704, 127.705 & 127.707]****Fee Payment**

(a) The permittee shall pay fees to the Department in accordance with the applicable fee schedules in 25 Pa. Code Chapter 127, Subchapter I (relating to plan approval and operating permit fees). The applicable fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" with the permit number clearly indicated and submitted to the respective regional office.

(b) Emission Fees. The permittee shall, on or before September 1st of each year, pay applicable annual Title V emission fees for emissions occurring in the previous calendar year as specified in 25 Pa. Code § 127.705. The permittee is not required to pay an emission fee for emissions of more than 4,000 tons of each regulated pollutant emitted from the facility.

(c) As used in this permit condition, the term "regulated pollutant" is defined as a VOC, each pollutant regulated under Sections 111 and 112 of the Clean Air Act and each pollutant for which a National Ambient Air Quality Standard has been promulgated, except that carbon monoxide is excluded.

(d) Late Payment. Late payment of emission fees will subject the permittee to the penalties prescribed in 25 Pa. Code § 127.707 and may result in the suspension or termination of the Title V permit. The permittee shall pay a penalty of fifty percent (50%) of the fee amount, plus interest on the fee amount computed in accordance with 26 U.S.C.A. § 6621(a)(2) from the date the emission fee should have been paid in accordance with the time frame specified in 25 Pa. Code § 127.705(c).

(e) The permittee shall pay an annual operating permit maintenance fee according to the following fee schedule established in 25 Pa. Code § 127.704(d) on or before December 31 of each year for the next calendar year.

- (1) Eight thousand dollars (\$8,000) for calendar years 2021—2025.
- (2) Ten thousand dollars (\$10,000) for calendar years 2026—2030.
- (3) Twelve thousand five hundred dollars (\$12,500) for the calendar years beginning with 2031.

#019 [25 Pa. Code §§ 127.14(b) & 127.449]**Authorization for De Minimis Emission Increases**

(a) This permit authorizes de minimis emission increases from a new or existing source in accordance with 25 Pa. Code §§ 127.14 and 127.449 without the need for a plan approval or prior issuance of a permit modification. The permittee shall provide the Department with seven (7) days prior written notice before commencing any de minimis emissions increase that would result from either: (1) a physical change of minor significance under § 127.14(c)(1); or (2) the construction, installation, modification or reactivation of an air contamination source. The written notice shall:

- (1) Identify and describe the pollutants that will be emitted as a result of the de minimis emissions increase.
- (2) Provide emission rates expressed in tons per year and in terms necessary to establish compliance consistent with any applicable requirement.

The Department may disapprove or condition de minimis emission increases at any time.

(b) Except as provided below in (c) and (d) of this permit condition, the permittee is authorized during the term of this permit to make de minimis emission increases (expressed in tons per year) up to the following amounts without the need for a plan approval or prior issuance of a permit modification:

- (1) Four tons of carbon monoxide from a single source during the term of the permit and 20 tons of carbon monoxide at the facility during the term of the permit.
- (2) One ton of NO_x from a single source during the term of the permit and 5 tons of NO_x at the facility during the term of the permit.
- (3) One and six-tenths tons of the oxides of sulfur from a single source during the term of the permit and 8.0 tons of

**SECTION B. General Title V Requirements**

oxides of sulfur at the facility during the term of the permit.

(4) Six-tenths of a ton of PM₁₀ from a single source during the term of the permit and 3.0 tons of PM₁₀ at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act or 25 Pa. Code Article III.

(5) One ton of VOCs from a single source during the term of the permit and 5.0 tons of VOCs at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act or 25 Pa. Code Article III.

(c) In accordance with § 127.14, the permittee may install the following minor sources without the need for a plan approval:

(1) Air conditioning or ventilation systems not designed to remove pollutants generated or released from other sources.

(2) Combustion units rated at 2,500,000 or less Btu per hour of heat input.

(3) Combustion units with a rated capacity of less than 10,000,000 Btu per hour heat input fueled by natural gas supplied by a public utility, liquefied petroleum gas or by commercial fuel oils which are No. 2 or lighter, viscosity less than or equal to 5.82 c St, and which meet the sulfur content requirements of 25 Pa. Code § 123.22 (relating to combustion units). For purposes of this permit, commercial fuel oil shall be virgin oil which has no reprocessed, recycled or waste material added.

(4) Space heaters which heat by direct heat transfer.

(5) Laboratory equipment used exclusively for chemical or physical analysis.

(6) Other sources and classes of sources determined to be of minor significance by the Department.

(d) This permit does not authorize de minimis emission increases if the emissions increase would cause one or more of the following:

(1) Increase the emissions of a pollutant regulated under Section 112 of the Clean Air Act except as authorized in Subparagraphs (b)(4) and (5) of this permit condition.

(2) Subject the facility to the prevention of significant deterioration requirements in 25 Pa. Code Chapter 127, Subchapter D and/or the new source review requirements in Subchapter E.

(3) Violate any applicable requirement of the Air Pollution Control Act, the Clean Air Act, or the regulations promulgated under either of the acts.

(4) Changes which are modifications under any provision of Title I of the Clean Air Act and emission increases which would exceed the allowable emissions level (expressed as a rate of emissions or in terms of total emissions) under the Title V permit.

(e) Unless precluded by the Clean Air Act or the regulations thereunder, the permit shield described in 25 Pa. Code § 127.516 (relating to permit shield) shall extend to the changes made under 25 Pa. Code § 127.449 (relating to de minimis emission increases).

(f) Emissions authorized under this permit condition shall be included in the monitoring, recordkeeping and reporting requirements of this permit.

(g) Except for de minimis emission increases allowed under this permit, 25 Pa. Code § 127.449, or sources and physical changes meeting the requirements of 25 Pa. Code § 127.14, the permittee is prohibited from making physical changes or engaging in activities that are not specifically authorized under this permit without first applying for a plan approval. In accordance with § 127.14(b), a plan approval is not required for the construction, modification, reactivation, or installation of the sources creating the de minimis emissions increase.

**SECTION B. General Title V Requirements**

(h) The permittee may not meet de minimis emission threshold levels by offsetting emission increases or decreases at the same source.

#020 [25 Pa. Code §§ 127.11a & 127.215]**Reactivation of Sources**

(a) The permittee may reactivate a source at the facility that has been out of operation or production for at least one year, but less than or equal to five (5) years, if the source is reactivated in accordance with the requirements of 25 Pa. Code §§ 127.11a and 127.215. The reactivated source will not be considered a new source.

(b) A source which has been out of operation or production for more than five (5) years but less than 10 years may be reactivated and will not be considered a new source if the permittee satisfies the conditions specified in 25 Pa. Code § 127.11a(b).

#021 [25 Pa. Code §§ 121.9 & 127.216]**Circumvention**

(a) The owner of this Title V facility, or any other person, may not circumvent the new source review requirements of 25 Pa. Code Chapter 127, Subchapter E by causing or allowing a pattern of ownership or development, including the phasing, staging, delaying or engaging in incremental construction, over a geographic area of a facility which, except for the pattern of ownership or development, would otherwise require a permit or submission of a plan approval application.

(b) No person may permit the use of a device, stack height which exceeds good engineering practice stack height, dispersion technique or other technique which, without resulting in reduction of the total amount of air contaminants emitted, conceals or dilutes an emission of air contaminants which would otherwise be in violation of this permit, the Air Pollution Control Act or the regulations promulgated thereunder, except that with prior approval of the Department, the device or technique may be used for control of malodors.

#022 [25 Pa. Code §§ 127.402(d) & 127.513(1)]**Submissions**

(a) Reports, test data, monitoring data, notifications and requests for renewal of the permit shall be submitted to the:

Regional Air Program Manager
PA Department of Environmental Protection
(At the address given on the permit transmittal letter, or otherwise notified)

(b) Any report or notification for the EPA Administrator or EPA Region III should be addressed to:

Enforcement & Compliance Assurance Division
Air, RCRA and Toxics Branch (3ED21)
Four Penn Center
1600 John F. Kennedy Boulevard
Philadelphia, PA 19103-2852

The Title V compliance certification shall be emailed to EPA at R3_APD_Permits@epa.gov.

(c) An application, form, report or compliance certification submitted pursuant to this permit condition shall contain certification by a responsible official as to truth, accuracy, and completeness as required under 25 Pa. Code § 127.402(d). Unless otherwise required by the Clean Air Act or regulations adopted thereunder, this certification and any other certification required pursuant to this permit shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.

#023 [25 Pa. Code §§ 127.441(c) & 127.463(e); Chapter 139; & 114(a)(3), 504(b) of the CAA]**Sampling, Testing and Monitoring Procedures**

(a) The permittee shall perform the emissions monitoring and analysis procedures or test methods for applicable requirements of this Title V permit. In addition to the sampling, testing and monitoring procedures specified in this

**SECTION B. General Title V Requirements**

permit, the Permittee shall comply with any additional applicable requirements promulgated under the Clean Air Act after permit issuance regardless of whether the permit is revised.

(b) The sampling, testing and monitoring required under the applicable requirements of this permit, shall be conducted in accordance with the requirements of 25 Pa. Code Chapter 139 unless alternative methodology is required by the Clean Air Act (including §§ 114(a)(3) and 504(b)) and regulations adopted thereunder.

#024 [25 Pa. Code § 127.513]**Compliance Certification**

(a) One year after the date of issuance of the Title V permit, and each year thereafter, unless specified elsewhere in the permit, the permittee shall submit to the Department and EPA Region III a certificate of compliance with the terms and conditions in this permit, for the previous year, including the emission limitations, standards or work practices.

This certification shall include:

- (1) The identification of each term or condition of the permit that is the basis of the certification.
- (2) The compliance status.
- (3) The methods used for determining the compliance status of the source, currently and over the reporting period.
- (4) Whether compliance was continuous or intermittent.

(b) The compliance certification shall be postmarked or hand-delivered no later than thirty days after each anniversary of the date of issuance of this Title V Operating Permit, or on the submittal date specified elsewhere in the permit, to the Department in accordance with the submission requirements specified in Section B, Condition #022 of this permit. The Title V compliance certification shall be emailed to EPA at R3_APD_Permits@epa.gov.

#025 [25 Pa. Code §§ 127.511 & Chapter 135]**Recordkeeping Requirements**

(a) The permittee shall maintain and make available, upon request by the Department, records of required monitoring information that include the following:

- (1) The date, place (as defined in the permit) and time of sampling or measurements.
- (2) The dates the analyses were performed.
- (3) The company or entity that performed the analyses.
- (4) The analytical techniques or methods used.
- (5) The results of the analyses.
- (6) The operating conditions as existing at the time of sampling or measurement.

(b) The permittee shall retain records of the required monitoring data and supporting information for at least five (5) years from the date of the monitoring sample, measurement, report or application. Supporting information includes the calibration data and maintenance records and original strip-chart recordings for continuous monitoring instrumentation, and copies of reports required by the permit.

(c) The permittee shall maintain and make available to the Department upon request, records including computerized records that may be necessary to comply with the reporting, recordkeeping and emission statement requirements in 25 Pa. Code Chapter 135 (relating to reporting of sources). In accordance with 25 Pa. Code Chapter 135, § 135.5, such records may include records of production, fuel usage, maintenance of production or pollution control equipment or other information determined by the Department to be necessary for identification and quantification of potential and actual air contaminant emissions. If direct recordkeeping is not possible or practical, sufficient records shall be kept to provide the needed information by indirect means.

**SECTION B. General Title V Requirements****#026 [25 Pa. Code §§ 127.411(d), 127.442, 127.463(e) & 127.511(c)]****Reporting Requirements**

(a) The permittee shall comply with the reporting requirements for the applicable requirements specified in this Title V permit. In addition to the reporting requirements specified herein, the permittee shall comply with any additional applicable reporting requirements promulgated under the Clean Air Act after permit issuance regardless of whether the permit is revised.

(b) Pursuant to 25 Pa. Code § 127.511(c), the permittee shall submit reports of required monitoring at least every six (6) months unless otherwise specified in this permit. Instances of deviations (as defined in 25 Pa. Code § 121.1) from permit requirements shall be clearly identified in the reports. The reporting of deviations shall include the probable cause of the deviations and corrective actions or preventative measures taken, except that sources with continuous emission monitoring systems shall report according to the protocol established and approved by the Department for the source. The required reports shall be certified by a responsible official.

(c) Every report submitted to the Department under this permit condition shall comply with the submission procedures specified in Section B, Condition #022(c) of this permit.

(d) Any records, reports or information obtained by the Department or referred to in a public hearing shall be made available to the public by the Department except for such records, reports or information for which the permittee has shown cause that the documents should be considered confidential and protected from disclosure to the public under Section 4013.2 of the Air Pollution Control Act and consistent with Sections 112(d) and 114(c) of the Clean Air Act and 25 Pa. Code § 127.411(d). The permittee may not request a claim of confidentiality for any emissions data generated for the Title V facility.

#027 [25 Pa. Code § 127.3]**Operational Flexibility**

The permittee is authorized to make changes within the Title V facility in accordance with the following provisions in 25 Pa. Code Chapter 127 which implement the operational flexibility requirements of Section 502(b)(10) of the Clean Air Act and Section 6.1(i) of the Air Pollution Control Act:

- (1) Section 127.14 (relating to exemptions)
- (2) Section 127.447 (relating to alternative operating scenarios)
- (3) Section 127.448 (relating to emissions trading at facilities with federally enforceable emissions caps)
- (4) Section 127.449 (relating to de minimis emission increases)
- (5) Section 127.450 (relating to administrative operating permit amendments)
- (6) Section 127.462 (relating to minor operating permit amendments)
- (7) Subchapter H (relating to general plan approvals and operating permits)

#028 [25 Pa. Code §§ 127.441(d), 127.512(i) and 40 CFR Part 68]**Risk Management**

(a) If required by Section 112(r) of the Clean Air Act, the permittee shall develop and implement an accidental release program consistent with requirements of the Clean Air Act, 40 CFR Part 68 (relating to chemical accident prevention provisions) and the Federal Chemical Safety Information, Site Security and Fuels Regulatory Relief Act (P.L. 106-40).

(b) The permittee shall prepare and implement a Risk Management Plan (RMP) which meets the requirements of Section 112(r) of the Clean Air Act, 40 CFR Part 68 and the Federal Chemical Safety Information, Site Security and Fuels Regulatory Relief Act when a regulated substance listed in 40 CFR § 68.130 is present in a process in more than the listed threshold quantity at the Title V facility. The permittee shall submit the RMP to the federal Environmental Protection Agency according to the following schedule and requirements:

- (1) The permittee shall submit the first RMP to a central point specified by EPA no later than the latest of the following:

**SECTION B. General Title V Requirements**

- (i) Three years after the date on which a regulated substance is first listed under § 68.130; or,
 - (ii) The date on which a regulated substance is first present above a threshold quantity in a process.
- (2) The permittee shall submit any additional relevant information requested by the Department or EPA concerning the RMP and shall make subsequent submissions of RMPs in accordance with 40 CFR § 68.190.
- (3) The permittee shall certify that the RMP is accurate and complete in accordance with the requirements of 40 CFR Part 68, including a checklist addressing the required elements of a complete RMP.
- (c) As used in this permit condition, the term "process" shall be as defined in 40 CFR § 68.3. The term "process" means any activity involving a regulated substance including any use, storage, manufacturing, handling, or on-site movement of such substances or any combination of these activities. For purposes of this definition, any group of vessels that are interconnected, or separate vessels that are located such that a regulated substance could be involved in a potential release, shall be considered a single process.
- (d) If the Title V facility is subject to 40 CFR Part 68, as part of the certification required under this permit, the permittee shall:
- (1) Submit a compliance schedule for satisfying the requirements of 40 CFR Part 68 by the date specified in 40 CFR § 68.10(a); or,
 - (2) Certify that the Title V facility is in compliance with all requirements of 40 CFR Part 68 including the registration and submission of the RMP.
- (e) If the Title V facility is subject to 40 CFR Part 68, the permittee shall maintain records supporting the implementation of an accidental release program for five (5) years in accordance with 40 CFR § 68.200.
- (f) When the Title V facility is subject to the accidental release program requirements of Section 112(r) of the Clean Air Act and 40 CFR Part 68, appropriate enforcement action will be taken by the Department if:
- (1) The permittee fails to register and submit the RMP or a revised plan pursuant to 40 CFR Part 68.
 - (2) The permittee fails to submit a compliance schedule or include a statement in the compliance certification required under Section B, Condition #026 of this permit that the Title V facility is in compliance with the requirements of Section 112(r) of the Clean Air Act, 40 CFR Part 68, and 25 Pa. Code § 127.512(i).

#029 [25 Pa. Code § 127.512(e)]**Approved Economic Incentives and Emission Trading Programs**

No permit revision shall be required under approved economic incentives, marketable permits, emissions trading and other similar programs or processes for changes that are provided for in this Title V permit.

#030 [25 Pa. Code §§ 127.516, 127.450(d), 127.449(f) & 127.462(g)]**Permit Shield**

(a) The permittee's compliance with the conditions of this permit shall be deemed in compliance with applicable requirements (as defined in 25 Pa. Code § 121.1) as of the date of permit issuance if either of the following applies:

- (1) The applicable requirements are included and are specifically identified in this permit.
- (2) The Department specifically identifies in the permit other requirements that are not applicable to the permitted facility or source.

(b) Nothing in 25 Pa. Code § 127.516 or the Title V permit shall alter or affect the following:

- (1) The provisions of Section 303 of the Clean Air Act, including the authority of the Administrator of the EPA provided thereunder.
- (2) The liability of the permittee for a violation of an applicable requirement prior to the time of permit issuance.

**SECTION B. General Title V Requirements**

(3) The applicable requirements of the acid rain program, consistent with Section 408(a) of the Clean Air Act.

(4) The ability of the EPA to obtain information from the permittee under Section 114 of the Clean Air Act.

(c) Unless precluded by the Clean Air Act or regulations thereunder, final action by the Department incorporating a significant permit modification in this Title V Permit shall be covered by the permit shield at the time that the permit containing the significant modification is issued.

#031 [25 Pa. Code §135.3]**Reporting**

(a) The permittee shall submit by March 1 of each year an annual emissions report for the preceding calendar year. The report shall include information for all active previously reported sources, new sources which were first operated during the preceding calendar year, and sources modified during the same period which were not previously reported. All air emissions from the facility should be estimated and reported.

(b) A source owner or operator may request an extension of time from the Department for the filing of an annual emissions report, and the Department may grant the extension for reasonable cause.

#032 [25 Pa. Code §135.4]**Report Format**

Emissions reports shall contain sufficient information to enable the Department to complete its emission inventory. Emissions reports shall be made by the source owner or operator in a format specified by the Department.

**SECTION C. Site Level Requirements****I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §123.1]****Prohibition of certain fugitive emissions**

The permittee shall not permit the emission of fugitive air contaminants into the outdoor atmosphere from a source other than the following:

- (1) Construction or demolition of buildings or structures.
- (2) Grading, paving and maintenance of roads and streets.
- (3) Use of roads and streets. Emissions from material in or on trucks, railroad cars and other vehicular equipment are not considered as emissions from use of roads and streets.
- (4) Clearing of land.
- (5) Stockpiling of materials.
- (6) Open burning operations.
- (7) Blasting in open pit mines. Emissions from drilling are not considered as emissions from blasting.
- (8) Sources and classes of sources other than those identified above, for which the permittee has obtained a determination from the Department that fugitive emissions from the source, after appropriate control, meet the following requirements:

- (a) the emissions are of minor significance with respect to causing air pollution; and
- (b) the emissions are not preventing or interfering with the attainment or maintenance of any ambient air quality standard.

002 [25 Pa. Code §123.2]**Fugitive particulate matter**

The permittee shall not permit fugitive particulate matter to be emitted into the outdoor atmosphere from a source specified in (1) through (8) in condition #001 above if the emissions are visible at the point the emissions pass outside the permittee's property.

003 [25 Pa. Code §123.41]**Limitations**

The permittee shall not permit the emission of visible air contaminants into the outdoor atmosphere in such a manner that the opacity of the emission is either of the following:

- (1) Equal to or greater than 20% for a period or periods aggregating more than three minutes in any 1 hour.
- (2) Equal to or greater than 60% at any time.

004 [25 Pa. Code §123.42]**Exceptions**

The emission limitations of 25 Pa. Code Section 123.41 shall not apply when:

- (1) The presence of uncombined water is the only reason for failure of the emission to meet the limitations;
- (2) The emission results from the operation of equipment used solely to train and test persons in observing the opacity of visible emissions;
- (3) The emission results from sources specified in 25 Pa. Code Sections 123.1(a)(1) through (9).

005 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from 25 Pa. Code Sections 127.1 and 127.12]

The total combined volatile organic compound emissions from the two (2) Dresser-Rand TCV-10 engines (Sources P101 & P102), the Tulpro gas heater (Source 033), the Cleaver Brooks boiler (Source 036) and the Waukesha generator (Source P201) shall not exceed 41.3 tons in any 12 consecutive month period.

II. TESTING REQUIREMENTS.**# 006 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

- (a) Pursuant to 25 Pa. Code § 139.3, at least 90 calendar days prior to commencing a EPA reference method testing program, a test protocol shall be submitted to the Department for review and approval. One electronic copy shall be sent to the Northcentral Regional Office Air Quality Program Manager (RA-EPNCstacktesting@pa.gov) and one electronic copy

**SECTION C. Site Level Requirements**

shall be sent to the PSIMS Administrator in Central Office (RA-EPstacktesting@pa.gov). The test protocol shall meet all applicable requirements specified in the most current version of the Department's Source Testing Manual.

(b) Pursuant to 25 Pa. Code § 139.3, at least 15 calendar days prior to commencing an emission testing program, notification as to the date and time of testing shall be given to the Northcentral Regional Office. Notification shall also be sent to the Division of Source Testing and Monitoring. Notification shall not be made without prior receipt of a protocol acceptance letter from the Department.

(c) Within sixty (60) days of the completion of the stack tests required by this permit, an electronically submitted copy of the report in .pdf format shall be submitted to the Department. This report shall contain the results of the tests, a description of the testing and analytical procedures actually used in performance of the tests, all process and operating data collected during the tests, a copy of all raw data, and a copy of all calculations generated during data analysis.

(d) Pursuant to 25 Pa. Code § 139.53(b) a complete test report shall include a summary of the emission results on the first page of the report indicating if each pollutant measured is within permitted limits and a statement of compliance or noncompliance with all applicable permit conditions. The summary results will include, at a minimum, the following information:

1. A statement that the owner or operator has reviewed the report from the emissions testing body and agrees with the findings.
2. Permit number(s) and condition(s) which are the basis for the evaluation.
3. Summary of results with respect to each applicable permit condition.
4. Statement of compliance or non-compliance with each applicable permit condition.

(e) Pursuant to 25 Pa. Code § 139.3, all submittals shall meet all applicable requirements specified in the most current version of the Department's Source Testing Manual.

(f) All testing shall be performed in accordance with the provisions of Chapter 139 of the Rules and Regulations of the Department of Environmental Protection.

(g) Pursuant to 25 Pa. Code §§ 139.53(a)(1) and 139.53(a)(3), one electronic copy of all submittals, besides notifications, shall be sent to the Northcentral Regional Office Air Quality Program Manager (RA-EPNCstacktesting@pa.gov) and one electronic copy shall be sent to the PSIMS Administrator in Central Office (RA-EPstacktesting@pa.gov) when the file is 35 MB or less, or a flash drive when the file is over 35 MB.

(h) The permittee shall ensure all federal reporting requirements contained in the applicable subpart of 40 CFR are followed, including timelines more stringent than those contained herein. In the event of an inconsistency or any conflicting requirements between state and the federal, the most stringent provision, term, condition, method or rule shall be used by default.

007 [25 Pa. Code §139.1]**Sampling facilities.**

Upon the request of the Department, the permittee shall provide adequate sampling ports, safe sampling platforms and adequate utilities for the performance by the Department of tests on such source. The Department will set forth, in the request, the time period in which the facilities shall be provided as well as the specifications for such facilities.

008 [25 Pa. Code §139.11]**General requirements.**

(1) As specified in 25 Pa. Code Section 139.11(1), performance tests shall be conducted while the source is operating at maximum routine operating conditions or under such other conditions, within the capacity of the equipment, as may be requested by the Department.

(2) As specified in 25 Pa. Code Section 139.11(2), the Department will consider test results for approval where sufficient information is provided to verify the source conditions existing at the time of the test and where adequate data is available to show the manner in which the test was conducted. Information submitted to the Department shall include, as a minimum all of the following:

**SECTION C. Site Level Requirements**

- (a) A thorough source description, including a description of any air cleaning devices and the flue.
- (b) Process conditions, for example, the charging rate of raw material or the rate of production of final product, boiler pressure, oven temperature and other conditions which may affect emissions from the process.
- (c) The location of the sampling ports.
- (d) Effluent characteristics, including velocity, temperature, moisture content, gas density (percentage CO, CO₂, O₂ and N₂), static and barometric pressures.
- (e) Sample collection techniques employed, including procedures used, equipment descriptions and data to verify that isokinetic sampling for particulate matter collection occurred and that acceptable test conditions were met.
- (f) Laboratory procedures and results.
- (g) Calculated results.

III. MONITORING REQUIREMENTS.**# 009 [25 Pa. Code §123.43]****Measuring techniques**

Visible emissions may be measured using either of the following:

- (1) A device approved by the Department and maintained to provide accurate opacity measurements.
- (2) Observers, trained and qualified to measure plume opacity with the naked eye or with the aid of any devices approved by the Department.

010 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

(a) The permittee shall conduct a weekly inspection of the facility during daylight hours while the facility is operating to detect visible emissions, visible fugitive emissions and malodorous air emissions. Weekly inspections are necessary to determine:

- (1) the presence of visible emissions,
- (2) the presence of visible fugitive emissions,
- (3) the presence of malodors beyond the boundaries of the facility.

(b) All detected visible emissions or visible fugitive emissions shall be reported to the manager of the facility.

IV. RECORDKEEPING REQUIREMENTS.**# 011 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) The permittee shall maintain a logbook, or uneditable electronic record, of the weekly facility inspections performed. The logbook, or uneditable electronic record, shall include the name of the company representative performing the weekly inspection, the date and time of inspections, any instances of exceedances of visible emissions limitations, visible fugitive emissions limitations and malodorous air emissions limitations, and the name of the manager informed if a potential exceedance is observed. The permittee shall also record the corrective action(s) taken to abate each recorded deviation to prevent future occurrences.

(b) The logbook, or uneditable electronic record, shall be retained for a minimum of five (5) years and shall be made available to the Department upon

012 [25 Pa. Code §135.5]**Recordkeeping**

The permittee shall maintain such records including computerized records as may be necessary to comply with 25 Pa. Code Sections 135.3 and 135.21. These may include records of production, fuel usage, maintenance of production or pollution control equipment or other information determined by the Department to be necessary for identification and quantification of potential and actual air contaminant emissions.

All records generated pursuant to this condition shall be retained for a minimum of 5 years and shall be made available to

**SECTION C. Site Level Requirements**

the Department upon request.

V. REPORTING REQUIREMENTS.**# 013 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The submission of annual or semi-annual reports required by Subpart ZZZZ of the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines, 40 CFR 63.6580 through 63.6675, or required by any other applicable section specified in the National Emission Standards for Hazardous Air Pollutants, or Subpart JJJJ of the Standards of Performance for New Stationary Sources, 40 CFR 60.4230 through 60.4248, or required by any other applicable section specified in the Standards of Performance for New Stationary Sources, must be made to both the Department of Environmental Protection and electronically to the Environmental Protection Agency. The electronic reports must be submitted using the subpart specific reporting form in the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) (www.epa.gov/cdx). However, if the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the written report must be submitted to the EPA e-mail address and Administrator postal address listed below.

The submission of all other requests, applications submittals and other communications required by Subpart ZZZZ of the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines, 40 CFR 63.6580 through 63.6675, or required by any other applicable section specified in the National Emission Standards for Hazardous Air Pollutants, or Subpart JJJJ of the Standards of Performance for New Stationary Sources, 40 CFR 60.4230 through 60.4248, or required by any other applicable section specified in the Standards of Performance for New Stationary Sources must be made to both the Department of Environmental Protection and the Environmental Protection Agency. The copies may be sent to:

R3_Air_Apps_and_Notices@epa.gov

and

Pennsylvania Department of Environmental Protection
Air Quality Program Manager
208 W. Third Street, Suite 101
Williamsport, PA 17701

014 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

(a) The permittee shall submit the annual compliance certifications to the Department and EPA Region III, as specified in Section B, General Title V Requirements, no later than September 1 (from July 1 of the previous year through June 30 of the current year). The following email address shall be used to submit the compliance certifications to EPA Region III:

R3_APD_Permits@epa.gov

(b) The permittee shall submit the semiannual reports of required monitoring to the Department, as specified in Section B, General Title V Requirements, no later than September 1 (for January 1 through June 30) and March 1 (for July 1 through December 31 of the previous year).

015 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

(a) The permittee shall report malfunctions, emergencies or incidents of excess emissions to the Department. A malfunction is any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner. An emergency is any situation arising from sudden and reasonably unforeseeable events beyond the control of the owner or operator of a facility which requires immediate corrective action to restore normal operation and which causes the emission source to exceed emissions, due to unavoidable increases in emissions attributable to the situation. An emergency shall not include situations caused by

**SECTION C. Site Level Requirements**

improperly designed equipment, lack of preventive maintenance, careless or improper operation, or operator error.

(b) When the malfunction, emergency or incident of excess emissions poses an imminent danger to the public health, safety, welfare, or environment, it shall be reported to the Department and the County Emergency Management Agency by telephone within one (1) hour after the discovery of the malfunction, emergency or incident of excess emissions. The owner or operator shall submit a written or emailed report of instances of such malfunctions, emergencies or incidents of excess emissions to the Department within three (3) business days of the telephone report.

(c) The report shall describe the following:

1. name, permit or authorization number, and location of the facility,
2. nature and cause of the malfunction, emergency or incident,
3. date and time when the malfunction, emergency or incident was first observed,
4. expected duration of excess emissions,
5. estimated rate of emissions,
6. corrective actions or preventative measures taken.

(d) Any malfunction, emergency or incident of excess emissions that is not subject to the notice requirements of paragraph (b) of this condition shall be reported to the Department by telephone within 24 hours (or by 4:00 PM of the next business day, whichever is later) of discovery and in writing or by e-mail within five (5) business days of discovery. The report shall contain the same information required by paragraph (c), and any permit specific malfunction reporting requirements.

(e) During an emergency an owner or operator may continue to operate the source at their discretion provided they submit justification for continued operation of a source during the emergency and follow all the notification and reporting requirements in accordance with paragraphs (b)-(d), as applicable, including any permit specific malfunction reporting requirements.

(f) Reports regarding malfunctions, emergencies or incidents of excess emissions shall be submitted to the appropriate DEP Regional Office Air Program Manager.

(g) Any emissions resulted from malfunction or emergency are to be reported in the annual emissions inventory report, if the annual emissions inventory report is required by permit or authorization.

016 [25 Pa. Code §135.21]**Emission statements**

(a) The permittee shall provide the Department a statement of each stationary source in a form prescribed by the Department, showing the actual emissions of oxides of nitrogen and volatile organic compounds (VOCs) from the permitted facility for each reporting period, a description of the method used to calculate the emissions and the time period over which the calculation is based.

(b) The annual emission statements are due by March 1 of the preceding calendar year and shall contain a certification by a company officer or the plant manager that the information contained in the statement is accurate. The permittee shall provide data consistent with requirements and guidance developed by the EPA.

(c) The Department may require more frequent submittals if the Department determines that one or more of the following applies:

(1) A more frequent submission is required by the EPA.

(2) Analysis of the data on a more frequent basis is necessary to implement the requirements of the Air Pollution Control Act.

017 [25 Pa. Code §135.3]**Reporting**

(1) A person who owns or operates a source to which 25 Pa. Code Section 135 applies, and who has previously been advised by the Department to submit an annual Air Information Management Systems (AIMS) report, shall submit by March

**SECTION C. Site Level Requirements**

1 of each year an annual AIMS report for the preceding calendar year. The report shall include information for all previously reported sources, new sources which were first operated during the preceding calendar year and sources modified during the same period which were not previously reported.

(2) A person who receives initial notification by the Department that an annual AIMS report is necessary shall submit an initial annual AIMS report within 60 days after receiving the notification or by March 1 of the year following the year for which the report is required, whichever is later.

(3) A source owner or operator may request an extension of time from the Department for the filing of an annual AIMS report, and the Department may grant the extension for reasonable cause.

VI. WORK PRACTICE REQUIREMENTS.**# 018 [25 Pa. Code §123.1]****Prohibition of certain fugitive emissions**

The permittee shall take all reasonable actions to prevent particulate matter from becoming airborne from any source specified in (1) through (8) in condition #001 above. These actions shall include, but not be limited to, the following:

(1) Use, where possible, of water or chemicals for control of dust in the demolition of buildings or structures, construction operations, the grading of roads, or the clearing of land.

(2) Application of asphalt, oil, water or suitable chemicals on dirt roads, material stockpiles and other surfaces which may give rise to airborne dusts.

(3) Paving and maintenance of roadways.

(4) Prompt removal of earth or other material from paved streets onto which earth or other material has been transported by trucking or earth moving equipment, erosion by water, or other means.

VII. ADDITIONAL REQUIREMENTS.**# 019 [25 Pa. Code §121.7]****Prohibition of air pollution.**

The permittee shall not permit air pollution as that term is defined in the Pennsylvania Air Pollution Control Act (35 P.S. Sections 4001 through 4015).

020 [25 Pa. Code §123.31]**Limitations**

The permittee shall not permit the emission of any malodorous air contaminants into the outdoor atmosphere from any source in such a manner that the malodors are detectable outside the property of the permittee on whose land the source is being operated.

021 [25 Pa. Code §129.14]**Open burning operations**

The permittee shall not permit the open burning of material at the facility unless in accordance with 25 Pa. Code Section 129.14.

VIII. COMPLIANCE CERTIFICATION.

No additional compliance certifications exist except as provided in other sections of this permit including Section B (relating to Title V General Requirements).

IX. COMPLIANCE SCHEDULE.

No compliance milestones exist.

***** Permit Shield In Effect *****

**SECTION D. Source Level Requirements**

Source ID: 033

Source Name: TULPRO HEATER 2 (18.6 MMBTU/HR)

Source Capacity/Throughput: 18.600 MMBTU/HR

Conditions for this source occur in the following groups: RACT III

**I. RESTRICTIONS.****Emission Restriction(s).****[25 Pa. Code §123.11]****Combustion units**

Source ID 033 shall not emit particulate matter in excess of the rate of 0.40 pounds per million Btu of heat input.

[25 Pa. Code §123.22]**Combustion units**The permittee shall not permit the emission of sulfur oxides, expressed as sulfur dioxide (SO₂), into the outdoor atmosphere from Source ID 033 in excess of the rate of 4 pounds per million Btu of heat input over any 1-hour period.**Fuel Restriction(s).****[25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Section 129.91]

Source ID 033 shall only be fired on pipeline quality natural gas.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.**[25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Section 129.95]

(a) The permittee shall maintain records in accordance with the recordkeeping requirements of 25 Pa. Code Section 129.95 which, at a minimum, shall include a record of each adjustment conducted under the procedures required in condition #006 for Source ID 033 in a permanently bound log book or other method approved by the Department. This log shall contain, at a minimum, the following information:

- (1) The date of the tuning procedure.

**SECTION D. Source Level Requirements**

- (2) The name of the service company and technicians.
- (3) The final operating rate or load
- (4) The final CO and NOx emission rates.
- (5) The final excess oxygen rate.

(b) The above records shall be retained for at least five years and made available to the Department upon request.

[40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.48c]**Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Reporting and recordkeeping requirements.**

The permittee shall comply with the applicable recordkeeping and reporting requirements specified in 40 CFR Sections 60.48c, 60.48c(a), 60.48c(g), and 60.48c(i) .

[25 Pa. Code §129.97]**Presumptive RACT requirements, RACT emission limitations and petition for alternative compliance schedule.**

[Additional authority for this permit condition is derived from 25 Pa. Code Section 129.100(d)(1), (2), and (i)]

The permittee shall keep records to demonstrate compliance with §§ 129.96—129.97 in the following manner:

- (1) The records must include sufficient data and calculations to demonstrate that the requirements of §§ 129.96—129.97 are met.
- (2) Data or information required to determine compliance shall be recorded and maintained in a time frame consistent with the averaging period of the requirement.

The records shall be retained by the owner or operator for 5 years and made available to the Department upon receipt of a written request from the Department.

[25 Pa. Code §129.97]**Presumptive RACT requirements, RACT emission limitations and petition for alternative compliance schedule.**

[Additional authority for this permit condition is derived from 25 Pa. Code Section 129.100(g) and (i)]

The permittee shall record each adjustment conducted under the procedures in § 129.97. This record must contain, at a minimum:

- (1) The date of the tuning procedure.
- (2) The name of the service company and the technician performing the procedure.
- (3) The final operating rate or load.
- (4) The final NOx and CO emission rates.
- (5) The final excess oxygen rate.
- (6) Other information required by the applicable operating permit.

The records shall be retained by the owner or operator for 5 years and made available to the Department upon receipt of a written request from the Department.

V. REPORTING REQUIREMENTS.**[40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.48c]****Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Reporting and recordkeeping requirements.**

The permittee shall comply with the applicable recordkeeping and reporting requirements specified in 40 CFR Sections 60.48c, 60.48c(a), 60.48c(g), and 60.48c(i) .

**SECTION D. Source Level Requirements****VI. WORK PRACTICE REQUIREMENTS.****[25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Section 129.93]

The permittee shall comply with the annual tune-up, maintenance, and operating vendor guidelines on the subject source in accordance with the presumptive RACT provisions of Sections 129.93(b)(2),(3),(4)& (5). The annual tune-up will also include at a minimum, the following adjustments:

- (1) Inspection, adjustment, cleaning or replacement of fuel-burning equipment, including the burners and moving parts necessary for proper operation as specified by the manufacturer.
- (2) Inspection of the flame pattern or characteristics and adjustments necessary to minimize total emissions of NO_x, and to the extent practicable minimize emissions of CO.
- (3) Inspection of the air-to-fuel ratio control system and adjustments necessary to ensure proper calibration and operation as specified by the manufacturer.

[25 Pa. Code §129.97]**Presumptive RACT requirements, RACT emission limitations and petition for alternative compliance schedule.**

[Additional authority for this permit condition is derived from 25 Pa. Code Section 129.97]

The permittee shall perform an annual tune-up conducted in accordance with the procedures in 40 CFR 63.11223 (relating to how do I demonstrate continuous compliance with the work practice and management practice standards). The annual tune-up must include, at a minimum, the following:

- (i) Inspection and cleaning or replacement of fuelburning equipment, including the burners and components, as necessary, for proper operation as specified by the manufacturer.
- (ii) Inspection of the flame pattern and adjustment of the burner, as necessary, to optimize the flame pattern to minimize total emissions of NO_x and, to the extent possible, emissions of CO.
- (iii) Inspection and adjustment, as necessary, of the air-to-fuel ratio control system to ensure proper calibration and operation as specified by the manufacturer.

[25 Pa. Code §129.97]**Presumptive RACT requirements, RACT emission limitations and petition for alternative compliance schedule.**

[Additional authority for this permit condition is derived from 25 Pa. Code Section 129.97]

The permittee shall install, maintain, and operate this source in accordance with the manufacturer's specifications and with good operating practices.

VII. ADDITIONAL REQUIREMENTS.**[25 Pa. Code §127.441]****Operating permit terms and conditions.**

Source ID 033 is a 18.6 million Btu per hour, Tulpro model 19000 heater (#2).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 036

Source Name: CLEAVER BROOKS BOILER (2.93 MMBTU/HR)

Source Capacity/Throughput: 2.930 MMBTU/HR

Conditions for this source occur in the following groups: RACT III

**I. RESTRICTIONS.****Emission Restriction(s).****[25 Pa. Code §123.22]****Combustion units**

The permittee shall not permit the emission of sulfur oxides, expressed as sulfur dioxide (SO₂), into the outdoor atmosphere from Source ID 036 in excess of the rate of 4 pounds per million Btu of heat input over any 1-hour period

[25 Pa. Code §123.11]**Combustion units**

Source ID 036 shall not emit particulate matter in excess of the rate of 0.40 pounds per million Btu of heat input.

Fuel Restriction(s).**[25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Section 129.91]

Source ID 036 shall be fired only on pipeline quality natural gas.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.**[25 Pa. Code §129.100]****Compliance demonstration and recordkeeping requirements.**

[Additional authority for this permit condition is derived from 25 Pa. Code Section 129.100(d)(1), (2), and (i)]

The permittee shall keep records to demonstrate compliance with §§ 129.96—129.97 in the following manner:

- (1) The records must include sufficient data and calculations to demonstrate that the requirements of §§ 129.96—129.97 are met.
- (2) Data or information required to determine compliance shall be recorded and maintained in a time frame consistent with the averaging period of the requirement.

**SECTION D. Source Level Requirements**

The records shall be retained by the owner or operator for 5 years and made available to the Department upon receipt of a written request from the Department.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

[25 Pa. Code §129.93]

Presumptive RACT emission limitations

Source ID 036 shall be maintained and operated in accordance with manufacturer's specifications and in accordance with good air pollution control practices.

[25 Pa. Code §129.97]

Presumptive RACT requirements, RACT emission limitations and petition for alternative compliance schedule.

[Additional authority for this permit condition is derived from 25 Pa. Code Section 129.97(c)]

The permittee shall install, maintain, and operate this source in accordance with the manufacturer's specifications and with good operating practices.

VII. ADDITIONAL REQUIREMENTS.

[25 Pa. Code §127.441]

Operating permit terms and conditions.

Source ID 036 is a 2.93 million Btu per hour, Cleaver Brooks model CB-700-70 Boiler (#1).

***** Permit Shield in Effect. *****


**SECTION D. Source Level Requirements**

Source ID: 038

Source Name: ETI REGEN HEATER

Source Capacity/Throughput: 5.250 MMBTU/HR

Conditions for this source occur in the following groups: RACT III

**I. RESTRICTIONS.****Emission Restriction(s).****[25 Pa. Code §123.11]****Combustion units**

Source ID 038 shall not emit particulate matter in excess of the rate of 0.40 pounds per million Btu of heat input.

[25 Pa. Code §123.22]**Combustion units**The permittee shall not permit the emission of sulfur oxides, expressed as sulfur dioxide (SO₂), into the outdoor atmosphere from Source ID 038 in excess of the rate of 4 pounds per million Btu of heat input over any 1-hour period.**Fuel Restriction(s).****[25 Pa. Code §127.441]****Operating permit terms and conditions.**

Source ID 038 shall only be fired on pipeline quality natural gas.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.**[25 Pa. Code §129.100]****Compliance demonstration and recordkeeping requirements.**

[Additional authority for this permit condition is derived from 25 Pa. Code Section 129.100(d)(1), (2), and (i)]

The permittee shall keep records to demonstrate compliance with §§ 129.96—129.97 in the following manner:

- (1) The records must include sufficient data and calculations to demonstrate that the requirements of §§ 129.96—129.97 are met.
- (2) Data or information required to determine compliance shall be recorded and maintained in a time frame consistent with the averaging period of the requirement.

The records shall be retained by the owner or operator for 5 years and made available to the Department upon receipt of a

**SECTION D. Source Level Requirements**

written request from the Department.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

[25 Pa. Code §129.97]

Presumptive RACT requirements, RACT emission limitations and petition for alternative compliance schedule.

[Additional authority for this permit condition is derived from 25 Pa. Code Section 129.97(c)]

The permittee shall install, maintain, and operate this source in accordance with the manufacturer's specifications and with good operating practices.

VII. ADDITIONAL REQUIREMENTS.

[25 Pa. Code §127.441]

Operating permit terms and conditions.

Source ID 038 is a 5.25 million Btu per hour ETI model 4.5 MM RFG-HTE regen gas heater equipped with a Maxon OPTIMA M-PAKT low nitrogen oxides burner.


***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: P01

Source Name: FACILITY FUGITIVE EMISSIONS

Source Capacity/Throughput:

**I. RESTRICTIONS.****Emission Restriction(s).****[25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from the permittee electing these restrictions to comply with 25 Pa. Code §123.1]

- (a) The total volatile organic compounds emissions from this source shall not equal or exceed 2.7 tons in any 12 consecutive month period.
- (b) The emissions of any combination of hazardous air pollutants from this source shall not equal or exceed 1.0 tons in any 12 consecutive month period.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.**[25 Pa. Code §123.1]****Prohibition of certain fugitive emissions**

Any leak detected during the monthly AVO inspection shall be repaired within 15 calendar days of detection unless facility shutdowns or ordering of replacement parts are necessary for repair of the leaks.

[25 Pa. Code §123.1]**Prohibition of certain fugitive emissions**

The permittee shall perform monthly audio, visual, and olfactory (AVO) inspections to ensure the fugitive air contaminant emissions are minimized.

IV. RECORDKEEPING REQUIREMENTS.**[25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) The permittee shall keep comprehensive and accurate records of the following to demonstrate compliance with the applicable emission limitations:

- (1) The total volatile organic compounds emissions and
 - (2) The emissions of any combination of hazardous air pollutants.
- (b) Records generated by this condition shall be kept for 5 years and provided to the Department upon request.

[25 Pa. Code §127.441]**Operating permit terms and conditions.**

(a) The permittee shall keep a logbook, or uneditable electronic record, of the following for the AVO inspections:

- (1) the date of each inspection,

**SECTION D. Source Level Requirements**

- (2) initials (or name) of the person(s) conducting each inspection,
- (3) the date each leak is detected,
- (4) the specific location of the leak,
- (5) the repair performed to eliminate the leak,
- (6) the date the leak is repaired,
- (7) the action/inspection taken to determine that the leak is repaired, and
- (8) the initials (or name) of the person(s) repairing the leak.

(b) The logbook, or uneditable electronic record, shall be kept for 5 years and made available to the Department upon request.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.

[25 Pa. Code §127.441]

Operating permit terms and conditions.

Source ID P01 consists of the facility fugitive emissions from the sources of fugitive emissions (e.g., pipeline valves, flanges, vents, etc) at the Tioga station.

*** **Permit Shield in Effect.** ***


**SECTION D. Source Level Requirements**

Source ID: P101

Source Name: 4200 HP DRESSER RAND TCV-10 ENGINE 1

Source Capacity/Throughput:

Conditions for this source occur in the following groups: P101, P102, P201

**I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §123.13]****Processes**

The concentration of particulate matter in the exhaust of Source ID P101 shall not exceed 0.04 grains per dry standard cubic foot of effluent gas volume.

002 [25 Pa. Code §123.21]**General**

The concentration of sulfur oxides, expressed as sulfur dioxide (SO₂), in the exhaust from Source ID P101 shall not exceed 500 parts per million, by volume, dry basis.

003 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from 25 Pa. Code Sections 127.1 and 127.12]

(a) The permittee shall not permit the following air contaminant emissions from the exhaust of ID C101B associated with Source ID P101 in excess of the limitations listed below:

- (1) total combined volatile organic compounds (VOC) - 4.7 pounds per hour and 20.59 tons in any 12 consecutive month period,
- (2) non-methane, non-ethane hydrocarbons (NMNEHC) - 4.03 pounds per hour and 17.65 tons in any 12 consecutive month period,
- (3) formaldehyde - 0.67 pounds per hour and 2.94 tons in any 12 consecutive month period.

(b) Based on the stack test results of the removal efficiencies of the volatile organic compound emissions from ID C101A associated with Source ID P101, the Department may revise the above emission limitations through the minor modification of the Title V operating permit.

004 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Sections 127.1, 127.12, 129.91 and 40 CFR 52.21]

The air contaminant emissions from Source ID P101 shall not exceed the following rates:

- (1) Nitrogen Oxides (NO_x, expressed as NO₂) - 27.76 pounds per hour
- (2) Carbon monoxide (CO) - 19.42 pounds per hour
- (3) Non-methane Hydrocarbons (NMHC) - 4.63 pounds per hour

**SECTION D. Source Level Requirements****# 005 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The emission of ammonia slip from ID C101B shall not exceed 10 ppmdv @ 15% O₂ at any time.

006 [25 Pa. Code §129.112]**Presumptive RACT requirements, RACT emission limitations and petition for alternative compliance schedule**

[Additional authority for, and compliance with this permit condition assures compliance with, the NO_x limit of 0.6 grams per brake horsepower-hour as specified in 25 Pa. Code Section 129.112(g)(3)(ii)(A)]

(a) The permittee shall not permit the following air contaminant emissions from the exhaust of ID C101B associated with Source ID P101 in excess of the limitations listed below:

(1) nitrogen oxides (NO_x, expressed as NO₂) – 0.6 grams per brake horsepower-hour, 5.56 pounds per hour and 23.54 tons in any 12 consecutive month period.

007 [25 Pa. Code §129.97]**Presumptive RACT requirements, RACT emission limitations and petition for alternative compliance schedule.**

[Additional authority for this permit condition is derived from 25 Pa. Code Section 129.97(g)(3)(i)(A)]

The potential to emit nitrogen oxides shall not exceed 3.0 grams per brake horsepower-hour.

Fuel Restriction(s).**# 008 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Section 129.91]

Source ID P101 shall only be fired on pipeline quality natural gas.

II. TESTING REQUIREMENTS.**# 009 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) The permittee shall perform stack testing upon Source ID P101 prior to December 31, 2023, and every five years after the date of the previous test, for nitrogen oxides (NO_x, expressed as NO₂), carbon monoxide, ammonia slip, and volatile organic compounds (expressed as non-methane hydrocarbons) using reference method test procedures acceptable to the Department. All testing is to be performed while Source ID P101 is operating within 90% of full load (i.e., at least 3780 brake horsepower). The permittee shall follow the stack testing requirements specified in Section C, Site Level Requirements, of this operating permit.

(b) The inlet gas temperature, outlet gas temperature, and the pressure drop across ID C101B shall be recorded in 15-minute intervals during testing. The requirement for the temperature ranges and pressure drop across ID C101B will be established based upon the recorded data and stack test report.

(c) In addition to the stack testing, the permittee shall perform annual NO_x and carbon monoxide tests upon Source ID P101 using a portable exhaust gas analyzer that has been approved by the Department. The reference method retesting may be substituted for the portable analyzer testing required by this condition on a one-for-one basis (one occurrence of reference method testing may be substituted for one of the once-per-year occurrences of portable analyzer testing).

010 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

(a) The permittee shall perform stack testing upon Source ID P101 prior to December 31, 2023, and every five years after the date of the previous test, for total combined volatile organic compounds, non-methane, non-ethane hydrocarbons, and formaldehyde to demonstrate compliance with the emission limitations using reference method test procedures acceptable

**SECTION D. Source Level Requirements**

to the Department. All testing is to be performed while Source ID P101 is operating within 90% of full load (i.e., at least 3780 brake horsepower). The permittee shall follow the stack testing requirements specified in Section C, Site Level Requirements, of this operating permit.

III. MONITORING REQUIREMENTS.**# 011 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from 25 Pa. Code Sections 127.1 and 127.12]

The permittee shall install instrumentation to monitor pressure drop across the catalyst and the inlet gas temperature of ID C101A on a continuous basis.

012 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall equip ID C101B with instrumentation to monitor pressure drop and the inlet and outlet gas temperatures of C101B. These parameters shall be readily displayed and easily viewed for compliance purposes. The permittee shall monitor these parameters on a continuous basis.

IV. RECORDKEEPING REQUIREMENTS.**# 013 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Section 127.511]

The permittee shall maintain records of the following for Source ID P101:

- (1) Stack test reports
- (2) Portable analyzer test reports.
- (3) Calculations, or stack test reports used to verify compliance with the short term (lb/hr) nitrogen oxides, carbon monoxide, non-methane hydrocarbon, total volatile organic compounds, non-methane, non-ethane hydrocarbons, and formaldehyde emission limitations.

(b) All records generated pursuant to this permit condition shall be retained for a minimum of five (5) years and shall be made available to the Department upon request.

014 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Sections 129.95 and 127.511]

(a) The permittee shall maintain records for Source ID P101 in accordance with the recordkeeping requirements of 25 Pa. Code Section 129.95 which, at a minimum, shall include:

- (1) The number of hours operated per month.
- (2) The amount of fuel consumed per month.
- (3) The gas quality characteristics in a current, valid purchase contract, tariff sheet, transportation contract for the fuel or other data compiled by the gas pipeline company, specifying the maximum total sulfur content of the fuel and verifying that the fuel is pipeline quality natural gas.

OR

- (4) Representative fuel sampling data showing the sulfur content of the fuel and verifying that the fuel is pipeline quality

**SECTION D. Source Level Requirements**

natural gas and shall include the following:

- (i) The date, place, and time of sampling;
- (ii) The date(s) analyses were performed;
- (iii) The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used;
- (v) The results of such analyses; and,
- (vi) The operating conditions at the time of sampling or measurement.

(b) All records generated pursuant to his permit condition shall be retained for a minimum of five (5) years and shall be made available to the Department upon request.

015 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

(a) The permittee shall keep records of the following information:

- (1) The supporting calculations on a monthly basis used to verify compliance with the nitrogen oxide and ammonia slip emission limitations for ID C101B associated with Source ID P101 in any 12 consecutive month period.
- (2) The test reports and supporting calculations used to verify compliance with the nitrogen oxide and ammonia slip emission limitations from ID C101B associated with Source ID P101.
- (3) The pressure drop across and the inlet and outlet gas temperatures of ID C101B on a continuous basis via a data acquisition system and shall compute the hourly averages for the inlet and outlet gas temperatures. The pressure drop across ID C101B shall be recorded at least once per day.

(b) These records shall be kept for a minimum of five (5) years and shall be made available to the Department upon request.

016 [25 Pa. Code §129.100]**Compliance demonstration and recordkeeping requirements.**

[Additional authority for this permit condition is derived from 25 Pa. Code Section 129.100(d)(1), (2), and (i)]

The permittee shall keep records to demonstrate compliance with §§ 129.96—129.97 in the following manner:

- (1) The records must include sufficient data and calculations to demonstrate that the requirements of §§ 129.96—129.97 are met.
- (2) Data or information required to determine compliance shall be recorded and maintained in a time frame consistent with the averaging period of the requirement.

The records shall be retained by the owner or operator for 5 years and made available to the Department upon receipt of a written request from the Department.

017 [25 Pa. Code §129.115]**Written notification, compliance demonstration and recordkeeping and reporting requirements**

[Additional authority for this condition is from 25 Pa. Code Section 129.115(f) and (k)]

(f) The permittee shall keep records to demonstrate compliance with §§ 129.111—129.114 and submit reports to the Department in accordance with the applicable regulations in 25 Pa. Code, Part I, Subpart C, Article III (relating to air resources)

- (1) The records shall include sufficient data and calculations to demonstrate that the requirements of §§ 129.111—129.114 are met.
- (2) Data or information required to determine compliance shall be recorded and maintained in a time frame consistent with

**SECTION D. Source Level Requirements**

the averaging period of the requirement.

(3) The records necessary to determine compliance shall be reported to the Department on a schedule specified in the applicable regulation or as otherwise specified in the operating permit or plan approval for the air contamination source.

(k) The records shall be retained by the owner or operator for 5 years and made available to the Department upon receipt of a written request from the Department.

V. REPORTING REQUIREMENTS.

018 [25 Pa. Code §127.441]

Operating permit terms and conditions.

[Additional authority for this permit condition is also derived from 25 Pa. Code Sections 129.91 and 127.511]

The permittee shall submit to the Department specifications for the portable exhaust gas analyzer prior to the testing and the results of all portable gas analyzer testing performed shall be submitted to the Department within 30 days of test performance.

VI. WORK PRACTICE REQUIREMENTS.

019 [25 Pa. Code §127.441]

Operating permit terms and conditions.

[Additional authority for this permit condition is derived from 25 Pa. Code Sections 127.1 and 127.12]

Source ID P101 shall not be operated without the simultaneous operation of ID C101A.

020 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall not operate Source ID P101 without the simultaneous operation of ID C101B at any time.

VII. ADDITIONAL REQUIREMENTS.

021 [25 Pa. Code §127.441]

Operating permit terms and conditions.

[Additional authority for this permit condition is derived from 25 Pa. Code sections 127.1 and 127.12]

(a) Source ID P101 is a 4,200 brake-horsepower Dresser Rand model TCV-10 natural gas-fired compressor engine.

(b) ID C101A is a Vanec model 141-48B-XXX oxidation catalyst, or DCL Special Oxidation-F Type (Authorized via Request for Determination May 13, 2016) (or equivalent, as determined by the Department).

(c) ID C101B is a AeriNOx selective catalytic reduction unit (authorized in Plan Approval 59-00002D).

(d) ID C101A and C101B shall control the air contaminant emissions from Source ID P101.

***** Permit Shield in Effect. *****


**SECTION D. Source Level Requirements**

Source ID: P102

Source Name: 4200 HP DRESSER RAND TCV-10 ENGINE 2

Source Capacity/Throughput:

Conditions for this source occur in the following groups: P101, P102, P201

**I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §123.13]****Processes**

The concentration of particulate matter in the exhaust of Source ID P102 shall not exceed 0.04 grains per dry standard cubic foot of effluent gas volume.

002 [25 Pa. Code §123.21]**General**

The concentration of sulfur oxides, expressed as sulfur dioxide (SO₂), in the exhaust from Source ID P102 shall not exceed 500 parts per million, by volume, dry basis.

003 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from 25 Pa. Code Sections 127.1 and 127.12]

(a) The permittee shall not permit the following air contaminant emissions from the exhaust of ID C102B associated with Source ID P102 in excess of the limitations listed below:

- (1) total combined volatile organic compounds (VOC) - 4.7 pounds per hour and 20.59 tons in any 12 consecutive month period,
- (2) non-methane, non-ethane hydrocarbons (NMNEHC) - 4.03 pounds per hour and 17.65 tons in any 12 consecutive month period,
- (3) formaldehyde - 0.67 pounds per hour and 2.94 tons in any 12 consecutive month period.

(b) Based on the stack test results of the removal efficiencies of the volatile organic compound emissions from ID C102A associated with Source ID P102, the Department may revise the above emission limitations through the minor modification of the Title V operating permit.

004 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Sections 127.1, 127.12, 129.91 and 40 CFR 52.21]

The air contaminant emissions from Source ID P102 shall not exceed the following rates:

- (1) Nitrogen Oxides (NO_x, expressed as NO₂) - 27.76 pounds per hour
- (2) Carbon monoxide (CO) - 19.42 pounds per hour
- (3) Non-methane Hydrocarbons (NMHC) - 4.63 pounds per hour

**SECTION D. Source Level Requirements****# 005 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The emission of ammonia slip from ID C102B shall not exceed 10 ppmdv @ 15% O₂ at any time.

006 [25 Pa. Code §129.112]**Presumptive RACT requirements, RACT emission limitations and petition for alternative compliance schedule**

[Additional authority for, and compliance with this permit condition assures compliance with, the NO_x limit of 0.6 grams per brake horsepower-hour as specified in 25 Pa. Code Section 129.112(g)(3)(ii)(A)]

(a) The permittee shall not permit the following air contaminant emissions from the exhaust of ID C102B associated with Source ID P102 in excess of the limitations listed below:

(1) nitrogen oxides (NO_x, expressed as NO₂) – 0.6 grams per brake horsepower-hour, 5.56 pounds per hour and 23.54 tons in any 12 consecutive month period.

007 [25 Pa. Code §129.97]**Presumptive RACT requirements, RACT emission limitations and petition for alternative compliance schedule.**

[Additional authority for this permit condition is derived from 25 Pa. Code Section 129.97(g)(3)(i)(A)]

The potential to emit nitrogen oxides shall not exceed 3.0 grams per brake horsepower-hour.

Fuel Restriction(s).**# 008 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Section 129.91]

Source ID P102 shall only be fired on pipeline quality natural gas.

II. TESTING REQUIREMENTS.**# 009 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) The permittee shall perform stack testing upon Source ID P102 prior to December 31, 2023, and every five years after the date of the previous test, for nitrogen oxides (NO_x, expressed as NO₂), carbon monoxide, ammonia slip, and volatile organic compounds (expressed as non-methane hydrocarbons) using reference method test procedures acceptable to the Department. All testing is to be performed while Source ID P102 is operating within 90% of full load (i.e., at least 3780 brake horsepower). The permittee shall follow the stack testing requirements specified in Section C, Site Level Requirements, of this operating permit.

(b) The inlet gas temperature, outlet gas temperature, and the pressure drop across ID C102B shall be recorded in 15-minute intervals during testing. The requirement for the temperature ranges and pressure drop across ID C102B will be established based upon the recorded data and stack test report.

(c) In addition to the stack testing, the permittee shall perform annual NO_x and carbon monoxide tests upon Source ID P102 using a portable exhaust gas analyzer that has been approved by the Department. The reference method retesting may be substituted for the portable analyzer testing required by this condition on a one-for-one basis (one occurrence of reference method testing may be substituted for one of the once-per-year occurrences of portable analyzer testing).

010 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

(a) The permittee shall perform stack testing upon Source ID P102 prior to December 31, 2023, and every five years after the date of the previous test, for total combined volatile organic compounds, non-methane, non-ethane hydrocarbons, and formaldehyde to demonstrate compliance with the emission limitations using reference method test procedures acceptable

**SECTION D. Source Level Requirements**

to the Department. All testing is to be performed while Source ID P102 is operating within 90% of full load (i.e., at least 3780 brake horsepower). The permittee shall follow the stack testing requirements specified in Section C, Site Level Requirements, of this operating permit.

III. MONITORING REQUIREMENTS.**# 011 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from 25 Pa. Code Sections 127.1 and 127.12]

The permittee shall install instrumentation to monitor pressure drop across the catalyst and the inlet gas temperature of ID C102A on a continuous basis.

012 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

The permittee shall equip ID C102B with instrumentation to monitor pressure drop and the inlet and outlet gas temperatures of C102B. These parameters shall be readily displayed and easily viewed for compliance purposes. The permittee shall monitor these parameters on a continuous basis.

IV. RECORDKEEPING REQUIREMENTS.**# 013 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Section 127.511]

The permittee shall maintain records of the following for Source ID P102:

- (1) Stack test reports
- (2) Portable analyzer test reports.
- (3) Calculations, or stack test reports used to verify compliance with the short term (lb/hr) nitrogen oxides, carbon monoxide, non-methane hydrocarbon, total volatile organic compounds, non-methane, non-ethane hydrocarbons, and formaldehyde emissions limitations.

(b) All records generated pursuant to this permit condition shall be retained for a minimum of five (5) years and shall be made available to the Department upon request.

014 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Sections 129.95 and 127.511]

(a) The permittee shall maintain records for Source ID P102 in accordance with the recordkeeping requirements of 25 Pa. Code Section 129.95 which, at a minimum, shall include:

- (1) The number of hours operated per month.
- (2) The amount of fuel consumed per month.
- (3) The gas quality characteristics in a current, valid purchase contract, tariff sheet, transportation contract for the fuel or other data compiled by the gas pipeline company, specifying the maximum total sulfur content of the fuel and verifying that the fuel is pipeline quality natural gas.

OR

- (4) Representative fuel sampling data showing the sulfur content of the fuel and verifying that the fuel is pipeline quality

**SECTION D. Source Level Requirements**

natural gas and shall include the following:

- (i) The date, place, and time of sampling;
- (ii) The date(s) analyses were performed;
- (iii) The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used;
- (v) The results of such analyses; and,
- (vi) The operating conditions at the time of sampling or measurement.

(b) All records generated pursuant to his permit condition shall be retained for a minimum of five (5) years and shall be made available to the Department upon request.

015 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

(a) The permittee shall keep records of the following information:

- (1) The supporting calculations on a monthly basis used to verify compliance with the nitrogen oxide and ammonia slip emission limitations for ID C102B associated with Source ID P102 in any 12 consecutive month period.
- (2) The test reports and supporting calculations used to verify compliance with the nitrogen oxide and ammonia slip emission limitations from ID C102B associated with Source ID P102.
- (3) The pressure drop across and the inlet and outlet gas temperatures of ID C102B on a continuous basis via a data acquisition system and shall compute the hourly averages for the inlet and outlet gas temperatures. The pressure drop across ID C102B shall be recorded at least once per day.

(b) These records shall be kept for a minimum of five (5) years and shall be made available to the Department upon request.

016 [25 Pa. Code §129.100]**Compliance demonstration and recordkeeping requirements.**

[Additional authority for this permit condition is derived from 25 Pa. Code Section 129.100(d)(1), (2), and (i)]

The permittee shall keep records to demonstrate compliance with §§ 129.96—129.97 in the following manner:

- (1) The records must include sufficient data and calculations to demonstrate that the requirements of §§ 129.96—129.97 are met.
- (2) Data or information required to determine compliance shall be recorded and maintained in a time frame consistent with the averaging period of the requirement.

The records shall be retained by the owner or operator for 5 years and made available to the Department upon receipt of a written request from the Department.

017 [25 Pa. Code §129.115]**Written notification, compliance demonstration and recordkeeping and reporting requirements**

[Additional authority for this condition is from 25 Pa. Code Section 129.115(f) and (k)]

(f) The permittee shall keep records to demonstrate compliance with §§ 129.111—129.114 and submit reports to the Department in accordance with the applicable regulations in 25 Pa. Code, Part I, Subpart C, Article III (relating to air resources)

- (1) The records shall include sufficient data and calculations to demonstrate that the requirements of §§ 129.111—129.114 are met.
- (2) Data or information required to determine compliance shall be recorded and maintained in a time frame consistent with

**SECTION D. Source Level Requirements**

the averaging period of the requirement.

(3) The records necessary to determine compliance shall be reported to the Department on a schedule specified in the applicable regulation or as otherwise specified in the operating permit or plan approval for the air contamination source.

(k) The records shall be retained by the owner or operator for 5 years and made available to the Department upon receipt of a written request from the Department.

V. REPORTING REQUIREMENTS.

018 [25 Pa. Code §127.441]

Operating permit terms and conditions.

[Additional authority for this permit condition is also derived from 25 Pa. Code Sections 129.91 and 127.511]

The permittee shall submit to the Department specifications for the portable exhaust gas analyzer prior to the testing and the results of all portable gas analyzer testing performed shall be submitted to the Department within 30 days of test performance.

VI. WORK PRACTICE REQUIREMENTS.

019 [25 Pa. Code §127.441]

Operating permit terms and conditions.

[Additional authority for this permit condition is derived from 25 Pa. Code Sections 127.1 and 127.12]

Source ID P102 shall not be operated without the simultaneous operation of ID C102A.

020 [25 Pa. Code §127.441]

Operating permit terms and conditions.

The permittee shall not operate Source ID P102 without the simultaneous operation of ID C102B at any time.

VII. ADDITIONAL REQUIREMENTS.

021 [25 Pa. Code §127.441]

Operating permit terms and conditions.

[Additional authority for this permit condition is derived from 25 Pa. Code sections 127.1 and 127.12]

(a) Source ID P102 is a 4,200 brake-horsepower Dresser Rand model TCV-10 natural gas-fired compressor engine.

(b) ID C102A is a Vanec model 141-48B-XXX oxidation catalyst, or DCL Special Oxidation-F Type (Authorized via Request for Determination May 13, 2016) (or equivalent, as determined by the Department).

(c) ID C102B is a AeriNOx selective catalytic reduction unit (authorized in Plan Approval 59-00002D).

(d) ID C102A and C102B shall control the air contaminant emissions from Source ID P102.

***** Permit Shield in Effect. *****


**SECTION D. Source Level Requirements**

Source ID: P201

Source Name: 596 BHP WAUKESHA GENERATOR ENGINE

Source Capacity/Throughput:

Conditions for this source occur in the following groups: P101, P102, P201

**I. RESTRICTIONS.****Emission Restriction(s).****[25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Sections 127.1, 127.12 and 40 CFR 52.21]

The air contaminant emissions from Source ID P201 shall not exceed the following rates:

- (a) Nitrogen oxide (NO_x, expressed as NO₂) - 8.89 pounds per hour,
- (b) Carbon monoxide (CO) - 35.53 pounds per hour
- (c) Non-methane hydrocarbon (NMHC) - 0.39 pounds per hour.

[25 Pa. Code §123.21]**General**The concentration of sulfur oxides, expressed as sulfur dioxide (SO₂), in the exhaust from Source ID P201 shall not exceed 500 parts per million, by volume, dry basis.**[25 Pa. Code §123.13]****Processes**

The concentration of particulate matter in the exhaust of Source ID P201 shall not exceed 0.04 grains per dry standard cubic foot of effluent gas volume.

Fuel Restriction(s).**[25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Section 129.91]

Source ID P201 shall only be fired on pipeline quality natural gas.

Operation Hours Restriction(s).**[25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Section 129.91]

Source ID P201 shall not be operated more than 500 hours in any 12 consecutive month period.

**SECTION D. Source Level Requirements****[25 Pa. Code §129.97]****Presumptive RACT requirements, RACT emission limitations and petition for alternative compliance schedule.**

[Additional authority for this permit condition is derived from 25 Pa. Code Section 129.97(c)(8)]

The permittee shall never operate this source equal to or in excess of 500 hours in any 12 consecutive month period.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.**[25 Pa. Code §129.115]****Written notification, compliance demonstration and recordkeeping and reporting requirements**

[Additional authority for this condition is from 25 Pa. Code Section 129.115(f) and (k)]

(f) The permittee shall keep records to demonstrate compliance with §§ 129.111—129.114 and submit reports to the Department in accordance with the applicable regulations in 25 Pa. Code, Part I, Subpart C, Article III (relating to air resources)

(1) The records shall include sufficient data and calculations to demonstrate that the requirements of §§ 129.111—129.114 are met.

(2) Data or information required to determine compliance shall be recorded and maintained in a time frame consistent with the averaging period of the requirement.

(3) The records necessary to determine compliance shall be reported to the Department on a schedule specified in the applicable regulation or as otherwise specified in the operating permit or plan approval for the air contamination source.

(k) The records shall be retained by the owner or operator for 5 years and made available to the Department upon receipt of a written request from the Department.

[25 Pa. Code §127.441]**Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Section 129.95 and 127.511]

(a) The permittee shall keep records in accordance with the recordkeeping requirements of 25 Pa. Code Section 129.95 which, at a minimum, shall include:

(1) The number of hours operated per month.

(2) The amount of fuel consumed per month.

(3) The gas quality characteristics in a current, valid purchase contract, tariff sheet, transportation contract for the fuel or other data compiled by the gas pipeline company, specifying the maximum total sulfur content of the fuel and verifying that the fuel is pipeline quality natural gas.

OR

**SECTION D. Source Level Requirements**

(4) Representative fuel sampling data showing the sulfur content of the fuel and verifying that the fuel is pipeline quality natural gas and shall include the following:

- (i) The date, place, and time of sampling;
- (ii) The date(s) analyses were performed;
- (iii) The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used;
- (v) The results of such analyses; and,
- (vi) The operating conditions at the time of sampling or measurement.

(b) All records generated pursuant to this permit condition shall be retained for a minimum of five (5) years and shall be made available to the Department upon request.

[25 Pa. Code §127.441]**Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Section 127.511]

(a) The permittee shall keep records of calculations or stack test results used to verify compliance with the short term (lb/hr) emission limitations for nitrogen oxides, carbon monoxide, and non-methane hydrocarbons.

(b) All records generated pursuant to this permit condition shall be retained for a minimum of five (5) years and shall be made available to the Department upon request.

[25 Pa. Code §129.100]**Compliance demonstration and recordkeeping requirements.**

[Additional authority for this permit condition is derived from 25 Pa. Code Section 129.100(d)(1), (2), and (i)]

The permittee shall keep records to demonstrate compliance with §§ 129.96—129.97 in the following manner:

- (1) The records must include sufficient data and calculations to demonstrate that the requirements of §§ 129.96—129.97 are met.
- (2) Data or information required to determine compliance shall be recorded and maintained in a time frame consistent with the averaging period of the requirement.

The records shall be retained by the owner or operator for 5 years and made available to the Department upon receipt of a written request from the Department.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.**[25 Pa. Code §129.112]****Presumptive RACT requirements, RACT emission limitations and petition for alternative compliance schedule**

[Additional authority for this condition is from 25 Pa. Code Section 129.112(c)(10)]

For this source the permittee shall install, maintain and operate the source in accordance with the manufacturer's specifications and with good operating practices.

[25 Pa. Code §127.441]**Operating permit terms and conditions.**

**SECTION D. Source Level Requirements**

[Additional authority for this permit condition is also derived from 25 Pa. Code Section 129.93]

Source ID P201 shall be maintained and operated in accordance with good air pollution control practices.

VII. ADDITIONAL REQUIREMENTS.

[25 Pa. Code §127.441]

Operating permit terms and conditions.

Source ID P201 is a 576 horsepower, 1.9 million Btu per hour, Waukesha model F3521GU natural gas-fired generator.


***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: P204

Source Name: 7 STORAGE TANKS (VP < 1.5 PSI)

Source Capacity/Throughput:

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.**[25 Pa. Code §127.441]****Operating permit terms and conditions.**

(a) The permittee shall keep records of the vapor pressure of the volatile organic compound-containing material in each tank incorporated in Source ID P204.

(b) All records generated pursuant to this permit condition shall be retained for a minimum of five (5) years and be made available to the Department upon request.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.**[25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall not store any volatile organic compound-containing materials in any tank incorporated in Source ID P204 which has a vapor pressure greater than 1.5 psia under actual storage conditions.

VII. ADDITIONAL REQUIREMENTS.**[25 Pa. Code §127.441]****Operating permit terms and conditions.**

Source ID P204 consists of the following storage tanks:

- (a) One (1) 2,000-gallon used oil tank (E-1)
- (b) One (1) 7,100-gallon lube oil tank (A-3)
- (c) One (1) 2,000-gallon reclaim oil tank (A-2)

**SECTION D. Source Level Requirements**

- (d) One (1) 10,000-gallon floor drain liquid tank (K-1)
- (e) One (1) 10,000-gallon dehydration wastewater tank (F-1)
- (f) One (1) 10,000-gallon produced fluids tank (I-1)
- (g) One (1) 8,000-gallon ethylene glycol tank (B-2)


***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: P205

Source Name: 2 STORAGE TANKS (VP > 1.5 PSI)

Source Capacity/Throughput:

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.**[25 Pa. Code §129.57]****Storage tanks less than or equal to 40,000 gallons capacity containing VOCs**

Source ID P205 shall have pressure relief valves which are maintained in good operating condition and which are set to release at no less than 0.7 psig (4.8 kilopascals) of pressure or 0.3 psig (2.1 kilopascals) of vacuum or the highest possible pressure and vacuum in accordance with state or local fire codes or the National Fire Prevention Association guidelines or other national consensus standards acceptable to the Department.

VII. ADDITIONAL REQUIREMENTS.**[25 Pa. Code §127.441]****Operating permit terms and conditions.**

Source ID P205 consists of the following tanks:

- (a) One (1) 10,000-gallon methanol tank (C-1)
- (b) One (1) 10,000-gallon dehydration distillate tank (D-1)


***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: P213

Source Name: GAS BLOWDOWNS

Source Capacity/Throughput:

**I. RESTRICTIONS.****Emission Restriction(s).****[25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from the permittee electing these restrictions to comply with 25 Pa. Code §123.1]

- (a) The total volatile organic compounds emissions from this source shall not equal or exceed 2.7 tons in any 12 consecutive month period.
- (b) The emissions of any combination of hazardous air pollutants from this source shall not equal or exceed 1.0 tons in any 12 consecutive month period.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.**[25 Pa. Code §127.441]****Operating permit terms and conditions.**

- (a) The permittee shall keep comprehensive and accurate records of the following to demonstrate compliance with the applicable emission limitations:
 - (1) The total volatile organic compounds emissions and
 - (2) The emissions of any combination of hazardous air pollutants.
- (b) Records generated by this condition shall be kept for 5 years and provided to the Department upon request.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

**SECTION D. Source Level Requirements****VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.

[25 Pa. Code §127.441]

Operating permit terms and conditions.

Source ID P213 consists of the gas blowdowns at the facility.

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: P101, P102, P201

Group Description: 40 CFR Part 60 Subpart ZZZZ

Sources included in this group

ID	Name
P101	4200 HP DRESSER RAND TCV-10 ENGINE 1
P102	4200 HP DRESSER RAND TCV-10 ENGINE 2
P201	596 BHP WAUKESHA GENERATOR ENGINE

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

II. TESTING REQUIREMENTS.

[40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6612]

Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake (please see below)

The permittee shall comply with the applicable testing requirements specified in 40 CFR Sections 63.6612(a) and 63.6620(a).

[40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6620]

Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

What performance tests and other procedures must I use?

The permittee shall comply with the applicable testing requirements specified in 40 CFR Sections 63.6612(a) and 63.6620(a).

III. MONITORING REQUIREMENTS.

[40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6635]

Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

How do I monitor and collect data to demonstrate continuous compliance?

The permittee shall comply with the applicable monitoring requirements specified in 40 CFR Section 63.6635.

IV. RECORDKEEPING REQUIREMENTS.

[40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6655]

Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

What records must I keep?

The permittee shall comply with the applicable recordkeeping requirements specified in 40 CFR Section 63.6655

V. REPORTING REQUIREMENTS.

[40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6645]

Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

What notifications must I submit and when?

The permittee shall comply with the applicable notification requirements specified in 40 CFR Sections 63.6645.

[40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6650]

Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

What reports must I submit and when?

The permittee shall comply with the applicable reporting requirements specified in 40 CFR Section 63.6650.

**SECTION E. Source Group Restrictions.****VI. WORK PRACTICE REQUIREMENTS.**

[40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6625]

Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

What are my monitoring, installation, operation, and maintenance requirements?

The permittee shall comply with the applicable maintenance requirements specified in 40 CFR Section 63.6625.

[40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6603]

Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

What emission limitations, operating limitations, and other requirements must I meet if I own or operate an existing stationary RICE located at an area source of HAP emissions?

The permittee shall comply with the applicable requirements specified in 40 CFR Section 63.6603.

VII. ADDITIONAL REQUIREMENTS.

[40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6605]

Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

What are my general requirements for complying with this subpart?

The permittee shall comply with the applicable general requirements specified in 40 CFR Section 63.6605.

(a) The permittee shall be in compliance with the emission limitations, operating limitations, and other requirements in 40 CFR Part 63 Subpart ZZZZ that apply to you at all times.

(b) At all times the permittee shall operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

[40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6630]

Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

How do I demonstrate initial compliance with the emission limitations and operating limitations?

The permittee shall comply with the applicable initial compliance requirements specified in 40 CFR Section 63.6630.

[40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6640]

Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

How do I demonstrate continuous compliance with the emission limitations, operating limitations, and other requirements?

The permittee shall comply with the applicable continuous compliance requirements specified in 40 CFR Sections 63.6640.

[40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6580]

Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

What is the purpose of subpart ZZZZ?

This source is subject to the requirements of Subpart ZZZZ of the National Emission Standards for Hazardous Air Pollutants as specified in 40 CFR Sections 63.6580 - 63.6675. The permittee shall comply with all applicable requirements of 40 CFR Part 63 Subpart ZZZZ.

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: RACT III

Group Description: 033, 036, and 038

Sources included in this group

ID	Name
033	TULPRO HEATER 2 (18.6 MMBTU/HR)
036	CLEAVER BROOKS BOILER (2.93 MMBTU/HR)
038	ETI REGEN HEATER

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.**[25 Pa. Code §129.115]****Written notification, compliance demonstration and recordkeeping and reporting requirements**

[Additional authority for this condition is from 25 Pa. Code Section 129.115(f) and (k)]

(f) The permittee shall keep records to demonstrate compliance with §§ 129.111—129.114 and submit reports to the Department in accordance with the applicable regulations in 25 Pa. Code, Part I, Subpart C, Article III (relating to air resources)

(1) The records shall include sufficient data and calculations to demonstrate that the requirements of §§ 129.111—129.114 are met.

(2) Data or information required to determine compliance shall be recorded and maintained in a time frame consistent with the averaging period of the requirement.

(3) The records necessary to determine compliance shall be reported to the Department on a schedule specified in the applicable regulation or as otherwise specified in the operating permit or plan approval for the air contamination source.

(k) The records shall be retained by the owner or operator for 5 years and made available to the Department upon receipt of a written request from the Department.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.**[25 Pa. Code §129.112]****Presumptive RACT requirements, RACT emission limitations and petition for alternative compliance schedule**

[Additional authority for this condition is from 25 Pa. Code Section 129.112(c)(4)]

For each source the permittee shall install, maintain and operate the source in accordance with the manufacturer's specifications and with good operating practices.

**SECTION E. Source Group Restrictions.****VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****



SECTION F. Alternative Operation Requirements.

No Alternative Operations exist for this Title V facility.

**SECTION G. Emission Restriction Summary.**

No emission restrictions listed in this section of the permit.



SECTION H. Miscellaneous.

Revision #1: This operating permit was modified on July 26, 2007, in accordance with the minor operating permit modification requirements of 25 Pa. Code Section 127.462, to increase the carbon monoxide emission limitation for Source P101 and Source P102 from 18.51 pounds per hour to 19.42 pounds per hour. Additionally, a new source (038) has been added to the permit and the source it replaced (032) has been removed.

Revision #2: This permit was administratively amended, pursuant to 25 Pa. Code Section 127.450, on December 21, 2015, to reflect a change in the owner's mailing address, responsible official, and permit contact.

Revision #3: This permit was modified in accordance with the minor operating permit modification requirements of 25 Pa. Code Section 127.462, on June 28, 2018, to incorporate presumptive RACT2 requirements.

Revision #4: This operating permit was modified on May 2, 2019, via minor modification requirements of 25 Pa. Code Section 127.462 to allow fuel tariff documentation or contract to verify the sulfur content of the fuel used in Sources P101, P102, P201.

Revision #5: This operating permit was modified on January 5, 2021, via administrative amendment requirements of 25 Pa. Code Section 127.450 to update the company name and mailing address.

Revision #6: This operating permit was modified on May 20, 2026, via administrative amendment requirements of 25 Pa. Code Section 127.450 to incorporate Plan Approval 59-00002D.

The following sources are located at the facility but are considered of minor significance:

- (1) One natural-gas fired 0.157 MMBtu/hr Rheem Water Heater



***** End of Report *****
