

Annex A

TITLE 25. ENVIRONMENTAL PROTECTION

PART I. DEPARTMENT OF ENVIRONMENTAL PROTECTION

Subpart D. ENVIRONMENTAL HEALTH AND SAFETY

ARTICLE IV. OCCUPATIONAL HEALTH AND SAFETY

CHAPTER 208. UNDERGROUND COAL MINE SAFETY

HIGH-VOLTAGE CONTINUOUS MINING MACHINE STANDARDS FOR UNDERGROUND COAL MINES

§ 208.81. Scope.

The provisions of 30 CFR 75.823 (relating to scope) are incorporated by reference.

§ 208.82. Electrical protection.

The provisions of 30 CFR 75.824 (relating to electrical protection) are incorporated by reference.

§ 208.83. Power centers.

The provisions of 30 CFR 75.825 (relating to power centers) are incorporated by reference.

§ 208.84. High-voltage trailing cables.

The provisions of 30 CFR 75.826 (relating to high-voltage trailing cables) are incorporated by reference.

§ 208.85. Guarding of trailing cables.

The provisions of 30 CFR 75.827 (relating to guarding of trailing cables) are incorporated by reference.

§ 208.86. Trailing cable pulling.

The provisions of 30 CFR 75.828 (relating to trailing cable pulling) are incorporated by reference.

§ 208.87. Tramming continuous mining machines in and out of the mine and from section to section.

The provisions of 30 CFR 75.829 (relating to tramming continuous mining machines in and out of the mine and from section to section) are incorporated by reference.

§ 208.88. Splicing and repair of trailing cables.

(a) *Incorporation by reference.* The provisions of 30 CFR 75.830(a) (relating to splicing and repair of trailing cables) are incorporated by reference.

(b) *Splicing limitations.*

(1) Splicing of the high-voltage trailing cable within 50 feet of the continuous mining machine is prohibited.

(2) The provisions of 30 CFR 75.830(b)(2) are incorporated by reference.

§ 208.89. Electrical work; troubleshooting and testing.

The provisions of 30 CFR 75.831 (relating to electrical work; troubleshooting and testing) are incorporated by reference.

§ 208.90. Frequency of examinations; recordkeeping.

The provisions of 30 CFR 75.832 (relating to frequency of examinations; recordkeeping) are incorporated by reference.

§ 208.91. Handling high-voltage trailing cables.

The provisions of 30 CFR 75.833 (relating to handling high-voltage trailing cables) are incorporated by reference.

§ 208.92. Training.

The provisions of 30 CFR 75.834 (relating to training) are incorporated by reference.

§ 208.93. Installation of electric equipment and conductors; permissibility.

The provisions of 30 CFR 75.1002 (relating to installation of electric equipment and conductors; permissibility) are incorporated by reference.