



September 19, 2024

CERTIFIED MAIL NO. [REDACTED]

Subject Address: [REDACTED]

Re: Water Supply Request for Investigation ID: 362465
58 Pa. C.S. § 3218 Determination
Lenox Township, Susquehanna County

Dear [REDACTED]

The Department of Environmental Protection (“Department”) has been investigating the possible degradation of your water supply located at the above-referenced Subject Address (“Water Supply”) from oil and gas activities. The Department has determined that your Water Supply was adversely affected by oil and gas activities, including but not limited to the drilling, alteration, or operation of an oil or gas well. The information upon which this determination is based is summarized below.

Please note that without any treatment, water quality sampling indicates that on occasion your water quality does not meet (i.e., is worse than) the following health and/or aesthetic statewide standards. Note that Primary Maximum Contaminant Levels (“MCLs”) are intended to reflect potential dangers to human health, while Secondary Maximum Contaminant Levels (“SMCLs”) reflect the aesthetics of the water (i.e., taste, smell, etc.). None of the parameters in the Water Supply were above a MCL or SMCL; however, certain samples were above the DEP Action Level, as set forth in the table below.

Parameters	Unit	Statewide Standards or Recommended Levels	Your <u>Highest</u> Sample Results that Were Detected Above Statewide Standards/Levels
Methane	mg/L	7 (DEP Action Level)	64

Summary of Investigation

On March 2, 2022, you reported hammering in the water pipes of the property, spurts of air from the faucets, and that the water had become cloudy and effervescent. Subsequently, water quality samples were collected from the Water Supply on several occasions by the Department and private consultants. The samples were submitted to the Department's laboratory in Harrisburg or to an accredited third-party laboratory for analysis. The analytical reports for the samples collected by the Department were previously provided to you, but are summarized for your convenience in the enclosed table along with sample results provided by Coterra Energy, Inc.

Samples of the methane from the Water Supply were collected and sent to a specialized laboratory for isotopic and compositional analysis. These analyses allowed for a more detailed characterization of the gas present in the Water Supply. The isotope and compositional analyses indicate that the stray gas in your Water Supply appears to be associated with oil and gas activities.


Methane is the predominant component of natural gas. Federal water standard limitations have not been established for methane gas. The level of concern begins above 28 mg/L methane, which is referred to as the saturation level. At this level, under normal atmospheric pressure, the water cannot hold additional methane in solution. This may allow the gas to come out of the water and concentrate in the air space of your home or building. There is a physical danger of fire or explosion due to the migration of natural gas into water wells or through soils into dwellings where it could be ignited by sources that are present in most homes/buildings. Natural gas can also cause a threat of asphyxiation, although this is extremely rare.

When the Department is made aware of methane levels greater than 7 mg/L, it notifies the water supply owner of the hazards associated with methane in their water supply. Note that methane has not been detected in your Water Supply at greater than 7 mg/L since sampling conducted in August 2022. Please be aware, however, that the methane levels can fluctuate. This means that even with a relatively low level of methane, you should be vigilant of changes in your water that could indicate an increase in methane concentration.

It is the Department's recommendation that all water wells should be equipped with a working vent. This will help alleviate the possibility of concentrating these gases in areas where ignition would pose a threat to life or property. Please note that it is not possible to completely eliminate the hazards of having natural gas in your Water Supply by simply venting your well.

The Department is continuing to work to permanently resolve this issue. Should you have any questions regarding the investigation, please contact Eric Rooney, P.G. at 570.346.5543.

Sincerely,



Jennifer W. Means
Environmental Program Manager
Eastern Oil and Gas District

Enclosures:

Laboratory Analytical Results Table

c: Michael O'Donnell
Eric Rooney, P.G.
Briana Cunningham
Complaint File # 362465

CID# 362465	8/1/2011	11/23/2021	3/2/2022	3/15/2022	4/22/2022	4/22/2022	8/25/2022	8/25/2022	3/30/2023	3/30/2023	5/31/2023	5/31/2023	MCL/Standard
	Cabot raw 0.00017 <0.0000250 <0.00005	Coterra raw 0.0050 <0.0050 <0.0050	Coterra raw 64 0.860 0.0054	Coterra raw 57 0.830 <0.0050	Coterra raw 37 0.440 <0.0050	Coterra treated 13 0.022 <0.0050	Coterra raw 36 0.440 <0.0050	Coterra treated 8.9 0.140 <0.0050	Coterra raw 85 0.320 <0.0050	Coterra treated 86 0.089 <0.0050	Coterra raw 0.170 <0.0050	Coterra treated 0.036 <0.0050	
Methane													**7
Ethane													No Standard
Propane													No Standard
Alkalinity			88										No Standard
Aluminum			0.10										0.2
Arsenic			<0.0020										*0.010
Barium			0.075										*2
Bromide			<0.50										No Standard
Calcium			49										No Standard
Hardness			150										No Standard
Iron			0.15										0.3
Lithium			<0.050										No Standard
Magnesium			3.7										No Standard
Manganese			0.012										0.05
pH (units)			7.3										6.5-8.5
Potassium			1.1										No Standard
Selenium			<0.0010										*0.05
Sodium			14										No Standard
SPC (µs/cm)			350										No Standard
Strontium			0.20										No Standard
Total Chloride			40										250
TDS			190										500
Total Sulfate			13										250
TSS			<4.0										No Standard
Turbidity (NTU)			3.6										No Standard
Zinc			<0.010										5

Highlighting indicates an exceeded standard or level~ = Not analyzed * Denotes Primary MCL < Indicates analyte was not detected above its detection limit.

** 7 mg/L represents the Department's official action level for dissolved methane in groundwater.

CID# 362465	7/11/2023		7/11/2023		7/11/2023		11/16/2023		11/16/2023		2/26/2024		MCL/Standard
	DEP	raw	Coterra	raw	Coterra	treated	raw	Coterra	treated	Coterra	raw		
Results in mg/L unless otherwise noted.													
		raw											
Methane		0.184	0.130	0.022	0.072	0.630	0.072	0.420					**7
Ethane		<0.0124	<0.0050	<0.0050	<0.0050	0.0053	<0.0050	<0.0050					No Standard
Propane		<0.0142	<0.0050	<0.0050	<0.0050	<0.0050	<0.0050	<0.0050					No Standard
Alkalinity		86.4	84	86	95	100	95	94					No Standard
Aluminum		<0.0150	<0.030	<0.030	<0.030	<0.030	<0.030	<0.030					0.2
Arsenic		<0.00300	<0.0020	<0.0020	<0.0020	<0.0020	<0.0020	<0.0020					*0.010
Barium		0.070	0.068	0.066	0.078	0.087	0.078	0.080					*2
Bromide		<0.2	<0.75	<7.5	<0.75	<0.75	<0.75	<7.5					No Standard
Calcium		48.000	49	51	50	51	50	50					No Standard
Hardness		134	150	170	140	140	140	140					No Standard
Iron		<0.100	<0.050	<0.050	<0.050	<0.050	<0.050	<0.050					0.3
Lithium		<0.0250	<0.050	<0.050	<0.050	<0.050	<0.050	<0.050					No Standard
Magnesium		3.38	3.5	3.6	3.9	4.0	3.9	3.8					No Standard
Manganese		<0.010	<0.0020	<0.0020	<0.0020	0.0022	<0.0020	0.0024					0.05
pH (units)		6.7	7.1	7.3	~	~	~	7.3					6.5-8.5
Potassium		1.06	1.0	1.1	1.1	1.1	1.1	1.1					No Standard
Selenium		<0.00400	<0.0010	<0.0010	<0.0010	<0.0010	<0.0010	<0.0010					*0.05
Sodium		12.50	12	14	16	17	16	15					No Standard
SPC (µS/cm)		349.00	350	370	~	~	~	~					No Standard
Strontium		0.164	0.18	0.18	0.21	0.23	0.21	0.21					No Standard
Total Chloride		43.01	44	49	45	47	45	53					No Standard
TDS		228	170	180	200	250	200	210					250
Total Sulfate		12.86	12	12	12	12	12	12					500
TSS		<20	<3.0	<3.0	<3.8	<3.8	<3.8	<3.0					250
Turbidity (NTU)		<1	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0					No Standard
Zinc		<0.0300	<0.010	<0.017	0.026	<0.010	0.026	<0.010					No Standard

Highlighting indicates an exceeded standard or level~ = Not analyzed * Denotes Primary MCL < Indicates analyte was not detected above its detection limit.

** 7 mg/L represents the Department's official action level for dissolved methane in groundwater.