



TETRA TECH

SURFACE WATER METERING PLAN FOR TUNKHANNOCK CREEK

ATLANTIC SUNRISE PROJECT

**Nicholson Township, Wyoming County,
Pennsylvania**

Prepared For:

**TRANSCONTINENTAL GAS PIPE LINE
COMPANY, LLC
HOUSTON, TEXAS**

Prepared By:

**TETRA TECH, INC.
PITTSBURGH, PENNSYLVANIA**

September 2016

SRBC Surface Water Withdrawal Application Metering Plan

A. Intake Design

The surface water withdrawal location on Tunkhannock Creek is located along the proposed gas pipeline route where the water will be required for hydrostatic testing. The anticipated volume of water to be withdrawn from Tunkhannock Creek for pipeline hydrotesting does not trigger any Susquehanna River Basin Commission (SRBC) permitting requirement (i.e., more than 100,000 gallons per day average over a 30-day period or 3,000,000 gallons in any consecutive 30-day period). No withdrawals from the creek in excess of these amounts are allowed at any time. All withdrawals must follow this document to protect the environment and ensure that the water volumes withdrawn from the creek are below the SRBC permit threshold volume. Water will be transferred from Tunkhannock Creek directly to the pipeline and/or hydrotest equipment for hydrostatic testing. This water source will only be used to supply water during pipeline construction and testing. Transcontinental Gas Pipe Line Company, LLC (Transco) proposes to use two (2), 5-foot long, 3-inch radius stainless steel screens with slot-size openings of 0.100-inch that are manufactured by Bilfinger Water Technologies™ to withdraw water from Tunkhannock Creek. The 5-foot long screens are connected by a tee fitting and include a foot valve to maintain a flooded suction and prevent backflow. The intake screen will be connected to a 10-inch diameter flexible hose or HDPE suction pipe. The intake screen will be a floated intake submerged in the approximate location of the creek's thalweg (lowest point of creek channel) in close proximity to the project site. The approximate water depth at the point of withdrawal is 3 feet. The slot openings were sized to avoid potential aquatic impacts associated with impingement and entrainment. Calculations for the intake's through-screen approach velocity (provided in Attachment A-1) show the screen entrance velocity to be less than 0.5 feet per second (ft/s). Manufacturer information for the intake screens is included in Attachment A-2. The PNDI Report, which indicates no agency coordination required, is included in Attachment A-3.

Transco proposes to use one 6" by 6" Pioneer Prime Series PP66C14 vacuum assisted, end suction centrifugal pump. This pump is mechanically driven and operates at a maximum of 2,200 revolutions per minute. Pump specification sheets and head curves are included in Attachments A-4 and A-5, respectively. Transco will limit the instantaneous pumping rate by using a Cla Val Combination Rate of Flow Controller & Solenoid Shut-off Valve (Model 43-01)) on the discharge end of the pump. Specifications are included in Attachment A-6. This valve will be locked to prevent unintentional changes to the flow rate. Transco's staff will be prepared to comply with monthly passby rates and withdrawal rates. To protect aquatic resources and downstream users, Transco will cease withdrawals from Tunkhannock Creek when the creek flow rate at the assigned reference gage is at or falls below the prescribed monthly passby flow rate.

Transco will ensure that the intake screen is regularly maintained and free of debris. Specifically, to ensure that the screen area is open and not clogged, prior to each operating event, Transco will retrieve the screen intake apparatus from the creek and inspect it for any debris or material that could clog the intake and reduce pumping efficiencies. In addition, the flow rate will be monitored during operation. If the pumping flow rate decreases by 20% or more during operation, the pump will be turned off and the screen intake assembly will be retrieved from the creek and inspected to ensure the screen is not clogged which could result in increased entrance velocities. If debris is

present in and around the screen opening, the screen will be cleaned prior to being put back into operation.

Water will be conveyed to the pipeline for hydrostatic testing from the skid/trailer-mounted pump through a combination of 6-inch steel and 8-inch flexible hose or HDPE pipe. This pipe was sized to accommodate a maximum flow rate of up to 1,800 gpm (see Attachment A-7 for basis). Water used for the pipeline hydrostatic testing will be discharged at a Pennsylvania Department of Environmental Protection permitted location (i.e., PAG-10 permit). The main pipeline hydrostatic testing is scheduled for 2017.

A wetland study was completed for the area on July 8, 2015. One wetland was identified in the vicinity of the proposed withdrawal equipment; equipment will not be placed within the wetland, and crossing the wetlands by personnel or equipment will be minimized. The intake pump will be located within the Federal Emergency Management Agency (FEMA) floodplain, but out of the FEMA floodway. The slope of the creek bank at the proposed location is gradual. All equipment will be temporary and removable, minimizing impact to riparian vegetation. Portable secondary containment will be utilized around the pump. It should also be noted that the pump will be located within the Transco project right-of-way and limit-of-disturbance.

Transco intends to put in place protective controls at its withdrawal site to enforce the passby requirements set by the SRBC with the intent to protect the stream during low-flow periods. For this project, flows at the proposed withdrawal point were calculated by proportioning based on the drainage area ratio method from a selected USGS gaging station on Tunkhannock Creek. At the proposed location, Tunkhannock Creek has a drainage area of 186 square miles (mi²). The selected USGS reference gage on Tunkhannock Creek for this project site is located in Tunkhannock, Pennsylvania and is identified as Gage No. 01534000. This gaging station is located downstream of the proposed intake location for this project and has a drainage area of approximately 383 mi². Based on a drainage area at the withdrawal point of approximately 186 mi², the Aquatic Resource Class (ARC) of Tunkhannock Creek is classified as 'ARC 3', which represents a small river. Creeks classified as ARC 3 are likely to be moderately sensitive to potential impacts from withdrawals due to their size, position in the landscape, and flow volumes. USGS records (scaled Gage Station data) indicate that at the proposed withdrawal location on Tunkhannock Creek the Q7-10 flow rate is 8.4 cubic feet per second (cfs) or 5.43 MGD. The requested daily withdrawal rates vary by month and range from 1.78 cfs (1.152 MGD) to 4.01 cfs (2.592 MGD). See withdrawal calculations in A-8.

Transco will stop or decrease withdrawals during low flow periods to avoid negatively impacting the quality of Tunkhannock Creek. The USGS gaging station located on Tunkhannock Creek at Tunkhannock, Pennsylvania (Gage No. 01534000) will be used to determine the flow rates of Tunkhannock Creek during surface water withdrawal operations.

B. Metering

To meter the volume of water withdrawn at the surface water withdrawal location, a 6-inch Seametrics AG2000 Irrigation Magmeter will be used (see manufacturer information in A-9). This spool-type electromagnetic flow meter and totalizer has no moving parts and minimal straight pipe

requirements both above (i.e., 12 inches, minimum) and below (i.e., 6 inches, minimum) the meter. This allows unobstructed flow and makes it an ideal choice for use in surface water withdrawal applications where debris may cause damage to the equipment. This model is capable of displaying up to 5 digits for flow rate and 8 digits for the totalizer. The minimum flow rate for this model of flow meter is 32 gpm; the maximum rate is 2,400 gpm. The proposed withdrawal rate range of 800 gpm to 1,800 gpm is within this range. The meter is accurate to within +/-1% for flows between 240 gpm and 2400 gpm and +/- 2% for flows under 240 gpm. The flow meter will be installed so that it cannot be bypassed, zeroed, or reset.

Transco will check the totalizer daily prior to pumping water from Tunkhannock Creek and at the end of each day to ensure that the proposed month-specific maximum daily withdrawal rate [1.78 cfs (1.152 MGD) to 4.01 cfs (2.592 MGD)] is not exceeded. Transco will maintain daily records of the project's withdrawal and consumptive water use and shall report the data to the SRBC on a quarterly and annual basis or as prescribed. Transco will also ensure that the meter readout will be accessible for SRBC staff at all times without locks, keys or other special access requirements.

C. Plans, Details, and Maps

A site plan, cross-section, details, and location map can be found in Attachment A-10. Site Photographs are included in Attachment A-11.

A-1 Intake Screen Calculations

CLIENT: TRANSCONTINENTAL PIPE LINE COMPANY, LLC		JOB NUMBER: 212C-PB-00282	
SUBJECT: TUNKHANNOCK CREEK SCREENED INTAKE EVALUATION			
BASED ON: Bilfinger Water Technologies		DRAWING NUMBER:	
BY: DTK	CHECKED BY: LMH	APPROVED BY: CAR	
DATE: 12/11/2015	DATE: 12/15/2015	DATE: 12/15/15	

PURPOSE:

The purpose of this calculation is to evaluate the minimum number of intake screens necessary to meet the requirement of maximum intake velocity of 0.5 feet per second. Creek depth is less than 3 feet.

APPROACH:

Use typical industry equations to calculate the minimum number of Bilfinger Water Technologies 6-inch diameter well screens necessary to allow a flow rate of 1,800 gallons per minute. Assume multiple intake screens with 0.1-inch slots.

CALCULATIONS:

- (1) Data was obtained from Bilfinger Water Technologies® for the well screen.

d	=	0.100	=	Maximum perforation diameter, inches
V	=	0.5	=	Maximum intake velocity, feet per second
Q	=	1,800	=	Maximum flow (withdrawal) rate, gallons per minute
r	=	3.09	=	Radius of perforated intake pipe, inches
b	=	5.000	=	length of perforated intake pipe, feet
n	=	unknown	=	number of screens
A _s	=	790	=	Area of screen, square inches
A _o	=	494	=	Open area of screen, square inches (see attached)
P	=	62.5%	=	Open area of perforated intake pipe (P = A _o /A _s)

- (2) Use the following equation from the Handbook of Groundwater Development, Roscoe Moss Company, to calculate first the minimum number of Bilfinger Water Technologies intake screens necessary for a withdrawal of 1,800 gallons per minute.

$$V = \frac{Q / n}{235 \times r \times b \times P}$$

$$n = \frac{Q}{235 \times r \times b \times P \times V}$$

$$n = \frac{1,800}{235 \times 3.09 \times 5 \times 0.625 \times 0.5}$$

$$n = 1.59$$

$$n = 2 \quad (\text{round up})$$

The minimum number of Bilfinger Water Technologies 6-inch diameter well screens necessary to allow for a total flow of 1,800 gpm to be withdrawn is 2.

- (3) Using the equation from Step 2, calculate the entrance velocity when 2 Bilfinger Water Technologies 6-inch diameter well screens are used.

$$V = \frac{Q / n}{235 \times r \times b \times P}$$

$$V = \frac{1,800 / 2}{235 \times 3.09 \times 5 \times 0.625}$$

$$V = 0.40 \quad \text{feet per second}$$

CLIENT: TRANSCONTINENTAL PIPE LINE COMPANY, LLC		JOB NUMBER: 212C-PB-00282	
SUBJECT: TUNKHANNOCK CREEK SCREENED INTAKE EVALUATION			
BASED ON: Bilfinger Water Technologies		DRAWING NUMBER:	
BY: DTK	CHECKED BY: LMH	APPROVED BY: CAR	
DATE: 12/11/2015	DATE: 12/15/2015	DATE: 12/15/15	

CONCLUSION:

Two Bilfinger Water Technologies 6-inch diameter well screens provide an intake flow capacity of 1,800 gallons per minute with a maximum screen entrance velocity of 0.40 feet per second, which is conservatively below the required maximum intake velocity of 0.5 feet per second. Therefore, Tetra Tech believes that the resulting velocity will minimize impingement and entrainment of aquatic organisms during operation. Additionally, to minimize sediment uptake, the intake screens will be cradled to elevate them a minimum of 6-inches off of the creek bed.


A-2 Intake Manufacturer Information

SCREEN INFORMATION		
CUSTOMER	Tetra-tech	
REFERENCE		
DIAMETER	6 in	PS
MATERIAL	304 Stainless	
COLLAPSE	45	PSI
SLOT SIZE	0.100	IN
OPEN AREA	62.50%	
ROD AREA	0.864	SQ IN
HANGING WT ¹	11,000	LB
¹ MAXIMUM RECOMMENDED HANGING WEIGHT FOR THE TOP SCREEN JOINT		
LENGTH (ft)	5	FULL
NO. OF PIECES	1	Joints
TOP FITTING	1.5 in	F/NPT
BTM FITTING	1.5 in	M/NPT

* A broad range of site conditions can impact the physical strength requirements for a successful screen installation. Consult Johnson Screens with questions for successful screen installation. Consult Johnson Screens with questions regarding the parameters presented above as they relate to your specific requirements.

** Vertical weight on screen that should not be exceeded without use of rigid centralizers!

Prepared by Waterwell Sales. Subject to Bilfinger Water Technologies, Inc Standard Terms and Conditions.



THIS DRAWING AND DESIGN DATA IS CONFIDENTIAL IN NATURE AND IS THE PROPERTY OF BILFINGER WATER TECHNOLOGIES INC, ST. PAUL, MN, USA, AND SHALL NOT BE REPRODUCED IN ANY MANNER OR USED FOR ANY PURPOSE WHATSOEVER EXCEPT BY WRITTEN PERMISSION OF BILFINGER WATER TECHNOLOGIES INC.



WELL SCREEN SUBMITTAL DATA

CLIENT: Tetra-tech
PROJECT:

Material	304 Stainless			
Nom Size	6	PS	150	mm
Top x Bottom Fitting Configuration	NPT x WR W/PB			
Estimated Total Well Depth	2	ft	1	meters
Estimated Feet of Screen	5	ft	2	meters
Design Slot Size	0.100	in	2.5	mm
Approx. Outside Diameter	6.72	in	171	mm
Screen Barrel Inside Diameter	6.18	in	157	mm
Approx. Clear ID at Fittings	6.02	in	153	mm
Approx. Weight Per Ft	6	lbs	3	kg
Wire Width	0.060	in	1.5	mm
Wire Height	0.100	in	2.5	mm
Calc. Collapse Strength *	45	PSI	3	kg/sq.cm
Open Area	62.5%			
Intake Area	158	sq.in./ft	3,349	sq.cm./meter
Transmitting Capacity-at 0.1 ft/sec	49	gpm/ft	10	lps/meter
Support Rod Diam	0.150	in	3.8	mm
No Rods	40			
Cross Sectional Rod Area	0.86	sq.in.	5.57	sq.cm.
Design Yield Strength	30,000	PSI	2,109	kg/sq.cm
Calc.Tensile Strength *	22,000	lbs	10,000	kg
Max.Recomended Hang Wt. *	11,000	lbs	5,000	kg
Column Load **	5,000	lbs	2,300	kg

* A broad range of site conditions can impact the physical strength requirements for a successful screen installation. Consult Johnson Screens with questions regarding the parameters presented above as they relate to your specific requirements.

** Vertical weight on screen that should not be exceeded without consulting manufacturer. Column load calculations should include some allowance for gravel pack contribution.

A-3 PNDI

1. PROJECT INFORMATION

Project Name: **Tunkhannock**

Date of review: **9/1/2015 7:57:28 AM**

Project Category: **Water extraction/transfer, Extraction of surface water (e.g., from stream, river, creek, lake, or pond)**


Project Area: **N/A**

County: **Wyoming** Township/Municipality: **Nicholson Twp**

Quadrangle Name: **HOP BOTTOM** ~ ZIP Code: **18446**

Decimal Degrees: **41.626716 N, -75.760338 W**

Degrees Minutes Seconds: **41° 37' 36.2" N, -75° 45' 37.2" W**



2. SEARCH RESULTS

Agency	Results	Response
PA Game Commission	No Known Impact	No Further Review Required
PA Department of Conservation and Natural Resources	No Known Impact	No Further Review Required
PA Fish and Boat Commission	No Known Impact	No Further Review Required
U.S. Fish and Wildlife Service	No Known Impact	No Further Review Required

As summarized above, Pennsylvania Natural Diversity Inventory (PNDI) records indicate no known impacts to threatened and endangered species and/or special concern species and resources within the project area. Therefore, based on the information you provided, no further coordination is required with the jurisdictional agencies. This response does not reflect potential agency concerns regarding impacts to other ecological resources, such as wetlands.

3. AGENCY COMMENTS

Regardless of whether a DEP permit is necessary for this proposed project, any potential impacts to threatened and endangered species and/or special concern species and resources must be resolved with the appropriate jurisdictional agency. In some cases, a permit or authorization from the jurisdictional agency may be needed if adverse impacts to these species and habitats cannot be avoided.

These agency determinations and responses are **valid for two years** (from the date of the review), and are based on the project information that was provided, including the exact project location; the project type, description, and features; and any responses to questions that were generated during this search. If any of the following change: 1) project location, 2) project size or configuration, 3) project type, or 4) responses to the questions that were asked during the online review, the results of this review are not valid, and the review must be searched again via the PNDI Environmental Review Tool and resubmitted to the jurisdictional agencies. The PNDI tool is a primary screening tool, and a desktop review may reveal more or fewer impacts than what is listed on this PNDI receipt. The jurisdictional agencies **strongly advise against** conducting surveys for the species listed on the receipt prior to consultation with the agencies.

PA Game Commission

RESPONSE: No Impact is anticipated to threatened and endangered species and/or special concern species and resources.

PA Department of Conservation and Natural Resources

RESPONSE: No Impact is anticipated to threatened and endangered species and/or special concern species and resources.

PA Fish and Boat Commission

RESPONSE: No Impact is anticipated to threatened and endangered species and/or special concern species and resources.

U.S. Fish and Wildlife Service

RESPONSE: No impacts to **federally** listed or proposed species are anticipated. Therefore, no further consultation/coordination under the Endangered Species Act (87 Stat. 884, as amended; 16 U.S.C. 1531 *et seq.*) is required. Because no take of federally listed species is anticipated, none is authorized. This response does not reflect potential Fish and Wildlife Service concerns under the Fish and Wildlife Coordination Act or other authorities.

4. DEP INFORMATION

The Pa Department of Environmental Protection (DEP) requires that a signed copy of this receipt, along with any required documentation from jurisdictional agencies concerning resolution of potential impacts, be submitted with applications for permits requiring PNDI review. For cases where a "Potential Impact" to threatened and endangered species has been identified before the application has been submitted to DEP, the application should not be submitted until the impact has been resolved. For cases where "Potential Impact" to special concern species and resources has been identified before the application has been submitted, the application should be submitted to DEP along with the PNDI receipt. The PNDI Receipt should also be submitted to the appropriate agency according to directions on the PNDI Receipt. DEP and the jurisdictional agency will work together to resolve the potential impact(s). See the DEP PNDI policy at <http://www.naturalheritage.state.pa.us>.

5. ADDITIONAL INFORMATION

The PNDI environmental review website is a **preliminary** screening tool. There are often delays in updating species status classifications. Because the proposed status represents the best available information regarding the conservation status of the species, state jurisdictional agency staff give the proposed statuses at least the same consideration as the current legal status. If surveys or further information reveal that a threatened and endangered and/or special concern species and resources exist in your project area, contact the appropriate jurisdictional agency/agencies immediately to identify and resolve any impacts.

For a list of species known to occur in the county where your project is located, please see the species lists by county found on the PA Natural Heritage Program (PNHP) home page (www.naturalheritage.state.pa.us). Also note that the PNDI Environmental Review Tool only contains information about species occurrences that have actually been reported to the PNHP.

6. AGENCY CONTACT INFORMATION

PA Department of Conservation and Natural Resources

Bureau of Forestry, Ecological Services Section
400 Market Street, PO Box 8552, Harrisburg, PA.
17105-8552
Fax: (717) 772-0271

U.S. Fish and Wildlife Service

Pennsylvania Field Office
110 Radnor Rd; Suite 101, State College, PA 16801
NO Faxes Please.

PA Fish and Boat Commission

Division of Environmental Services
450 Robinson Lane, Bellefonte, PA. 16823-7437
NO Faxes Please

PA Game Commission

Bureau of Wildlife Habitat Management
Division of Environmental Planning and Habitat Protection
2001 Elmerton Avenue, Harrisburg, PA. 17110-9797
Fax: (717) 787-6957

7. PROJECT CONTACT INFORMATION

Name: _____
Company/Business Name: _____
Address: _____
City, State, Zip: _____
Phone: (____) _____ Fax: (____) _____
Email: _____

8. CERTIFICATION

I certify that ALL of the project information contained in this receipt (including project location, project size/configuration, project type, answers to questions) is true, accurate and complete. In addition, if the project type, location, size or configuration changes, or if the answers to any questions that were asked during this online review change, I agree to re-do the online environmental review.


applicant/project proponent signature

12-28-2015
date

A-4 Pump Specification



Pioneer Prime

PP66C14L71



Typical Pump Configuration

Performance

Pioneer Prime series - vacuum assisted, end suction centrifugal pump

Bare shaft, frame mounted, fully automatic dry priming, vacuum assisted, run dry, heavy duty pump

Size	6" x 6"
	150 x 150 mm
Flow, Max	2,825 USgpm
	660 m ³ /h
	180 l/s
Head, Max	320 feet
	100 meters
Flow at BEP	2,625 USgpm
	600 m ³ /h
	170 l/s
Efficiency at BEP	81%
Solids Handling, Max	1.0"
	25 mm
Operating Speed, Max	2200 rpm
Suction Connection	6" (150 mm)
	150 ANSI Flanges
Delivery Connection	6" (150 mm)
	150 ANSI Flanges
Bearing Lubrication	Oil STD
	Grease optional
Fasteners	Imperial

Applications

Oil & Gas	Construction
Industrial	Mining
Petrochemical	Rental
Agriculture	Irrigation

High flow, heavy duty pump

The PP66C14 is a high flow, ruggedized pump designed to run over a broad range of performance and deliver outstanding suction lift. The rugged construction and modular design provide proven reliability and flexibility in the most demanding applications.

UltraPrime™ Priming System

Priming System	Mechanically Driven Diaphragm Style Vacuum Pump
Air Removal Capability	50 CFM
Priming Chamber	Single chamber with positive sealing air separation PosiValve™ with stainless steel float ball & linkage.
Discharge Check Valve	Swing Style - ductile iron with Buna-n Disc

Other Specifications

Mechanical Seal	Single seal w/ tungsten carbide vs. silicon carbide seal faces, Viton® elastomers, 300 series stainless steel hardware and spring, designed for indefinite dry running	
Pump End Bearing	Single Row Ball	
Drive End Bearing	Single Row Ball	
Shaft	17-4 PH Stainless Steel	

Construction Materials


	Standard Construction	CD4MCu Stainless Steel
Impeller	CA6NM SS	CD4MCu
Volute	Ductile Iron ASTM A536 65-45-12	CD4MCu
Wear Ring	ASTM A48 Class 40 Gray Iron	316 SS
Suction Cover	Ductile Iron ASTM A536 65-45-12	CD4MCu
Brac-plate	Ductile Iron ASTM A536 65-45-12	CD4MCu

Mechanical Dimensions




Typical Pump Configuration

PP66C14




Performance Curve

Model: PP66C14	Impeller Dia: 14"	Speed: Variable	Solids Size: 1.0"	Curve #A2578HQ
----------------	-------------------	-----------------	-------------------	----------------



A-5 Pump Head Curves and Pump Selection Justification



NOTES:

CURVE ACCOUNTS FOR LOSSES FROM CHECK VALVE, PRIMING SYSTEM, AND OPEN CLEARANCE WEAR RING

125 ft
TDH

13.0 ft
NPSHr



MODEL : PP66C14


SIZE : 6" x 6"

IMPELLER DIA. 14.0"

SOLIDS SIZE : 1.0"

DWG NO. A7524HQ
REVISION: 001
DRAWN BY: DAP
DATE: 09/16/2010

Note: Losses from priming system not shown



Model	PP66C14	
Size	6" x 6"	150 mm x 150 mm
Impeller Diameter	14.0"	356 mm
Solids Handling Size	1.38"	35 mm

DWG No. A2578HQ
Revision 001
Drawn By DAP
Date 23 Jul 2010

A-6 Flow Control Valve Specification

Model 43-01 (Uses Basic Valve Model 100-01)

Pressure Ratings (Recommended Maximum Pressure - psi)



Valve Body & Cover		Pressure Class				
		Flanged	Grooved	Threaded		
Grade	Material	ANSI Standards*	150 Class	300 Class	300 Class	End† Details
ASTM A536	Ductile Iron	B16.42	250	400	400	400
ASTM A216-WCB	Cast Steel	B16.5	285	400	400	400
ASTM B62	Bronze	B16.24	225	400	400	400

Note: * ANSI standards are for flange dimensions only.
 Flanged valves are available faced but not drilled.
 † End Details machined to ANSI B2.1 specifications.
Valves for higher pressure are available; consult factory for details

Materials

Component	Standard Material Combinations		
Body & Cover	Ductile Iron	Cast Steel	Bronze
Available Sizes	1-1/2" - 36"	1-1/2" - 16"	1-1/2" - 16"
Disc Retainer & Diaphragm Washer	Cast Iron	Cast Steel	Bronze
Trim: Disc Guide, Seat & Cover Bearing	Bronze is Standard Stainless Steel is Optional		
Disc	Buna-N® Rubber		
Diaphragm	Nylon Reinforced Buna-N® Rubber		
Stem, Nut & Spring	Stainless Steel		
For material options not listed, consult factory. Cla-Val manufactures valves in more than 50 different alloys.			

Dimensions (In inches)



Model 43-01 Dimensions (In Inches)

Valve Size (Inches)	1 1/2	2	2 1/2	3	4	6	8	10	12	14	16	18	20	24	30	36
A Threaded	7.25	9.38	11.00	12.50	—	—	—	—	—	—	—	—	—	—	—	—
AA 150 ANSI	8.50	9.38	11.00	12.00	15.00	20.00	25.38	29.75	34.00	39.00	41.38	46.00	52.00	61.50	63.00	76.00
AAA 300 ANSI	9.00	10.00	11.62	13.25	15.62	21.00	26.38	31.12	35.50	40.50	43.50	47.64	53.62	63.24	64.50	76.00
AAAA Grooved End	8.50	9.00	11.00	12.50	15.00	20.00	25.38	—	—	—	—	—	—	—	—	—
B Dia.	5.62	6.62	8.00	9.12	11.50	15.75	20.00	23.62	28.00	32.75	35.50	41.50	45.00	53.16	56.00	66.00
C Max.	5.50	6.50	7.56	8.19	10.62	13.38	16.00	17.12	20.88	24.19	25.00	39.06	41.90	43.93	54.60	61.50
CC Max. Grooved End	4.75	5.75	6.88	7.25	9.31	12.12	14.62	—	—	—	—	—	—	—	—	—
D Threaded	3.25	4.75	5.50	6.25	—	—	—	—	—	—	—	—	—	—	—	—
DD 150 ANSI	4.00	4.75	5.50	6.00	7.50	10.00	12.69	14.88	17.00	19.50	20.81	—	—	30.75	—	—
DDD 300 ANSI	4.25	5.00	5.88	6.38	7.88	10.50	13.25	15.56	17.75	20.25	21.62	—	—	31.62	—	—
DDDD Grooved End	—	4.75	—	6.00	7.50	—	—	—	—	—	—	—	—	—	—	—
E	1.12	1.50	1.69	2.06	3.19	4.31	5.31	9.25	10.75	12.62	15.50	12.95	15.00	17.75	21.31	24.56
EE Grooved End	2.00	2.50	2.88	3.12	4.25	6.00	7.56	—	—	—	—	—	—	—	—	—
F 150 ANSI	2.50	3.00	3.50	3.75	4.50	5.50	6.75	8.00	9.50	10.50	11.75	15.00	16.50	19.25	22.50	25.60
FF 300 ANSI	3.06	3.25	3.75	4.13	5.00	6.25	7.50	8.75	10.25	11.50	12.75	15.00	16.50	19.25	24.00	25.60
G Threaded	1.88	3.25	4.00	4.50	—	—	—	—	—	—	—	—	—	—	—	—
GG 150 ANSI	4.00	3.25	4.00	4.00	5.00	6.00	8.00	8.62	13.75	14.88	15.69	—	—	22.06	—	—
GGG 300 ANSI	4.25	3.50	4.31	4.38	5.31	6.50	8.50	9.31	14.50	15.62	16.50	—	—	22.90	—	—
GGGG Grooved End	—	3.25	—	4.25	5.00	—	—	—	—	—	—	—	—	—	—	—
H NPT Body Tapping	.375	.375	.50	.50	.75	.75	1	1	1	1	1	1	1	1	2	2
J NPT Cover Center Plug	.25	.50	.50	.50	.75	.75	1	1	1.25	1.5	2	1.5	1.5	1.5	2	2
K NPT Cover Tapping	.375	.375	.50	.50	.75	.75	1	1	1	1	1	1	1	1	2	2
Stem Travel	0.4	0.6	0.7	0.8	1.1	1.7	2.3	2.8	3.4	4.0	4.5	5.1	5.63	6.75	7.5	8.5
Approx. Ship Wt. Lbs.	15	35	50	70	140	285	500	780	1165	1600	2265	2982	3900	6200	7703	11720
X Pilot System	11	13	14	15	17	29	31	33	36	40	40	43	47	68	79	85
Y Pilot System	9	9	10	11	12	20	22	24	26	29	30	32	34	39	40	45
Z Pilot System	9	9	10	11	12	20	22	24	26	29	30	32	34	39	42	47

Note: The top two flange holes on valve size 36 are threaded to 1 1/2"-6 UNC.


Model 643-01 (Uses Basic Valve Model 100-20)

Dimensions (In inches)

Pressure Ratings (Recommended Maximum Pressure - psi)

Valve Body & Cover		Pressure Class		
		Flanged		
Grade	Material	ANSI Standards*	150 Class	300 Class
ASTM A536	Ductile Iron	B16.42	250	400
ASTM A216-WCB	Cast Steel	B16.5	285	400
ASTM B62	Bronze	B16.24	225	400


Note: * ANSI standards are for flange dimensions only.
Flanged valves are available faced but not drilled.
Valves for higher pressure are available; consult factory for details



Materials

Component	Standard Material Combinations		
Body & Cover	Ductile Iron	Cast Steel	Bronze
Available Sizes	3" - 48"	3" - 16"	3" - 16"
Disc Retainer & Diaphragm Washer	Cast Iron	Cast Steel	Bronze
Trim: Disc Guide, Seat & Cover Bearing	Bronze is Standard Stainless Steel is Optional		
Disc	Buna-N® Rubber		
Diaphragm	Nylon Reinforced Buna-N® Rubber		
Stem, Nut & Spring	Stainless Steel		

For material options not listed, consult factory.
Cla-Val manufactures valves in more than 50 different alloys.



Model 643-01 Dimensions (In Inches)

Valve Size (Inches)	3	4	6	8	10	12	14	16	18	20	24	30	36	42	48
A 150 ANSI	10.25	13.88	17.75	21.38	26.00	30.00	34.25	35.00	42.12	48.00	48.00	63.25	65.00	76.00	94.50
AA 300 ANSI	11.00	14.50	18.62	22.38	27.38	31.50	35.75	36.62	43.63	49.62	49.75	63.75	67.00	76.00	94.50
B Dia.	6.62	9.12	11.50	15.75	20.00	23.62	27.47	28.00	35.44	35.44	35.44	53.19	56.00	66.00	66.00
C Max.	7.00	8.62	11.62	15.00	17.88	21.00	20.88	25.75	25.00	31.00	31.00	43.94	54.60	61.50	61.50
D 150 ANSI	—	6.94	8.88	10.69	CF*	CF*	CF*	CF*	CF*	CF*	CF*	—	—	—	—
DD 300 ANSI	—	7.25	9.38	11.19	CF*	CF*	CF*	CF*	CF*	CF*	CF*	—	—	—	—
E 150 ANSI	—	5.50	6.75	7.25	CF*	CF*	CF*	CF*	CF*	CF*	CF*	—	—	—	—
EE 300 ANSI	—	5.81	7.25	7.75	CF*	CF*	CF*	CF*	CF*	CF*	CF*	—	—	—	—
F 150 ANSI	3.75	4.50	5.50	6.75	8.00	9.50	11.00	11.75	15.88	14.56	17.00	19.88	25.50	28.00	31.50
FF 300 ANSI	4.12	5.00	6.25	7.50	8.75	10.25	11.50	12.75	15.88	16.06	19.00	22.00	27.50	28.00	31.50
H NPT Body Tapping	.375	.50	.75	.75	1	1	1	1	1	1	1	1	2	2	2
J NPT Cover Center Plug	.50	.50	.75	.75	1	1	1.25	1.25	2	2	2	2	2	2	2
K NPT Cover Tapping	.375	.50	.75	.75	1	1	1	1	1	1	1	1	2	2	2
Stem Travel	0.6	0.8	1.1	1.7	2.3	2.8	3.4	3.4	4.5	4.5	4.5	6.5	7.5	8.5	8.5
Approx. Ship Wt. Lbs.	45	85	195	330	625	900	1250	1380	1500	2551	2733	6500	8545	12450	13100
X Pilot System	13	15	27	30	33	36	36	41	40	46	55	68	79	85	86
Y Pilot System	10	11	18	20	22	24	26	26	30	30	30	39	40	45	47
Z Pilot System	10	11	18	20	22	24	26	26	30	30	30	39	42	47	49

*Consult Factory

Note: The top two flange holes on valve sizes 36 thru 48 are threaded to 1 1/2"-6 UNC.

43-01 Valve Selection	100-01 Pattern: Globe (G), Angle (A), End Connections: Threaded (T), Grooved (GR), Flanged (F) Indicate Available Sizes																
	Inches	1½	2	2½	3	4	6	8	10	12	14	16	18	20	24	30	36
	mm	40	50	65	80	100	150	200	250	300	350	400	450	500	600	750	900
Basic Valve 100-01	Pattern	G, A	G, A	G, A	G, A	G, A	G, A	G, A	G, A	G, A	G, A	G, A	G	G	G, A	G	G
	End Detail	T, F, Gr*	T, F, Gr	T, F, Gr*	T, F, Gr	F, Gr	F, Gr*	F, Gr*	F	F	F	F	F	F	F	F	F
Suggested Flow (gpm)	Maximum	125	210	300	460	800	1800	3100	4900	7000	8400	11000	14000	17000	25000	42000	50000
	Maximum Intermittent	160	260	370	580	990	2250	3900	6150	8720	10540	13700	17500	21700	31300	48000	62500
	Minimum	1	1	2	2	4	10	15	35	50	70	95	120	150	275	450	650
Suggested Flow (Liters/Sec)	Maximum	8	13	19	29	50	113	195	309	442	530	694	883	1073	1577	2650	3150
	Maximum Intermittent	10	16	23	37	62	142	246	387	549	664	863	1104	1369	1972	3028	3940
	Minimum	.03	.06	.09	0.13	0.25	0.63	0.95	2.2	3.2	4.4	6.0	7.6	9.5	17.4	28.4	41.0
100-01 Series is the full internal port Hytrol. For Lower Flows Consult Factory *Globe Grooved Only																	

643-01 Valve Selection	100-20 Pattern: Globe (G), Angle (A), End Connections: Flanged (F) Indicate Available Sizes															
	Inches	3	4	6	8	10	12	14	16	18	20	24	30	36	42	48
	mm	80	100	150	200	250	300	350	400	450	500	600	750	900	1000	1200
Basic Valve 100-20	Pattern	G	G, A	G, A	G, A	G	G	G	G	G	G	G	G	G	G	G
	End Detail	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F
Suggested Flow (gpm)	Maximum	260	580	1025	2300	4100	6400	9230	9230	16500	16500	16500	28000	33500	33500	33500
	Minimum	1	2	4	10	15	35	50	50	95	95	95	275	450	450	450
Suggested Flow (Liters/Sec)	Maximum	16	37	65	145	258	403	581	581	1040	1040	1040	1764	2115	2115	2115
	Minimum	.06	.13	.25	.63	.95	2.2	3.2	3.2	6.0	6.0	6.0	17.4	28.4	41.0	41.0
100-20 Series is the reduced internal port size version of the 100-01 Series.																
For Lower Flows Consult Factory																

Pilot System Specifications

Adjustment Range

Low flow equals one-fourth maximum flow.

Temperature Range

Water: to 180°F

Electrical Ratings

24, 48, 120, 240, 480 - 60 Hz AC
6, 12, 24, 120, 240 DC

Materials

Standard Pilot System Materials

Pilot Control: Bronze ASTM B62

Trim: Stainless Steel 303

Orifice Plate: Stainless Steel 303

Rubber: Buna-N® Synthetic Rubber

Optional Pilot System Materials

Pilot systems are available with optional Aluminum, Stainless Steel or Monel materials.

Note: Orifice plate assembly (X52E) may be attached to the main valve outlet flange, however, better control is obtained if it is located one to five pipe diameters downstream. Orifice plate sensing connection should be located in the pipeline on the side of the orifice plate assembly. The orifice plate assembly should not be mounted directly to a butterfly valve. See E-X52E Data Sheet for Orifice Bore adjustment range.

When Ordering, Please Specify

1. Catalog No. 43-01 or No. 643-01
2. Valve Size
3. Pattern - Globe or Angle
4. Pressure Class
5. Threaded or Flanged
6. Trim Material
7. Adjustment Range/Orifice Bore
8. Energized or De-Energized to Open
9. Desired Options
10. When Vertically Installed

A-7 Pipeline Sizing Justification

Title: Tunkhannock Creek Pipe Size Calculation
 Project Name: Atlantic Sunrise
 Client: Transcontinental Gas Pipe Line Company LLC

Prepare By: DTK
 Checked By: LMH

Date: 12/9/2015
 Date: 12/15/2015

Design Flow Rate **1,800** gpm
 Length¹ **246** ft
 Elevation at Start¹ **727** ft MSL
 Elevation at Pump **729** ft MSL
 Elevation at End¹ **729** ft MSL
 Backpressure at Discharge **46** psig (NOTE: to account for minor losses; throttle discharge valve as required)
 Hazen-Williams Coefficient **140**
 Suction Pipe Length **105** ft

¹ design basis to transfer water to pipeline, additional equipment to be used by hydrotest contractor.

Estimate Pipe Size based on velocity

Maintain Velocity at **15.0** ft/sec or less (temporary piping)
 needed area 0.27 sf or a dia. = 7.0 inches I.D.

Pressure Drop Calculations

Use: Hazen-Williams Eq.:

$$h_f = \frac{0.2083 * \left(\frac{100}{C}\right)^{1.85} * Q^{1.85} * L}{100 * D^{4.8655}}$$

Flow rate, gpm	(gpm)	1,800	1,800	1,800
Pipe Size	(inch)	8	10	10
Outer Diameter	(inch)	8.625	10.75	10.75
DR rating	-	13.5	13.5	13.5
Diameter (D)*	(inch)	7.27	9.06	9.06
Length (L)	(feet)	246	246	105
Friction Head Loss (dH)	(feet)	18.6	6.4	3.7
Total Head loss	(feet)	125.25	113.02	24.6
	(psi)	54	49	

24.6 NPSHa > NPSHr = **13.0** ft

* - includes 6% safety factor on wall thickness

Horsepower Required


Determine Theoretical Hp req'd: HP	57	51
Pump Efficiency (est)	80%	80%
Motor Efficiency (est)	85%	85%
Motor Horsepower (est) HP	84	76

Design Considerations for Hydrotest

CPL Max Elevation: **1366.49** ft MSL
 Max Static Head: 637 ft

LOOKUP TABLE: DIAMETER	
2	2.375
3	3.5
4	4.5
6	6.625
8	8.625
10	10.75
12	12.75
14	14
16	16
18	18
20	20
22	22
24	24

DR	MAWP
7.3	317
9	250
11	200
13.5	160
17	125
21	100
26	80
32.5	63



A-8 Withdrawal Calculation

Withdrawal Location: Tunkhannock Creek

Watershed Information	
Watershed:	Upper Susquehanna-Tunkhannock
Designation:	TSF
Trout Sensitive Stream?	No
USGS Station:	01534000
Station Drainage Area ⁽¹⁾ (mi ²):	383.0
Station Average Daily Flow ⁽¹⁾ (cfs):	544.4
Station Q ₇₋₁₀ Flow Rate ⁽¹⁾ (cfs):	17.3
Operator Withdrawal Rate ⁽²⁾ (cfs)	4.01
Operator 30-day Average Withdrawal Rate ⁽⁷⁾ (cfs)	0.079

Method:

Follow Susquehanna River Basin Commission (SRBC) Policy No. 2012-01.

Footnotes:

⁽¹⁾ From USGS StreamStats Data-Collection Station Rprt for Station Tunkhannock Crk @ Tunkhannock, PA

⁽²⁾ Typical maximum withdrawal rate by operator is 42.9 bpm = 1,800 gpm = 2.6 MGD = 4.01 cfs.

⁽³⁾ From USGS StreamStats Ungaged Report

⁽⁴⁾ Area-weighted flow rate.

⁽⁵⁾ From SRBC Policy No. 2012-01 Attachment E

⁽⁶⁾ Total required flow rate is the sum of the weighted P_x flow rate and the required operator withdrawal rate. The minimum passby flow must be equal to or greater than the monthly P95 flow rate.

⁽⁷⁾ Total Withdrawal Rate averaged over 30 days = 1,530,400 gallons/30 days = 0.051 MGD = 0.079 cfs

Step #1: Determine ARC Classification

Withdrawal Location	Latitude / Longitude	Drainage Area ⁽³⁾ (mi ²)	ARC Classification
Tunkhannock Creek	41.626897 -75.760386	186	3

Step #2: Determine Q₇₋₁₀ Flow Rate and Total Flow Requirement and Monthly Percent Exceedance

Withdrawal Location	Drainage Area ⁽³⁾ (mi ²)	Q ₇₋₁₀ flow ⁽⁴⁾ (cfs)	Monthly Percent Exceedance (P _x)	30-day Average Withdrawal Rate as a Percentage of Q ₇₋₁₀	Maximum Withdrawal Rate as a percentage of Q ₇₋₁₀
Tunkhannock Creek	186	8.40	80	0.94%	47.7%

Step #3: Determine the Months of the Year When the Total Required Flow Will Be Available

Month	Station Mean Flow Rate ⁽¹⁾ (cfs)	Weighted Mean Flow Rate ⁽⁴⁾ (cfs)	Station P _x Flow Rate ⁽⁵⁾ (cfs)	Weighted P _x Flow Rate ⁽⁴⁾ (cfs)	Total Required Flow Rate ⁽⁶⁾ (cfs)	Is There Sufficient Flow To Allow For Withdrawal?
January	594	288.5	150	72.8	76.9	Yes
February	646	313.7	177	86.0	90.0	Yes
March	1170	568.2	384	186.5	190.5	Yes
April	1100	534.2	416.5	202.3	206.3	Yes
May	632	306.9	219	106.4	110.4	Yes
June	364	176.8	93	45.2	49.2	Yes
July	218	105.9	53	25.7	29.7	Yes
August	183	88.9	38	18.5	22.5	Yes
September	242	117.5	37	18.0	22.0	Yes
October	348	169.0	52	25.3	29.3	Yes
November	545	264.7	104	50.5	54.5	Yes
December	656	318.6	180	87.4	91.4	Yes

CONCLUSION

There is sufficient flow in Tunkhannock Creek to allow a varying withdrawal rate of 1.78 cfs to 4.01 cfs and maintain a monthly passby flow based on a percent exceedance of 80. A rule-of-thumb (Weighted Mean Flow Rate > 2 × Total Required Flow Rate) was used to determine the months when flow rates may be too low for withdrawal. SRBC methodology was used to determine allowable withdrawal rates (See attached Withdrawal Worksheet).

Month	Station P80 Flow Rate (cfs)	Weighted P80 Flow Rate (cfs)	10% P80 (cfs)	10% P80 (gpm)	Weighted P80 Flow Rate Divided by 9 (cfs)	Weighted P80 Flow Rate Divided by 9 (gpm)	Transco Proposed Withdrawal Rate (gpm)	Required Flow Rate at USGS Gage (cfs)
January	150	72.8	7.3	3269.3	8.1	3632.6	1800	158
February	177	86.0	8.6	3857.8	9.6	4286.5	1800	185
March	384	186.5	18.6	8369.5	20.7	9299.4	1800	392
April	416.5	202.3	20.2	9077.8	22.5	10086.5	1800	425
May	219	106.4	10.6	4773.2	11.8	5303.6	1800	227
June	93	45.2	4.5	2027.0	5.0	2252.2	1800	101
July	53	25.7	2.6	1155.2	2.9	1283.5	1200	59
August	38	18.5	1.8	828.2	2.1	920.3	800	42
September	37	18.0	1.8	806.4	2.0	896.0	800	41
October	52	25.3	2.5	1133.4	2.8	1259.3	1200	58
November	104	50.5	5.1	2266.7	5.6	2518.6	1800	112
December	180	87.4	8.7	3923.2	9.7	4359.1	1800	188

Month	Station P95 Flow Rate (cfs)	Weighted P95 Flow Rate (cfs)	De Minimus Flow Rate at 5% of Weighted P95 Flow Rate (cfs)	De Minimus Flow Rate at 5% of Weighted P95 Flow Rate (gpm)
January	90	43.7	2.19	980.8
February	98	47.6	2.38	1068.0
March	200	97.1	4.86	2179.6
April	252	122.4	6.12	2746.2
May	131	63.6	3.18	1427.6
June	55	26.7	1.34	599.4
July	30	14.6	0.73	326.9
August	22	10.7	0.53	239.8
September	21	10.2	0.51	228.9
October	27	13.1	0.66	294.2
November	45.5	22.1	1.10	495.8
December	76	36.9	1.85	828.2

A-9 Flow Meter Specification




APPLICATIONS

- Irrigation
- Chemigation
- Agricultural automation
- Well usage monitoring
- Dairy Lagoons

FEATURES


- Simple as a mechanical meter
- No moving parts
- Minimal straight pipe required
- Battery power standard; External power optional
- Solar compatible
- Built-in rate & total indicator
- Built-in pulse output for data-logging or telemetry
- Tamper-evident seal



AG2000-600



AG2000-300



Unobstructed Flow

Seametrics' series of standard and IP68 (submersible) flanged magmeters.

Available in sizes from 3" up to 12".

GENERAL INFORMATION

The AG2000 is a spool-type electromagnetic flowmeter for use in irrigation applications in 3" to 12" pipe. With no moving parts, these meters provide unobstructed flow and are resistant to wear from debris found in ground or surface water. Little maintenance is required because there are no bearings to wear out or propellers to stop turning. Minimal straight pipe requirements allow AG2000 meters to be used in piping configurations where there is little space between the meter and an elbow.

The standard AG2000 is battery powered. Where an external power source is available, the AG2000 can be optionally converted to 8-32 Vdc, with the batteries then serving as back-up to maintain continuous operation in case of power failure. This configuration will prolong battery life indefinitely.


An IP68 version (-168 option) is available for burial or applications where the meter may be under water up to a depth of 3 meters for prolonged periods of time.

The meter comes with built-in pulse output (requires optional cable) for data logging or telemetry. Several pulse rates are available. An internal data logger is also available for secure flow logging (-127 option). A Seametrics FT415W or FT420W display can be added if remote rate/total reading is desired, or an AO55W if a (4-20 mA) analog signal is required. (High-frequency pulse rate is required for use with most Seametrics controllers.)



The AG2000 is secured with a seal wire to protect against unauthorized access. The seal can be broken by an authorized agent, to change units of measure, replace the battery pack, or to field-install an optional power/output cable. The cable can be factory or field-installed where external power is available and/or pulse output is needed. An accessory weather guard is available for additional protection in outdoor applications.

For chemigation applications, the chemical injection point must be placed downstream of the meter **OR** far enough upstream for **complete mixing** to occur before the flow reaches the meter. (See tech bulletin on Seametrics' website, www.seametrics.com).

FEATURES



FEATURES Continued





AG2000 Irrigation Magmeter



SPECIFICATIONS*

Pipe Sizes		3", 4" 6" 8", 10", 12"					
Fittings		ANSI 150 lb. drilling					
Pressure		150 psi (10.3 bar) working pressure					
Temperature	Operating	10° to 130° F (-12° to 54° C)					
	Non-Operating	-40° to 158° F (-40° to 70° C)					
Accuracy		+/- 1% of reading for flow between 10% to 100% of max flow					
		+/- 2% of reading for flow from cutoff to 10% of max flow					
Materials	Body (3" Only)	Ductile cast iron, powder coated w/NSF61 listed epoxy powder					
	Body (4"-12")	Welded steel, epoxy-coated					
	Liner (3" Only)	Noryl®					
	Liner (4"-12")	Santoprene/Polypropylene					
	Electronics Housing	Diecast aluminum, powder-coated (non-IP68)			Ductile Cast Iron (IP68)		
	Electrodes	316 stainless steel					
	O-ring (3" Only)	EPDM					
Display		Rate			Total		
	Digits	5			8		
	Units	Gallon/Minute, Liter/Minute, Cubic Feet/Minute, Cubic Meter/Hour, Gallons/Sec, Liter/Second Cubic Feet/ Sec, Miner's Inch, Cubic Meter/Min			Gallon, Gallon x 1000, Liter, Liter x 1000, Mega Liter, Cubic Meters, Cubic Meter x 1000, Acre Feet, Cubic Feet, Cubic Feet x 1000, Million Gallon, Miner's Inch Day, Acre Inch		
Power		1 battery pack that contains 2 Lithium 3.6V "D" batteries, replaceable. Standard battery life 2.5 years 5 years with extended battery life (EBL) option With external power option (uses 8-32 Vdc, 30 mA), Lithium batteries serve as backup in power failure (10 year life)					
Pulse Output (with optional cable)							
		Signal		Current sinking pulse, opto-isolated, 30 Vdc at 10 mA max			
		Pulse Rates		High Frequency; 10 units/pulse; 100 units/pulse; 1000 units/pulse			
		High Frequency (pulse/gal)	3"	4"	6"	8"	10"
25.228	16.362		6.307	3.344	2.15	1.530	
Conductivity		>20 microSiemens/cm					
Empty Pipe Detection		Hardware/software, conductivity-based					
Environmental		NEMA 4X Standard (IP68 Option)					


*Specifications subject to change. Please consult our website for the most current data (www.seametrics.com).

**Extended battery life option is standard on all IP68 meters.

OUTPUT CAPABILITIES




DIMENSIONS





AG2000 (Standard Housing)

Standard AG2000 Meter Size	L		H		T		ID		Shipping Weight Standard	
	inch	mm	inch	mm	inch	mm	inch	mm	pounds	Kg
4"	10.24	260	7.0	178	.62	20.9	3.12	79.25	32	15
6"	12.27	312	8.1	206	.69	23.3	5.05	128.27	47	21
8"	14.24	362	9.1	231	.69	23.3	6.44	163.58	69	31
10"	18.18	462	10.1	257	.69	23.3	8.61	218.69	125	57
12"	19.68	500	11.1	282	.81	20.6	10.55	267.97	145	66
Flanges									Standard ANSI 150 lb. drilling	
									Cable (AG2000) 1 lb.	


DIMENSIONS



AG2000-300 Shown (3")
IP68 housing standard for 3" model



**AG2000 Shown
(4" - 12" IP68 Housing)**




AG2000 with IP68 Housing (-168 option)


IP68 AG2000 Meter Size	L		H		T		ID		Shipping Weight IP68 Version	
	inch	mm	inch	mm	inch	mm	inch	mm	pounds	Kg
3"	12.0	305	6.80	173	.68	17.3	2.60	66.04	41	19
4"	10.24	260	8.12	206	.62	20.9	3.12	79.25	35	16
6"	12.27	312	9.22	234	.69	23.3	5.05	128.27	50	23
8"	14.24	362	10.22	260	.69	23.3	6.44	163.58	72	33
10"	18.18	462	11.22	285	.69	23.3	8.61	218.69	128	58
12"	19.68	500	12.28	312	.81	20.6	10.55	267.97	148	67
Flanges		Standard ANSI 150 lb. drilling							Cable (AG2000) 1 lb.	

STRAIGHT PIPE RECOMMENDATIONS

(X = pipe diameter)



(X = pipe diameter)



FLOW RANGE (3" - 12")

Meter Size	3"		4"		6"		8"		10"		12"	
	Gal/Min	Liter/Sec	Gal/Min	Liter/Sec	Gal/Min	Liter/Sec	Gal/Min	Liter/Sec	Gal/Min	Liter/Sec	Gal/Min	Liter/Sec
Minimum	7.5	.47	12	.75	32	2	60	3.8	95	6	130	8.2
Maximum	700	44.2	1,000	63	2,400	151.4	4,400	277.6	7,000	441.6	10,000	630.9

HOW TO ORDER

MODEL	SIZE	OPTIONS	PULSE RATE (With Option -11)	UNITS
AG2000	3" = -300* 4" = -400 6" = -600 8" = -800 10" = -1000 12" = -1200	Factory Installed Power/ Output Cable: 6m (20 ft) = -11/6 15m (50 ft) = -11/15 30m (100 ft) = -11/30 Factory Installed IP68 Power/Output Cable: 6m (20 ft) = -11/6S 15m (50 ft) = -11/15S 30m (100 ft) = -11/30S Internal Data Logger = -127 Serial Output = -131 IP68 Submersible = -168 Extend. Battery Life ¹ = -178	10 Units*/Pulse = -PxX 100 Units*/Pulse = -PxH 1000 Units*/Pulse = -PxK High Frequency** = -HF	Gal/Min = GPM Liter/Min = LPM Cu Ft/Min = CFM Cu Meter/Hr = CMH Gal/Sec = GPS Liters/Sec = LPS Cu Ft/Sec = CFS Miner's In** = MI Cu Met/Min = CMM Gal = G Gal x 1000 = GT Liter = L Liter x 1000 = LT Mega Liters = ML Cubic Meters = CM Cu Met x 1000 = CMT Acre Feet = AF Cubic Feet = CF Cu Feet x 1000 = CFT Million Gal = MG Miner's Inch Day = MID Acre Inch = AI
	*-300 available in IP68 only	¹ Extended battery life is standard on all IP68 meters	*Units = Gal or Liter depending on Rate/Total unit selection **High Frequency pulse rate will shorten battery life	Consult factory for additional units Any rate selection can be combined with any total selection ** 1 Miner's Inch = 1.2 CFM

ACCESSORIES

Remote 4-20 mA (analog) signal = **AO55W**

Remote Rate and Total Indicator (Battery) = **FT415W***

Remote Rate and Total Indicator (Powered) = **FT420W***

Remote Data Logger = **DL76W**

Dual Power Supply, 115 Vac, 12/24 Vdc = **PC42**
(Use with High Frequency pulse rate)

Replacement Battery Pack = 100889

Weather Guard = **100961**

Post-Factory 20-ft. Power/Output Cable
(Standard Housing Only) = **DC30**

Post-Factory 50-ft. Power/Output Cable
(Standard Housing Only) = **DC35**

Post-Factory 20-ft. Power/Output Cable
(IP68 Housing Only) = **DC30S**

Post-Factory 50-ft. Power/Output Cable
(IP68 Housing Only) = **DC35S**

Grounding Rings
(not needed for most applications):

3" = **102157**

4" = **100876**

6" = **100877**

8" = **100878**


10" = **100879**



12" = **103288**

*Consult customer service to determine the appropriate indicator based on the distance it will be installed from the meter.


CONTACT YOUR SUPPLIER

A-10 Plans, Details, and Maps






**PUMP & FLOW METER
DETAIL A**
NOT TO SCALE



**SHALLOW WATER INTAKE
DETAIL B**
NOT TO SCALE

LEGEND

- LIMIT OF DISTURBANCE
- 1320--- EXISTING 10' CONTOUR
- EXISTING 2' CONTOUR
- EXISTING ROAD
- EXISTING TREE LINE
- EXISTING BUILDING
- EXISTING STREAM WITH FLOW DIRECTION
- FEMA FLOODWAY
- FEMA FLOODPLAIN
- ⋈ VALVE



NOTES:

SURVEY DATUM:
HORIZONTAL: PA STATE PLANE NAD83
VERTICAL: NAVD88




661 ANDERSEN DRIVE - FOSTER PLAZA 7
PITTSBURGH, PA 15220
T: (412) 921-7090 | F: (412) 921-4040

TRANSCONTINENTAL GAS PIPE LINE COMPANY LLC
TUNKHANNOCK CREEK, NICHOLSON TWP, WYOMING CO.


SITE PLAN

DATE: 08/12/16
PROJECT NO.: 212C-PB-00282
DESIGNED BY: RD
DRAWN BY: NN
CHECKED BY: CR
SHEET: 1 OF 2

COPYRIGHT TETRA TECH INC.
FIGURE 2



INTAKE PROFILE
DETAIL C
NOT TO SCALE



CROSS-SECTION A-A'



NOTES:

SURVEY DATUM:
HORIZONTAL: PA STATE PLANE NAD83
VERTICAL: NAVD88



TETRA TECH

WWW.TETRATECH.COM

661 ANDERSEN DRIVE – FOSTER PLAZA 7
PITTSBURGH, PA 15220
T: (412) 921-7090 | F: (412) 921-4040

TRANSCONTINENTAL GAS PIPE LINE COMPANY LLC
TUNKHANNOCK CREEK, NICHOLSON TWP, WYOMING CO.

CROSS-SECTION OF INTAKE SYSTEM

DATE: 12/1/15
PROJECT NO.: 212C-PB-00282
DESIGNED BY: RD
DRAWN BY: NN
CHECKED BY: CR
SHEET: 2 OF 2

COPYRIGHT TETRA TECH INC.

FIGURE 3

A-11 Field Photographs



Tunkhannock Creek



Tunkhannock Creek