

From: [Rossi, Nicholas](#)
To: [William Brett](#); [Haight, Shannon](#); [Binckley, Sarah](#)
Cc: [Albert, Rebecca](#); [Jim Pillsbury](#); [Chelsea Gross](#); [Christie Sebek](#)
Subject: Conemaugh River Crossing Project, DEP Application No. ESG836520001-00
Date: Thursday, January 14, 2021 8:12:00 AM

Mr. Brett,

The Department of Environmental Protection (DEP) has reviewed the above-referenced application/NOI and has identified the following technical deficiencies. The Pennsylvania Erosion and Sediment Pollution Control Program Manual and the Pennsylvania Stormwater Best Management Practices Manual include information that will aid you in responding to some of the deficiencies listed below. The deficiencies are based on applicable laws and regulations, and the guidance sets forth the DEP's established means of satisfying the applicable regulatory and statutory requirements.

PCSM Report/Plan

1. The Construction Sequence in Section 8.0 BMP Installation Sequence Narrative and Drawing PCSM-2 do not match and neither includes the permeable soil. Please revise so that the sequences match and are consistent with the infiltration trench plan details. §102.8(f)(9)
2. Please clarify the source and composition of the permeable soil, expressed in percentages of coarse sand, topsoil, and organic material. §102.8(f)(9)

Please submit 1 paper copy of the revised PCSM plans to the District at their previously provided mail address and an electronic copy of the revised materials to the DEP.

Please have this information to the DEP on or before **March 14, 2021**.

You may request a time extension, in writing, before **Tuesday, March 14, 2021**, to respond to the deficiencies. Requests for time extension will be reviewed by DEP and considered. You will be notified in writing of the decision either to grant or deny, including the specific due date to respond if the extension is granted. Time extensions shall be in accordance with 25 Pa. Code § 102.6(c).

Thank you,

Nicholas Rossi | Project Manager
Department of Environmental Protection | Regional Permit Coordination Office
Rachel Carson State Office Building
400 Market St., Harrisburg PA 17101
Phone: 717-772-5667
nicrossi@pa.gov
www.dep.pa.gov/RPCO