

HanoverEngineering

48 North Market Street • Elizabethtown, PA 17022-2025
Phone: 717.367.0144 • Fax: 717.361.1012 • HanoverEng.com

September 15, 2016

Mr. Scott Galbraith, Acting Manager
South Londonderry Township
20 West Market Street
PO Box 3
Campbelltown, PA 17010-0003

RE: Sunoco Pennsylvania Pipeline
Stormwater Management Plan
Hanover Project SL16-19

Dear Scott:

On June 24, 2016, we received the following items regarding the above-referenced project:

1. Erosion and Sediment Control Plan, dated March, 2016 (45 sheets)
2. Site Restoration and Post-Construction Stormwater Management Plan, dated March, 2016

All of the above materials are as prepared by Tetra Tech, Inc. The submitted plan proposes the construction of 20-inch and 16-inch pipeline through the southern portion of the Township. We would note that the submitted materials included the entire pipeline route through all of Lebanon County. Our review focused on only those portions that pass through South Londonderry Township. We would note that no permanent stormwater BMP's or impervious areas are proposed within South Londonderry Township in conjunction with this project.

We have reviewed this Plan and supporting documentation for conformance with the current Township Stormwater Management regulations. We offer the following comments for Township review:

STORMWATER MANAGEMENT ORDINANCE

Section 315.A.1 and .2 – Proof of all necessary approvals and permits from Lebanon County Conservation District and D.E.P. shall be provided to the Township.

Section 316 – A Riparian Corridor Easement shall be created and recorded at all proposed stream crossings. This section also requires protection of existing native vegetation, removal of invasive vegetation and plantings of native plant materials. Since the applicant does not own the land where the easements would be created, perhaps the Township could accept, in lieu of this easement, additional plantings of suitable native plant materials proposed in the applicable riparian stream areas. These plantings shall be noted on the plans.

Section 601 - An estimate for the erosion control improvements shall be prepared and forwarded to our office for review. Upon approval, performance security shall be provided to the Township prior to the start of construction.

Mr. Scott Galbraith
Acting Township Manager

2


September 15, 2016

The above items shall be provided to the Township prior to start of construction.

If you have any questions, please contact the undersigned.

Respectfully,

HANOVER ENGINEERING ASSOCIATES, INC.

A handwritten signature in black ink, appearing to read 'BKocher', written over the typed name.

Brian R. Kocher, PE
Township Engineer

RJW;bk/jle

S:\Projects\Municipal\S LondonderryTwp\SH16-19-SunocoPipeline\Docs\SWM review letter 09-15-16.doc

Cc: Mr. Pat Armstrong, Biehn and Thatcher
Ms. Megan Carson, Tetra Tech