

NICHOLS & SLAGLE ENGINEERING, INC.

PROFESSIONAL ENGINEERS

333 Rouser Road, Airport Office Park, Building 4, Suite 600, Moon Township, PA 15108-2773 - 412-269-9440 - Fax 412-269-0533

November 18, 2016

Mrs. Jodi Noble, Manager
Chartiers Township
2 Buccaneer Drive
Houston, PA 15342

Subject: Houston Injection Station Site Plan
Stormwater Management & Floodplain Plan Review
Resubmitted: November 11, 2016
NSE No. P046-164(h)

Dear Ms. Noble:


Pursuant to your request, we have reviewed the Houston Injection Station Stormwater Management Plan and H&H Report as prepared by Tetra Tech. In accordance with Township Ordinance and our review letter dated May 19, 2016, the Applicant has redesigned the proposed Houston Injection Station so that all petroleum products are located at least 1.5 feet above the 100-year floodplain. Our remaining comments are as follows:

Stormwater Management Review:

1. Provide PaDEP/WCCD approval of the proposed E&S Control Plan and Stormwater Management Plan for Oil and Gas activities.

Please note that our review has been limited to the Stormwater Management and Floodplain Management Ordinances of the Township. In addition, our review is based on information prepared by others under the assumption that this information is accurate and complete. Should you have any questions regarding this matter, please do not hesitate to contact us.

Very truly yours,



Daniel B. Slagle, P.E.
Principal Engineer

DBS/RDH

cc: Sam Stockton, CDC
Jim Liekar, Esq.
Tetra Tech
Sunoco Pipeline, L.P.