

PROPOSED RULEMAKING - PFAS Monitoring Frequency Summary

Initial	Routine Criteria	Routine Frequency	Reduced Criteria	Reduced Frequency	Waiver Criteria	Waiver Frequency
4 consecutive quarters	n/a	n/a	All ND	Triennial	n/a	n/a
	Any result \geq MRL, but \leq 80% MCL	A, Previously Detected (all)	n/a	n/a	3 yrs ND	Triennial
	Any result > 80% MCL	Quarterly (all)	All results R&C < MCL	A, Previously Detected (all)	3 yrs ND	Triennial

Notes:

- 80% of the MCL value is the reliably & consistently criteria specified in § 109.1.
- There are additional waiver criteria specified in § 109.301(16)(vii)
- Triennial sampling for EPs with a waiver must occur during the quarter with the highest previous detection