

From: [Merritt McGlynn](#)
To: [Piktel, Joseph](#)
Cc: [Bailey, Brian \(P.E.\)](#)
Subject: RE: [External] RE: KDI Wyalusing Power LLC Plan Approval 08-00060A Technical Deficiency Letter 04-23-2025
Date: Monday, June 9, 2025 10:02:01 AM
Attachments: [image001.png](#)
[Klondike Emissions Inventory \(05-23-2025\).xlsx](#)

Hi Joe,

Please see attached for the KDI Wyalusing Data Center's proposed "monthly" emissions basis.

Utilizing the examples provided, we calculated potential monthly emissions, front-loading the Month 1 potential emissions to accommodate engine commissioning and startup events. Month 1 is 50% of the annual emissions, Months 2-12 increase in smaller increments to Month 12 which equals the potential annual emissions total.

Please confirm that this is acceptable and let me know if you have any additional questions. Thanks!



Merritt McGlynn / Senior Managing Consultant

610.422.1133 / [Profile](#) / [LinkedIn](#)

[www.all4inc.com](#) / [Locations](#) / [Articles](#) / [Podcast](#) / [Training](#)

[ALL4](#) // STRATEGY WITH SOLUTION. PARTNERSHIP WITH A PURPOSE.

From: Piktel, Joseph <jpiktel@pa.gov>
Sent: Thursday, May 8, 2025 3:01 PM
To: Merritt McGlynn <mmcglynn@all4inc.com>
Cc: Bailey, Brian (P.E.) <bribailey@pa.gov>
Subject: RE: [External] RE: KDI Wyalusing Power LLC Plan Approval 08-00060A Technical Deficiency Letter 04-23-2025

Merritt,

Muhammad would like to have a conference call with you regarding the proposed project next week on Wednesday or Thursday (5/14 or 5/15) if your team is available either of those days. Please let me know if those days work. It will be primarily to discuss CEMS monitoring the turbines for NOX and CO. It would be preferable to have the call in the afternoon if that works on your end.

Thanks,

Joseph Piktel | Project Manager
Department of Environmental Protection | Air Quality
North Central Regional Office
208 West Third Street Suite 101 | Williamsport PA 17701
Phone: 570.321.6559 | Fax: 570.327.3420
[www.dep.pa.gov](#)

From: Merritt McGlynn <mmcglynn@all4inc.com>

Sent: Tuesday, May 6, 2025 10:05 AM

To: Bailey, Brian (P.E.) <bribailey@pa.gov>; Piktel, Joseph <jpiktel@pa.gov>; Zaman, Muhammad <mzaman@pa.gov>; Hackenberg, Martha <mahackenbe@pa.gov>

Cc: Lily Hassan <lhassan@newfortressenergy.com>; Debra Raggio <draggio@newfortressenergy.com>; John Slade <jslade@all4inc.com>; Colleen Nagel <cnagel@all4inc.com>

Subject: [External] RE: KDI Wyalusing Power LLC Plan Approval 08-00060A Technical Deficiency Letter 04-23-2025

ATTENTION: *This email message is from an external sender. Do not open links or attachments from unknown senders. To report suspicious email, use the [Report Phishing button in Outlook](#).*

Good morning,

Following up from our discussion last week regarding your April 23 letter requesting additional information for the pending Plan Approval, please see attached for a letter response and a revised spreadsheet.

To address the Department's concerns regarding potential emissions and major source applicability, and to establish practically enforceable limits, the Facility is proposing the following:

- Short-term maximum emissions rates presented in Table E-3 in lb/hr and lb/MMBtu based on the maximum potential emissions rate across all operating scenarios provided by the equipment vendor.
- Annual emissions rate presented in Table E-5, based on GE Case Number 5, with the combustion turbines operating at maximum load at an average temperature of 59 degrees F.
- Annual emissions are based on a proposed annual equivalent fuel usage of 18,560 million standard cubic feet of natural gas, for all eight proposed CTs combined, on a rolling 12-consecutive month period.
- For each CT: the facility will install both NOx and CO CEMS, as well as individual fuel flow meters to monitor emissions and fuel use, respectively.
- Compliance with short-term emissions rates will be demonstrated by initial stack testing and NOx and CO CEMS data.
- Ongoing compliance with annual emissions rates will be based on fuel consumption and emissions rates established during the initial stack testing, and NOx and CO CEMS data.
- The facility will calculate actual emissions and fuel consumption to document minor source status.

Please review the attached materials and let us know if you have any questions or if you would like to set up a meeting to discuss. We appreciate your attention to this project and look forward to hearing from you soon.

Thank you,
Merritt



Merritt McGlynn / Senior Managing Consultant

610.422.1133 / [Profile](#) / [LinkedIn](#)

www.all4inc.com / [Locations](#) / [Articles](#) / [Podcast](#) / [Training](#)

ALL4 // STRATEGY WITH SOLUTION. PARTNERSHIP WITH A PURPOSE.

From: "Bailey, Brian (P.E.)" <bribailey@pa.gov>

Date: April 23, 2025 at 3:35:26 PM EDT

To: Debra Raggio <draggio@newfortressenergy.com>

Cc: "Piktel, Joseph" <jpiktel@pa.gov>, "Zaman, Muhammad" <mzaman@pa.gov>, "Hackenberg, Martha" <mahackenbe@pa.gov>

Subject: KDI Wyalusing Power LLC Plan Approval 08-00060A Technical Deficiency Letter 04-23-2025

Ms. Raggio,

Please see the attached technical deficiency letter regarding KDI Wyalusing Power LLC.

Sincerely,

Brian K. Bailey, P.E. | Environmental Engineer Manager
Department of Environmental Protection | Air Quality
North Central Regional Office
208 West Third Street Suite 101 | Williamsport PA 17701
Phone: 570.974.2604 | Fax: 570.327.3420
www.dep.pa.gov

Table E-5B - Monthly Emissions Basis
Combustion Turbine Annual Potential Emissions ^{(a)/(b)}
KDI Wyalusing Power LLC - Wyalusing, PA

Pollutant	PTE											
	Month 1	Month 2	Month 3	Month 4	Month 5	Month 6	Month 7	Month 8	Month 9	Month 10	Month 11	Month 12
NO _x	37.12	43.30	46.40	49.49	52.58	55.68	58.77	61.86	64.96	68.05	71.14	74.24
CO	46.59	54.36	58.24	62.12	66.00	69.89	73.77	77.65	81.53	85.42	89.30	93.18
VOC	20.11	23.46	25.14	26.81	28.49	30.16	31.84	33.52	35.19	36.87	38.54	40.22
PM	45.82	53.45	57.27	61.09	64.91	68.73	72.54	76.36	80.18	84.00	87.82	91.63
PM ₁₀ /PM _{2.5}	45.82	53.45	57.27	61.09	64.91	68.73	72.54	76.36	80.18	84.00	87.82	91.63

Pollutant	PTE
	(tpy)
NO _x	74.24
CO	93.18
VOC	40.22
PM	91.63
PM ₁₀ /PM _{2.5}	91.63
CO ₂ e	1,113,658.66
SO ₂	13.26
H ₂ SO ₄	2.03

^(a) Annual potential emissions for the CTs are based on the following assumptions:

- short-term emissions factors for each pollutant in "lb/MMBtu" obtained from CT reliability data supplied by KDI and GE in file "TM2500 at Wyalusing 12112024.xlsx."
- operating profiles for each proposed turbine, resulting in a facility-wide annual heat input limit of 19,021,256 MMBtu/yr
- 365 startup events per year

^(b) For annual emissions totals, KDI selected emissions rates corresponding to the average ambient conditions of 59 degrees Fahrenheit (°F) and maximum operating load. This operating case establishes an annual potential-to-emit (PTE) that considers the variability of operations and ambient conditions throughout the year. Operating conditions of 59°F at 99.5% load were assumed to be representative of average annual climate conditions based on average temperature data for Binghamton, NY, which is 46°F, obtained from the Cornell Northeast Regional Climate Center: <https://www.nrcc.cornell.edu/wxstation/comparative/comparative.html#>.

Number of CTs Operating Simultaneously	Operating Time (hr/yr)	Equivalent Heat Input (MMBtu/yr)	Equivalent Fuel Usage (MMSCF/yr)
6	6,000	2,061,180	2,011
7	2,710	930,966	908
8	50	17,177	17
Cumulative Total	55,370	19,021,256	18,560

Table E-1 Performance/Emissions Specifications for Single-Cycle Combustion Turbine ^(a) KDI Wyalusing Power LLC - Wyalusing, PA																									
Specifications																									
Case Number	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
Case Description	-10°F, 100% Load	0°F, 100% Load	10°F, 98.4% Load	32°F, 93.7% Load	59°F, 99.5% Load	70°F, 100% Load	92°F, 100% Load	105°F, 100% Load	-10°F, 75% Load	0°F, 75% Load	10°F, 75% Load	32°F, 75% Load	59°F, 75% Load	70°F, 75% Load	92°F, 75% Load	105°F, 75% Load	-10°F, 50% Load	0°F, 50% Load	10°F, 50% Load	32°F, 50% Load	59°F, 50% Load	70°F, 50% Load	92°F, 50% Load	105°F, 50% Load	
Site Conditions																									
Ambient Temperature	°F	-10	0	10	32	59	70	92	105	-10	0	10	32	59	70	92	-10	0	10	32	59	70	92	105	
Ambient Relative Humidity	%	90%	70%	65%	60%	60%	50%	45%	35%	90%	70%	65%	60%	60%	50%	45%	35%	90%	70%	65%	60%	60%	50%	45%	35%
Plant Status																									
Gas Turbine Load	%	100.00	100.00	98.40	93.70	99.50	100.00	100.00	100.00	75.00	75.00	75.00	75.00	75.00	75.00	75.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00	
Gas Turbines Operating	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
Fuel Data (Natural Gas)																									
Combustion Turbine Heat Consumption	MMBtu/hr, HHV	328.60	330.80	329.30	322.30	312.30	294.60	254.00	232.10	257.10	258.60	261.10	266.50	248.30	235.60	206.00	189.90	192.90	194.00	195.70	199.40	187.40	179.10	159.30	148.40
Pre-Control Exhaust Gas																									
Ar	%Vol	0.87	0.87	0.87	0.86	0.86	0.86	0.85	0.85	0.88	0.88	0.87	0.87	0.87	0.87	0.86	0.86	0.89	0.89	0.89	0.88	0.88	0.87	0.87	
CO ₂	%Vol	3.17	3.21	3.24	3.28	3.35	3.30	3.20	3.14	2.79	2.82	2.87	2.98	3.02	3.00	2.95	2.91	2.47	2.50	2.54	2.65	2.70	2.70	2.67	2.66
H ₂ O	%Vol	9.85	10.03	10.22	10.65	11.49	11.43	11.78	11.84	8.25	8.40	8.66	9.32	10.01	10.14	10.74	10.89	6.99	7.13	7.35	7.95	8.70	8.89	9.64	9.88
N ₂	%Vol	72.82	72.70	72.58	72.28	71.68	71.68	71.33	71.24	73.77	73.68	73.52	73.09	72.58	72.46	71.95	71.81	74.51	74.42	74.28	73.90	73.36	73.20	72.60	72.40
O ₂	%Vol	13.28	13.17	13.08	12.91	12.62	12.72	12.83	12.92	14.29	14.21	14.06	13.72	13.52	13.52	13.50	13.52	15.12	15.04	14.92	14.61	14.37	14.32	14.21	14.19
Molecular Weight	lb/lbmol	28.16	28.14	28.12	28.07	28.00	27.99	27.95	27.93	28.29	28.28	28.26	28.19	28.13	28.11	28.04	28.02	28.40	28.39	28.37	28.32	28.25	28.22	28.13	28.11
Temperature	°F	816.80	829.80	845.40	877.00	921.90	926.60	948.60	963.20	749.10	761.60	781.50	827.80	874.60	890.80	923.00	942.90	713.30	725.50	744.90	790.30	842.80	863.10	903.00	927.80
Mass Flow	lb/hr	758,880.00	754,920.00	743,760.00	715,680.00	679,680.00	651,600.00	578,880.00	538,560.00	672,840.00	669,240.00	663,120.00	649,440.00	597,240.00	569,160.00	506,520.00	471,960.00	560,520.00	557,280.00	551,880.00	539,640.00	496,800.00	474,120.00	424,800.00	397,440.00
Standard Volume Flow	Standard ft ³ /min (SCFM)	173,109.81	172,321.55	169,864.68	163,727.56	155,929.44	149,491.72	133,035.27	123,822.30	152,734.42	151,974.16	150,712.29	147,948.68	136,371.43	130,047.60	116,012.32	108,187.05	126,748.62	126,071.01	124,939.17	122,397.71	112,964.26	107,908.82	96,977.17	90,807.35
Dry Standard Volume Flow	DSCFM	156,058.50	155,037.70	152,504.51	146,290.58	138,013.15	132,404.81	117,363.71	109,161.74	140,133.83	139,208.33	137,660.61	134,159.86	122,720.65	116,860.78	103,552.60	96,405.48	117,888.89	117,082.15	115,756.14	112,667.09	103,136.37	98,315.72	87,628.57	81,835.59
Dry Standard Volume Flow	DSCFM @ 15% O ₂	201,553.52	203,125.67	202,133.09	198,112.15	193,686.25	183,571.42	160,529.69	147,645.88	156,997.39	157,848.09	159,592.97	163,265.73	153,504.82	146,175.01	129,879.53	120,588.55	115,491.15	116,288.37	117,325.72	120,114.57	114,149.23	109,647.03	99,361.88	93,070.64
Pre-Control Exhaust Gas Emissions																									
NO _x	ppmvd @ 15% O ₂	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00
NO _x	lb/hr	29.21	29.46	29.29	28.63	27.81	26.27	22.64	20.68	22.64	22.75	23.00	23.49	21.88	20.76	18.15	16.75	16.61	16.72	16.85	17.19	16.15	15.46	13.76	12.80
CO	ppmvd @ 15% O ₂	100.10	96.60	91.30	82.70	60.60	49.60	29.90	25.10	101.30	97.20	90.60	72.30	50.90	44.90	32.50	31.10	158.40	155.20	145.90	113.20	85.90	82.20	74.10	80.90
CO	lb/hr	71.21	69.30	65.14	57.67	41.05	31.73	16.48	12.64	55.86	53.86	50.75	41.35	27.12	22.70	14.36	12.69	64.07	63.18	59.86	47.39	33.78	30.95	24.82	25.21
VOC	ppmvd @ 15% O ₂ as CH ₄	12.00	11.60	11.00	9.90	7.30	5.50	2.50	2.00	12.20	11.70	10.90	8.70	5.70	4.80	2.90	2.70	19.00	18.60	17.50	13.60	10.30	9.90	8.90	9.70
VOC	ppmvd @ 15% O ₂ as C ₃ H ₈	4.00	3.87	3.67	3.30	2.43	1.83	0.83	0.67	4.07	3.90	3.63	2.90	1.90	1.60	0.97	0.90	6.33	6.20	5.83	4.53	3.43	3.30	2.97	3.23
VOC	lb/hr as methane	4.89	4.77	4.49	3.95	2.83	2.02	0.79	0.58	3.85	3.71	3.50	2.85	1.74	1.39	0.73	0.63	4.40	4.34	4.11	3.26	2.32	2.13	1.71	1.73
VOC	lb/hr as propane	4.48	4.37	4.12	3.62	2.60	1.85	0.72	0.53	3.53	3.40	3.21	2.61	1.59	1.27	0.67	0.58	4.04	3.98	3.77	2.99	2.13	1.96	1.57	1.59
Catalyst Inlet Exhaust Gas																									
Tempering Air Flow	Actual ft ³ /min (ACFM)	4,750.00	4,750.00	4,750.00	11,750.00	22,000.00	22,750.00	26,250.00	28,500.00	4,750.00	4,750.00	4,750.00	4,750.00	9,750.00	12,750.00	18,000.00	21,000.00	4,750.00	4,750.00	4,750.00	4,750.00	4,750.00	6,250.00	12,000.00	15,250.00
Tempering Air Flow	lb/hr	24,529.44	23,991.31	23,473.16	55,384.33	97,905.64	98,852.58	108,498.37	114,120.53	24,529.44	23,991.31	23,473.16	22,389.41	43,390.00	55,400.89	74,398.88	84,088.81	24,529.44	23,991.31	23,473.16	22,389.41	21,138.72	27,157.30	49,599.26	61,064.50
Ar	%Vol	0.87	0.87	0.87	0.86	0.87	0.87	0.86	0.85	0.88	0.88	0.88	0.87	0.87	0.87	0.86	0.86	0.89	0.89	0.89	0.88	0.88	0.87	0.87	
CO ₂	%Vol	3.07	3.11	3.14	3.05	2.94	2.88	2.71	2.60	2.70	2.73	2.78	2.88	2.82	2.74	2.58	2.48	2.37	2.40	2.44	2.55	2.59	2.56	2.40	2.31
H ₂ O	%Vol	9.55	9.73	9.92	9.95	10.28	10.27	10.71	11.01	7.97	8.12	8.38	9.04	9.46	9.47	10.00	10.32	6.71	6.85	7.06	7.66	8.42	8.55	9.15	9.51
N ₂	%Vol	72.98	72.86	72.74	72.65	72.31	72.26	71.79	71.47	73.92	73.83	73.67	73.24	72.86	72.78	72.24	71.92	74.65	74.56	74.43	74.04	73.50	73.36	72.77	72.42
O ₂	%Vol	13.51	13.40	13.31	13.46	13.60	13.71	13.93	14.06	14.52	14.44	14.29	13.95	13.99	14.12	14.31	14.41	15.36	15.28	15.16	14.85	14.62	14.65	14.80	14.89
Molecular Weight at Inlet	lb/lbmol	28.18	28.16	28.15	28.13	28.09	28.08	28.02	27.98	28.32	28.30	28.28	28.22	28.17	28.16	28.09	28.04	28.42	28.41	28.39	28.34	28.27	28.24	28.16	28.12
Temperature at Inlet	°F	793.75	807.10	822.76	822.60	823.58	823.99	824.11	823.45	724.81	737.67	757.64	803.98	824.58	824.46	824.78	824.38	685.43	698.04	717.50	762.70	813.68	823.78	824.33	824.96
Mass Flow at Inlet	lb/hr	783,409.44	778,911.31	767,233.16	771,064.33	777,585.64	750,452.58	687,378.37	652,680.53	697,369.44	693,231.31	686,593.16	671,829.41	640,630.00	624,560.89	580,918.88	556,048.81	585,049.44	581,271.31	575,353.16	562,029.41	517,938.72	501,277.30	474,399.26	458,504.50
Standard Volume Flow at Inlet	Standard ft ³ /min (SCFM)	178,552.10	177,645.53	175,075.38	176,040.84	177,784.80	171,623.13	157,553.97	149,830.30	158,176.71	157,298.13	155,922.99	152,926.39	146,057.33	142,450.93	132,825.15	127,350.84	132,190.91	131,394.99	130,149.87	127,375.42	117,683.03	113,988.88	108,185.72	104,723.92
Dry Standard Volume Flow at Inlet	DSCFM	161,496.67	160,354.79	157,703.95	158,527.71	159,499.85	153,993.06	140,684.28	133,331.25	145,572.00	144,525.41	142,860.05	139,106.79	132,243.16	128,959.68	119,543.83	114,214.59	123,327.06	122,399.23	120,955.58	117,614.01	107,775.53	104,246.55	98,289.39	94,768.39
Dry Standard Volume Flow at Inlet	DSCFM @ 15% O ₂	202,192.42	203,778.20	202,800.92	199,820.39	197,336.85	187,537.95	166,100.94	154,652.26	157,451.08	158,312.88	160,083.53	163,837.99	154,899.72	148,150.09	133,459.15	125,539.80	115,816.73	116,625.77	117,684.94	120,551.75	114,724.28	110,499.19	101,586.97	96,514.32

Table E-1
Performance/Emissions Specifications for Single-Cycle Combustion Turbine ^(a)
KDI Wyalusing Power LLC - Wyalusing, PA

		Specifications																							
Case Number		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Case Description		-10°F, 100% Load	0°F, 100% Load	10°F, 98.4% Load	32°F, 93.7% Load	59°F, 99.5% Load	70°F, 100% Load	92°F, 100% Load	105°F, 100% Load	-10°F, 75% Load	0°F, 75% Load	10°F, 75% Load	32°F, 75% Load	59°F, 75% Load	70°F, 75% Load	92°F, 75% Load	105°F, 75% Load	-10°F, 50% Load	0°F, 50% Load	10°F, 50% Load	32°F, 50% Load	59°F, 50% Load	70°F, 50% Load	92°F, 50% Load	105°F, 50% Load
		Post-Control Exit Exhaust Gas Emissions																							
NO _x	ppmvd @ 15% O ₂	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50
NO _x	lb/hr	2.82	2.85	2.83	2.64	2.40	2.26	1.89	1.69	2.18	2.19	2.22	2.26	2.03	1.88	1.57	1.41	1.59	1.60	1.61	1.65	1.54	1.46	1.23	1.10
NO _x	lb/MMBtu	8.59E-03	8.61E-03	8.60E-03	8.19E-03	7.70E-03	7.66E-03	7.42E-03	7.28E-03	8.47E-03	8.47E-03	8.49E-03	8.50E-03	8.17E-03	7.98E-03	7.62E-03	7.44E-03	8.23E-03	8.24E-03	8.23E-03	8.25E-03	8.24E-03	8.14E-03	7.69E-03	7.44E-03
CO	ppmvd @ 15% O ₂	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00
CO	lb/hr	3.44	3.47	3.45	3.22	2.93	2.75	2.30	2.06	2.65	2.67	2.70	2.76	2.47	2.29	1.91	1.72	1.93	1.95	1.96	2.00	1.88	1.77	1.49	1.34
CO	lb/MMBtu	0.010	0.010	0.010	9.98E-03	9.37E-03	9.32E-03	9.04E-03	8.87E-03	0.010	0.010	0.010	0.010	9.95E-03	9.71E-03	9.28E-03	9.05E-03	0.010	0.010	0.010	0.010	0.010	9.91E-03	9.36E-03	9.05E-03
VOC	ppmvd @ 15% O ₂ as CH ₄	5.70	5.40	4.90	4.10	2.80	2.80	1.20	1.00	6.60	6.20	5.70	4.40	2.80	2.30	1.40	1.30	10.30	10.00	9.30	7.00	4.90	4.60	4.10	4.50
VOC	ppmvd @ 15% O ₂ as C ₂ H ₆	1.90	1.80	1.63	1.37	1.23	0.93	0.40	0.33	2.20	2.07	1.90	1.47	0.93	0.77	0.47	0.43	3.43	3.33	3.10	2.33	1.63	1.53	1.37	1.50
VOC	lb/hr as methane	2.32	2.22	2.00	1.64	1.43	1.02	0.38	0.29	2.08	1.97	1.83	1.44	0.85	0.67	0.35	0.30	2.39	2.33	2.18	1.68	1.10	0.99	0.79	0.80
VOC	lb/hr as propane	2.13	2.03	1.83	1.50	1.31	0.94	0.35	0.26	1.91	1.80	1.68	1.32	0.78	0.61	0.32	0.28	2.19	2.14	2.00	1.54	1.01	0.91	0.72	0.74
VOC	lb/MMBtu as propane	6.48E-03	6.15E-03	5.57E-03	4.65E-03	4.21E-03	3.19E-03	1.37E-03	1.14E-03	7.43E-03	6.97E-03	6.42E-03	4.96E-03	3.15E-03	2.59E-03	1.57E-03	1.46E-03	0.01	0.01	0.01	7.71E-03	5.40E-03	5.07E-03	4.52E-03	4.95E-03
NH ₃ Slip	ppmvd @ 15% O ₂	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00
NH ₃ Slip	lb/hr	2.16	2.18	2.17	2.12	2.06	1.94	1.67	1.53	1.68	1.68	1.70	1.74	1.62	1.54	1.34	1.24	1.23	1.24	1.25	1.27	1.20	1.14	1.02	0.95
CO ₂	lb/hr	38,438.34	38,695.69	38,520.22	37,701.39	36,531.63	34,461.15	29,711.92	27,150.15	30,074.55	30,250.01	30,542.45	31,174.12	29,045.16	27,559.56	24,097.07	22,213.76	22,564.69	22,693.36	22,892.22	23,325.03	21,921.32	20,950.42	18,634.29	17,359.25
CO ₂	lb/MMBtu	116.98	116.98	116.98	116.98	116.98	116.98	116.98	116.98	116.98	116.98	116.98	116.98	116.98	116.98	116.98	116.98	116.98	116.98	116.98	116.98	116.98	116.98	116.98	116.98
SO _x	lb/hr as SO ₂	0.46	0.46	0.46	0.45	0.44	0.41	0.35	0.32	0.36	0.36	0.37	0.35	0.33	0.29	0.26	0.27	0.27	0.27	0.27	0.28	0.26	0.25	0.22	0.21
SO ₂ ^(c)	lb/MMBtu	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03
PM ₁₀ /PM _{2.5}	lb/hr	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00
PM ₁₀ /PM _{2.5}	lb/MMBtu	9.13E-03	9.07E-03	9.11E-03	9.31E-03	9.61E-03	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.013	0.015	0.016	0.016	0.015	0.015	0.015	0.016	0.017	0.019	0.020
PM filterable	lb/hr	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00
PM filterable	lb/MMBtu	9.13E-03	9.07E-03	9.11E-03	9.31E-03	9.61E-03	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
Sulfuric Acid Mist ^(d)	lb/hr	0.07	0.07	0.07	0.07	0.07	0.06	0.05	0.05	0.05	0.06	0.06	0.06	0.05	0.05	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.03	0.03
Sulfuric Acid Mist ^(d)	lb/MMBtu	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04	2.13E-04
Formaldehyde ^(e)	lb/hr	0.09	0.09	0.09	0.09	0.08	0.08	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.06	0.06	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.04	0.04
Formaldehyde ^(e)	lb/MMBtu	2.62E-04	2.62E-04	2.62E-04	2.64E-04	2.69E-04	2.71E-04	2.78E-04	2.84E-04	2.61E-04	2.60E-04	2.61E-04	2.62E-04	2.65E-04	2.68E-04	2.76E-04	2.81E-04	2.55E-04	2.56E-04	2.56E-04	2.57E-04	2.60E-04	2.63E-04	2.71E-04	2.77E-04
CO ₂ ^(b)	lb/MWh gross	1,239.93	1,242.76	1,249.14	1,265.23	1,281.68	1,294.89	1,350.94	1,395.10	1,293.51	1,295.35	1,299.16	1,307.61	1,351.65	1,380.75	1,460.86	1,521.92	1,455.77	1,457.65	1,460.63	1,467.56	1,530.20	1,574.44	1,694.52	1,783.99
CH ₄ ^(b)	lb/hr	0.72	0.73	0.73	0.71	0.69	0.65	0.56	0.51	0.57	0.58	0.59	0.55	0.52	0.45	0.43	0.43	0.43	0.43	0.44	0.44	0.41	0.39	0.35	0.33
N ₂ O ^(b)	lb/hr	0.07	0.07	0.07	0.07	0.07	0.06	0.06	0.05	0.06	0.06	0.06	0.06	0.05	0.05	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.03
GHG/CO ₂ ^(b)	lb/hr	38,477.82	38,735.43	38,559.79	37,740.11	36,569.15	34,496.55	29,742.44	27,178.03	30,105.44	30,281.08	30,573.82	31,206.14	29,074.99	27,587.87	24,121.82	22,236.57	22,587.86	22,716.67	22,915.73	23,348.99	21,943.83	20,971.93	18,653.43	17,377.08
GHG/CO ₂ ^(b)	lb/MMBtu	117.10	117.10	117.10	117.10	117.10	117.10	117.10	117.10	117.10	117.10	117.10	117.10	117.10	117.10	117.10	117.10	117.10	117.10	117.10	117.10	117.10	117.10	117.10	117.10
		Heat and Mass Balance Summary																							
Plant Gross Output	kW	31,000.50	31,137.00	30,837.30	29,798.10	28,502.90	26,613.20	21,993.50	19,461.10	23,250.40	23,352.70	23,509.30	23,840.60	21,488.70	19,959.90	16,495.10	14,595.90	15,500.20	15,568.50	15,672.80	15,893.70	14,325.80	13,306.60	10,996.80	9,730.60
Generator Output, Gross	MW	31.00	31.14	30.84	29.80	28.50	26.61	21.99	19.46	23.25	23.35	23.51	23.84	21.49	19.96	16.50	14.60	15.50	15.57	15.67	15.89	14.33	13.31	11.00	9.73

^(a) As supplied by Sisu Energy & Environmental in file "C24-127 TM2500 SAC Emissions Design REV2 non-calc.xlsx" provided 12/19/2024.

^(b) CO₂ and CO₂e emissions factors obtained from 40 CFR Part 98, Subpart C, Tables C-1 and C-2. Global warming potentials obtained from Part 98, Subpart A, Table A-1.

BTU/MW	10.60	10.62	10.68	10.82	10.96	11.07	11.55	11.93	11.06	11.07	11.11	11.18	11.55	11.80	12.49	13.01	12.45	12.46	12.49	12.55	13.08	13.46	14.49	15.25
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

40 CFR Part 98, Subpart A, Table A-1	
Pollutant	Global Warming Potential
CO ₂	1
CH ₄	28
N ₂ O	265

40 CFR Part 98, Subpart C, Tables C-1 and C-2				
Pollutant	Value	Unit	Fuel	Reference
CO ₂	53.06	kg/MMBtu	NG	40 CFR Part 98, Subpart C, Table C-1
CH ₄	1.00E-03	kg/MMBtu	NG	40 CFR Part 98, Subpart C, Table C-2
N ₂ O	1.00E-04	kg/MMBtu	NG	40 CFR Part 98, Subpart C, Table C-2

^(c) Sulfur emissions factors calculated based on natural gas specifications as provided in Roberts Corrosion Services Natural Gas Analysis Report (attached) dated 01/08/2024.

^(d) H₂SO₄ emissions factors conservatively calculated based on 10% molar conversion of SO₂ to SO₃ and 100% conversion of SO₃ to H₂SO₄.

^(e) Although the facility is not a major source HAP, formaldehyde emissions conservatively calculated based on 40 CFR Part 63, Subpart Yyyy using 91 parts per billion emissions standard.

Table E-2
Natural Gas Specifications
KDI Wyalusing Power LLC - Wyalusing, PA

Natural Gas Fuel Parameter	Value	Units
High Heating Value @ 60°F ^(a)	1,025	Btu/SCF
Sulfur Content ^(a)	0.003	ppm
Sulfur Content ^(b)	0.5	grains/100 scf
SO ₂ emissions factor from gas combustion	0.0014	lb/MMBtu

^(a) Natural gas specifications as provided in Roberts Corrosion Services Natural Gas Analysis Report (attached) dated 01/08/2024.

^(b) As defined in 40 CFR §72.2 for "pipeline quality natural gas".

Table E-3
Maximum Hourly Heat Input and Post-Control Emissions During Steady-State Operations
KDI Wyalusing Power LLC - Wyalusing, PA

Gross Maximum Electrical Capacity ^(a)	31.1	MW total	
Maximum CT Heat Input (Natural Gas) ^(a)	330.80	MMBtu/hr	
Maximum Short Term Emissions Rates Per CT ^(b)			
Pollutant	Post-Control Emissions Rate		
	(ppmvd @ 15% O ₂)	(lb/hr)	(lb/MMBtu) ^(c)
NO _x	2.5	2.85	8.61E-03
CO	5.0	3.47	0.01
VOC as propane	3.4	2.19	0.01
NH ₃ Slip	5.0	2.18	6.59E-03
CO ₂ e	--	38,735.43	117.10
SO ₂	--	0.46	1.39E-03
PM	--	3.00	0.02
PM ₁₀ and PM _{2.5}	--	3.00	0.02
Formaldehyde	--	0.09	2.62E-04
H ₂ SO ₄	--	0.07	2.13E-04

^(a) For compliance purposes, KDI has provided a worst-case short-term emissions rate, per CT, based on the maximum emissions rate across all operating loads and ambient conditions.

^(b) No emissions of fluoride (F), hydrogen sulfide (H₂S), total reduced sulfur (TRS), or lead (Pb) are expected to occur.

^(c) Lb/MMBtu emissions rates based on higher heating value (HHV) fuel basis.

Table E-4
Combustion Turbine Startup Emissions
KDI Wyalusing Power LLC - Wyalusing, PA

CT Startup Emissions Rates Per CT									
Event	Maximum Duration	NO _x	CO	VOC as Propane	PM/PM ₁₀ /PM _{2.5}	NO _x	CO	VOC as Propane	PM/PM ₁₀ /PM _{2.5}
	(min)	(lb/hr)				(lb/event)			
Startup Phase 1 ^(a)	10	16.20	97.20	3.30	3.00	2.70	16.20	0.55	0.50
Startup Phase 2 ^(b)	20	8.88	17.87	1.57	3.00	2.96	5.96	0.52	1.00
Total Startup	30	25.08	115.07	4.87	6.00	5.66	22.16	1.07	1.50

^(a) Startup Phase 1 includes the duration of time from the turbine being turned on, to achieving NO_x emissions of 25 parts per million (ppm) with water injection.

^(b) Startup Phase 2 includes the duration of time after Phase 1 for the turbine's flow to reach the temperature required for the optimum control guaranteed by the selective catalytic reduction and oxidation catalyst control technology. It is assumed that the average control efficiency during Phase 2 of NO_x, CO, and VOC is equal to half of the following guaranteed reductions during steady state operation at 59 °F and 50% load:

Pollutant	Phase 2 Control Efficiency
NO _x	45%
CO	47%
VOC	26%

Table E-6
Fire Water Pump Engine Emissions ^(a)
KDI Wyalusing Power LLC - Wyalusing, PA

Pollutant	Emissions Factor	Emissions Factor Units	Emissions Factor Source	PTE	
				(lb/hr)	(tpy)
NO _x	2.85	g/bhp-hr	40 CFR Part 60, Subpart IIII Table 4 ^(c)	0.79	0.20
CO	3.70	g/bhp-hr	40 CFR Part 60, Subpart IIII Table 4	1.02	0.25
VOC	0.15	g/bhp-hr	40 CFR Part 60, Subpart IIII Table 4 ^(c)	0.04	0.01
PM	0.22	g/bhp-hr	40 CFR Part 60, Subpart IIII Table 4 ^(d)	0.06	0.02
PM ₁₀ /PM _{2.5}	0.24	g/bhp-hr	(d)	0.07	0.02
SO ₂	5.50E-03	g/bhp-hr	AP-42 Table 3.4-1 ^(e)	1.52E-03	3.79E-04
H ₂ SO ₄	8.43E-04	g/bhp-hr	(f)	2.32E-04	5.81E-05
CO ₂	73.96	kg/MMBtu	(g)	142.67	35.67
CH ₄	3.00E-03	kg/MMBtu	(g)	5.79E-03	1.45E-03
N ₂ O	6.00E-04	kg/MMBtu	(g)	1.16E-03	2.89E-04
CO ₂ e	-	-	(g)	143.14	35.79
Pb	9.00E-06	lb/MMBtu	AP-42 Table 1.3-10	7.88E-06	1.97E-06

^(a) Pump engine PTE calculated using the following parameters:

Parameter	Value
Fuel	Ultra Low Sulfur Diesel
Number of units	1
BHP	125
Conversion (Btu/hp-hr)	7,000
MMBtu/hr ^(b)	0.88
Diesel sulfur content, wt. %	0.0015
Max. hrs/yr	500

^(b) Calculated from pump engine horsepower and Btu/hp-hr conversion factor found in AP-42 Chapter 3.3.

^(c) Published emissions factor is for NO_x+NMHC. Assumed that NO_x emissions are 95% of this factor and VOC emissions are 5% based on "CARB Emission Factor for CI Diesel Engines - Percent HC in Relation to NMHC + NO_x" policy.

^(d) It is assumed that PM₁₀ = PM_{2.5}. PM₁₀ and PM_{2.5} emissions factors account for both the filterable and condensable portions of PM. The filterable portion of PM₁₀ and PM_{2.5} is based on 40 CFR Part 60, Subpart IIII Table 4. The condensable portion of PM₁₀ and PM_{2.5} was obtained from AP-42 Chapter 3.4 Table 3.4-2 (10/96).

^(e) AP-42 Chapter 3.4 (Large Stationary Diesel and ALL Stationary Dual-fuel Engines) utilized in lieu of AP-42 Chapter 3.3 (Gasoline and Diesel Industrial Engines) since AP-42 Chapter 3.3 SO₂ emissions factor utilizes higher sulfur content than proposed for the Fire Water Pump Engine.

^(f) H₂SO₄ emissions factor conservatively based on 10% conversion of SO₂ to SO₃ and 100% conversion of SO₃ to H₂SO₄.

^(g) The CO₂ emissions factor is obtained from Table C-1 to 40 CFR Part 98, Subpart C, while CH₄ and N₂O emissions factors are obtained using Table C-2 to 40 CFR Part 98, Subpart C. CO₂e is carbon dioxide equivalent, calculated according to 40 CFR Part 98 Equation A-1:

$$CO_2e = \sum_{i=1}^n GHG_i \times GWP_i$$

GHG_i = Mass emissions of each greenhouse gas

GWP_i = Global warming potential for each

n = Number of greenhouse gases emitted.

Pollutant	GWP (100 year)
CO ₂	1
CH ₄	28
N ₂ O	265

Table E-7
HAP Potential Emissions
KDI Wyalusing Power LLC - Wyalusing, PA

Emissions Unit Description		Combustion Turbines ^(a)	Fire Water Pump
Cumulative Operating Time, hr/yr		55,370	500
Fuel Type		Natural Gas	ULSD
Heat Input, Max. MMBtu/hr each unit		312.30	0.88

Emissions Factor Reference (unless otherwise noted)		Emissions Factors for Natural Gas-Fired Turbines	Emissions Factors for Small Diesel Engines	Annual Emissions		
		AP-42 Ch 3.1 Table 3.1-3	AP-42 Ch. 3.3 Table 3.3-2	CTs	Fire Water Pump Engine	Combined Annual Emissions
HAP	CAS Number	(lb/MMBtu)	(lb/MMBtu)	(tpy)		
1,3-Butadiene	106-99-0	4.30E-07	3.91E-05	3.72E-03	8.55E-06	3.73E-03
Acenaphthene	83-32-9	-	1.42E-06	-	3.11E-07	3.11E-07
Acenaphthylene	208-96-8	-	5.06E-06	-	1.11E-06	1.11E-06
Acetaldehyde	75-07-0	4.00E-05	7.67E-04	0.35	1.68E-04	0.35
Anthracene	120-12-7	-	1.87E-06	-	4.09E-07	4.09E-07
Acrolein	107-02-8	6.40E-06	9.25E-05	0.06	2.02E-05	0.06
Benz(a)anthracene	56-55-3	-	1.68E-06	-	3.68E-07	3.68E-07
Benzene	71-43-2	1.20E-05	9.33E-04	0.10	2.04E-04	0.10
Benzo(a)pyrene	50-32-8	-	1.88E-07	-	4.11E-08	4.11E-08
Benzo(b)fluoranthene	205-99-2	-	9.91E-08	-	2.17E-08	2.17E-08
Benzo(g,h,i)perylene	191-24-2	-	4.89E-07	-	1.07E-07	1.07E-07
Benzo(k)fluoranthene	207-08-9	-	1.55E-07	-	3.39E-08	3.39E-08
Chrysene	218-01-9	-	3.53E-07	-	7.72E-08	7.72E-08
Dibenz(a,h)anthracene	53-70-3	-	5.83E-07	-	1.28E-07	1.28E-07
Ethylbenzene	100-41-4	3.20E-05	-	0.28	-	0.28
Fluoranthene	206-44-0	-	7.61E-06	-	1.66E-06	1.66E-06
Fluorene	86-73-7	-	2.92E-05	-	6.39E-06	6.39E-06
Formaldehyde ^(b)	50-00-0	2.69E-04	1.18E-03	2.32	2.58E-04	2.32
Indeno(1,2,3-cd)pyrene	193-39-5	-	3.75E-07	-	8.20E-08	8.20E-08
Lead ^(c)	7439-92-1	-	9.00E-06	-	1.97E-06	1.97E-06
Naphthalene	91-20-3	1.30E-06	8.48E-05	0.01	1.86E-05	0.01
Phenanthrene	85-01-8	-	2.94E-05	-	6.43E-06	6.43E-06
Polycyclic Aromatic Hydrocarbons	Various	2.20E-06	-	0.02	-	0.02
Propylene Oxide	75-56-9	2.90E-05	-	0.25	-	0.25
Pyrene	129-00-0	-	4.78E-06	-	1.05E-06	1.05E-06
Toluene	108-88-3	1.30E-04	4.09E-04	1.12	8.95E-05	1.12
Xylenes	1330-20-7	6.40E-05	2.85E-04	0.55	6.23E-05	0.55

Maximum Individual HAP (tpy)				2.32
Total HAP (tpy)				5.07
				8.49E-04
				5.07

^(a) Annual potential emissions for the CTs assume representative average annual operating conditions of 99.5% load at 59 °F.

^(b) Combustion turbine formaldehyde emissions factor based on a maximum exhaust concentration of 91 parts per billion (ppb) as listed in Table 1 to 40 CFR Part 63, Subpart YYYY.

^(c) Pump engine lead emissions factor from AP-42 Chapter 1.3 Table 1.3-10.

Table E-5 - Revised
Combustion Turbine Annual Potential Emissions ^{(a)(b)}
KDI Wyalusing Power LLC - Wyalusing, PA

Pollutant	PTE
	(tpy)
NO _x	74.24
CO	93.18
VOC	40.22
PM	91.63
PM ₁₀ /PM _{2.5}	91.63
CO ₂ e	1,113,658.66
SO ₂	13.26
H ₂ SO ₄	2.03

^(a) Annual potential emissions for the CTs are based on the following assumptions:

- short-term emissions factors for each pollutant in "lb/MMBtu" obtained from CT reliability data supplied by KDI and GE in file "TM2500 at Wyalusing 12112024.xlsx."
- operating profiles for each proposed turbine, resulting in a facility-wide annual heat input limit of 19,021,256 MMBtu/yr
- 365 startup events per year

^(b) For annual emissions totals, KDI selected emissions rates corresponding to the average ambient conditions of 59 degrees Fahrenheit (°F) and maximum operating load. This operating case establishes an annual potential-to-emit (PTE) that considers the variability of operations and ambient conditions throughout the year. Operating conditions of 59°F at 99.5% load were assumed to be representative of average annual climate conditions based on average temperature data for Binghamton, NY, which is 46°F, obtained from the Cornell Northeast Regional Climate Center:
<https://www.nrcc.cornell.edu/wxstation/comparative/comparative.html#>.

Number of CTs Operating Simultaneously	Operating Time (hr/yr)	Equivalent Heat Input (MMBtu/yr)	Equivalent Fuel Usage (MMSCF/yr)
6	6,000	2,061,180	2,011
7	2,710	930,966	908
8	50	17,177	17
Cumulative Total	55,370	19,021,256	18,560

Conversion Factors:

2000 lb/ton

365 startup events/yr

1.1 Contingency Factor

Table E-8
Emissions Summary and Major Source Threshold Applicability Table
KDI Wyalusing Power LLC - Wyalusing, PA

Source	PM	PM ₁₀	PM _{2.5}	CO	VOC ^(a)	NO _x ^(a)	SO ₂	Pb	Individual HAP ^(b)	Total HAP	CO ₂ e ^(c)
	(tpy)										
Combustion Turbines	91.63	91.63	91.63	93.18	40.22	74.24	13.26	-	2.32	5.07	1,113,658.66
Fire Water Pump Engine	0.02	0.02	0.02	0.25	0.01	0.20	3.79E-04	1.97E-06	2.58E-04	8.49E-04	35.79
Total Project Emissions	91.65	91.65	91.65	93.44	40.23	74.43	13.26	1.97E-06	2.32	5.07	1,113,694.44
PSD/NNSR Major Source Threshold	250	250	250	250	50	100	250	250	N/A	N/A	N/A
PSD/NNSR Major Source?	No	No	No	No	No	No	No	No	N/A	N/A	N/A
Title V Major Source Threshold	100	100	100	100	50	100	100	100	10	25	N/A
Title V Major Source?	No	No	No	No	No	No	No	No	No	No	N/A

^(a) Major Source Threshold for the ozone transport region (OTR) pursuant to 25 Pa. Code §127.201(c).

^(b) The individual HAP with the highest total project emissions is formaldehyde.

^(c) Per the June 23, 2014 Supreme Court decision in Utility Air Regulatory Group v. U.S. EPA, U.S. EPA may not treat GHGs as an air pollutant for the specific purpose of determining whether a source is required to obtain a PSD or Title V Operating Permit.