

Report Parameters:

Client Id - 298406  
 Client AKA - All  
 ICS Organization - All  
 Program Code - All  
 Related Clients Indicator - Y  
 Enforcement Type - All  
 Pending Indicator - All  
 Date Referred - All  
 Progress Date - All  
 Date Receipt - All  
 Date Final - All  
 Date Executed - 03/06/2023 To 03/06/2026

Current Client

Client Id: 298406 Client Name: HOMER CITY GENERATION LP

ICS Organization: 4600 EP NW Rgnl Off Meadvil Program: AQ Air Quality  
 Program Specific Id: 80-0833693-1

Enf Id: 413998 Tracking #: Enf Type: Consent Assessment of Ci  
 Date Executed: 03/07/2023 Date Receipt: Date Referred:  
 Date Progress: Date Final: 03/08/2023 Final Status: Comply/Closed

Appeal Ind:N Pen Amt: \$889.00 Enf Comment: CEMS 1Q22 CACP

Violation Type	Violation Type Description	Violation Date	Date Resolved	Inspection Id	Entity AKA/Other Id
139.103	Sampling and Testing, Requirements for Source Monitoring for Stationary Sources, Opacity monitoring requirements. Failure to meet the data availability requirements for opacity.	06/02/2022	03/07/2023	3372061	80-0833693-1

ICS Organization: 4600 EP NW Rgnl Off Meadvil Program: STSTA Storage Tanks  
 Program Specific Id: 32-24007

Enf Id: 423294 Tracking #: Enf Type: Notice of Violation  
 Date Executed: 12/22/2023 Date Receipt: Date Referred:  
 Date Progress: Date Final: 04/18/2024 Final Status: Comply/Closed

Appeal Ind:N Pen Amt: Enf Comment:

<u>Violation Type</u>	<u>Violation Type Description</u>	<u>Violation Date</u>	<u>Date Resolved</u>	<u>Inspection Id</u>	<u>Entity AKA/Other Id</u>
245.612(D)	Failure to meet aboveground storage tank secondary and/or emergency containment requirements	09/14/2023	04/18/2024	3627468	32-24007

Summary Section:

Client Id: 298406 Client Name: HOMER CITY GENERATION LP

<u>Enforcement Type</u>	<u># of Enforcements</u>
Consent Assessment of Civil Penalty	1
Notice of Violation	1
<b>Total # of Enforcements:</b>	<b>2</b>