

ANALYTICAL REPORT

Eurofins Lancaster Laboratories Env, LLC
2425 New Holland Pike
Lancaster, PA 17601
Tel: (717)656-2300

Laboratory Job ID: 410-32304-1
Client Project/Site: Newberry System
Sampling Event: Newberry System

For:
SUEZ Water Environmental Services Inc
6310 Allentown Blvd
Suite 104
Harrisburg, Pennsylvania 17112

Attn: Penny Bumbarger



Authorized for release by:
3/24/2021 8:17:35 AM

Elizabeth Zanar, Project Manager
(717)556-7290
Elizabeth.Zanar@eurofinset.com

LINKS

Review your project
results through
TotalAccess

Have a Question?



Visit us at:

www.eurofinsus.com/Env

The test results in this report meet all 2003 NELAC, 2009 TNI, and 2016 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.



Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- QC results that exceed the upper limits and are associated with non-detect samples are qualified but further narration is not required since the bias is high and does not change a non-detect result. Further narration is also not required with QC blank detection when the associated sample concentration is non-detect or more than ten times the level in the blank.
 - Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD is performed, unless otherwise specified in the method.
 - Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.
- Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Measurement uncertainty values, as applicable, are available upon request.

Test results relate only to the sample tested. Clients should be aware that a critical step in a chemical or microbiological analysis is the collection of the sample. Unless the sample analyzed is truly representative of the bulk of material involved, the test results will be meaningless. If you have questions regarding the proper techniques of collecting samples, please contact us. We cannot be held responsible for sample integrity, however, unless sampling has been performed by a member of our staff. Times are local to the area of activity. Parameters listed in the 40 CFR Part 136 Table II as "analyze immediately" and tested in the laboratory are not performed within 15 minutes of collection.

This report shall not be reproduced except in full, without the written approval of the laboratory.

WARRANTY AND LIMITS OF LIABILITY - In accepting analytical work, we warrant the accuracy of test results for the sample as submitted. The foregoing express warranty is exclusive and is given in lieu of all other warranties, expressed or implied, except as otherwise agreed. We disclaim any other warranties, expressed or implied, including a warranty of fitness for particular purpose and warranty of merchantability. In no event shall Eurofins Lancaster Laboratories Environmental, LLC be liable for indirect, special, consequential, or incidental damages including, but not limited to, damages for loss of profit or goodwill regardless of (A) the negligence (either sole or concurrent) of Eurofins Lancaster Laboratories Environmental and (B) whether Eurofins Lancaster Laboratories Environmental has been informed of the possibility of such damages. We accept no legal responsibility for the purposes for which the client uses the test results. Except as otherwise agreed, no purchase order or other order for work shall be accepted by Eurofins Lancaster Laboratories Environmental which includes any conditions that vary from the Standard Terms and Conditions, and Eurofins Lancaster Laboratories Environmental hereby objects to any conflicting terms contained in any acceptance or order submitted by client.

Elizabeth Zanar
Project Manager
3/24/2021 8:17:35 AM



Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	8
Surrogate Summary	16
QC Sample Results	17
QC Association Summary	21
Lab Chronicle	23
Certification Summary	26
Method Summary	27
Sample Summary	28
Chain of Custody	29
Receipt Checklists	31

Definitions/Glossary

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Qualifiers

LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
1C	Result is from the primary column on a dual-column method.
2C	Result is from the confirmation column on a dual-column method.
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Job ID: 410-32304-1

Laboratory: Eurofins Lancaster Laboratories Env, LLC

Narrative

Job Narrative
410-32304-1

Receipt

The samples were received on 3/12/2021 11:30 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperatures of the 2 coolers at receipt time were 0.8°C and 0.9°C

LCMS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15

Detection Summary

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Client Sample ID: 7670061 002 Coppersmith Well

Lab Sample ID: 410-32304-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanoic acid	7.6		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluoroheptanoic acid	4.0		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanoic acid	5.2		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorononanoic acid	2.4		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorobutanesulfonic acid	7.2		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorohexanesulfonic acid	48		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanesulfonic acid	50		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA

Client Sample ID: 7670061 002 Coppersmith Well FB

Lab Sample ID: 410-32304-2

No Detections.

Client Sample ID: 7670061 003 DuPont Well

Lab Sample ID: 410-32304-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanoic acid	8.5		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluoroheptanoic acid	3.1		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanoic acid	5.8		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorononanoic acid	1.9		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorobutanesulfonic acid	6.5		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorohexanesulfonic acid - DL	110		17	4.2	ng/L	10		EPA 537 Ver 1.1	Total/NA
Perfluorooctanesulfonic acid - DL	110		17	4.2	ng/L	10		EPA 537 Ver 1.1	Total/NA

Client Sample ID: 7670061 003 DuPont Well FB

Lab Sample ID: 410-32304-4

No Detections.

Client Sample ID: 7670061 302 DuPont Between Lead & Lag

Lab Sample ID: 410-32304-5

No Detections.

Client Sample ID: 7670061 302 DuPont After Lag Vessel

Lab Sample ID: 410-32304-7

No Detections.

Client Sample ID: 7670061 102 DuPont EP

Lab Sample ID: 410-32304-9

No Detections.

Client Sample ID: 7670061 001 Playground Well

Lab Sample ID: 410-32304-11

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanoic acid	7.2		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluoroheptanoic acid	2.4		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanoic acid	5.6		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorobutanesulfonic acid	3.1		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorohexanesulfonic acid	4.5		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanesulfonic acid	9.8		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA

Client Sample ID: 7670061 001 Playground Well FB

Lab Sample ID: 410-32304-12

No Detections.

Client Sample ID: 7670061 301 Conley Between Lead & Lag

Lab Sample ID: 410-32304-13

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanoic acid	7.5		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Lancaster Laboratories Env, LLC

Detection Summary

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Client Sample ID: 7670061 301 Conley Between Lead & Lag (Continued)

Lab Sample ID: 410-32304-13

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluoroheptanoic acid	2.5		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanoic acid	5.0		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorobutanesulfonic acid	3.0		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorohexanesulfonic acid	4.3		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanesulfonic acid	5.5		1.7	0.42	ng/L	1		EPA 537 Ver 1.1	Total/NA

Client Sample ID: 7670061 301 Conley Between Lead & Lag FB

Lab Sample ID: 410-32304-14

No Detections.

Client Sample ID: 7670061 301 Conley After Lag Vessel

Lab Sample ID: 410-32304-15

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanoic acid	8.3		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluoroheptanoic acid	2.3		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanoic acid	3.6		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorobutanesulfonic acid	3.1		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorohexanesulfonic acid	3.0		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanesulfonic acid	1.8		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA

Client Sample ID: 7670061 301 Conley After Lag Vessel FB

Lab Sample ID: 410-32304-16

No Detections.

Client Sample ID: 7670061 101 Conley EP Grab Water

Lab Sample ID: 410-32304-17

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanoic acid	8.5		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluoroheptanoic acid	2.2		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanoic acid	3.6		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorobutanesulfonic acid	3.1		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorohexanesulfonic acid	2.9		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA
Perfluorooctanesulfonic acid	1.7		1.7	0.43	ng/L	1		EPA 537 Ver 1.1	Total/NA

Client Sample ID: 7670061 101 Conley Field Blank Grab Water

Lab Sample ID: 410-32304-18

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Lancaster Laboratories Env, LLC

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Client Sample ID: 7670061 002 Coppersmith Well

Lab Sample ID: 410-32304-1

Date Collected: 03/11/21 08:50

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	7.6		1.7	0.42	ng/L		03/22/21 07:21	03/23/21 13:23	1
Perfluoroheptanoic acid	4.0		1.7	0.42	ng/L		03/22/21 07:21	03/23/21 13:23	1
Perfluorooctanoic acid	5.2		1.7	0.42	ng/L		03/22/21 07:21	03/23/21 13:23	1
Perfluorononanoic acid	2.4		1.7	0.42	ng/L		03/22/21 07:21	03/23/21 13:23	1
Perfluorodecanoic acid	<1.7		1.7	0.42	ng/L		03/22/21 07:21	03/23/21 13:23	1
Perfluorotridecanoic acid	<1.7		1.7	0.42	ng/L		03/22/21 07:21	03/23/21 13:23	1
Perfluorotetradecanoic acid	<1.7		1.7	0.42	ng/L		03/22/21 07:21	03/23/21 13:23	1
Perfluorobutanesulfonic acid	7.2		1.7	0.42	ng/L		03/22/21 07:21	03/23/21 13:23	1
Perfluorohexanesulfonic acid	48		1.7	0.42	ng/L		03/22/21 07:21	03/23/21 13:23	1
Perfluorooctanesulfonic acid	50		1.7	0.42	ng/L		03/22/21 07:21	03/23/21 13:23	1
NEtFOSAA	<1.7		1.7	0.42	ng/L		03/22/21 07:21	03/23/21 13:23	1
NMeFOSAA	<1.7		1.7	0.42	ng/L		03/22/21 07:21	03/23/21 13:23	1
Perfluoroundecanoic acid	<1.7		1.7	0.42	ng/L		03/22/21 07:21	03/23/21 13:23	1
Perfluorododecanoic acid	<1.7		1.7	0.42	ng/L		03/22/21 07:21	03/23/21 13:23	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	87		70 - 130				03/22/21 07:21	03/23/21 13:23	1
13C2 PFDA	76		70 - 130				03/22/21 07:21	03/23/21 13:23	1
13C2 PFHxA	74		70 - 130				03/22/21 07:21	03/23/21 13:23	1

Client Sample ID: 7670061 002 Coppersmith Well FB

Lab Sample ID: 410-32304-2

Date Collected: 03/11/21 08:50

Matrix: Potable Water

Date Received: 03/12/21 11:30

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.8		1.8	0.46	ng/L		03/22/21 07:21	03/23/21 23:09	1
Perfluoroheptanoic acid	<1.8		1.8	0.46	ng/L		03/22/21 07:21	03/23/21 23:09	1
Perfluorooctanoic acid	<1.8		1.8	0.46	ng/L		03/22/21 07:21	03/23/21 23:09	1
Perfluorononanoic acid	<1.8		1.8	0.46	ng/L		03/22/21 07:21	03/23/21 23:09	1
Perfluorodecanoic acid	<1.8		1.8	0.46	ng/L		03/22/21 07:21	03/23/21 23:09	1
Perfluorotridecanoic acid	<1.8		1.8	0.46	ng/L		03/22/21 07:21	03/23/21 23:09	1
Perfluorotetradecanoic acid	<1.8		1.8	0.46	ng/L		03/22/21 07:21	03/23/21 23:09	1
Perfluorobutanesulfonic acid	<1.8		1.8	0.46	ng/L		03/22/21 07:21	03/23/21 23:09	1
Perfluorohexanesulfonic acid	<1.8		1.8	0.46	ng/L		03/22/21 07:21	03/23/21 23:09	1
Perfluorooctanesulfonic acid	<1.8		1.8	0.46	ng/L		03/22/21 07:21	03/23/21 23:09	1
NEtFOSAA	<1.8		1.8	0.46	ng/L		03/22/21 07:21	03/23/21 23:09	1
NMeFOSAA	<1.8		1.8	0.46	ng/L		03/22/21 07:21	03/23/21 23:09	1
Perfluoroundecanoic acid	<1.8		1.8	0.46	ng/L		03/22/21 07:21	03/23/21 23:09	1
Perfluorododecanoic acid	<1.8		1.8	0.46	ng/L		03/22/21 07:21	03/23/21 23:09	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	94		70 - 130				03/22/21 07:21	03/23/21 23:09	1
13C2 PFDA	87		70 - 130				03/22/21 07:21	03/23/21 23:09	1
13C2 PFHxA	94		70 - 130				03/22/21 07:21	03/23/21 23:09	1

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Client Sample ID: 7670061 003 DuPont Well

Lab Sample ID: 410-32304-3

Date Collected: 03/11/21 09:25

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	8.5		1.7	0.42	ng/L		03/17/21 07:58	03/18/21 14:11	1
Perfluoroheptanoic acid	3.1		1.7	0.42	ng/L		03/17/21 07:58	03/18/21 14:11	1
Perfluorooctanoic acid	5.8		1.7	0.42	ng/L		03/17/21 07:58	03/18/21 14:11	1
Perfluorononanoic acid	1.9		1.7	0.42	ng/L		03/17/21 07:58	03/18/21 14:11	1
Perfluorodecanoic acid	<1.7		1.7	0.42	ng/L		03/17/21 07:58	03/18/21 14:11	1
Perfluorotridecanoic acid	<1.7		1.7	0.42	ng/L		03/17/21 07:58	03/18/21 14:11	1
Perfluorotetradecanoic acid	<1.7		1.7	0.42	ng/L		03/17/21 07:58	03/18/21 14:11	1
Perfluorobutanesulfonic acid	6.5		1.7	0.42	ng/L		03/17/21 07:58	03/18/21 14:11	1
NEtFOSAA	<1.7		1.7	0.42	ng/L		03/17/21 07:58	03/18/21 14:11	1
NMeFOSAA	<1.7		1.7	0.42	ng/L		03/17/21 07:58	03/18/21 14:11	1
Perfluoroundecanoic acid	<1.7		1.7	0.42	ng/L		03/17/21 07:58	03/18/21 14:11	1
Perfluorododecanoic acid	<1.7		1.7	0.42	ng/L		03/17/21 07:58	03/18/21 14:11	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	97		70 - 130				03/17/21 07:58	03/18/21 14:11	1
13C2 PFDA	101		70 - 130				03/17/21 07:58	03/18/21 14:11	1
13C2 PFHxA	107		70 - 130				03/17/21 07:58	03/18/21 14:11	1

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1 - DL

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanesulfonic acid	110		17	4.2	ng/L		03/17/21 07:58	03/19/21 04:55	10
Perfluorooctanesulfonic acid	110		17	4.2	ng/L		03/17/21 07:58	03/19/21 04:55	10
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	93		70 - 130				03/17/21 07:58	03/19/21 04:55	10
13C2 PFDA	94		70 - 130				03/17/21 07:58	03/19/21 04:55	10
13C2 PFHxA	99		70 - 130				03/17/21 07:58	03/19/21 04:55	10

Client Sample ID: 7670061 003 DuPont Well FB

Lab Sample ID: 410-32304-4

Date Collected: 03/11/21 09:25

Matrix: Potable Water

Date Received: 03/12/21 11:30

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.8		1.8	0.44	ng/L		03/17/21 07:58	03/18/21 14:23	1
Perfluoroheptanoic acid	<1.8		1.8	0.44	ng/L		03/17/21 07:58	03/18/21 14:23	1
Perfluorooctanoic acid	<1.8		1.8	0.44	ng/L		03/17/21 07:58	03/18/21 14:23	1
Perfluorononanoic acid	<1.8		1.8	0.44	ng/L		03/17/21 07:58	03/18/21 14:23	1
Perfluorodecanoic acid	<1.8		1.8	0.44	ng/L		03/17/21 07:58	03/18/21 14:23	1
Perfluorotridecanoic acid	<1.8		1.8	0.44	ng/L		03/17/21 07:58	03/18/21 14:23	1
Perfluorotetradecanoic acid	<1.8		1.8	0.44	ng/L		03/17/21 07:58	03/18/21 14:23	1
Perfluorobutanesulfonic acid	<1.8		1.8	0.44	ng/L		03/17/21 07:58	03/18/21 14:23	1
Perfluorohexanesulfonic acid	<1.8		1.8	0.44	ng/L		03/17/21 07:58	03/18/21 14:23	1
Perfluorooctanesulfonic acid	<1.8		1.8	0.44	ng/L		03/17/21 07:58	03/18/21 14:23	1
NEtFOSAA	<1.8		1.8	0.44	ng/L		03/17/21 07:58	03/18/21 14:23	1
NMeFOSAA	<1.8		1.8	0.44	ng/L		03/17/21 07:58	03/18/21 14:23	1
Perfluoroundecanoic acid	<1.8		1.8	0.44	ng/L		03/17/21 07:58	03/18/21 14:23	1
Perfluorododecanoic acid	<1.8		1.8	0.44	ng/L		03/17/21 07:58	03/18/21 14:23	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	98		70 - 130				03/17/21 07:58	03/18/21 14:23	1

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Client Sample ID: 7670061 003 DuPont Well FB

Lab Sample ID: 410-32304-4

Date Collected: 03/11/21 09:25

Matrix: Potable Water

Date Received: 03/12/21 11:30

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1 (Continued)

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	94		70 - 130	03/17/21 07:58	03/18/21 14:23	1
13C2 PFHxA	101		70 - 130	03/17/21 07:58	03/18/21 14:23	1

Client Sample ID: 7670061 302 DuPont Between Lead & Lag

Lab Sample ID: 410-32304-5

Date Collected: 03/11/21 09:20

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:34	1
Perfluoroheptanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:34	1
Perfluorooctanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:34	1
Perfluorononanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:34	1
Perfluorodecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:34	1
Perfluorotridecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:34	1
Perfluorotetradecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:34	1
Perfluorobutanesulfonic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:34	1
Perfluorohexanesulfonic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:34	1
Perfluorooctanesulfonic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:34	1
NEtFOSAA	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:34	1
NMeFOSAA	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:34	1
Perfluoroundecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:34	1
Perfluorododecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:34	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	95		70 - 130	03/17/21 07:58	03/18/21 14:34	1
13C2 PFDA	103		70 - 130	03/17/21 07:58	03/18/21 14:34	1
13C2 PFHxA	109		70 - 130	03/17/21 07:58	03/18/21 14:34	1

Client Sample ID: 7670061 302 DuPont After Lag Vessel

Lab Sample ID: 410-32304-7

Date Collected: 03/11/21 09:15

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:57	1
Perfluoroheptanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:57	1
Perfluorooctanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:57	1
Perfluorononanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:57	1
Perfluorodecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:57	1
Perfluorotridecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:57	1
Perfluorotetradecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:57	1
Perfluorobutanesulfonic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:57	1
Perfluorohexanesulfonic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:57	1
Perfluorooctanesulfonic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:57	1
NEtFOSAA	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:57	1
NMeFOSAA	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:57	1
Perfluoroundecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:57	1
Perfluorododecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/18/21 14:57	1

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Client Sample ID: 7670061 302 DuPont After Lag Vessel

Lab Sample ID: 410-32304-7

Date Collected: 03/11/21 09:15

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	98		70 - 130	03/17/21 07:58	03/18/21 14:57	1
13C2 PFDA	95		70 - 130	03/17/21 07:58	03/18/21 14:57	1
13C2 PFHxA	103		70 - 130	03/17/21 07:58	03/18/21 14:57	1

Client Sample ID: 7670061 102 DuPont EP

Lab Sample ID: 410-32304-9

Date Collected: 03/11/21 09:10

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.9		1.9	0.47	ng/L		03/17/21 07:58	03/18/21 15:20	1
Perfluoroheptanoic acid	<1.9		1.9	0.47	ng/L		03/17/21 07:58	03/18/21 15:20	1
Perfluorooctanoic acid	<1.9		1.9	0.47	ng/L		03/17/21 07:58	03/18/21 15:20	1
Perfluorononanoic acid	<1.9		1.9	0.47	ng/L		03/17/21 07:58	03/18/21 15:20	1
Perfluorodecanoic acid	<1.9		1.9	0.47	ng/L		03/17/21 07:58	03/18/21 15:20	1
Perfluorotridecanoic acid	<1.9		1.9	0.47	ng/L		03/17/21 07:58	03/18/21 15:20	1
Perfluorotetradecanoic acid	<1.9		1.9	0.47	ng/L		03/17/21 07:58	03/18/21 15:20	1
Perfluorobutanesulfonic acid	<1.9		1.9	0.47	ng/L		03/17/21 07:58	03/18/21 15:20	1
Perfluorohexanesulfonic acid	<1.9		1.9	0.47	ng/L		03/17/21 07:58	03/18/21 15:20	1
Perfluorooctanesulfonic acid	<1.9		1.9	0.47	ng/L		03/17/21 07:58	03/18/21 15:20	1
NEtFOSAA	<1.9		1.9	0.47	ng/L		03/17/21 07:58	03/18/21 15:20	1
NMeFOSAA	<1.9		1.9	0.47	ng/L		03/17/21 07:58	03/18/21 15:20	1
Perfluoroundecanoic acid	<1.9		1.9	0.47	ng/L		03/17/21 07:58	03/18/21 15:20	1
Perfluorododecanoic acid	<1.9		1.9	0.47	ng/L		03/17/21 07:58	03/18/21 15:20	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	102		70 - 130	03/17/21 07:58	03/18/21 15:20	1
13C2 PFDA	103		70 - 130	03/17/21 07:58	03/18/21 15:20	1
13C2 PFHxA	111		70 - 130	03/17/21 07:58	03/18/21 15:20	1

Client Sample ID: 7670061 001 Playground Well

Lab Sample ID: 410-32304-11

Date Collected: 03/11/21 10:05

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	7.2		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:06	1
Perfluoroheptanoic acid	2.4		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:06	1
Perfluorooctanoic acid	5.6		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:06	1
Perfluorononanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:06	1
Perfluorodecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:06	1
Perfluorotridecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:06	1
Perfluorotetradecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:06	1
Perfluorobutanesulfonic acid	3.1		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:06	1
Perfluorohexanesulfonic acid	4.5		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:06	1
Perfluorooctanesulfonic acid	9.8		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:06	1
NEtFOSAA	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:06	1
NMeFOSAA	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:06	1
Perfluoroundecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:06	1
Perfluorododecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:06	1

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Client Sample ID: 7670061 001 Playground Well

Lab Sample ID: 410-32304-11

Date Collected: 03/11/21 10:05

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	91		70 - 130	03/17/21 07:58	03/19/21 05:06	1
13C2 PFDA	97		70 - 130	03/17/21 07:58	03/19/21 05:06	1
13C2 PFHxA	93		70 - 130	03/17/21 07:58	03/19/21 05:06	1

Client Sample ID: 7670061 001 Playground Well FB

Lab Sample ID: 410-32304-12

Date Collected: 03/11/21 10:05

Matrix: Potable Water

Date Received: 03/12/21 11:30

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 05:18	1
Perfluoroheptanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 05:18	1
Perfluorooctanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 05:18	1
Perfluorononanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 05:18	1
Perfluorodecanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 05:18	1
Perfluorotridecanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 05:18	1
Perfluorotetradecanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 05:18	1
Perfluorobutanesulfonic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 05:18	1
Perfluorohexanesulfonic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 05:18	1
Perfluorooctanesulfonic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 05:18	1
NEtFOSAA	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 05:18	1
NMeFOSAA	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 05:18	1
Perfluoroundecanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 05:18	1
Perfluorododecanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 05:18	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	97		70 - 130	03/17/21 07:58	03/19/21 05:18	1
13C2 PFDA	90		70 - 130	03/17/21 07:58	03/19/21 05:18	1
13C2 PFHxA	90		70 - 130	03/17/21 07:58	03/19/21 05:18	1

Client Sample ID: 7670061 301 Conley Between Lead & Lag

Lab Sample ID: 410-32304-13

Date Collected: 03/11/21 10:00

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	7.5		1.7	0.42	ng/L		03/17/21 07:58	03/19/21 05:29	1
Perfluoroheptanoic acid	2.5		1.7	0.42	ng/L		03/17/21 07:58	03/19/21 05:29	1
Perfluorooctanoic acid	5.0		1.7	0.42	ng/L		03/17/21 07:58	03/19/21 05:29	1
Perfluorononanoic acid	<1.7		1.7	0.42	ng/L		03/17/21 07:58	03/19/21 05:29	1
Perfluorodecanoic acid	<1.7		1.7	0.42	ng/L		03/17/21 07:58	03/19/21 05:29	1
Perfluorotridecanoic acid	<1.7		1.7	0.42	ng/L		03/17/21 07:58	03/19/21 05:29	1
Perfluorotetradecanoic acid	<1.7		1.7	0.42	ng/L		03/17/21 07:58	03/19/21 05:29	1
Perfluorobutanesulfonic acid	3.0		1.7	0.42	ng/L		03/17/21 07:58	03/19/21 05:29	1
Perfluorohexanesulfonic acid	4.3		1.7	0.42	ng/L		03/17/21 07:58	03/19/21 05:29	1
Perfluorooctanesulfonic acid	5.5		1.7	0.42	ng/L		03/17/21 07:58	03/19/21 05:29	1
NEtFOSAA	<1.7		1.7	0.42	ng/L		03/17/21 07:58	03/19/21 05:29	1
NMeFOSAA	<1.7		1.7	0.42	ng/L		03/17/21 07:58	03/19/21 05:29	1
Perfluoroundecanoic acid	<1.7		1.7	0.42	ng/L		03/17/21 07:58	03/19/21 05:29	1
Perfluorododecanoic acid	<1.7		1.7	0.42	ng/L		03/17/21 07:58	03/19/21 05:29	1

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Client Sample ID: 7670061 301 Conley Between Lead & Lag

Lab Sample ID: 410-32304-13

Date Collected: 03/11/21 10:00

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	90		70 - 130	03/17/21 07:58	03/19/21 05:29	1
13C2 PFDA	94		70 - 130	03/17/21 07:58	03/19/21 05:29	1
13C2 PFHxA	90		70 - 130	03/17/21 07:58	03/19/21 05:29	1

Client Sample ID: 7670061 301 Conley Between Lead & Lag

Lab Sample ID: 410-32304-14

FB

Date Collected: 03/11/21 10:00

Matrix: Potable Water

Date Received: 03/12/21 11:30

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.9		1.9	0.46	ng/L		03/17/21 07:58	03/19/21 05:41	1
Perfluoroheptanoic acid	<1.9		1.9	0.46	ng/L		03/17/21 07:58	03/19/21 05:41	1
Perfluorooctanoic acid	<1.9		1.9	0.46	ng/L		03/17/21 07:58	03/19/21 05:41	1
Perfluorononanoic acid	<1.9		1.9	0.46	ng/L		03/17/21 07:58	03/19/21 05:41	1
Perfluorodecanoic acid	<1.9		1.9	0.46	ng/L		03/17/21 07:58	03/19/21 05:41	1
Perfluorotridecanoic acid	<1.9		1.9	0.46	ng/L		03/17/21 07:58	03/19/21 05:41	1
Perfluorotetradecanoic acid	<1.9		1.9	0.46	ng/L		03/17/21 07:58	03/19/21 05:41	1
Perfluorobutanesulfonic acid	<1.9		1.9	0.46	ng/L		03/17/21 07:58	03/19/21 05:41	1
Perfluorohexanesulfonic acid	<1.9		1.9	0.46	ng/L		03/17/21 07:58	03/19/21 05:41	1
Perfluorooctanesulfonic acid	<1.9		1.9	0.46	ng/L		03/17/21 07:58	03/19/21 05:41	1
NEtFOSAA	<1.9		1.9	0.46	ng/L		03/17/21 07:58	03/19/21 05:41	1
NMeFOSAA	<1.9		1.9	0.46	ng/L		03/17/21 07:58	03/19/21 05:41	1
Perfluoroundecanoic acid	<1.9		1.9	0.46	ng/L		03/17/21 07:58	03/19/21 05:41	1
Perfluorododecanoic acid	<1.9		1.9	0.46	ng/L		03/17/21 07:58	03/19/21 05:41	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	89		70 - 130	03/17/21 07:58	03/19/21 05:41	1
13C2 PFDA	90		70 - 130	03/17/21 07:58	03/19/21 05:41	1
13C2 PFHxA	88		70 - 130	03/17/21 07:58	03/19/21 05:41	1

Client Sample ID: 7670061 301 Conley After Lag Vessel

Lab Sample ID: 410-32304-15

Date Collected: 03/11/21 09:55

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	8.3		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:52	1
Perfluoroheptanoic acid	2.3		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:52	1
Perfluorooctanoic acid	3.6		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:52	1
Perfluorononanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:52	1
Perfluorodecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:52	1
Perfluorotridecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:52	1
Perfluorotetradecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:52	1
Perfluorobutanesulfonic acid	3.1		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:52	1
Perfluorohexanesulfonic acid	3.0		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:52	1
Perfluorooctanesulfonic acid	1.8		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:52	1
NEtFOSAA	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:52	1
NMeFOSAA	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:52	1
Perfluoroundecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:52	1
Perfluorododecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 05:52	1

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Client Sample ID: 7670061 301 Conley After Lag Vessel

Lab Sample ID: 410-32304-15

Date Collected: 03/11/21 09:55

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	96		70 - 130	03/17/21 07:58	03/19/21 05:52	1
13C2 PFDA	98		70 - 130	03/17/21 07:58	03/19/21 05:52	1
13C2 PFHxA	91		70 - 130	03/17/21 07:58	03/19/21 05:52	1

Client Sample ID: 7670061 301 Conley After Lag Vessel FB

Lab Sample ID: 410-32304-16

Date Collected: 03/11/21 09:55

Matrix: Potable Water

Date Received: 03/12/21 11:30

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 06:03	1
Perfluoroheptanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 06:03	1
Perfluorooctanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 06:03	1
Perfluorononanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 06:03	1
Perfluorodecanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 06:03	1
Perfluorotridecanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 06:03	1
Perfluorotetradecanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 06:03	1
Perfluorobutanesulfonic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 06:03	1
Perfluorohexanesulfonic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 06:03	1
Perfluorooctanesulfonic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 06:03	1
NEtFOSAA	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 06:03	1
NMeFOSAA	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 06:03	1
Perfluoroundecanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 06:03	1
Perfluorododecanoic acid	<1.8		1.8	0.45	ng/L		03/17/21 07:58	03/19/21 06:03	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	88		70 - 130	03/17/21 07:58	03/19/21 06:03	1
13C2 PFDA	95		70 - 130	03/17/21 07:58	03/19/21 06:03	1
13C2 PFHxA	91		70 - 130	03/17/21 07:58	03/19/21 06:03	1

Client Sample ID: 7670061 101 Conley EP Grab Water

Lab Sample ID: 410-32304-17

Date Collected: 03/11/21 09:50

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	8.5		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 06:15	1
Perfluoroheptanoic acid	2.2		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 06:15	1
Perfluorooctanoic acid	3.6		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 06:15	1
Perfluorononanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 06:15	1
Perfluorodecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 06:15	1
Perfluorotridecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 06:15	1
Perfluorotetradecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 06:15	1
Perfluorobutanesulfonic acid	3.1		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 06:15	1
Perfluorohexanesulfonic acid	2.9		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 06:15	1
Perfluorooctanesulfonic acid	1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 06:15	1
NEtFOSAA	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 06:15	1
NMeFOSAA	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 06:15	1
Perfluoroundecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 06:15	1
Perfluorododecanoic acid	<1.7		1.7	0.43	ng/L		03/17/21 07:58	03/19/21 06:15	1

Client Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Client Sample ID: 7670061 101 Conley EP Grab Water

Lab Sample ID: 410-32304-17

Date Collected: 03/11/21 09:50

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	85		70 - 130	03/17/21 07:58	03/19/21 06:15	1
13C2 PFDA	94		70 - 130	03/17/21 07:58	03/19/21 06:15	1
13C2 PFHxA	93		70 - 130	03/17/21 07:58	03/19/21 06:15	1

Client Sample ID: 7670061 101 Conley Field Blank Grab Water

Lab Sample ID: 410-32304-18

Date Collected: 03/11/21 09:50

Matrix: Potable Water

Date Received: 03/12/21 11:30

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorohexanoic acid	<1.8		1.8	0.46	ng/L		03/17/21 07:58	03/19/21 06:26	1
Perfluoroheptanoic acid	<1.8		1.8	0.46	ng/L		03/17/21 07:58	03/19/21 06:26	1
Perfluorooctanoic acid	<1.8		1.8	0.46	ng/L		03/17/21 07:58	03/19/21 06:26	1
Perfluorononanoic acid	<1.8		1.8	0.46	ng/L		03/17/21 07:58	03/19/21 06:26	1
Perfluorodecanoic acid	<1.8		1.8	0.46	ng/L		03/17/21 07:58	03/19/21 06:26	1
Perfluorotridecanoic acid	<1.8		1.8	0.46	ng/L		03/17/21 07:58	03/19/21 06:26	1
Perfluorotetradecanoic acid	<1.8		1.8	0.46	ng/L		03/17/21 07:58	03/19/21 06:26	1
Perfluorobutanesulfonic acid	<1.8		1.8	0.46	ng/L		03/17/21 07:58	03/19/21 06:26	1
Perfluorohexanesulfonic acid	<1.8		1.8	0.46	ng/L		03/17/21 07:58	03/19/21 06:26	1
Perfluorooctanesulfonic acid	<1.8		1.8	0.46	ng/L		03/17/21 07:58	03/19/21 06:26	1
NEtFOSAA	<1.8		1.8	0.46	ng/L		03/17/21 07:58	03/19/21 06:26	1
NMeFOSAA	<1.8		1.8	0.46	ng/L		03/17/21 07:58	03/19/21 06:26	1
Perfluoroundecanoic acid	<1.8		1.8	0.46	ng/L		03/17/21 07:58	03/19/21 06:26	1
Perfluorododecanoic acid	<1.8		1.8	0.46	ng/L		03/17/21 07:58	03/19/21 06:26	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	94		70 - 130	03/17/21 07:58	03/19/21 06:26	1
13C2 PFDA	88		70 - 130	03/17/21 07:58	03/19/21 06:26	1
13C2 PFHxA	91		70 - 130	03/17/21 07:58	03/19/21 06:26	1

Surrogate Summary

Client: SUEZ Water Environmental Services Inc
 Project/Site: Newberry System

Job ID: 410-32304-1

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		d5NEFOS (70-130)	PFDA (70-130)	PFHxA (70-130)
410-32304-1	7670061 002 Coppersmith Well	87	76	74
410-32304-3	7670061 003 DuPont Well	97	101	107
410-32304-3 - DL	7670061 003 DuPont Well	93	94	99
410-32304-5	7670061 302 DuPont Between Lead & Lag	95	103	109
410-32304-7	7670061 302 DuPont After Lag Vessel	98	95	103
410-32304-9	7670061 102 DuPont EP	102	103	111
410-32304-11	7670061 001 Playground Well	91	97	93
410-32304-13	7670061 301 Conley Between Lead & Lag	90	94	90
410-32304-15	7670061 301 Conley After Lag Vessel	96	98	91
410-32304-17	7670061 101 Conley EP Grab Water	85	94	93
LCS 410-104025/2-A	Lab Control Sample	94	96	102
LCS 410-105505/2-A	Lab Control Sample	88	81	90
LCS 410-104025/3-A	Lab Control Sample Dup	91	95	98
LCS 410-105505/3-A	Lab Control Sample Dup	89	87	93
LLCS 410-104025/4-A	Lab Control Sample	102	94	102
LLCS 410-105505/4-A	Lab Control Sample	84	83	92
MB 410-104025/1-A	Method Blank	98	92	96
MB 410-105505/1-A	Method Blank	83	79	83

Surrogate Legend

d5NEFOS = d5-NEtFOSAA

PFDA = 13C2 PFDA

PFHxA = 13C2 PFHxA

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Matrix: Potable Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		d5NEFOS (70-130)	PFDA (70-130)	PFHxA (70-130)
410-32304-2	7670061 002 Coppersmith Well FB	94	87	94
410-32304-4	7670061 003 DuPont Well FB	98	94	101
410-32304-12	7670061 001 Playground Well FB	97	90	90
410-32304-14	7670061 301 Conley Between Lead & Lag FB	89	90	88
410-32304-16	7670061 301 Conley After Lag Vessel FB	88	95	91
410-32304-18	7670061 101 Conley Field Blank Grab Water	94	88	91

Surrogate Legend

d5NEFOS = d5-NEtFOSAA

PFDA = 13C2 PFDA

PFHxA = 13C2 PFHxA

QC Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1

Lab Sample ID: MB 410-104025/1-A

Matrix: Drinking Water

Analysis Batch: 104594

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 104025

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Perfluorohexanoic acid	<2.0		2.0	0.50	ng/L		03/17/21 07:58	03/18/21 13:25	1
Perfluoroheptanoic acid	<2.0		2.0	0.50	ng/L		03/17/21 07:58	03/18/21 13:25	1
Perfluorooctanoic acid	<2.0		2.0	0.50	ng/L		03/17/21 07:58	03/18/21 13:25	1
Perfluorononanoic acid	<2.0		2.0	0.50	ng/L		03/17/21 07:58	03/18/21 13:25	1
Perfluorodecanoic acid	<2.0		2.0	0.50	ng/L		03/17/21 07:58	03/18/21 13:25	1
Perfluorotridecanoic acid	<2.0		2.0	0.50	ng/L		03/17/21 07:58	03/18/21 13:25	1
Perfluorotetradecanoic acid	<2.0		2.0	0.50	ng/L		03/17/21 07:58	03/18/21 13:25	1
Perfluorobutanesulfonic acid	<2.0		2.0	0.50	ng/L		03/17/21 07:58	03/18/21 13:25	1
Perfluorohexanesulfonic acid	<2.0		2.0	0.50	ng/L		03/17/21 07:58	03/18/21 13:25	1
Perfluorooctanesulfonic acid	<2.0		2.0	0.50	ng/L		03/17/21 07:58	03/18/21 13:25	1
NEtFOSAA	<2.0		2.0	0.50	ng/L		03/17/21 07:58	03/18/21 13:25	1
NMeFOSAA	<2.0		2.0	0.50	ng/L		03/17/21 07:58	03/18/21 13:25	1
Perfluoroundecanoic acid	<2.0		2.0	0.50	ng/L		03/17/21 07:58	03/18/21 13:25	1
Perfluorododecanoic acid	<2.0		2.0	0.50	ng/L		03/17/21 07:58	03/18/21 13:25	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
d5-NEtFOSAA	98		70 - 130	03/17/21 07:58	03/18/21 13:25	1
13C2 PFDA	92		70 - 130	03/17/21 07:58	03/18/21 13:25	1
13C2 PFHxA	96		70 - 130	03/17/21 07:58	03/18/21 13:25	1

Lab Sample ID: LCS 410-104025/2-A

Matrix: Drinking Water

Analysis Batch: 104594

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 104025

Analyte	Spike Added	LCS	LCS	Unit	D	%Rec	%Rec. Limits
		Result	Qualifier				
Perfluorohexanoic acid	20.5	18.3		ng/L		89	70 - 130
Perfluoroheptanoic acid	20.5	18.9		ng/L		93	70 - 130
Perfluorooctanoic acid	20.5	19.5		ng/L		95	70 - 130
Perfluorononanoic acid	20.5	19.9		ng/L		97	70 - 130
Perfluorodecanoic acid	20.5	19.5		ng/L		95	70 - 130
Perfluorotridecanoic acid	20.5	17.9		ng/L		87	70 - 130
Perfluorotetradecanoic acid	20.5	17.6		ng/L		86	70 - 130
Perfluorobutanesulfonic acid	18.1	17.0		ng/L		94	70 - 130
Perfluorohexanesulfonic acid	18.7	18.1		ng/L		97	70 - 130
Perfluorooctanesulfonic acid	19.0	17.6		ng/L		93	70 - 130
NEtFOSAA	20.5	18.8		ng/L		92	70 - 130
NMeFOSAA	20.5	19.4		ng/L		95	70 - 130
Perfluoroundecanoic acid	20.5	20.1		ng/L		98	70 - 130
Perfluorododecanoic acid	20.5	18.4		ng/L		90	70 - 130

Surrogate	LCS	LCS	Limits
	%Recovery	Qualifier	
d5-NEtFOSAA	94		70 - 130
13C2 PFDA	96		70 - 130
13C2 PFHxA	102		70 - 130

QC Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1 (Continued)

Lab Sample ID: LCSD 410-104025/3-A
Matrix: Drinking Water
Analysis Batch: 104594

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 104025

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec.		RPD	Limit
							Limits	RPD		
Perfluorohexanoic acid	20.5	18.5		ng/L		90	70 - 130	1	30	
Perfluoroheptanoic acid	20.5	18.3		ng/L		89	70 - 130	4	30	
Perfluorooctanoic acid	20.5	19.2		ng/L		94	70 - 130	1	30	
Perfluorononanoic acid	20.5	20.3		ng/L		99	70 - 130	2	30	
Perfluorodecanoic acid	20.5	19.4		ng/L		95	70 - 130	1	30	
Perfluorotridecanoic acid	20.5	17.1		ng/L		84	70 - 130	5	30	
Perfluorotetradecanoic acid	20.5	17.1		ng/L		84	70 - 130	3	30	
Perfluorobutanesulfonic acid	18.1	15.9		ng/L		88	70 - 130	6	30	
Perfluorohexanesulfonic acid	18.7	17.3		ng/L		93	70 - 130	4	30	
Perfluorooctanesulfonic acid	19.0	16.8		ng/L		88	70 - 130	5	30	
NEtFOSAA	20.5	18.0		ng/L		88	70 - 130	4	30	
NMeFOSAA	20.5	18.2		ng/L		89	70 - 130	6	30	
Perfluoroundecanoic acid	20.5	18.7		ng/L		92	70 - 130	7	30	
Perfluorododecanoic acid	20.5	17.7		ng/L		86	70 - 130	4	30	

Surrogate	LCSD LCSD		Limits
	%Recovery	Qualifier	
d5-NEtFOSAA	91		70 - 130
13C2 PFDA	95		70 - 130
13C2 PFHxA	98		70 - 130

Lab Sample ID: LLCS 410-104025/4-A
Matrix: Drinking Water
Analysis Batch: 104594

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 104025

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec.		RPD	Limit
							Limits	RPD		
Perfluorohexanoic acid	1.92	1.75	J	ng/L		91	50 - 150			
Perfluoroheptanoic acid	1.92	1.64	J	ng/L		85	50 - 150			
Perfluorooctanoic acid	1.92	1.83	J	ng/L		95	50 - 150			
Perfluorononanoic acid	1.92	1.85	J	ng/L		97	50 - 150			
Perfluorodecanoic acid	1.92	1.71	J	ng/L		89	50 - 150			
Perfluorotridecanoic acid	1.92	1.63	J	ng/L		85	50 - 150			
Perfluorotetradecanoic acid	1.92	1.58	J	ng/L		82	50 - 150			
Perfluorobutanesulfonic acid	1.70	1.44	J	ng/L		85	50 - 150			
Perfluorohexanesulfonic acid	1.75	1.53	J	ng/L		88	50 - 150			
Perfluorooctanesulfonic acid	1.78	1.65	J	ng/L		93	50 - 150			
NEtFOSAA	1.92	1.66	J	ng/L		87	50 - 150			
NMeFOSAA	1.92	1.74	J	ng/L		91	50 - 150			
Perfluoroundecanoic acid	1.92	1.70	J	ng/L		89	50 - 150			
Perfluorododecanoic acid	1.92	1.60	J	ng/L		83	50 - 150			

Surrogate	LLCS LLCS		Limits
	%Recovery	Qualifier	
d5-NEtFOSAA	102		70 - 130
13C2 PFDA	94		70 - 130
13C2 PFHxA	102		70 - 130

QC Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1 (Continued)

Lab Sample ID: MB 410-105505/1-A

Matrix: Drinking Water

Analysis Batch: 106118

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 105505

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Perfluorohexanoic acid	<2.0		2.0	0.50	ng/L		03/22/21 07:21	03/23/21 12:38	1
Perfluoroheptanoic acid	<2.0		2.0	0.50	ng/L		03/22/21 07:21	03/23/21 12:38	1
Perfluorooctanoic acid	<2.0		2.0	0.50	ng/L		03/22/21 07:21	03/23/21 12:38	1
Perfluorononanoic acid	<2.0		2.0	0.50	ng/L		03/22/21 07:21	03/23/21 12:38	1
Perfluorodecanoic acid	<2.0		2.0	0.50	ng/L		03/22/21 07:21	03/23/21 12:38	1
Perfluorotridecanoic acid	<2.0		2.0	0.50	ng/L		03/22/21 07:21	03/23/21 12:38	1
Perfluorotetradecanoic acid	<2.0		2.0	0.50	ng/L		03/22/21 07:21	03/23/21 12:38	1
Perfluorobutanesulfonic acid	<2.0		2.0	0.50	ng/L		03/22/21 07:21	03/23/21 12:38	1
Perfluorohexanesulfonic acid	<2.0		2.0	0.50	ng/L		03/22/21 07:21	03/23/21 12:38	1
Perfluorooctanesulfonic acid	<2.0		2.0	0.50	ng/L		03/22/21 07:21	03/23/21 12:38	1
NEtFOSAA	<2.0		2.0	0.50	ng/L		03/22/21 07:21	03/23/21 12:38	1
NMeFOSAA	<2.0		2.0	0.50	ng/L		03/22/21 07:21	03/23/21 12:38	1
Perfluoroundecanoic acid	<2.0		2.0	0.50	ng/L		03/22/21 07:21	03/23/21 12:38	1
Perfluorododecanoic acid	<2.0		2.0	0.50	ng/L		03/22/21 07:21	03/23/21 12:38	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
d5-NEtFOSAA	83		70 - 130	03/22/21 07:21	03/23/21 12:38	1
13C2 PFDA	79		70 - 130	03/22/21 07:21	03/23/21 12:38	1
13C2 PFHxA	83		70 - 130	03/22/21 07:21	03/23/21 12:38	1

Lab Sample ID: LCS 410-105505/2-A

Matrix: Drinking Water

Analysis Batch: 106118

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 105505

Analyte	Spike Added	LCS	LCS	Unit	D	%Rec	%Rec.
		Result	Qualifier				Limits
Perfluorohexanoic acid	20.5	17.0		ng/L		83	70 - 130
Perfluoroheptanoic acid	20.5	16.4		ng/L		80	70 - 130
Perfluorooctanoic acid	20.5	15.8		ng/L		77	70 - 130
Perfluorononanoic acid	20.5	15.9		ng/L		78	70 - 130
Perfluorodecanoic acid	20.5	15.5		ng/L		76	70 - 130
Perfluorotridecanoic acid	20.5	14.7		ng/L		72	70 - 130
Perfluorotetradecanoic acid	20.5	15.4		ng/L		75	70 - 130
Perfluorobutanesulfonic acid	18.1	16.4		ng/L		91	70 - 130
Perfluorohexanesulfonic acid	18.7	16.4		ng/L		88	70 - 130
Perfluorooctanesulfonic acid	19.0	16.0		ng/L		85	70 - 130
NEtFOSAA	20.5	17.8		ng/L		87	70 - 130
NMeFOSAA	20.5	16.9		ng/L		83	70 - 130
Perfluoroundecanoic acid	20.5	14.7		ng/L		72	70 - 130
Perfluorododecanoic acid	20.5	15.1		ng/L		74	70 - 130

Surrogate	LCS	LCS	Limits
	%Recovery	Qualifier	
d5-NEtFOSAA	88		70 - 130
13C2 PFDA	81		70 - 130
13C2 PFHxA	90		70 - 130

QC Sample Results

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Method: EPA 537 Ver 1.1 - EPA 537 Version 1.1 (Continued)

Lab Sample ID: LCSD 410-105505/3-A

Matrix: Drinking Water

Analysis Batch: 106118

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 105505

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec.		RPD	Limit
							Limits	RPD		
Perfluorohexanoic acid	20.5	18.2		ng/L		89	70 - 130	7	30	
Perfluoroheptanoic acid	20.5	17.4		ng/L		85	70 - 130	6	30	
Perfluorooctanoic acid	20.5	17.3		ng/L		84	70 - 130	9	30	
Perfluorononanoic acid	20.5	17.1		ng/L		84	70 - 130	7	30	
Perfluorodecanoic acid	20.5	16.6		ng/L		81	70 - 130	7	30	
Perfluorotridecanoic acid	20.5	15.8		ng/L		77	70 - 130	7	30	
Perfluorotetradecanoic acid	20.5	15.7		ng/L		77	70 - 130	2	30	
Perfluorobutanesulfonic acid	18.1	15.3		ng/L		85	70 - 130	7	30	
Perfluorohexanesulfonic acid	18.7	15.4		ng/L		82	70 - 130	6	30	
Perfluorooctanesulfonic acid	19.0	16.0		ng/L		84	70 - 130	0	30	
NEtFOSAA	20.5	17.8		ng/L		87	70 - 130	0	30	
NMeFOSAA	20.5	16.9		ng/L		82	70 - 130	0	30	
Perfluoroundecanoic acid	20.5	16.1		ng/L		79	70 - 130	10	30	
Perfluorododecanoic acid	20.5	15.4		ng/L		75	70 - 130	2	30	

Surrogate	LCSD LCSD		Limits
	%Recovery	Qualifier	
d5-NEtFOSAA	89		70 - 130
13C2 PFDA	87		70 - 130
13C2 PFHxA	93		70 - 130

Lab Sample ID: LLCS 410-105505/4-A

Matrix: Drinking Water

Analysis Batch: 106118

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 105505

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec.		Limit
							Limits	RPD	
Perfluorohexanoic acid	1.92	1.65	J	ng/L		86	50 - 150		
Perfluoroheptanoic acid	1.92	1.50	J	ng/L		78	50 - 150		
Perfluorooctanoic acid	1.92	1.53	J	ng/L		80	50 - 150		
Perfluorononanoic acid	1.92	1.46	J	ng/L		76	50 - 150		
Perfluorodecanoic acid	1.92	1.54	J	ng/L		80	50 - 150		
Perfluorotridecanoic acid	1.92	1.34	J	ng/L		70	50 - 150		
Perfluorotetradecanoic acid	1.92	1.34	J	ng/L		70	50 - 150		
Perfluorobutanesulfonic acid	1.70	1.47	J	ng/L		87	50 - 150		
Perfluorohexanesulfonic acid	1.75	1.44	J	ng/L		82	50 - 150		
Perfluorooctanesulfonic acid	1.78	1.49	J	ng/L		84	50 - 150		
NEtFOSAA	1.92	1.66	J	ng/L		87	50 - 150		
NMeFOSAA	1.92	1.49	J	ng/L		78	50 - 150		
Perfluoroundecanoic acid	1.92	1.42	J	ng/L		74	50 - 150		
Perfluorododecanoic acid	1.92	1.29	J	ng/L		67	50 - 150		

Surrogate	LLCS LLCS		Limits
	%Recovery	Qualifier	
d5-NEtFOSAA	84		70 - 130
13C2 PFDA	83		70 - 130
13C2 PFHxA	92		70 - 130

QC Association Summary

Client: SUEZ Water Environmental Services Inc
 Project/Site: Newberry System

Job ID: 410-32304-1

LCMS

Prep Batch: 104025

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-32304-3	7670061 003 DuPont Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-32304-3 - DL	7670061 003 DuPont Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-32304-4	7670061 003 DuPont Well FB	Total/NA	Potable Water	EPA 537 Ver 1.1	
410-32304-5	7670061 302 DuPont Between Lead & Lag	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-32304-7	7670061 302 DuPont After Lag Vessel	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-32304-9	7670061 102 DuPont EP	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-32304-11	7670061 001 Playground Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-32304-12	7670061 001 Playground Well FB	Total/NA	Potable Water	EPA 537 Ver 1.1	
410-32304-13	7670061 301 Conley Between Lead & Lag	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-32304-14	7670061 301 Conley Between Lead & Lag FB	Total/NA	Potable Water	EPA 537 Ver 1.1	
410-32304-15	7670061 301 Conley After Lag Vessel	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-32304-16	7670061 301 Conley After Lag Vessel FB	Total/NA	Potable Water	EPA 537 Ver 1.1	
410-32304-17	7670061 101 Conley EP Grab Water	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-32304-18	7670061 101 Conley Field Blank Grab Water	Total/NA	Potable Water	EPA 537 Ver 1.1	
MB 410-104025/1-A	Method Blank	Total/NA	Drinking Water	EPA 537 Ver 1.1	
LCS 410-104025/2-A	Lab Control Sample	Total/NA	Drinking Water	EPA 537 Ver 1.1	
LCS D 410-104025/3-A	Lab Control Sample Dup	Total/NA	Drinking Water	EPA 537 Ver 1.1	
LLCS 410-104025/4-A	Lab Control Sample	Total/NA	Drinking Water	EPA 537 Ver 1.1	

Analysis Batch: 104594

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-32304-3	7670061 003 DuPont Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	104025
410-32304-4	7670061 003 DuPont Well FB	Total/NA	Potable Water	EPA 537 Ver 1.1	104025
410-32304-5	7670061 302 DuPont Between Lead & Lag	Total/NA	Drinking Water	EPA 537 Ver 1.1	104025
410-32304-7	7670061 302 DuPont After Lag Vessel	Total/NA	Drinking Water	EPA 537 Ver 1.1	104025
410-32304-9	7670061 102 DuPont EP	Total/NA	Drinking Water	EPA 537 Ver 1.1	104025
MB 410-104025/1-A	Method Blank	Total/NA	Drinking Water	EPA 537 Ver 1.1	104025
LCS 410-104025/2-A	Lab Control Sample	Total/NA	Drinking Water	EPA 537 Ver 1.1	104025
LCS D 410-104025/3-A	Lab Control Sample Dup	Total/NA	Drinking Water	EPA 537 Ver 1.1	104025
LLCS 410-104025/4-A	Lab Control Sample	Total/NA	Drinking Water	EPA 537 Ver 1.1	104025

Analysis Batch: 104908

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-32304-3 - DL	7670061 003 DuPont Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	104025
410-32304-11	7670061 001 Playground Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	104025
410-32304-12	7670061 001 Playground Well FB	Total/NA	Potable Water	EPA 537 Ver 1.1	104025
410-32304-13	7670061 301 Conley Between Lead & Lag	Total/NA	Drinking Water	EPA 537 Ver 1.1	104025
410-32304-14	7670061 301 Conley Between Lead & Lag FB	Total/NA	Potable Water	EPA 537 Ver 1.1	104025
410-32304-15	7670061 301 Conley After Lag Vessel	Total/NA	Drinking Water	EPA 537 Ver 1.1	104025
410-32304-16	7670061 301 Conley After Lag Vessel FB	Total/NA	Potable Water	EPA 537 Ver 1.1	104025
410-32304-17	7670061 101 Conley EP Grab Water	Total/NA	Drinking Water	EPA 537 Ver 1.1	104025
410-32304-18	7670061 101 Conley Field Blank Grab Water	Total/NA	Potable Water	EPA 537 Ver 1.1	104025

Prep Batch: 105505

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-32304-1	7670061 002 Coppersmith Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	
410-32304-2	7670061 002 Coppersmith Well FB	Total/NA	Potable Water	EPA 537 Ver 1.1	
MB 410-105505/1-A	Method Blank	Total/NA	Drinking Water	EPA 537 Ver 1.1	
LCS 410-105505/2-A	Lab Control Sample	Total/NA	Drinking Water	EPA 537 Ver 1.1	
LCS D 410-105505/3-A	Lab Control Sample Dup	Total/NA	Drinking Water	EPA 537 Ver 1.1	
LLCS 410-105505/4-A	Lab Control Sample	Total/NA	Drinking Water	EPA 537 Ver 1.1	

QC Association Summary

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

LCMS

Analysis Batch: 106118

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-32304-1	7670061 002 Coppersmith Well	Total/NA	Drinking Water	EPA 537 Ver 1.1	105505
410-32304-2	7670061 002 Coppersmith Well FB	Total/NA	Potable Water	EPA 537 Ver 1.1	105505
MB 410-105505/1-A	Method Blank	Total/NA	Drinking Water	EPA 537 Ver 1.1	105505
LCS 410-105505/2-A	Lab Control Sample	Total/NA	Drinking Water	EPA 537 Ver 1.1	105505
LCSD 410-105505/3-A	Lab Control Sample Dup	Total/NA	Drinking Water	EPA 537 Ver 1.1	105505
LLCS 410-105505/4-A	Lab Control Sample	Total/NA	Drinking Water	EPA 537 Ver 1.1	105505

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15

Lab Chronicle

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Client Sample ID: 7670061 002 Coppersmith Well

Lab Sample ID: 410-32304-1

Date Collected: 03/11/21 08:50

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			105505	03/22/21 07:21	W5MU	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	106118	03/23/21 13:23	PY4D	ELLE

Client Sample ID: 7670061 002 Coppersmith Well FB

Lab Sample ID: 410-32304-2

Date Collected: 03/11/21 08:50

Matrix: Potable Water

Date Received: 03/12/21 11:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			105505	03/22/21 07:21	W5MU	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	106118	03/23/21 23:09	PY4D	ELLE

Client Sample ID: 7670061 003 DuPont Well

Lab Sample ID: 410-32304-3

Date Collected: 03/11/21 09:25

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			104025	03/17/21 07:58	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	104594	03/18/21 14:11	DCS9	ELLE
Total/NA	Prep	EPA 537 Ver 1.1	DL		104025	03/17/21 07:58	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1	DL	10	104908	03/19/21 04:55	DCS9	ELLE

Client Sample ID: 7670061 003 DuPont Well FB

Lab Sample ID: 410-32304-4

Date Collected: 03/11/21 09:25

Matrix: Potable Water

Date Received: 03/12/21 11:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			104025	03/17/21 07:58	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	104594	03/18/21 14:23	DCS9	ELLE

Client Sample ID: 7670061 302 DuPont Between Lead & Lag

Lab Sample ID: 410-32304-5

Date Collected: 03/11/21 09:20

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			104025	03/17/21 07:58	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	104594	03/18/21 14:34	DCS9	ELLE

Client Sample ID: 7670061 302 DuPont After Lag Vessel

Lab Sample ID: 410-32304-7

Date Collected: 03/11/21 09:15

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			104025	03/17/21 07:58	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	104594	03/18/21 14:57	DCS9	ELLE

Lab Chronicle

Client: SUEZ Water Environmental Services Inc
 Project/Site: Newberry System

Job ID: 410-32304-1

Client Sample ID: 7670061 102 DuPont EP

Lab Sample ID: 410-32304-9

Date Collected: 03/11/21 09:10

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			104025	03/17/21 07:58	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	104594	03/18/21 15:20	DCS9	ELLE

Client Sample ID: 7670061 001 Playground Well

Lab Sample ID: 410-32304-11

Date Collected: 03/11/21 10:05

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			104025	03/17/21 07:58	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	104908	03/19/21 05:06	DCS9	ELLE

Client Sample ID: 7670061 001 Playground Well FB

Lab Sample ID: 410-32304-12

Date Collected: 03/11/21 10:05

Matrix: Potable Water

Date Received: 03/12/21 11:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			104025	03/17/21 07:58	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	104908	03/19/21 05:18	DCS9	ELLE

Client Sample ID: 7670061 301 Conley Between Lead & Lag

Lab Sample ID: 410-32304-13

Date Collected: 03/11/21 10:00

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			104025	03/17/21 07:58	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	104908	03/19/21 05:29	DCS9	ELLE

Client Sample ID: 7670061 301 Conley Between Lead & Lag FB

Lab Sample ID: 410-32304-14

Date Collected: 03/11/21 10:00

Matrix: Potable Water

Date Received: 03/12/21 11:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			104025	03/17/21 07:58	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	104908	03/19/21 05:41	DCS9	ELLE

Client Sample ID: 7670061 301 Conley After Lag Vessel

Lab Sample ID: 410-32304-15

Date Collected: 03/11/21 09:55

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			104025	03/17/21 07:58	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	104908	03/19/21 05:52	DCS9	ELLE

Lab Chronicle

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Client Sample ID: 7670061 301 Conley After Lag Vessel FB

Lab Sample ID: 410-32304-16

Date Collected: 03/11/21 09:55

Matrix: Potable Water

Date Received: 03/12/21 11:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			104025	03/17/21 07:58	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	104908	03/19/21 06:03	DCS9	ELLE

Client Sample ID: 7670061 101 Conley EP Grab Water

Lab Sample ID: 410-32304-17

Date Collected: 03/11/21 09:50

Matrix: Drinking Water

Date Received: 03/12/21 11:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			104025	03/17/21 07:58	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	104908	03/19/21 06:15	DCS9	ELLE

Client Sample ID: 7670061 101 Conley Field Blank Grab Water

Lab Sample ID: 410-32304-18

Date Collected: 03/11/21 09:50

Matrix: Potable Water

Date Received: 03/12/21 11:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	EPA 537 Ver 1.1			104025	03/17/21 07:58	RDL8	ELLE
Total/NA	Analysis	EPA 537 Ver 1.1		1	104908	03/19/21 06:26	DCS9	ELLE

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Env, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300

Accreditation/Certification Summary

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Laboratory: Eurofins Lancaster Laboratories Env, LLC

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Pennsylvania	NELAP	36-00037	01-31-22

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

Method Summary

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Method	Method Description	Protocol	Laboratory
EPA 537 Ver 1.1	EPA 537 Version 1.1	EPA	ELLE
EPA 537 Ver 1.1	EPA 537 Version 1.1	EPA	ELLE

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Env, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300



Sample Summary

Client: SUEZ Water Environmental Services Inc
Project/Site: Newberry System

Job ID: 410-32304-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Asset ID
410-32304-1	7670061 002 Coppersmith Well	Drinking Water	03/11/21 08:50	03/12/21 11:30	
410-32304-2	7670061 002 Coppersmith Well FB	Potable Water	03/11/21 08:50	03/12/21 11:30	
410-32304-3	7670061 003 DuPont Well	Drinking Water	03/11/21 09:25	03/12/21 11:30	
410-32304-4	7670061 003 DuPont Well FB	Potable Water	03/11/21 09:25	03/12/21 11:30	
410-32304-5	7670061 302 DuPont Between Lead & Lag	Drinking Water	03/11/21 09:20	03/12/21 11:30	
410-32304-7	7670061 302 DuPont After Lag Vessel	Drinking Water	03/11/21 09:15	03/12/21 11:30	
410-32304-9	7670061 102 DuPont EP	Drinking Water	03/11/21 09:10	03/12/21 11:30	
410-32304-11	7670061 001 Playground Well	Drinking Water	03/11/21 10:05	03/12/21 11:30	
410-32304-12	7670061 001 Playground Well FB	Potable Water	03/11/21 10:05	03/12/21 11:30	
410-32304-13	7670061 301 Conley Between Lead & Lag	Drinking Water	03/11/21 10:00	03/12/21 11:30	
410-32304-14	7670061 301 Conley Between Lead & Lag FB	Potable Water	03/11/21 10:00	03/12/21 11:30	
410-32304-15	7670061 301 Conley After Lag Vessel	Drinking Water	03/11/21 09:55	03/12/21 11:30	
410-32304-16	7670061 301 Conley After Lag Vessel FB	Potable Water	03/11/21 09:55	03/12/21 11:30	
410-32304-17	7670061 101 Conley EP Grab Water	Drinking Water	03/11/21 09:50	03/12/21 11:30	
410-32304-18	7670061 101 Conley Field Blank Grab Water	Potable Water	03/11/21 09:50	03/12/21 11:30	

Login Sample Receipt Checklist

Client: SUEZ Water Environmental Services Inc

Job Number: 410-32304-1

Login Number: 32304

List Source: Eurofins Lancaster Laboratories Env

List Number: 1

Creator: Jeremiah, Cory T

Question	Answer	Comment
Radioactivity wasn't checked or is \leq background as measured by a survey meter.	N/A	
The cooler's custody seal is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable ($\leq 6^{\circ}\text{C}$, not frozen).	True	
Cooler Temperature is recorded.	True	
WV: Container Temperature is acceptable ($\leq 6^{\circ}\text{C}$, not frozen).	N/A	
WV: Container Temperature is recorded.	N/A	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses.	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	N/A	
Is the Field Sampler's name present on COC?	True	
Sample Preservation Verified.	N/A	
Residual Chlorine Checked.	N/A	
Sample custody seals are intact.	N/A	

