

**MIPC Chelsea Tank Farm Site  
Potable Well Analytical Results Summary**

Sample ID	Well Depth (feet)	Pump Depth (feet)	Sample Date	Benzene (ug/L)	Toluene (ug/L)	Ethylbenzene (ug/L)	Xylenes (total) (ug/L)	Isopropylbenzene (ug/L)	Methyl Tert Butyl Ether (MTBE) (ug/L)	Naphthalene (ug/L)	1,2,4-Trimethylbenzene (ug/L)	1,3,5-Trimethylbenzene (ug/L)
<b>PADEP Residential Statewide Health Standard (SHS)</b>				<b>5</b>	<b>1,000</b>	<b>700</b>	<b>10,000</b>	<b>840</b>	<b>20</b>	<b>100</b>	<b>130</b>	<b>130</b>
<b>EPA Maximum Contaminant Level (MCL)</b>				<b>5</b>	<b>1,000</b>	<b>700</b>	<b>10,000</b>	<b>NE</b>	<b>NE</b>	<b>NE</b>	<b>NE</b>	<b>NE</b>
<b>PW-01</b>	195	75	1/29/2026	ND	ND	ND	ND	ND	ND	ND	ND	ND
<b>PW-DUP</b>				ND	ND	ND	ND	ND	ND	ND	ND	ND
<b>PW-02</b>	Unknown	Unknown	1/29/2026	ND	ND	ND	ND	ND	ND	ND	ND	ND
<b>PW-03</b>	Unknown	Unknown	1/29/2026	ND	ND	ND	ND	ND	ND	ND	ND	ND

Notes:

PADEP Pennsylvania Department of Environmental Protection

EPA United States Environmental Protection Agency

ug/L Micrograms/Liter

NE Not Established

ND Not Detected

Samples analyzed via EPA Method 524.2