



WATER  
AT YOUR SERVICE

*Vanport Township Municipal Authority*

285 RIVER AVENUE

VANPORT, PENNSYLVANIA 15009

(412) 774-2091

(412) 775-1038

May 23, 1991

Westinghouse Corporation  
One Tuscarawas Road  
Beaver, PA 15009

Attn: E.F. Farland

Dear Mr. Farland:

In regards to your correspondence of May 14, 1991 and in conjunction with our telecommunication on May 22, 1991 concerning tower operation sampling.

At the last scheduled Authority meeting, your letter was discussed and the general consensus was that 2 towers will remain in operation.

This decision is based on lab data which shows during demand hours when 3 wells are engaged that the effluent from tower #1 does not meet State or Federal standards.

As for your decision of discontinuing sampling of tower #1 discharges, it would certainly seem logical; however, this matter would best be discussed with the DER as our involvement in such matters are limited.

Sincerely,

David P. Brooks  
Superintendent

DPB/djl

CC: Dept. of Environmental Resources - C.A. Duritsa  
Westinghouse - Pittsburgh - R.E. Wills



Westinghouse  
Electric Corporation

Distribution and Control  
Business Unit

1 Tuscarawas Road  
Beaver Pennsylvania 15009  
(412) 775 2000

June 28, 1991

Mr. Dave Hreha  
NUS Corporation  
Laboratory Services Group  
5350 Campbells Run Road  
Pittsburgh, PA 15205

Subject: Revised Sampling Procedure  
Vanport Stripping Towers

Dear Mr. Hreha:

Effective immediately, sampling at tower #1 discharge is to be eliminated and samples will be taken at tower #1 inlet and tower 2 discharge only. This change is due to the Municipal Authority's decision to run two towers continuously rather than one as per the design.

  
E.F. Farland, Manager  
Works Engineering

cc: (W) Beaver - W.A. Schmidt  
(W) Pgh. Gateway - R.E. Wills  
PADER - C. Duritsa  
Vanport Municipal Authority - R. Bumiller

HREHA/s