

Date(s) of Inspection: 1/22/26	TV <input checked="" type="checkbox"/> SM <input type="checkbox"/> NM <input type="checkbox"/>	PA <input checked="" type="checkbox"/> GP <input type="checkbox"/> MEGA <input type="checkbox"/>	Permit #(s): PA-04-740 A,B,C	Expiration Date:	Case #: 04-740	PF ID #: 775836
Company Name: Shell Chemicals		Municipality: Potter Twp.		County: Beaver		
Plant Name: Petrochemical Complex		Physical Location: Route 18		Federal ID — Plant Code #: 46-1624986-1		
Responsible Official: Nathan Levin			Mailing Address: 300 Frankfort Rd. Monaca, PA 15061			
Title: General Manager						
Phone #(s): 724-709-2825						

Mark (X) All Inspection Types That Apply To This Inspection:

<input type="checkbox"/> Full Compliance Evaluation (FCE)	<input type="checkbox"/> Plan Approval Inspection	<input type="checkbox"/> File Review (FR)
<input type="checkbox"/> Operating Permit Inspection (PI)	<input type="checkbox"/> Initial Permit Inspection (IPI)	<input type="checkbox"/> Complaint Inspection (CI)
<input checked="" type="checkbox"/> Routine/Partial (RTPT)	<input type="checkbox"/> Follow-Up Inspection (Ref. Date: _____)	<input type="checkbox"/> Sample Collection (SC)
<input type="checkbox"/> Minor Source(s) Inspection (RFD)	<input type="checkbox"/> Stack Test Observation	<input type="checkbox"/> Multi-Media Inspection (MM)
<input type="checkbox"/> Other:	<input type="checkbox"/> Announced	

Annual Compliance Certification Received: YES NO N/A ~ Date Received:

AIMS Report Received: YES NO N/A Date Received:

Mark (X) All Activities That Apply:

<input checked="" type="checkbox"/> File Review	<input checked="" type="checkbox"/> Pre-Inspection Briefing	<input checked="" type="checkbox"/> Exit Interview/Briefing
<input checked="" type="checkbox"/> Pre-Inspection Observations	<input type="checkbox"/> Check For New/Unreported Sources	<input type="checkbox"/> Sample(s) Collected
<input type="checkbox"/> Visible Emissions Observations	<input type="checkbox"/> Verify Operation of CEMS	<input type="checkbox"/> Other

Comments/Recommendations: Enforcement since last FCE Yes No (If yes, attach summary)

Today I performed a Routine Partial Inspection at Shell Chemical Appalachias Petrochemical complex in Potter Twp. I met with Lauren Uffelman, Shell Chemicals. The facility was in operation today. We discussed the Flaring that occurred at shell during the night of 1/15/26 and into 1/16/26.

Compliance Status: In Out Pending Awaiting Co. Report Needs a Follow-Up Inspection? Yes No

Company Representative: Lauren Uffelman	Title: Environmental Engineer	Signature: 	Date: 1/22/26
DEP Representative: Scott Beaudry	Title: AQS	Signature: 	Date/Time: 1/22/26

This document is official notification that a representative of the Department of Environmental Protection, Air Quality Program, inspected the identified site. The findings of this inspection are shown above and on any attached pages, and may include violations uncovered during the inspection. Violations may also be discovered upon review of sample results or from any additional review of Department records. Notification will be forthcoming, if such violations are noted.



INSPECTION REPORT

Continued

Polyethylene #3 began start-up on 1/15/26 at 12:00 PM. PE3 was vented, as needed to the Continuous Vent Thermal Oxidizer (CVTO) as required/designed. At 6:40 PM the pressure of the CVTO went gas header reached the pressure set point of the valve separating the CVTO from the Multipoint Ground Flare (MPGF), sending all flow to the MPGF as designed. The MPGF Flared until 11:15 AM on 1/16/26. Shell chemicals did not observe any visible, fugitive or malodor emissions from the flaring. This was not a malfunction.

The process operated as designed and per the Plan Approval Permit. Lauren Uffelman confirmed that this did meet the definition of a Flaring Event.

Shell will complete the Root Cause Analysis Report ~~as required~~, as required.

I reviewed the Shell camera footage of the MPGF Flaring, from 6:30 PM on 1/15/26 to 12:00 PM on 1/16/26. I did not observe any visible, or fugitive emissions. I only observed steam from the Cooling Towers, the light of the MPGF illuminating the steam plumes.

I did not observe any violations. I did not observe any visible, fugitive or malodor emissions on site at Shell chemicals today.

Company -- plant name:

Shell Chemicals

Initials of representative interviewed:

Date:

1/22/26

Page 2 of 2Reviewed By Stephen J. Wiedemer White - Site Yellow - District Office Pink - Regional Office