2700-FM-AQ0023 Rev. 1/2008 pennsylvania DEPARTMENT OF ENVIRONMENTAL PROTECTION			INSPECTION REPORT			Commonwealth of Pennsylvania Department of Environmental Protection Air Quality Program			
Date(s) of Inspection: TV □ PA □ GP □ GP □ NM □ MEGA □ MEGA		□	Permit #(s): PA-04-00740A, B, C	Expiratio	on Date:	Case 04 -	• #: -00740	PF ID #: 775836	
Company Name: Shell Chemical Appalachia LLC			Municipality: Potter Township			County: Beaver			
SI /P	ant Name: HELL CHEM APPALACHIA ETROCHEMICALS COMPLEX	Physical Location: Route 18		Federal ID — Plant Code #: 46-1624986-1					
Responsible Official: William Watson				Mailing Address: 300 Frankfort Road					
General Manager				Monaca, PA 15061-2210					
	one #(s): 24-709-2825								
M	ark(X) All Inspection Types T	hat	Apply To This In:	spectio	n:				
	Full Compliance Evaluation (FCE)		Plan Approval Inspect	tion			File Review (FR)		
	Operating Permit Inspection (PI)		Initial Permit Inspectio	on (IPI)		☒	Complaint Inspection (CI)		
\boxtimes	Routine/Partial (RTPT)		Follow-Up Inspection (Ref. Date:	:)		Sample Collection	n(SC)	
	Minor Source(s) Inspection (RFD)		Stack Test Observation	n			Multi-Media Inspection (MM)		
	Other:		Announced						
Annual Compliance Certification Received: Ye			ES ☐ NO ☒ N/A Date Receive			ed:			
ΑI	MS Report Received:	S ☐ NO ☒ N/A Date Receive			ed:				
M	ark (X) All Activities That App	ly:							
	File Review		Pre-Inspection Briefing	ng			Exit Interview/Briefing		
	Pre-Inspection Observations		Check For New/Unrep	oorted Sou	ırces		Sample(s) Collected		
☐ Visible Emissions Observations ☐			Verify Operation of CEMS				Other		
Compliance Status: In Out Pending Awaiting Co. Report Needs a Follow-Up Inspection? Yes No SIC: 2821 NAICS: 221112 I inspected Beaver and Vanport downwind of the Shell Chemicals facility late-morning today and did not observe any malodors. I observed the Shell Chemicals facility today from 11:30 AM to 1:30 PM. The weather was partly cloudy, dry									
and 45 degrees F. I was located across the river at the at the Dock 6 building. I did not observe any visible, fugitive or malodor emissions today. I inspected Beaver and Vanport downwind of the Shell Chemicals facility early-afternoon today and did not									
	nspected Beaver and Vanport doserve any malodors.	owr	nwind of the Shell (Snemic	als facility e	arıy [.]	-arternoon toda	ay and did not	
' ' '			tle:		Signature:			Date:	
MEMO TO FILE									
		Titl			Signature:		'05	Date/Time:	
•			r Quality Specialist		Scott Beau			3/28/23	
ins	s document is official notification that a representa pection are shown above and on any attached pag ults or from any additional review of Department re	jes, a	nd may include violations und	covered dur	ing the inspection.	Violati			

Page 1 of 3 eFacts Inspection ID#: 3527878 Date: 3/28/23 Reviewed By_____

Shell Chemical Appalachia LLC, 04-00740

I contacted Shell Chemicals to inform them of my observations and to request the list of operating sources and control devices. Shell Chemicals provided a list of sources and control devices in operation at the time of my observations.

Sources reported to be in operation during my site observation:

```
031 Ethane Cracking Furnace 1 - Operating Hot Steam Standby
032 Ethane Cracking Furnace 2 - Operating Hot Steam Standby
033 Ethane Cracking Furnace 3 - Operating Hot Steam Standby
034 Ethane Cracking Furnace 4 - Operating Hot Steam Standby
035 Ethane Cracking Furnace 5 - Not Operating (Pilots Only)
036 Ethane Cracking Furnace 6 - Not Operating (Pilots Only)
037 Ethane Cracking Furnace 7 - Operating Hot Steam Standby
101 Cogen 1 CT+ DB - Operating
102 Cogen 2 CT+ DB - Operating
103 Cogen 3 CT+ DB - Operating
104 Cogeneration Plant Cooling Tower - Operating
105 Diesel-Fired Emergency Generator Engines - Standby
106 Fire Pump Engines - Standby
107 Natural Gas Fired Emergency Generator Engines - Standby
201 Ethylene Manufacturing Line - Operating Minimum Rates
202 Polyethylene Manufacturing Lines - PE1, PE2, PE3 Not Operating
203 Process Cooling Tower - Operating
204 Low Pressure (LP) Header System - Operating LP Incinerator and Multipoint Ground Flare
205 High Pressure (HP) Header System - Operating HP Ground Flare A and B. Not Operating HP Elevated
Flare
206 Spent Caustic Vent Header System - Operating Spent Caustic Vent Incinerator
301 Polyethylene Pellet Material Storage/Handling/Loadout - Operating
302 Liquid Loadout (Recovered Oil) - Not Operating
303 Liquid Loadout (Pyrolysis Fuel Oil, Light Gasoline) - Operating
304 Liquid Loadout (C3+, Butene, Isopentane, Isobutane, C3+ Ref) - Operating
305 Liquid Loadout (Coke Residue/Tar) - Not Operating
401 Storage Tanks (Recovered Oil, Equalization Wastewater) - Operating
402 Storage Tank (Spent Caustic) - Operating
403 Storage Tanks (Light Gasoline) - Operating
404 Storage Tanks (Hexene) - Operating
405 Storage Tanks (Misc Pressurized/Refrigerated) - Operating
406 Storage Tanks (Diesel Fuel > 150 Gallons) - Operating
407 Storage Tanks (Pyrolysis Fuel Oil) - Operating
408 Storage Tanks (Diesel Fuel < 150 Gallons) - Operating
409 Methanol Storage Vessels and Associated Components -Operating
501 Equipment Components - Operating
502 Wastewater Treatment Plant - Operating
```

All Listed Controls Operating

503 Plant Roadways - In Use

Shell Chemical Appalachia LLC, 04-00740

Effective January 16, 2021, all air quality applications, Permits, Requests for Determinations and initial Asbestos Notifications will be subject to new and/or increased fees. The new fees and other PADEP Air Quality information can be found at: https://www.dep.pa.gov/Business/Air/Pages/default.aspx

As of July 29, 2021, the Source Testing Section has gone paperless. An individual Source Testing Section reviewer may request a hard copy from the facility or the consultant. Note that the section will continue to require electronic submissions of protocols and reports to the resource email account (<u>raepstacktesting@pa.gov</u> or by disk and snail mail when the file is over 35 MBs). Periodic Monitoring reports (generally three 20-minute test runs) shall only be submitted to the regional office.

As of November 10, 2021, there have been some changes to how the regional offices will accept electronic submission. OnBase submissions of protocols and reports will no longer be accepted for Source Testing.

SWRO: Any email submission to <u>ra-epstacktesting@pa.gov</u> should also be CC-ed to <u>ra-epswstacktesting@pa.gov</u>. Beyond that email cc, no further submission is necessary to DEP SWRO (i.e. no hard copy or disk needed for SWRO).