

Disinfection Requirements Rule (DRR) Reporting Instructions: *What's New for Public Water Systems using Chlorine Dioxide?*

Beginning with the **JUNE 2018** compliance period, please use the specific method codes listed below:

Contaminant /ID	Method Name	Method Number	DEP Method Code	Reporting under the Disinfectants and Disinfectant Byproducts Rule (DDBP) or Surface Water Treatment Rule (SWT)
Chlorine Dioxide 1008	DPD	SM 4500-ClO ₂ D	578	DDBP or SWT
	Amperometric Titration	SM 4500-ClO ₂ E	594	DDBP or SWT
	Lissamine Green Spectrophotometric	EPA 327.0 Rev 1.1	175	DDBP or SWT
	Amperometric Sensor	ChlordioX Plus 32 (PalinTest)	596	DDBP or SWT
	Amperometric Titration	SM 4500-ClO ₂ C	598	SWT ONLY

Contaminant /ID	Method Name	Method Number	DEP Method Code	For Reporting of Samples Analyzed by PWS (Daily) or Samples Analyzed by Lab (Monthly/Additional)
Chlorite 1009	Chemically Suppressed Ion Chromatography	ASTM D6581-08 A	995	Daily or Monthly/Additional
	Electrically Suppressed Ion Chromatography	ASTM D6581-08 B	994	Daily or Monthly /Additional
	Amperometric Titration	SM 4500-ClO ₂ E	594	Daily Only
	Amperometric Sensor	ChlordioX Plus 32 (PalinTest)	596	Daily Only
	Lissamine Green Spectrophotometric	EPA 327.0 Rev 1.1	175	Daily Only
	Ion Chromatography	EPA 300.0, 300.1	120	Daily or Monthly/Additional
		EPA 317.0 Rev 2.0	172	
EPA 326.0		173		