

Disinfection Requirements Rule (DRR)

DRR Website:

- Go to www.dep.pa.gov
- At the top, click on “Businesses”
- Click the blue button for “Water”
- On the right, click on “Bureau of Safe Drinking Water”
- Click on “Drinking Water Management”
- Click on “Regulations”
- Click on “Disinfection Requirements Rule”

DRR Treatment Technique (TT):

Minimum distribution residual disinfectant concentration	= 0.2 mg/L
---	-------------------

DRR Monitoring Requirements:

- Monitor in accordance with DRR sample siting plan (SSP)
- Monitor at the same time and from the same location as required coliform samples under Revised Total Coliform Rule (RTCR)
- Monitor at representative locations in the distribution system at least once per week (Sunday to Saturday)
- Monitor during normal operating conditions
- For any sites that do NOT meet the minimum (0.2 mg/L), monitor those sites the following month

DRR Reporting Requirements:

- Report all individual results on SDWA-1
- Report electronically via DWELR by the 10th of the following month
- For grab sample results, report all results, even if more than one measurement per day per location
- For online monitoring, report a daily average result
- Use the reporting instructions, found on the DRR website, for proper reporting codes and examples

DRR Compliance Determination:

***SW or GUDI systems collecting
≥ 20 samples per month****

- **More than 5% of samples per month below the minimum of 0.2 mg/L in 2 consecutive months is a treatment technique (TT) violation**
 - Failure to meet the DRR TT is a Tier 2 TT violation requiring Tier 2 Public Notice (PN)
- * NOTE: This is based on the number of samples per month according to the sample siting plan (SSP)

System Specific Compliance:

PWS ID	
Parameter monitored (free chlorine, total chlorine, other)	
# of samples collected per month for DRR (per SSP)	
# of samples per month in 2 consecutive months that will cause a TT violation	

PA Safe Drinking Water Regulations (Chapter 109):

- Go to www.pacode.com
- On the left, click on “Browse”
- Click “25 ENVIRONMENTAL PROTECTION”, then click “Select”
- Scroll to Chapter 109, and click on “Safe Drinking Water”

