

2010 Chapter 109 Index - November 10, 2010

(yellow highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, and GWR citations)

This index provides many of the Chapter 109 citations. Those highlighted in yellow are new citations as a result of the following regulations:

PN Revisions - May 2009

General Update Revisions - May 2009

Groundwater Rule - December 2009

Long-Term 2 Enhanced Surface Water Treatment Rule - December 2009

Stage 2 Disinfectants and Disinfection Byproducts Rule - December 2009

This is the hierarchy of names that are used in Chapter 109:

109 Chapter

A Subchapter

.1 Section

(a) Subsection

(1) Paragraph

(i) Subparagraph

(A) Clause

(V) Subclause

(-a-) Item

(-1-) Subitem

2010 Chapter 109 Index - November 10, 2010

(yellow highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, and GWR citations)

A	GENERAL PROVISIONS	109-1
109.1	Definitions	109-2
	Bag filter	109-2
	Bank filtration	109-2
	Cartridge filter	109-3
	Combined distribution system	109-4
	Conventional filtration	109-4
	DBP	109-4
	Dual sample set	109-5
	Flowing stream	109-6
	GAC10	109-6
	GAC20	109-6
	Groundwater	109-6
	IDSE	109-7
	LRAA	109-7
	Lake/reservoir	109-7
	Log inactivation	109-7
	Log treatment	109-9
	Membrane filtration	109-10
	Microorganism	109-10
	Plant intake	109-10
	Presedimentation	109-11
	RAA	109-11
	Reliably and consistently below the MCL	109-11
	Significant deficiency	109-12
	Wholesale system	109-14
109.2	Purpose	109-15
109.3	Scope	109-15
109.4	General requirements	109-15
109.5	Organization of chapter	109-15
109.5(e)	Subchapter L (LT2ESWTR) applies to all PWSs using surface water or GUDI sources	109-16
109.5(f)	Subchapter M (additional requirements for GW sources) applies to all PWSs that use groundwater, excluding those systems that combine GW with SW or GUDI sources prior to treatment	109-16
109.6	Inspection authorization	109-16
B	MCLS, MRDLS, OR TREATMENT TECHNIQUE REQUIREMENTS	109-18
109.201	Authority	109-18
109.202	State MCLs, MRDLS and treatment technique requirements	109-19
109.202(a)	Primary MCLs	109-19
109.202(b)	Secondary MCLs	109-19
109.202(c)	Treatment technique requirements for pathogenic bacteria, viruses and protozoan cysts	109-19
109.202(c)(1)(i)(A)	Conventional or direct filtration	109-20
109.202(c)(1)(i)(B)	Slow sand or diatomaceous earth filtration	109-20
109.202(c)(1)(i)(C)	Other filtration technologies	109-20
109.202(c)(1)(ii)	Combined total disinfection processes for filtration plants	109-20
109.202(c)(1)(iii)	Unfiltered surface water treatment technique requirements	109-21
109.202(c)(1)(iv)	Unfiltered SW experiencing turbidity, microbial violations, contamination or outbreak feasibility study and permit requirements	109-22
109.202(c)(1)(v)	Subparagraph iv requirements do not impact compliance order requirements	109-23

2010 Chapter 109 Index - November 10, 2010

(yellow highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, and GWR citations)

109.202(c)(1)(vi)	Springs, infiltration galleries and GUDI source treatment technique requirements	109-23
109.202(c)(2)	PWS using SW or GUDI sources comply with Subchapter L (LT2ESWTR)	109-23
109.202(c)(3)	CWS shall provide continuous disinfection and comply with Subchapter M (GWR)	109-23
109.202(d)	Fluoride	109-23
109.202(e)	Treatment technique requirements for acrylamide and epichlorohydrin	109-23
109.202(f)	MRDLs.....	109-23
109.202(g)	Treatment technique requirements for disinfection byproduct precursors	109-24
109.202(h)	Recycling of waste stream	109-24
109.203	Unregulated contaminants.....	109-24.1
109.204	Disinfection profiling and benchmarking	109-24.1
109.204(a)	Disinfection profiling and benchmarking requirements are incorporated by reference.....	109-24.1
109.204(b)	PWs that serve 10,000 or more before 1/1/05 shall comply with this section	109-24.1
109.204(c)	PWSs shall conduct disinfection profiling using EPA's guidance manual.....	109-24.2
C	MONITORING REQUIREMENTS	109-24.2
109.301	General monitoring requirement.....	109-24.2
109.301(1)	Performance monitoring for filtration and disinfection	109-24.3
109.301(1)(i)(A)	Shall determine and record the turbidity level as follows:	109-24.3
109.301(1)(i)(A)(I)	For systems that operate continuously, at least once every 4 hours that the system is in operation except provided in clause (B)	109-24.3
109.301(1)(i)(A)(II)	For systems that do not operate continuously, at start-up, at least once every 4 hours that the system is in operation and also prior to shutting down the plant, except as provided in clause (B).....	109-24.3
109.301(1)(i)(B)	May substitute continuous turbidity monitoring and recording..At a minimum, calibration with an EPA-approved primary standard shall be conducted at least quarterly	109-24.3
109.301(2)	Performance monitoring for unfiltered surface water and GUDI	109-25
109.301(3)	Monitoring requirements for coliforms.....	109-27
109.301(3)(i)	Frequency.....	109-27
109.301(3)(ii)	Repeat Monitoring	109-29
109.301(3)(iii)	Invalidation of total coliform samples	109-30
109.301(3)(iv)	Compliance determinations	109-31
109.301(3)(v)	Special purpose samples.....	109-32
109.301(4)	Exception	109-32
109.301(5)	Monitoring requirements for VOCs.....	109-32
109.301(5)(i)	Vinyl chloride.....	109-32
109.301(5)(ii)	Initial monitoring schedule.....	109-32
109.301(5)(iii)	Repeat monitoring for entry points at which a VOC is detected.....	109-33
109.301(5)(iv)	Repeat monitoring for entry points at which no VOC is detected	109-34
109.301(5)(v)	Repeat monitoring for VOCS with MCL exceedances.....	109-34
109.301(5)(vi)	Confirmation samples.....	109-34
109.301(5)(vii)	Reduced monitoring	109-34
109.301(5)(viii)	Waivers	109-35
109.301(5)(ix)	Invalidation of VOC samples	109-35
109.301(5)(ix)	Compliance determinations.....	109-35
109.301(6)	Monitoring requirements for SOCs	109-36
109.301(6)(i)	Initial monitoring schedule.....	109-36
109.301(6)(ii)	Repeat monitoring for SOCs that are detected	109-36
109.301(6)(iii)	Repeat monitoring for SOCs that are not detected	109-36
109.301(6)(iv)	Repeat monitoring for SOCs with MCL exceedances	109-37
109.301(6)(v)	Confirmation samples.....	109-37
109.301(6)(vi)	Reduced monitoring	109-37
109.301(6)(vii)	Waivers	109-38
109.301(6)(vii)(A)	Vulnerability assessment area for SOCs except dioxin and PCBs.....	109-38
109.301(6)(vii)(B)	Use waivers	109-38
109.301(6)(vii)(C)	Susceptibility waivers	109-38

2010 Chapter 109 Index - November 10, 2010

(yellow highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, and GWR citations)

109.301(6)(vii)(D)	Waiver requests and renewals	109-39
109.301(6)(vii)(E)	Waivers for dioxin and PCBs	109-39
109.301(6)(viii)	Invalidation of SOC samples	109-39
109.301(6)(ix)	Compliance determinations	109-39
109.301(7)	Monitoring requirements for IOCs	109-39
109.301(7)(i)	Monitoring requirements for asbestos	109-40
109.301(7)(i)(A)	Waivers for asbestos monitoring	109-40
109.301(7)(i)(B)	Initial monitoring schedule	109-40
109.301(7)(i)(C)	Monitoring of new entry points	109-40
109.301(7)(i)(D)	Repeat monitoring for systems that exceed the asbestos MCL	109-40
109.301(7)(i)(E)	Confirmation samples	109-40
109.301(7)(ii)	Monitoring requirements for nitrate and nitrite	109-40
109.301(7)(ii)(A)	Initial monitoring schedule	109-40
109.301(7)(ii)(B)	Monitoring of new entry points	109-41
109.301(7)(ii)(C)	Repeat monitoring for systems with nitrate or nitrite levels equal to or greater than 50% of the MCL	109-41
109.301(7)(ii)(D)	Repeat monitoring for systems with nitrate or nitrite levels less than 50% of the MCL	109-42
109.301(7)(iii)	Monitoring requirements for antimony, arsenic, barium beryllium, cadmium, cyanide, chromium, fluoride, mercury, nickel, selenium and thallium	109-42
109.301(7)(iii)(A)	Initial monitoring schedule	109-42
109.301(7)(iii)(B)	Monitoring of new entry points	109-42
109.301(7)(iii)(C)	Repeat monitoring for entry points at which an IOC MCL is exceeded	109-42
109.301(7)(iii)(D)	Waivers for IOC monitoring	109-42
109.301(7)(iii)(E)	Waivers for cyanide monitoring	109-43
109.301(7)(iii)(F)	Operational monitoring for fluoride	109-44
109.301(7)(iv)	Invalidation of IOC samples	109-44
109.301(7)(v)	Compliance determinations	109-44
109.301(8)	Monitoring requirements for public water systems that obtain finished water from another public water system	109-45
109.301(8)(iii)	Consecutive water supplies may be exempt from conducting monitoring for the MCLS for VOCS, SOCs, and IOCs and rads if the PWS from which finished water is obtained complies with monitoring and is in compliance with the MCLS.	109-45
109.301(9)	Monitoring requirements for POE devices	109-46
109.301(10)	Additional monitoring	109-46
109.301(11)	Monitoring requirements for entry points that do not provide water continuously	109-46
109.301(12)	Monitoring requirements for disinfection byproducts and disinfection byproduct precursors	109-46
109.301(12)(i)	TTHMs and HAA5 Stage 1 DBP Rule	109-46
109.301(12)(i)(A)	Routine monitoring	109-46
109.301(12)(i)(B)	Reduced monitoring Systems serving at least 500 persons and that use SW or GUDI sources shall monitor source water TOC for at least 1 year prior to qualifying for reduced TTHM and HAA5 monitoring	109-48
109.301(12)(ii)	TTHMs and HAA5 Stage 2 DBP Rule	109-49
109.301(12)(ii)(A)	Applicability and schedule	109-50
109.301(12)(ii)(B)	Routine monitoring	109-50
109.301(12)(ii)(C)	Reduced monitoring	109-52
109.301(12)(ii)(D)	Increased monitoring	109-55
109.301(12)(ii)(E)	General monitoring and compliance requirements	109-55
109.301(12)(iii)	Chlorite	109-56
109.301(12)(iii)(A)	Routine monitoring	109-56
109.301(12)(iii)(A)(I)	Daily monitoring	109-56
109.301(12)(iii)(A)(II)	Monthly monitoring	109-56
109.301(12)(iii)(A)(III)	Additional monitoring	109-57
109.301(12)(iii)(B)	Reduced monitoring	109-57

2010 Chapter 109 Index - November 10, 2010

(yellow highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, and GWR citations)

109.301(12)(iv)	Bromate	109-57
109.301(12)(iv)(A)	Routine monitoring	109-57
109.301(12)(iv)(B)	Reduced monitoring	109-57
109.301(12)(iv)(B)(II)	Beginning April 1, 2009, a system required to analyze for bromate may reduce monitoring from monthly to quarterly, if the system's RAA bromate concentration computed quarterly is less than or equal to 0.0025 mg/l based on monthly measurements as prescribed in clause (A) for the most recent 4 quarters.....	109-57
109.301(12)(v)	Disinfection byproduct precursors	109-58
109.301(12)(v)(A)	Routine monitoring	109-58
109.301(12)(v)(B)	Reduced monitoring	109-58
109.301(12)(v)(C)	Early monitoring	109-58
109.301(13)	Monitoring requirements for disinfectant residuals	109-58
109.301(13)(i)	Chlorine and chloramines	109-59
109.301(13)(ii)	Chlorine dioxide	109-59
109.301(13)(ii)(A)	Routine monitoring	109-59
109.301(13)(ii)(B)	Additional monitoring	109-59
109.301(14)	Monitoring requirements for radionuclides	109-59
109.301(14)(i)	Monitoring requirements for gross alpha particle activity, radium-226, radium-228 and uranium	109-60
109.301(14)(i)(A)	Initial monitoring schedule	109-60
109.301(14)(i)(A)(IV)	Systems that add new entry points shall conduct monitoring beginning the first full quarter the entry point begins serving the public	109-60
109.301(14)(i)(A)(VI)	Quarterly monitoring is required when the average of initial monitoring > MCL	109-60
109.301(14)(i)(B)	Repeat monitoring	109-60
109.301(14)(i)(C)	Gross alpha substitution	109-61
109.301(14)(i)(D)	Grandfathering	109-61
109.301(14)(ii)	Monitoring requirements for beta-particle and photon radioactivity	109-62
109.301(14)(iii)	General monitoring and compliance requirements	109-63
109.302	Special monitoring requirements	109-64
109.302(a)	Additional monitoring if PWS is not in compliance with MCL, MRDL or TT	109-64
109.302(b)	Additional monitoring where potential health hazard may exist	109-65
109.302(c)	Special monitoring of UCMR	109-65
109.302(d)	Schedule for sampling for special monitoring	109-65
109.302(e)	Special monitoring for experimental facilities	109-65
109.302(f)	GUDI sampling requirements	109-65
109.302(g)	DEP may reduce or eliminate GUDI sampling requirements	109-65
109.303	Sampling requirements	109-66
109.303(a)	Sampling locations identified in 109.301 or 109.302 or as follows:	109-66
109.303(a)(1)	turbidity MCL at EP	109-66
109.303(a)(2)	total coliform MCL within distribution system	109-66
109.303(a)(3)	fluoride MCL at EP	109-66
109.303(a)(4)	organics and inorganics MCLS and UCMR at EP	109-66
109.303(a)(5)	asbestos sampling points in distribution system with A/C pipe and EP	109-66
109.303(b)	TT performance monitoring locations	109-66
109.303(c)	PWSs assure that samples are properly collected and preserved	109-66
109.303(d)	Compliance monitoring for VOCs shall be collected by a trained person	109-67
109.303(e)	Samples may be composited	109-67
109.303(f)	POE free flowing tap location	109-67
109.303(g)	Rad samples may be composited	109-67
109.303(h)	Beta particle and photon radioactivity samples may be composited	109-67
109.304	Analytical requirements	109-68
109.304(a)	Analytical techniques adopted by EPA or methods approved by DEP	109-68
109.304(b)	Alternative analytical technique may be employed with the written approval from DEP	109-68

2010 Chapter 109 Index - November 10, 2010

(yellow highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, and GWR citations)

109.304(c)	For the purpose of determining compliance with the monitoring and analytical requirements established under this subchapter and Subchapters K, L and M ...Turbidity, fluoridation operation, residual disinfectants, WQPs, daily chlorite may be performed by:	109-68
109.304(c)(1)	certified operator	109-68
109.304(c)(2)	person using SOPs	109-68
109.304(c)(3)	environmental lab	109-68
109.304(d)	<i>Cryptosporidium</i> samples analyzed by EPA-approved lab	109-69
109.305	Fees	109-69
109.305(a)	Data management fees	109-69
109.305(b)	Waivers	109-69
D	PUBLIC NOTIFICATION	109-70
109.407	General public notification requirements	109-72
109.407(a)	Violation categories and other situations requiring a public notice	109-72
109.407(a)(2)	Failure to comply with a prescribed treatment technique requirement in Subchapter B, G, K, L or M	109-72
109.407(b)	Definition of public notice tiers	109-72
109.407(b)(1)	Tier 1 public notice	109-73
109.407(b)(2)	Tier 2 public notice	109-73
109.407(b)(3)	Tier 3 public notice	109-73
109.407(c)	Public notice recipients	109-73
109.407(d)	Additional requirements	109-74
109.408	Tier 1 public notice - categories, timing and delivery of notice	109-74
109.408(a)	General violation categories and other situations requiring a Tier 1 public notice	109-74
109.408(a)(7)	Violation of a TT requirement for <i>Cryptosporidium</i> resulting from a failure to provide the bin level of treatment	109-75
109.408(a)(8)	Detection of <i>E. coli</i> in source water samples for triggered or assessment monitoring	109-75
109.408(a)(9)	A breakdown in treatment for GW sources as specified in 109.1307(a)(1)(ii)	109-75
109.408(a)(10)	Occurrence of a waterborne disease outbreak or other emergency situation as defined in 109.701(a)(3)(iii) that adversely affects the quality or quantity of the finished water and has a significant potential to have serious adverse effects on human health as a result of short-term exposure	109-75
109.408(b)	Timing for a Tier 1 public notice	109-75
109.408(b)(5)	Provide a "Problem Corrected" PN	109-76
109.408(c)	Form and manner of a Tier 1 public notice prior to May 10, 2010	109-76
109.408(d)	Delivery of a Tier 1 public notice beginning on May 10, 2010	109-76
109.409	Tier 2 public notice - categories, timing and delivery of notice	109-77
109.409(a)	General violation categories and other situations requiring a Tier 2 public notice	109-77
109.409(a)(1)	All violations and failure to take corrective action in Subchapters B, G, K, L, or M	109-77
109.409(a)(2)	Violations of monitoring requirements In Subchapter C, K or M, lead and copper and additional requirements for groundwater sources	109-77
109.409(b)	Timing for a Tier 2 public notice	109-78
109.409(c)	Form and manner of a Tier 2 public notice	109-78
109.410	Tier 3 public notice - categories, timing and delivery of notice	109-79
109.410(a)	General violation categories and other situations requiring a Tier 3 public notice	109-79
109.410(a)(1)	Monitoring violations under Subchapter C, K, L or M	109-79
109.410(a)(2)	Reporting and record maintenance violations under 109.701(h)	109-80
109.410(b)	Timing for a Tier 3 public notice	109-80
109.410(c)	Delivery of a Tier 3 public notice	109-80
109.410(d)	Use of a CCR to meet the Tier 3 public notice requirements	109-81

2010 Chapter 109 Index - November 10, 2010

(yellow highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, and GWR citations)

109.411	Content of a public notice	109-81
109.411(a)	Elements of a public notice	109-81
109.411(b)	Abbreviated notice	109-82
109.411(c)	Elements of a public notice for public water systems operating under a variance or exemption	109-82
109.411(d)	Presentation of a public notice.....	109-83
109.411(e)	Standard language for a public notice	109-83
109.411(e)(1)	Standard health effects language for primary MCL or MRDL violations, treatment technique violations, and violations of the condition of a variance or exemption.....	109-83
109.411(e)(2)	Standard language for violations of monitoring requirements	109-84
109.411(e)(3)	Standard language to encourage the distribution of the public notice to all persons served	109-84
109.412	Special notice of the availability of unregulated contaminant monitoring results	109-85
109.412(a)	Timing for a special notice.....	109-85
109.412(b)	Delivery of a special notice	109-85
109.413	Special notice for nitrate exceedances above MCL by noncommunity water systems, where granted permission by the Department	109-85
109.413(a)	Timing for a special notice.....	109-85
109.413(b)	Delivery of a special notice	109-86
109.414	Notice to new billing units or new customers	109-86
109.414(a)	Requirements for community water systems.....	109-86
109.414(b)	Requirements for noncommunity water systems	109-86
109.415	Notice by the Department on behalf of the public water system	109-86
109.415(a)	Failure to give public notice	109-86
109.415(b)	System responsibilities when public notice is given by the Department	109-87
109.416	CCR requirements	109-87
109.416(1)	EPA definitions of "customer" and "detected" are incorporated by reference	109-87
109.416(2)	Each CWS shall deliver to its customers an annual CCR on the dates established by EPA	109-87
109.416(3)	Report contains EPA language except health effects language for fluoride MCL violation	109-87
109.416(4)	Report delivery and recordkeeping	109-88
109.417	Special notice for significant deficiencies by NCWS.....	109-89
109.417(a)	NCWS shall inform the public of an uncorrected significant deficiency	109-89
109.417(b)	If directed by DEP, NCWS with corrected significant deficiency shall inform its customers	109-90
109.418	Special notice for failure to conduct source water <i>Cryptosporidium</i> monitoring or failure to determine bin classification	109-90
109.418(a)	Special notice for repeated failure to conduct monitoring of the source water for <i>Cryptosporidium</i> and for failure to determine bin classification or <i>Cryptosporidium</i> level.....	109-90
109.418(b)	Delivery of the special notice for failure to determine bin classification or <i>Cryptosporidium</i> level. .	109-90
109.418(c)	Form and manner of the special notice	109-91
E	PERMIT REQUIREMENTS.....	109-92
109.501	General permit requirements.....	109-92
109.502	Permitting of currently operating systems; compliance deadlines.....	109-93
109.503	Public water system construction permits	109-94
109.503(a)	Permit application requirements	109-94
109.503(a)(1)	General requirements.....	109-94
109.503(a)(1)(i)	Permit application signatures.....	109-94
109.503(a)(1)(ii)	Plans, specifications and engineer's report	109-95
109.503(a)(1)(iii)	Information describing new sources	109-95

2010 Chapter 109 Index - November 10, 2010

(yellow highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, and GWR citations)

109.503(a)(1)(iii)(B)(I)	VOCs for which MCLS have been established	109-95
109.503(a)(1)(iii)(B)(V)	Total coliform concentration and, if TC+, analyze for the presence of <i>E. coli</i>	109-96
109.503(a)(1)(iii)(B)(VI)(-a-)	Except for SOCs that have been granted a statewide waiver, SOCs.....	109-96
109.503(a)(1)(iii)(B)(VI)(-c-)	PCBs where there is a source of PCB contamination within 1000 feet.....	109-96
109.503(a)(1)(iii)(B)(XII)	For surface water or GUDI sources, <i>E. coli</i> or <i>Cryptosporidium</i> or both as specified in 109.1202	109-96
109.503(a)(1)(iv)	Chapter 102 requirements.....	109-97
109.503(a)(2)	Special requirements for public water suppliers proposing to use POE devices	109-97
109.503(a)(3)	Business plan requirements for new community water systems	109-97
109.503(a)(3)(i)	Facilities plan	109-98
109.503(a)(3)(ii)	Management plan	109-98
109.503(a)(3)(iii)	Financial plan	109-98
109.503(b)	Amendments.....	109-99
109.503(c)	Permit fees	109-99
109.503(d)	Department's review.....	109-100
109.503(e)	Issuance and conditions	109-100
109.504	Public water system operation permits.....	109-101
109.505	Requirements for noncommunity water systems	109-102
109.505(a)(3)(i)(B)	Total coliform concentration and, if TC+, analyze for the presence of <i>E. coli</i>	109-103
109.505(b)	A NCWS providing 4-log treatment shall obtain a NCWS 4-log treatment permit	109-103
109.506	Emergency permits.....	109-104
109.507	Permits for innovative technology	109-104
109.507	DEP may consider proposals for innovative water treatment processes...that the proposal will provide drinking water that complies with Subchapters B, L and M	109-104
F	DESIGN AND CONSTRUCTION STANDARDS.....	109-106
109.601	Application of standards	109-106
109.602	Acceptable design	109-106
109.602(a)	A PWS shall be designed to provide... and capable of providing water that complies with MCLs, MRDLs and TT established in Subchapters B, L and M.....	109-106
109.603	Source quality and quantity	109-107
109.604	Facilities siting	109-108
109.605	Minimum treatment design standards.....	109-109
109.605(2)	For surface water and GUDI sources, the minimum treatment design...except NCWs may propose and DEP may approve, an alternative to the <i>Giardia</i> design standard when 99.9% inactivation is not feasible	109-109
109.605(3)	For surface water and GUDI sources permitted after 12/26/09, that are determined to be bin 2 or higher, the minimum treatment design for filtration and disinfection must also meet requirements of 109.1203 and 109.1204.....	109-109
109.605(4)	For CWSs using groundwater, the minimum treatment design standard for disinfection is 99.99% treatment of viruses.	109-109
109.605(5)	For NCWs using groundwater with an <i>E. coli</i> positive groundwater source, the minimum treatment design standard for disinfection is 99.99% treatment of viruses.....	109-110
109.606	Chemicals, materials and equipment.....	109-110
109.607	Pressures	109-111

2010 Chapter 109 Index - November 10, 2010

(yellow highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, and GWR citations)

109.608 Cross-connections 109-112

109.609 Reserved capacity and finished water storage 109-112

109.611 Disinfection 109-113

109.611 Disinfection facilities shall be designed to provide the dosage rate and contact time... to provide water that complies with the microbiological MCL, MRDL and TT requirements under 109.202 and 109.1302 ... 109-113

109.612 POE devices 109-113

G SYSTEM MANAGEMENT RESPONSIBILITIES.....109-114

109.701 Reporting and recordkeeping 109-114

109.701(a) Reporting requirements for public water systems 109-114

109.701(a)(1) General reporting requirements..... 109-114

109.701(a)(2) Monthly reporting requirements for performance monitoring..... 109-115

109.701(a)(2)(i)(B)(I) The date, time and lowest value each day the residual disinfectant remains equal to or greater than the required minimum..... 109-116

109.701(a)(2)(i)(B)(II) The initial date, time and value for each occurrence that the residual disinfectant concentration is less than the required minimum, and the subsequent date, time and value that the residual disinfect concentration is equal to or greater than the required minimum 109-116

109.701(a)(2)(i)(B)(III) The date the entry point is not in operation 109-116

109.701(a)(3) One-hour reporting requirements- 109-117

109.701(a)(3)(i) A primary MCL or MRDL has been exceeded or a treatment technique requirement has been violated under Subchapter B, K, L or M 109-117

109.701(a)(3)(iii)(F) An overfeed of a drinking water chemical that exceeds NSF maximum use value 109-117

109.701(a)(3)(iii)(G) A situation that causes a loss of positive water pressure in the distribution system where there is evidence of contamination or a water supplier suspects a high risk of contamination 109-117

109.701(a)(3)(iii)(H) A lack of resources that adversely affect operations, such as staff shortages, notification by the power utility of planned lengthly power outages or imminent depletion of treatment chemical inventory..... 109-117

109.701(a)(4) Notice..... 109-117

109.701(a)(5) Siting plan..... 109-118

109.701(a)(6) Records 109-118

109.701(a)(7) Form 109-118

109.701(a)(8) Reporting requirements for disinfectant residuals 109-118

109.701(a)(8)(i) Systems monitoring for chlorine dioxide shall report the number of days chlorine dioxide was used at each entry point during the last month 109-118

109.701(a)(8)(ii) Systems monitoring for either chlorine or chloramines shall report the following..... 109-118

109.701(a)(9) Noncompliance report Except where a different reporting period is specified in this chapter, the water supplier shall report to DEP within 48 hours the failure to comply with any NPDWR, including the failure to comply with any monitoring requirement set forth in this chapter. 109-119

109.701(b) Reporting requirements for community water systems 109-119

109.701(c) Reporting requirements for nontransient noncommunity water systems..... 109-119

109.701(d) Record maintenance 109-119

109.701(d)(2) Records of turbidity performance monitoring shall be kept for at least 5 years 109-120

109.701(e) Reporting requirements for public water systems required to perform individual filter monitoring under § 109.301(1)(iv) 109-120

109.701(f) Alternative individual filter turbidity exceedance levels 109-121

109.701(g)(2) Stage 2 DBP Rule..... 109-122

109.701(g)(2)(i) IDSE requirements 109-122

109.701(g)(2)(ii) Stage 2 DPB Rule monitoring plan..... 109-122

109.701(g)(2)(iii) Operational evaluation levels..... 109-123

109.701(g)(2)(iv) Reporting and recordkeeping requirements 109-124

109.701(i) Accuracy of data 109-125

2010 Chapter 109 Index - November 10, 2010

(yellow highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, and GWR citations)

109.701(j)	Electronic reporting	109-125
109.701(k)	Monitoring plan to determine if a source is directly influenced by surface water	109-126
109.701(l)	Additional reporting and recordkeeping requirements for systems using surface water or GUDI sources.....	109-126
109.701(m)	Additional reporting and recordkeeping requirements for systems using groundwater sources	109-126
109.702	Operation and maintenance plan	109-127
109.702(a)(3)	Procedures for repairing and replacing water mains that conform to DEP and water industry standards	109-127
109.702(a)(14)	Date of last update	109-127
109.703	Facilities operation.....	109-128
109.704	Operator certification	109-129
109.704(a)	CWS and NCWS shall have personnel certified under Op Cert Act.....	109-129
109.704(b)	TNCWS shall have competent personnel qualified to operate and maintain.....	109-129
109.705	Sanitary surveys	109-130
109.705(c)(1)	A NCWS undergo sanitary survey every 5 years	109-130
109.705(c)(2)	Increase the number of routine coliform samples collected to at least 5 per month if DEP does not conduct a sanitary survey every 5 years.....	109-130
109.705(d)	The following apply to significant deficiencies identified at PWSs by a SW source and PWSs supplied by a GUDI source	109-131
109.705(e)	Significant deficiencies identified at DEP at a PWSs using groundwater shall comply with 109.1302(c).....	109-131
109.706	System distribution map	109-131
109.707	Emergency response plan.....	109-132
109.707(a)(2)(ii)	Key public officials	109-132
109.707(a)(2)(iv)	Facilities within a water supplier's service area, including, but not limited to, hospitals, schools, day-care facilities, nursing homes, social service agencies, industrial and commercial users	109-132
109.707(c)	The CWS shall review and update the plan at least annually and as necessary to reflect changes to communication procedures and contact information under subsection(a)(2)	109-133
109.708	Planned service interruptions	109-133
109.709	Cross-connection control program.....	109-133
109.710	Disinfectant residual in the distribution system	109-134
109.711	Disinfection of facilities prior to placing them into service	109-135
109.712	Control of POE devices	109-135
109.713	Wellhead protection program.....	109-136
109.714	Filter profile, filter self-assessment and comprehensive performance evaluations	109-137
H	LABORATORY CERTIFICATION.....	109-138
109.801	Certification requirement	109-138
109.801	A laboratory shall be accredited...demonstrating compliance with monitoring requirements established in Subchapters C, K, L and M	109-138

2010 Chapter 109 Index - November 10, 2010

(yellow highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, and GWR citations)

109.810 Reporting and notification requirements..... 109-140
 109.810(a) Beginning November 13, 2009, a lab accredited shall electronically report..... 109-140
 109.810(b) A lab accredited shall whenever an MCL, MRDL, TT or AL is exceeded or a sample requires a check or confirmation sample or is *E. coli*-positive shall do the following..... 109-141
 109.810(d) A lab accredited shall be responsible for the accurate reporting of data..... 109-142

I VARIANCES AND EXEMPTIONS ISSUED BY THE DEPARTMENT109-142

109.901 Requirements for a variance 109-143

109.901(a)(1) DEP may grant a variance from the MCL requirements if the PWS has installed and is using the best treatment technology, treatment methods or other means available to reduce the level of the contaminant, and has determined that alternate sources of water are not reasonably available 109-143
 109.901(b) The MCL for total coliforms is not eligible for a variance..... 109-143
 109.901(c) The TT requirements under 109.202(c), 109.1102(b), 109.1203 and 109.1302 are not eligible for a variance 109-143

109.902 Variance request..... 109-143

109.903 Requirements for an exemption..... 109-144

109.903(a)(1) PWS is unable to comply with the contaminant level or treatment technique requirement, or to implement measures to develop an alternative source of water supply..... 109-144
 109.903(a)(4) Management or restructuring changes or both cannot reasonably be made that will result in compliance with the applicable MCL or TT or, if compliance cannot be achieved, improve the quality of the drinking water..... 109-145
 109.903(b) The MCL for total coliforms is not eligible for an exemption 109-145
 109.903(c) The TT requirements under 109.202(c), 109.1102(b), 109.1203 and 109.1302 are not eligible for an exemption 109-145

109.904 Exemption request 109-145

109.905 Public hearing on a variance or exemption 109-146

109.906 Consideration of a request for a variance or exemption 109-147

109.906(1) In its consideration of whether the PWS satisfies the requirements for a variance, DEP will, and whether the system has evaluated that alternative sources of water are not reasonably available 109-147
 109.906(3)(iii) The availability of an alternative source of water, including the feasibility of partnerships with neighboring PWSs, as identified by the PWS or DEP 109-148

109.907 Disposition of a request for a variance or exemption..... 109-148

109.907(c) If DEP makes a determination to grant a variance or exemption request, it will document its findings for granting a variance or exemption 109-148

109.908 Compliance schedules 109-148.1

109.908(e) In accordance with 40 CFR 142.20(b)(2), DEP may renew an exemption for a PWS that serves fewer than 3,300 persons and which needs financial assistance for the necessary improvements 109-148.1

J BOTTLED WATER AND VENDED WATER SYSTEMS, RETAIL WATER FACILITIES AND BULK WATER HAULING SYSTEMS.....109-148.2

109.1001 Scope 109-148.2

109.1002 MCLs, MRDLs or treatment techniques 109-148.2

109.1002(c) BRVB systems shall comply with TTs under Subchapter L..... 109-148.2
 109.1002(d) BRVB systems shall comply with Subchapter M. BRVBs shall comply with standards pertaining to NCWSs..... 109-148.2

2010 Chapter 109 Index - November 10, 2010

(yellow highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, and GWR citations)

109.1003	Monitoring requirements	109-148.3
109.1003(a)(1)(ix)	Bottled, retail and bulk EP TTHM and HAA5 Stage 2 DBP Rule monitoring beginning October 1, 2013	109-148.7
109.1003(d)	A bulk hauling system that serves at least 25 of the same persons year round	109-148.9
109.1003(e)	A bulk hauling system or vended water system that serves at least 25 of the same persons over 6 months per year	109-148.9
109.1003(f)	Additional monitoring requirements for SW and GUDI sources (comply with Subchapter L)	109-148.10
109.1003(g)	Additional monitoring requirements for GW sources (comply with Subchapter M)	109-148.10
109.1004	Public notification	109-148.10
109.1004(a)	General public notification requirements	109-148.10
109.1004(b)	Description and content of notice	109-148.11
109.1004(c)	Notice by the Department	109-148.12
109.1004(d)	CCR Requirements	109-148.12
109.1005	Permit requirements	109-148.12
109.1005(a)	General permit requirements	109-148.12
109.1005(b)	Special permit by rule requirement for vended water systems	109-148.12
109.1005(c)	Special permit by rule requirement for bottled water systems	109-148.13
109.1005(d)	Permit amendments	109-148.14
109.1005(e)	Permit applications	109-148.15
109.1005(f)	Permit amendment applications	109-148.16
109.1005(g)	Emergency permits	109-148.18
109.1005(h)	Department's review	109-148.18
109.1005(i)	Permit fees	109-148.19
109.1006	Design and construction standards	109-148.19
109.1006(a)	Application of standards	109-148.19
109.1006(b)	Acceptable design	109-148.19
109.1007	Labeling requirements for bottled water systems, vended water systems and retail water facilities	109-148.20
109.1007(a)	General labeling requirements	109-148.20
109.1007(b)	Corporate name and trade name	109-148.21
109.1007(c)	Special vending machine label	109-148.20
109.1007(d)	Special retail water facility label	109-148.20
109.1008	System management responsibilities	109-148.21
109.1008(a)	Reporting and recordkeeping requirements for bottled water and vended water systems, retail water facilities and bulk water hauling systems	109-148.21
109.1008(a)(4)	BVRB systems using surface water or GUDI sources shall also comply with Subchapter L	109-148.23
109.1008(a)(5)	BVRB systems using groundwater sources, including purchasing groundwater shall also comply with Subchapter M	109-148.23
109.1008(b)	Operation and maintenance plan requirements	109-148.23
109.1008(c)	Operator requirements	109-148.23
109.1008(d)	Sanitary survey requirements	109-148.23
109.1008(e)	Emergency response requirements	109-148.24
109.1008(f)	Cross-connection control program	109-148.24
109.1009	System operational requirements	109-148.25
109.1009(a)	General facilities operation	109-148.25
109.1009(b)	Special bottled water system requirements	109-148.25
109.1009(c)	Disinfectant residual requirements	109-148.25
109.1009(d)	Disinfection of facilities following construction, modification or repair	109-148.25
109.1009(e)	Dedicated equipment	109-148.25
109.1009(f)	Special operational requirements for bottled water systems and retail water facilities	109-148.26
109.1009(g)	Special operational requirements for water vending machine systems	109-148.26

2010 Chapter 109 Index - November 10, 2010

(yellow highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, and GWR citations)

109.1009(h)	Special operational requirements for bulk water hauling systems	109-148.26
K	LEAD AND COPPER	109-148.27
109.1101	Scope	109-148.27
109.1102	Action levels and treatment technique requirements	109-148.28
109.1102(a)	Action levels for lead and copper	109-148.28
109.1102(a)(4)	The 90 th percentile lead and copper action level computation	109-148.28
109.1102(b)	Treatment technique requirement for corrosion control	109-148.28
109.1102(b)(1)	Optimal corrosion control treatment	109-148.28
109.1102(b)(2)	Corrosion control treatment compliance schedule	109-149
109.1102(b)(3)	Corrosion control treatment feasibility study	109-150
109.1102(b)(4)	Source water treatment	109-151
109.1102(b)(5)	Water quality parameter performance requirements	109-152
109.1103	Monitoring requirements	109-153
109.1103(a)	Initial monitoring	109-153
109.1103(a)(1)	Initial lead and copper tap monitoring	109-153
109.1103(a)(2)	Initial water quality parameter monitoring	109-154
109.1103(a)(3)	Initial source water monitoring	109-155
109.1103(b)	Special lead and copper tap monitoring	109-155
109.1103(c)	Follow-up monitoring after construction or modification of corrosion control treatment facilities	109-155
109.1103(c)(1)	Lead and copper tap monitoring	109-156
109.1103(c)(2)	Water quality parameter monitoring	109-156
109.1103(c)(3)	Source water monitoring	109-157
109.1103(d)	Monitoring after performance requirements are established	109-157
109.1103(d)(1)	Lead and copper tap monitoring	109-158
109.1103(d)(2)	Water quality parameter performance monitoring	109-158
109.1103(d)(3)	Source water monitoring	109-159
109.1103(e)	Reduced monitoring	109-159
109.1103(e)(1)	Reduced lead and copper tap monitoring	109-159
109.1103(e)(1)(i)	Annual lead and copper tap monitoring	109-159
109.1103(e)(1)(ii)	Triennial lead and copper tap monitoring	109-160
109.1103(e)(1)(iii)	Request for reduced monitoring	109-160
109.1103(e)(1)(iv)	Sample sites and timing	109-160
109.1103(e)(1)(v)	Reduced lead and copper tap monitoring revocation	109-160
109.1103(e)(2)	Reduced water quality parameter monitoring for large systems	109-161
109.1103(e)(2)(i)	Reduced sites	109-161
109.1103(e)(2)(ii)	Reduced water quality parameter monitoring	109-162
109.1103(e)(2)(iii)	Reduced water quality parameter monitoring revocation	109-162
109.1103(f)	Additional monitoring by systems	109-162
109.1103(g)	Sample site location plan	109-162
109.1103(g)(1)	Materials evaluation	109-163
109.1103(g)(2)	Lead and copper tap sample site selection	109-163
109.1103(g)(2)(i)	Site selection for community water systems	109-163
109.1103(g)(2)(ii)	Site selection for nontransient noncommunity water systems	109-164
109.1103(g)(2)(iii)	Sample sites with lead service lines	109-164
109.1103(g)(2)(iv)	Sample sites with point-of-use or point-of-entry devices	109-165
109.1103(g)(3)	Water quality parameter sample site selection	109-165
109.1103(g)(3)(i)	Water quality parameter distribution samples	109-165
109.1103(g)(3)(ii)	Water quality parameter entry point samples	109-165
109.1103(g)(4)	Sample procedure certification	109-165
109.1103(h)	Sample collection methods	109-165
109.1103(h)(1)	Lead and copper tap samples	109-165
109.1103(h)(2)	Water quality parameter distribution samples	109-166
109.1103(h)(3)	Water quality parameter entry point samples	109-166
109.1103(h)(4)	Source water samples	109-167

2010 Chapter 109 Index - November 10, 2010

(yellow highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, and GWR citations)

109.1103(h)(5)	Lead service line samples	109-167
109.1103(i)	Analytical methods	109-167
109.1103(j)	Invalidation of lead or copper tap water samples	109-167
109.1103(k)	Monitoring waivers for small systems	109-168
109.1103(k)(1)	Materials criteria	109-168
109.1103(k)(1)(i)	Lead	109-168
109.1103(k)(1)(ii)	Copper	109-168
109.1103(k)(2)	Monitoring criteria for waiver issuance	109-168
109.1103(k)(2)(i)	Lead levels	109-169
109.1103(k)(2)(ii)	Copper levels	109-169
109.1103(k)(3)	Department approval of waiver application	109-169
109.1103(k)(4)	Monitoring frequency for systems with waivers	109-169
109.1103(k)(5)	Continued eligibility	109-169
109.1103(k)(6)	Requirements following waiver revocation	109-169
109.1104	Public education and notification	190-170
109.1104(a)	Public education program	190-170
109.1104(a)(1)	Content	190-170
109.1104(a)(1)(i)	Mandatory language for newspapers and water bill inserts	190-170
109.1104(a)(1)(ii)	Mandatory language for pamphlets and brochures	190-171
109.1104(a)(1)(iii)	Mandatory language for public service announcements	190-171
109.1104(a)(1)(iv)	Mandatory language for nontransient noncommunity water systems	190-171
109.1104(a)(2)	Delivery	190-171
109.1104(a)(2)(i)	Community water system requirements	190-171
109.1104(a)(2)(ii)	Nontransient noncommunity water system requirements	190-172
109.1104(a)(3)	Discontinuation of public education program	190-172
109.1104(a)(4)	Notification of customer monitoring	190-173
109.1104(b)	Public notification requirements	190-173
109.1105	Permit requirements	109-173
109.1105(a)	General permit requirements	190-173
109.1105(b)	Construction permits and permit amendments	190-173
109.1105(b)(1)	Community water system minor permit amendments	190-173
109.1105(b)(2)	Nontransient noncommunity water system permits	190-174
109.1105(c)	Operation permits	190-174
109.1106	Design standards	109-175
109.1106(1)	A minimum pH in distribution samples of at least 7.0	109-75
109.1106(2)	For systems that are exempt from submitting a construction permit application, a minimum alkalinity measured in all distribution samples of 20 mg/L	109-75
109.1107	System management responsibilities	109-175
109.1107(a)	Reporting and recordkeeping	190-175
109.1107(a)(1)	Sample site location plan maintain on file and submit to DEP prior to initial lead and copper monitoring or upon request	190-175
109.1107(a)(2)	Reporting of monitoring results	190-175
109.1107(a)(2)(i)	Lead and copper tap monitoring results	190-176
109.1107(a)(2)(i)(I)	 The sample location	190-176
109.1107(a)(2)(ii)	Water quality parameter monitoring results	190-176
109.1107(a)(2)(iii)	Source water monitoring results	190-176
109.1107(a)(3)	Corrosion control treatment reporting requirements	190-177
109.1107(a)(4)	Public education reporting requirements	190-177
109.1107(a)(5)	Lead service line replacement reporting	190-178
109.1107(a)(6)	Record maintenance	190-178
109.1107(b)	Operation and maintenance plan	190-179
109.1107(c)	Operator certification	190-179
109.1107(d)	Lead service line replacement	190-179

2010 Chapter 109 Index - November 10, 2010

(yellow highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, and GWR citations)

109.1107(d)(1)	Initiation of lead service line replacement	190-179
109.1107(d)(2)	Replacement schedule	190-179
109.1107(d)(3)	Lead service line sampling	190-180
109.1107(d)(4)	Conditions of replacement	190-180
109.1107(d)(5)	Discontinuation of lead service line replacement	190-180
109.1108	Fees	109-181
109.1108(1)	Construction or permit amendment fee	109-181
109.1108(2)	System not paying construction fee	109-181

L LONG-TERM 2 ENHANCED SURFACE WATER TREATMENT RULE109-182

109.1201	Scope	109-182
109.1201(a)	Scope	109-182
109.1201(b)	Applicability	109-182

109.1202	Monitoring Requirements.....	109-183
109.1202(a)	Initial round of source water monitoring	109-183
109.1202(b)	Second round of source water monitoring	109-184
109.1202(c)	Source water monitoring schedule.....	109-184
109.1202(d)	Source water monitoring avoidance	109-185
109.1202(e)	Plants operating only part of the year	109-185
109.1202(f)	New sources	109-185
109.1202(g)	Monitoring violations	109-186
109.1202(h)	Source water sampling schedules	109-186
109.1202(i)	Source water sample collection period	109-186
109.1202(j)	Missed samples	109-187
109.1202(k)	Source water sampling location	109-187
109.1202(l)	Chemical treatment prior to sampling location	109-187
109.1202(m)	Source water sample location for plants that recycle.....	109-187
109.1202(n)	Bank filtration.....	109-187
109.1202(o)	Multiple sources.....	109-188
109.1202(p)	Additional requirements.....	109-188

109.1203	Bin classification and treatment technique requirements	109-189
109.1203(a)	Bin classification.....	109-189
109.1203(b)	Procedures for calculating bin classifications	109-189
109.1203(c)	<i>Cryptosporidium</i> bin concentration thresholds	109-189
109.1203(d)	<i>Cryptosporidium</i> bin concentration recalculation requirements	109-190
109.1203(e)	Filtered system additional <i>Cryptosporidium</i> treatment requirements.....	109-190
109.1203(f)	Treatment and management options for filtered systems, microbial toolbox.....	109-191
109.1203(g)	Failure to meet treatment credit	109-191
109.1203(h)	Increased watershed contamination.....	109-191
109.1203(i)	Unfiltered systems determination of <i>Cryptosporidium</i> bin level, initial round	109-191
109.1203(j)	Unfiltered systems determination of <i>Cryptosporidium</i> bin level, second round	109-191
109.1203(k)	Schedule for compliance with <i>Cryptosporidium</i> treatment requirements	109-192
109.1203(l)	Treatment technique requirements for unfiltered systems	109-192
109.1203(m)	<i>Cryptosporidium</i> treatment compliance dates	109-192
109.1203(n)	Change in <i>Cryptosporidium</i> level for filtered system.....	109-192
109.1203(o)	Change in <i>Cryptosporidium</i> level for unfiltered system.....	109-192

109.1204	Requirements for microbial toolbox components	109-193
109.1204(a)	System will receive Treatment credits listed in Appendix B	109-193
109.1204(b)	Watershed control program.....	109-193
109.1204(c)	Alternative source	109-195
109.1204(d)	Presedimentation	109-195
109.1204(e)	2-stage lime softening	109-196

2010 Chapter 109 Index - November 10, 2010

(yellow highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, and GWR citations)

109.1204(f)	Bank filtration.....	109-196
109.1204(g)	Combined filter performance.....	109-197
109.1204(h)	Individual filter performance.....	109-197
109.1204(i)	Demonstration of performance.....	109-197
109.1204(j)	Bag and cartridge filters.....	109-198
109.1204(k)	Membrane filtration.....	109-199
109.1204(l)	Second stage filtration.....	109-203
109.1204(m)	Slow sand filtration (as secondary filter).....	109-203
109.1204(n)	Inactivation toolbox components.....	109-204
109.1204(o)	Chlorine dioxide.....	109-204
109.1204(p)	Ozone.....	109-204
109.1204(q)	Ultraviolet light.....	109-204
109.1205 Grandfathering previously collected data.....		109-206
109.1206 Reporting and recordkeeping requirements.....		109-206
109.1206(a)	Source water reporting time frame.....	109-206
109.1206(b)	Methods for reporting initial source water monitoring results to EPA.....	109-206
109.1206(c)	Methods for reporting initial source water monitoring results to DEP.....	109-206
109.1206(d)	Methods for reporting second round of source water monitoring results to DEP.....	109-206
109.1206(e)	Source water reporting data elements.....	109-206
109.1206(f)	Sampling schedule reporting.....	109-207
109.1206(g)	Bin classification reporting.....	109-207
109.1206(h)	Microbial toolbox reporting requirements.....	109-208
109.1206(i)	Reporting significant change in disinfection practices.....	109-208
109.1206(j)	Source water monitoring recordkeeping requirements.....	109-208
109.1206(k)	Notification retention.....	109-208
109.1206(l)	Results retention.....	109-208
M ADDITIONAL REQUIREMENT FOR GROUNDWATER SOURCES.....		109-209
109.1301 Scope.....		109-209
109.1302 Treatment technique requirements.....		109-210
109.1302(a)	Community groundwater systems.....	109-210
109.1302(b)	Noncommunity groundwater systems including BVRBs.....	109-210
109.1302(c)	Groundwater systems with significant deficiencies or source water <i>E. coli</i> contamination.....	109-211
109.1303 Triggered monitoring requirements for groundwater sources.....		109-212
109.1303(a)	Source water sample for <i>E. coli</i> required within 24 hours of a TC+.....	109-212
109.1303(b)	DEP may extend 24 hours to 72 hours for logical problem.....	109-213
109.1303(c)	Source water samples that are representative of multiple sources.....	109-213
109.1303(d)	Source water sample collected prior to any treatment.....	109-213
109.1303(e)	Purchased water system notifies selling system of TC+ within 24 hours.....	109-213
109.1303(f)	Source water monitoring waived if 2 conditions apply.....	109-213
109.1303(g)	Invalidation criteria of <i>E. coli</i> + source water sample.....	109-213
109.1303(h)	Requirements following a <i>E. coli</i> + source water sample.....	109-214
109.1303(i)	Selling systems must comply with triggered monitoring requirements under (a).....	109-214
109.1304 Assessment source water monitoring.....		109-214
109.1304(a)	To determine if a noncommunity groundwater source contains fecal contamination.....	109-214
109.1304(b)	Invalidation criteria of <i>E. coli</i> TC+ source water sample.....	109-215
109.1305 Compliance monitoring.....		109-215
109.1305(a)	Chemical disinfection residual disinfection monitoring requirements.....	109-215
109.1305(b)	Alternative treatment compliance monitoring requirements.....	109-216

2010 Chapter 109 Index - November 10, 2010

(yellow highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, and GWR citations)

109.1306	Information describing 4-log treatment and compliance monitoring	109-217
109.1306(a)	CWS, BRVBs and NCWs with valid operations permits submit forms to evaluate treatment effectiveness	109-217
109.1306(b)	NCWs without permits demonstrating 4-log treatment submittal requirements	109-217
109.1306(c)	Plans, specifications and engineer report requirements	109-217
109.1307	System management responsibilities	109-218
109.1307(a)	Reporting	109-218
109.1307(b)	Recordkeeping	109-219

APPENDIX A TO SUBCHAPTER L (LT2ESWTR)109-220

Table 1	CT Values for <i>Cryptosporidium</i> inactivation by chlorine dioxide	109-220
Table 2	CT Values for <i>Cryptosporidium</i> inactivation by ozone.....	109-220
Table 3	UV Dose for <i>Cryptosporidium</i> , <i>Giardia lamblia</i> and virus inactivation credit	109-221

APPENDIX B TO SUBCHAPTER L (LT2ESWTR)109-222

Microbial Toolbox Summary Table: Options, Treatment Credits and Criteria	109-222
--	---------

APPENDIX C TO SUBCHAPTER L (LT2ESWTR)109-225

Microbial Toolbox Reporting Requirements	109-225
--	---------