



## WATER QUALITY MANAGEMENT PERMIT

<p>A. PERMITTEE (Name and Address): CLIENT ID#: <b>65292</b>  <b>West Grove Borough Authority Chester County</b>  <b>117 Rosehill Avenue PO Box 61</b>  <b>West Grove, PA 19390-1214</b></p>	<p>B. PROJECT/FACILITY (Name):  <b>West Grove Borough STP</b></p>
--	---

<p>C. LOCATION (Municipality, County):  <b>West Grove Borough, Chester County</b></p>	<p>SITE ID#: <b>451238</b></p>
---	--------------------------------

D. This amendment approves the modification and operation of sewage facilities consisting of: UV disinfection unit  
 The treatment plant consists of Influent screen, two primary clarifiers, two Anaerobic tanks, oxidation ditch, two final clarifiers and a UV disinfection system.

The treatment plant was originally permitted in 1987 under WQM #1587403. Thereafter, the plant had undergone modifications under WQM 1599402.

In 2000, WQM #1599402 was issued for rerating of the WWTP from 0.25 MGD to a maximum monthly average flow of 0.288 MGD to avoid the occasional exceedances of daily flow due to I&I. In 2003, #1599402 was amended to install density current baffles in the final clarifiers to reduce the solids from being carried over from the weir.

In 2009, WQM #1508412 was issued for a re-rate of organic loading from 521 lbs/day BOD5 to 646 lbs/day BOD5 by retrofitting the existing contact aeration basins with new biological media. In 2012, WQM #1508412 was amended and issued for modifications of the treatment plant that will allow rerate of organic loading to enable the plant to meet the two-tier nitrogen limits which became effective in 2013. Upon completion of the modifications, the plant will be able to treat upto 900 lbs/day BOD5. The modifications included installation of a new influent flow meter, removal of vertical plate media from contact aeration basins and the contact aeration basins were converted to anaerobic and anoxic tanks. A mixer and air diffuser were installed in each basin, exiting blower was modified (downsized to reduce air demand) to 190 cfm, a pump and 4" forcemain to pump RAS from the oxidation ditch's outer ring to the flow channel of the contact aeration basins, a recycling pump to convey nitrates from the oxidation ditch's inner channel to the anoxic outer channel for denitrification, installation of fine screen at the raw sewage pump station and upgrading the oxidation ditch's aeration process controls.

Continued on Page 2...

Pump Stations: _____ Design Capacity: _____ GPM	Manure Storage: Volume: _____ MG Freeboard: _____ inches	Sewage Treatment Facility: Annual Average Flow: <b>0.250</b> MGD Design Hydraulic Capacity: <b>0.288</b> MGD Design Organic Capacity: <b>900</b> lb/day
--	--	--

E. APPROVAL GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING:

- Amendments:** All construction, operations and procedures shall be in accordance with the Water Quality Management Permit Amendment application dated **December 22, 2021** and its supporting documentation which are hereby made a part of this amendment.  
 Except for any herein approved modifications, all terms, conditions, supporting documentation and addendums approved under Water Quality Management Permit No. **1599402 & 1587403** dated **October 30, 2000 & June 11, 1987** shall remain in effect.
- Permit Conditions Relating to Sewerage are attached and made part of this permit.

F. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS:

- If there is a conflict between the application or its supporting documents and amendments and the attached conditions, the attached conditions shall apply.
- Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the authority given to the permittee by the issuance of this permit.
- This permit is issued pursuant to the Clean Streams Law Act of June 22, 1937, P.L. 1987, as amended 35 P.S. §691.1 *et seq.* Issuance of this permit shall not relieve the permittee of any responsibility under any other law.

PERMIT ISSUED:  <u>2/18/2022</u>	BY:	<u>/s/</u> <b>Thomas L. Magge</b> Clean Water Program Manager Southeast Regional Office
	TITLE:	

A. PERMITTEE (Name and Address): CLIENT ID#: <b>65292</b> <b>West Grove Borough Authority Chester County</b> <b>117 Rosehill Avenue PO Box 61</b> <b>West Grove, PA 19390-1214</b>	B. PROJECT/FACILITY (Name): <b>West Grove Borough STP</b>
C. LOCATION (Municipality, County): <b>West Grove Borough, Chester County</b>	SITE ID#: <b>451238</b>
<p><i>... Continued from Page 1</i></p> <p><b>Hereafter, DEP would like to combine and replace WQM # 1508412 and #1508412-A1 into one permit #1599402.</b></p> <p>Currently, the treatment plant consists of (1) Influent screen, two primary clarifiers, two Anaerobic and anoxic tanks, (1) oxidation ditch, two final clarifiers and a UV disinfection system.</p> <p>In this amendment, the authority is proposing to replace the Aquionic Ozonia medium pressure UV system with Trojan UV3000 system. The new system is capable of effectively treating wastewater at a peak design flow of 1.1 MGD.</p> <p>The flow from the existing effluent monitoring flume will flow into the pump tank. A set of Flygt pumps (NP 3102 LT 3 -60 Hz) equipped with variable frequency drives (VFD) will pump the wastewater through the valve vault to the Trojan UV disinfection units. The pumps shall be sized to handle the design flow rate. Which will provide redundancy in case of pump failure. The VFD will be controlled with a pressure transducer to monitor water elevation in the pump tank. This will allow the controller to increase or decrease pumping rates to maintain a desirable elevation in the tank. Additionally, there will be a set of float switches for pump off if the water is too low for high water alarm and lag pump on if the water elevation is too high. The elevation in the Trojan UV units will be maintained by check valves on the pump side and a fixed weir on the effluent side. The Trojan UV unit consists of two banks of UV lamps in series and are sized to treat the peak flow rate. Typical flow rates can be treated by one bank of lamps. This allows for maintenance during periods of typical flow. Effluent piping from the Trojan UV will connect to the existing piping and discharge at the existing steam discharge.</p>	



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF POINT AND NON-POINT SOURCE MANAGEMENT

**PERMIT CONDITIONS RELATING TO SEWERAGE**  
For use in Water Quality Management Permits

(Check boxes that apply)

**General**

- 1. The Department of Environmental Protection (DEP) considers the licensed Professional Engineer whose seal is affixed to the design documents to be fully responsible for the adequacy of all aspects of the facility design.
- 2. The permittee shall adopt and enforce an ordinance requiring the abandonment of privies, cesspools or similar receptacles for human waste and onlot sewage disposal systems on the premises of occupied structures accessible to public sewers. All such structures must be connected to the public sewers.
- 3. The outfall sewer or drain shall be extended to the low water mark of the receiving body of water. Where necessary to ensure proper mixing and waste assimilation, an outfall sewer or drain may be extended with appurtenances below the low water mark and into the bed of a navigable stream provided that the permittee has secured an easement, right-of-way, license or lease from DEP in accordance with Section 15 of the Dam Safety and Encroachments Act, the Act of November 26, 1978, P.L. 1375, as amended.
- 4. The approval is specifically made contingent on the permittee acquiring all necessary property rights, by easement or otherwise, providing for the satisfactory construction, operation, maintenance and replacement of all sewers or sewerage structures in, along or across private property with full rights of ingress, egress and regress.
- 5. When construction of the approved sewerage facilities is completed and before they are placed in operation, the permittee shall notify DEP in writing so that a DEP representative may inspect the facilities.
- 6. The approval of the plans, and the authority granted in this permit, if not specifically extended, shall cease and be null and void 5 years from the issuance date of this permit unless construction or modification of the facilities covered by this permit has begun on or before the fifth anniversary of the permit date.
- 7. If, at any time, the sewerage facilities covered by this permit create a public nuisance, including but not limited to, causing malodors or causing environmental harm to waters of the Commonwealth, DEP may require the permittee to adopt appropriate remedial measures to abate the nuisance or harm.
- 8. If, after the issuance of this permit, DEP approves a municipal sewage facilities official plan or an amendment to an official plan under Act 537 (Pennsylvania Sewage Facilities Act, the Act of January 24, 1966, P.L. 1535 as amended) in which sewage from the herein approved facilities will be treated and disposed of at other planned facilities, the permittee shall, upon notification from the municipality or DEP, provide for the conveyance of its sewage to the planned facilities, abandon use and decommission the herein approved facilities including the proper disposal of solids, and notify DEP accordingly. The permittee shall adhere to schedules in the approved official plan, amendments to the plan, or other agreements between the permittee and municipality. This permit shall then, upon notice from DEP, terminate and become null and void and shall be relinquished to DEP.
- 9. This permit does not relieve the permittee of its obligations to comply with all federal, interstate, state or local laws, ordinances and regulations applicable to the sewerage facilities.
- 10. This permit does not give any real or personal property rights or grant any exclusive privileges, nor shall it be construed to grant or confirm any right, easement or interest in, on, to or over any lands which belong to the Commonwealth.
- 11. The authority granted by this permit is subject to all effluent requirements, monitoring requirements and other conditions as set forth in the NPDES Permit and all subsequent amendments and renewals. No discharge is authorized from these facilities unless approved by an NPDES Permit.

**Construction**

- 12. This permit is issued under the authorization of The Clean Streams Law and 25 Pa. Code Chapter 91. The permittee shall obtain all necessary permits, approvals and/or registrations under 25 Pa. Code Chapters 102, 105 and 106 prior to commencing construction of the facilities authorized by this permit, as applicable. The permittee should contact the DEP office that issued this permit if there are any questions concerning the applicability of additional permits.

- 13. The facilities shall be constructed under the supervision of a Pennsylvania licensed Professional Engineer in accordance with the approved reports, plans and specifications.
- 14. A Pennsylvania licensed Professional Engineer shall certify that construction of the permitted facilities was completed in accordance with the application and design plans submitted to DEP, using the "Post Construction Certification" form (3800-PM-WSFR0179a). It is the permittee's responsibility to ensure that a Professional Engineer is on-site to provide the necessary oversight and/or inspections to certify the facilities. The certification must be submitted to DEP before the facility is placed in operation. As-built drawings, photographs (if available) and a description of all deviations from the application and design plans must be submitted to DEP within 30 days of certification.
- 15. Manhole inverts shall be formed to facilitate the flow of the sewage and to prevent the stranding of sewage solids. The manhole structure shall be built to prevent undue infiltration, entrance of street wash or grit and provide safe access to facilitate manhole maintenance activities.
- 16. The local Waterways Conservation Officer of the Pennsylvania Fish and Boat Commission (PFBC) shall be notified when the construction of any stream crossing and/or outfall is started and completed. A written permit must be secured from the PFBC if the use of explosives in any waterways is required and the permittee shall notify the local Waterways Conservation Officer when explosives are to be used.

#### **Operation and Maintenance**

- 17. The permittee shall maintain records of "as-built" plans showing all the treatment facilities as actually constructed together with facility operation and maintenance (O&M) manuals and any other relevant information that may be required. Upon request, the "as-built" plans and O&M manuals shall be filed with DEP.
- 18. The sewers shall have adequate foundation support as soil conditions require. Trenches shall be back-filled to ensure that sewers will have proper structural stability, with minimum settling and adequate protection against breakage. Concrete used in connection with these sewers shall be protected from damage by water, freezing, drying or other harmful conditions until cured.
- 19. Stormwater from roofs, foundation drains, basement drains or other sources shall not be admitted directly to the sanitary sewers.
- 20. The approved sewers shall be maintained in good condition, kept free of deposits by flushing or other cleaning methods and repaired when necessary.
- 21. The sewerage facilities shall be properly operated and maintained to perform as designed.
- 22. The attention of the permittee is called to the highly explosive nature of certain gases generated by the digestion of sewage solids when these gases are mixed in proper proportions with air and to the highly toxic character of certain gases arising from such digestion or from sewage in poorly ventilated compartments or sewers. Therefore, at all places throughout the sewerage facilities where hazard of fire, explosion or danger from toxic gases may occur, the permittee shall post conspicuous permanent and legible warnings. The permittee shall instruct all employees concerning the aforesaid hazards, first aid and emergency methods of meeting such hazards and shall make all necessary equipment and material accessible.
- 23. An operator certified in accordance with the Water and Wastewater Systems Operator Certification Act of February 21, 2002, 63 P.S. §§1001, *et seq.* shall operate the sewage treatment plant.
- 24. The permittee shall properly control any industrial waste discharged into its sewerage system by regulating the rate and quality of such discharge, requiring necessary pretreatment and excluding industrial waste, if necessary, to protect the integrity or operation of the permittee's sewerage system.
- 25. There shall be no physical connection between a public water supply system and a sewer or appurtenance to it which would permit the passage of any sewage or polluted water into the potable water supply. No water pipe shall pass through or come in contact with any part of a sewer manhole.
- 26. All connections to the approved sanitary sewers must be in accordance with the official Act 537 Plan and, if applicable, a corrective action plan as contained in the approved Title 25 Pa. Code Chapter 94 Municipal Wasteload Management Annual Report.
- 27. Collected screenings, slurries, sludge and other solids shall be handled and disposed of in compliance with Title 25 Pa. Code Chapters 271, 273, 275, 283 and 285 (related to permits and requirements for land filling, land application, incineration and storage of sewage sludge), Federal Regulations 40 CFR 257 and the Federal Clean Water Act and its amendments.



**WATER QUALITY MANAGEMENT  
 POST CONSTRUCTION CERTIFICATION**

<b>PERMITTEE IDENTIFIER</b>	
Permittee	West Grove Borough Authority Chester County
Municipality	West Grove Borough
County	Chester
WQM Permit No.	<u>1599402</u>
Facility Type	Sewage
<b>PERMITTEE IDENTIFIER</b>	
<b>All of the above information should be taken directly from the Water Quality Management Permit.</b>	
<b>CERTIFICATION</b>	
<p>This certification must be completed and returned to the permits section of the DEP's regional office issuing the WQM permit within 30 days of completion of the project and received by DEP prior to operation, and if requested, as-built drawings, photographs (if available) and a discussion of any DEP-approved deviations from the design plans during construction.</p>	
<p>I, being a Registered Professional Engineer in Pennsylvania, do hereby certify to the best of my knowledge and belief, based upon personal observation and interviews, that the above facility approved under the Water Quality Management Permit has been constructed in accordance with the plans, specifications and modifications approved by DEP.</p>	
<p>Construction Completion Date (MM/DD/YYYY): _____</p>	
<p>Engineer' s Seal</p>	<b>Professional Engineer</b>
	Name _____ (Please Print or Type)
	Signature
	Date
	License Expiration Date
	Firm or Agency
	Telephone
	<b>Permittee or Authorized Representative</b>
	Name _____ (Please Print or Type)
	Signature
	Title
	Telephone