

Application Type Renewal  
 Facility Type \_\_\_\_\_  
 Major / Minor Major

**NPDES PERMIT FACT SHEET  
 INDIVIDUAL INDUSTRIAL WASTE (IW)  
 AND IW STORMWATER**

Application No. PA0009920  
 APS ID 780559  
 Authorization ID 926487

**Applicant and Facility Information**

Applicant Name	<u>Exelon Generation Co. LLC</u>	Facility Name	<u>Exelon Three Mile Island Nuclear Station</u>
Applicant Address	<u>PO Box 480 Route 441 South Middletown, PA 17057-0480</u>	Facility Address	<u>Route 441 South P O Box 480 Middletown, PA 17057</u>
Applicant Contact	<u>Scott Cogley</u>	Facility Contact	<u>Scott Cogley</u>
Applicant Phone	<u>(717) 948-8881</u>	Facility Phone	<u>717-948-8881</u>
Client ID	<u>273620</u>	Site ID	<u>450833</u>
SIC Code	<u>4911</u>	Municipality	<u>Londonderry Township</u>
SIC Description	<u>Trans. &amp; Utilities - Electric Services</u>	County	<u>Dauphin</u>
Date Application Received	<u>May 3, 2012</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>May 8, 2012</u>	If No, Reason	<u>Major Facility</u>
Purpose of Application	<u>.Approval of chemical additive Nalco Nalclean 2568 PULV (sulfamic acid)</u>		

**Summary of Review**

Exelon requested approval to use of Nalco Nalclean 2568 PULV to periodically clean and descale TMI Unit 1 radioactive liquid Miscellaneous Wastewater evaporator unit.

Recommend approval of additive by letter.

Approve	Return	Deny	Signatures	Date
X			Martin L. Ferry, P.E. / Environmental Engineer	October 17, 2013
			Jay E. Patel, P.E. / Environmental Engineer Manager	
			Maria D. Bebenek, P.E., Environmental Manager	

**Discharge, Receiving Waters and Water Supply Information**

Outfall No. 001 Design Flow (MGD) 43

Latitude 40° 9' 8.00" Longitude 76° 43' 40.00"

Quad Name Middletown Quad Code 1732

Wastewater Description: Treated wastewater containing minimal levels of Nalco Nalclean 2568 PULV

Receiving Waters Unnamed Tributary of Susquehanna River Stream Code 06685

NHD Com ID 56406043 RMI 59.15

Drainage Area 24,966 Yield (cfs/mi<sup>2</sup>) 0.1328

Q<sub>7-10</sub> Flow (cfs) 3,315.5 Q<sub>7-10</sub> Basis USGS 01570500

Elevation (ft) \_\_\_\_\_ Slope (ft/ft) \_\_\_\_\_

Watershed No. 7-G Chapter 93 Class. WWF, MF

Existing Use WWF, MF Existing Use Qualifier \_\_\_\_\_

Exceptions to Use \_\_\_\_\_ Exceptions to Criteria \_\_\_\_\_

Assessment Status Attaining Use(s)

Cause(s) of Impairment \_\_\_\_\_

Source(s) of Impairment \_\_\_\_\_

TMDL Status \_\_\_\_\_ Name \_\_\_\_\_

Background/Ambient Data \_\_\_\_\_ Data Source \_\_\_\_\_

pH (SU) \_\_\_\_\_

Temperature (°F) \_\_\_\_\_

Hardness (mg/L) \_\_\_\_\_

Other: \_\_\_\_\_

Nearest Downstream Public Water Supply Intake Columbia Water Company

PWS Waters Susquehanna River Flow at Intake (cfs) 3453

PWS RMI 42.83 Distance from Outfall (mi) 16.3

**Development of Effluent Limitations**

<b>Outfall No.</b>	<u>001</u>	<b>Design Flow (MGD)</b>	<u>43</u>
<b>Latitude</b>	<u>40° 09' 08"</u>	<b>Longitude</b>	<u>76° 43' 40"</u>
<b>Wastewater Description:</b> <u>Discharge of treated water after cleaning Miscellaneous Wastewater evaporator unit</u>			

Exelon periodically cleans and descales TMI Unit 1 radioactive liquid Miscellaneous Wastewater evaporator unit. Exelon is requesting approval for use of Nalco Nalclean 2568 PULV (sulfamic acid) where 30 lbs (35 gallons) is added.

Sulfamic acid and the resulting salts from descaling will be concentrated in the evaporator bottoms during cleaning. The evaporator distillate is processed through a downstream evaporator condensate demineralizer. Exelon estimates that 99% of the sulfamic acid will remain in the evaporator bottoms for disposal as low level radioactive waste. The remaining 1% will carry-over into the distillate as a potential liquid effluent.

The distillate is collected in downstream tanks, sampled, and, if results are acceptable, released in batches generally not greater than 5,000 gallons at 30 gpm for mixing with cooling water for discharge from Main Station Discharge Outfall 001 to Susquehanna River.

The Chemical Additive Notification form lists a discharge flow of 81.2 MGD and a LTA of 19 MGD. The NPDES renewal application lists a maximum daily flow of 43 MGD and a monthly average of 19 MGD. 43 MGD will be used for the evaluation. The use of 81.2 MGD or 43 MGD does not significantly change the outcome because the larger discharge will result in a corresponding lower effluent concentration.

The discharge of Nalco Nalclean 2568 PULV will be evaluated at the worst case scenario of 100% discharge of chemical used where effluent concentration = lbs used/(43\*8.34 = 0.0837 mg/l.

Nalco Nalclean 2568 PULV was modeled using Pentoxsd (printouts attached) resulting in a WQBEL of 207 ug/l compared to the effluent concentration of 83.7 ug/l. The actual effluent concentration is expected to be significantly lower and the chemical additive is approved for use.

PENTOXSD

Modeling Input Data

Stream Code	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope	PWS With (mgd)	Apply FC
6685	59.15	266.47	24966.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

LFY	Trib Flow (cfs)	Stream Flow (cfs)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Rch Velocity (fps)	Rch Trav Time (days)	Tributary		Stream		Analysis	
								Hard (mg/L)	pH	Hard (mg/L)	pH	Hard (mg/L)	pH
Q7-10	0.1328	0	0	0	0	0	0	100	7	0	0	0	0
Qh		0	0	0	0	0	0	100	7	0	0	0	0

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	AFC PMF	CFC PMF	THH PMF	CRL PMF	Disc Hard (mg/L)	Disc pH
Exelon	PA000992	0	43	0	0	0	0	0	0	100	7

Parameter Data

Parameter Name	Disc Conc (µg/L)	Trib Conc (µg/L)	Disc Daily CV	Disc Hourly CV	Steam Conc (µg/L)	Stream CV	Fate Coef	FOS	Crit Mod	Max Disc Conc (µg/L)
Nalco Naclean 2568 PULV	83.7	0	0.5	0.5	0	0	0	0	1	0

Stream Code	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope	PWS With (mgd)	Apply FC
6685	57.80	262.10	25018.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

LFY	Trib Flow (cfs)	Stream Flow (cfs)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Rch Velocity (fps)	Rch Trav Time (days)	Tributary		Stream		Analysis	
								Hard (mg/L)	pH	Hard (mg/L)	pH	Hard (mg/L)	pH
Q7-10	0.1328	0	0	0	0	0	0	100	7	0	0	0	0
Qh		0	0	0	0	0	0	100	7	0	0	0	0

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	AFC PMF	CFC PMF	THH PMF	CRL PMF	Disc Hard (mg/L)	Disc pH
		0	0	0	0	0	0	0	0	100	7

Parameter Data

Parameter Name	Disc Conc (µg/L)	Trib Conc (µg/L)	Disc Daily CV	Disc Hourly CV	Steam Conc (µg/L)	Stream CV	Fate Coef	FOS	Crit Mod	Max Disc Conc (µg/L)
Nalco Naclean 2568 PULV	0	0	0.5	0.5	0	0	0	0	1	0

**PENTOXSD Analysis Results**

**Hydrodynamics**

<u>SWP Basin</u>		<u>Stream Code:</u>		<u>Stream Name:</u>							
07K		6685		SUSQUEHANNA RIVER							
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope	Depth (ft)	Width (ft)	WD Ratio	Velocity (fps)	Reach Trav Time (days)	CMT (min)

**Q7-10 Hydrodynamics**

59.150	3315.5	0	3315.5	66.521	0.0006	0.6777	2251.1	3321.8	2.217	0.0372	1000+
57.800	3322.4	0	3322.4	NA	0	0	0	0	0	0	NA

**Qh Hydrodynamics**

59.150	8870.5	0	8870.5	66.521	0.0006	1.0392	2251.1	2166.1	3.8202	0.0216	1000+
57.800	8886.6	0	8886.6	NA	0	0	0	0	0	0	NA

**PENTOXSD Analysis Results**

**Recommended Effluent Limitations**

<u>SWP Basin</u>	<u>Stream Code:</u>	<u>Stream Name:</u>	
07K	6685	SUSQUEHANNA RIVER	

RMI	Name	Permit Number	Disc Flow (mgd)
59.15	Exelon	PA000992	43.0000

Parameter	Effluent Limit (µg/L)	Governing Criterion	Max. Daily Limit (µg/L)	Most Stringent	
				WQBEL (µg/L)	WQBEL Criterion
Nalco Nucleon 2568 PULV	83.7	INPUT	130.585	201.745	CFC