

Summary of Review

Review shows there has been no discharge via Outfall 001 since the last permit renewal.

The settled solids are removed from the sludge thickener tank by a tanker and transported for disposal. Calcium thiosulfate is used for dechlorination. Vtag-8812 is used as a polymer.

No upgrades are proposed for the treatment facility at this renewal.

All the chemicals listed in the application under chemical additives are used for the treatment of drinking water.

DEP inspection was conducted on July 14, 2025. No violations were noted in the inspection report.

The Christina River Basin Total Maximum Daily Load (TMDL) for nutrients and dissolved oxygen for low-flow conditions was issued by the EPA in January 2001 and revised in October 2002 and April 2006. Page 44 of the original report says that water filtration plant backwash facilities were not included in the allocation analysis, since a model run covering all small discharges (0.25 mgd or less) indicated that the daily average DO and minimum DO were protected at all locations in the Christina River Basin. Summary Table 13 in the TMDL report lists the permit number, a flow of 0.14 mgd, and values in the wasteload allocation columns that correspond to the characteristic (default) concentrations (except for CBOD₅) for Water Filtration Plants, listed in Table 6-4 in the EPA report Hydrodynamic and Water Quality Model of Christina River Basin. Default for CBOD₅ was listed as 2.0 mg/l but Table 13 lists 10 mg/l. The current NPDES permit included the TMDL parameters with limits, to be consistent with EPA TMDL requirements.

On June 27, 2012, the Department of Environmental Protection (DEP) submitted "Alternate Reduction Scenario" to EPA's 2006 Addendum to Christina River Basin Low-Flow TMDL for review and approval to USEPA Region 3. On August 29, 2012, EPA provided written notification of their acceptance of DEP's proposed alternative reduction scenario for Christina River Basin Low-Flow TMDL in Chester County, PA. EPA's 2006 Addendum to the TMDL (Addendum) provides one scenario for load reductions that, together with other sources' reductions, result in achieving water quality standards throughout the length of the impaired waterbody. The Addendum contemplates the development of, and is sufficiently flexible to allow for, an alternative reduction scenario that also demonstrates that water quality standards are met throughout the length of the impaired waterbody, without the need for a formal TMDL revision, given the dynamic nature of NPDES permits in TMDL waters. The aggregate sum of the wasteload allocations is unchanged and there are no changes to the total loading by basin or sub watershed segment. The alternative reduction scenario, as approved by EPA with wasteload allocation for all the dischargers was published in PA Bulletin Document No. 12-2146d. The wasteload allocations for Rock Run WFP listed in the PA Bulletin are similar to the allocations in the original TMDL report except for TN.

Review of the records from last permit renewal indicates that there was an error in Pennsylvania's Alternative Reduction Scenario for Christina River Basin Low-Flow TMDL dated June 27, 2012, for Rock Run WFP and assigned the original TMDL net wasteload allocations for NH₃-N, TP and TN for this facility. Accordingly, the same limits are carried over to the new permit (from previous fact sheet).

Christina River Basin High-Flow TMDL for Fecal Coliform= #2/100 ml (Geo. Mean), and for TSS=20 mg/l for this facility. These existing limits are also carried over to the new permit.

The limits imposed in the permit are consistent with the 2006 revision to the low flow Christina TMDL, where the TMDL assigned net WLAs for TN, NH₃-N, and TP. The facility is also listed under Christina River Basin TMDLs for Nutrient and Low Dissolved Oxygen Under High-Flow Conditions and WLAs are assigned for CBOD₅, NH₃-N, TP and TN in the TMDL report. Since the Christina River Low-Flow TMDL is the driver for the Christina River High-Flow TMDL, especially for nutrients, it is assumed that compliance with the low flow TMDL, satisfies the compliance of the high flow TMDL.

The Department's guidance document, Technology-Based Control Requirements for Water Treatment Plant Wastes (362-2183-003), includes BPT effluent requirements for filter backwash, as indicated in the following table. These have been applied previously and continue, except for parameters with WQ limits that are already lower (Suspended Solids and Aluminum).

Summary of Review

Table 1

Parameter	Monthly Avg (mg/l)		Daily Max (mg/l)
Suspended Solids	30		60
Iron (Total)	2		4
Aluminum (Total)	4		8
Manganese (total)	1		2
Flow	Monitor		
pH	6 – 9 at all times		
Total Residual Chlorine	0.5		1.0

DRBC Docket No. D-2006-036 CP-3 was approved for this discharge on September 9, 2021. The effluent limits in the current NPDES permit are consistent or more stringent than the effluent limits listed in the docket.

There was no discharge via Outfall 001 since the last permit renewal. Samples were collected from the sample line at Outfall 001. A “Reasonable Potential Analysis” determined the following parameters were candidates for limitations & monitoring:

Table 2

Parameter	Monthly Ave. Conc (ug/l)	Maximum Daily Conc. (ug/l)	Inst. Max. (ug/l)	Recommendation/Basis
Total Copper*	14.5	22.2	22.2	TMS v.1.4
Free Cyanide**	6.11	9.53	15.3	TMS v.1.4
Total Iron***	Report	Report	Report	TMS v.1.4
Total Manganese***	Report	Report	Report	TMS v.1.4

*The facility is tied into the sanitary sewer; the need to be discharged via Outfall 001 is greatly reduced. Review of copper data shows mostly non-detect results except for summer months which is directly linked to the addition of copper sulfate in the reservoir during summer months. This reservoir has a long history of having high nutrients due to the runoff from the adjacent Coatesville Country Club (Golf). This has caused major algae issues. Permittee has tried various different ways to reduce and control algae in the reservoir - discussion with golf course operations, various treatment trials and mechanisms in the reservoir including SolarBees, LG sonic units - and have had the most success using copper sulfate. Since intake water from, and the discharge to, the same water body, we want to collect data to see if the facility is contributing any copper to the discharge. Monitoring for Copper - intake, effluent and effluent net are incorporated into the new permit (from 2021 fact sheet). Similarly, the current monitoring requirements are carried over to the draft permit to collect data if there is any discharge during the next permit term.

** The facility is tied into the sanitary sewer; the need to be discharged via Outfall 001 is greatly reduced. Monitoring is recommended for the draft permit to collect data if there is any discharge during the next permit term.

***Existing technology-based limits are recommended to continue in the draft permit.

TMS report is attached for reference.

PFAS:

Facility provided PFAS sampling results in the application. Review shows no concerns. Facility does not have a treatment process specifically designed to remove PFAS from drinking water. No monitoring is required at this time.

Summary of Review

Following are the recommended effluent limits:

PARAMETER	AVERAGE MONTHLY LIMIT (mg/l)	BASIS
CBOD5	10	TMDL
Total Suspended Solids	20	TMDL
Ammonia-Nitrogen (effluent net)	0.10	TMDL
Total Nitrogen (effluent net)	0.24	TMDL
Total Phosphorus (effluent net)	0.10	TMDL
Dissolved Oxygen	5.0 Inst. Minimum	TMDL
pH	6.0 – 9.0 SU	BPT
Total Aluminum*	0.8	Existing limit/previous calculation
Total Iron	2.0	BPT
Total Manganese	1.0	BPT
Total Residual Chlorine	0.5	BPT
Chlorodibromomethane**	0.005	Existing limit /previous TMS
Dichlorobromomethane**	0.006	Existing limit /previous TMS
Chloroform**	0.035	Existing limit /previous TMS
Total Dissolved Solids	1,000	DRBC
Fecal Coliform	2 #/100 ml (Geo. Mean)	TMDL
Total Copper	Report	Existing requirement
Hexavalent Chromium*	Report	Existing requirement
Dissolved Iron*	Report	Existing requirement
Total Thallium*	Report	Existing requirement
Free Cyanide	Report	***

*There were no discharges from the facility since April 2020. Existing monitoring / limits requirements for these parameters are carried over to the draft permit.

**According to the 2021 fact sheet the discharge consistently shows elevated concentrations for chloroform, chlorodibromomethane, and dichlorobromomethane. Effluent limits were established at the last permit renewal and recommended to continue in the draft permit.

***Explanation is under Table # 2

All the existing limits are carried over to the permit draft.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Act 14 Notifications:

West Caln Township - October 20, 2025
 Chester County - November 19, 2025

Permit Conditions:

- A. Acquire Necessary Property Rights
- B. Proper Sludge Disposal
- C. WQM Permit

Summary of Review

- D. BAT/ELG Reopener
- E. Chlorine Optimization
- F. Intake Monitoring
- G. Chemical Additives

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.14</u>
Latitude	<u>40° 0' 17.89"</u>	Longitude	<u>-75° 51' 13.23"</u>
Quad Name	<u>Wagontown</u>	Quad Code	<u>1839</u>
Wastewater Description: <u>Water Treatment Effluent</u>			
Receiving Waters	<u>Rock Run Reservoir (Unnamed Tributary to West Branch Brandywine Creek)</u>	Stream Code	<u>00206</u>
NHD Com ID	<u>26105796</u>	RMI	<u>1.9</u>
Drainage Area	<u>5.12 mi²</u>		
Q ₇₋₁₀ Flow (cfs)	<u>0.114*</u>	Q ₇₋₁₀ Basis	<u>usgs streamstats</u>
Elevation (ft)	<u>492.11</u>		
Watershed No.	<u>3-H</u>	Chapter 93 Class.	<u>TSF</u>
Assessment Status	<u>Not Assessed</u>		

*Discharge is into the Rock Run Reservoir, Q₇₋₁₀ is calculated at the upstream point of the Reservoir.

Compliance History

DMR Data for Outfall 001 (from February 1, 2025 to January 31, 2026)

Parameter	JAN-26	DEC-25	NOV-25	OCT-25	SEP-25	AUG-25	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25
Total Nitrogen (lbs/day) Intake Average Monthly	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG
Total Nitrogen (mg/L) Intake Average Monthly	3.93	3.13	3.32	1.83	2.79	3.40	3.10	2.10	2.63	3.21	4.36	4.36
Total Nitrogen (mg/L) Intake Daily Maximum	3.93	3.13	3.32	1.83	2.79	3.40	3.10	GG	GG	3.21	4.36	4.36
Ammonia (lbs/day) Intake Average Monthly	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG
Ammonia (mg/L) Intake Average Monthly	0.17	0.30	0.40	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10
Ammonia (mg/L) Intake Daily Maximum	0.17	0.30	0.40	< 0.10	< 0.10	< 0.10	< 0.10	GG	GG	< 0.10	< 0.10	< 0.10
Total Phosphorus (lbs/day) Intake Average Monthly	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG
Total Phosphorus (mg/L) Intake Average Monthly	< 0.10	< 0.10	0.10	< 0.10	< 0.10	< 0.10	< 0.10	0.10	0.13	0.14	< 0.10	< 0.10
Total Phosphorus (mg/L) Intake Daily Maximum	< 0.10	< 0.10	0.10	< 0.10	< 0.10	< 0.10	< 0.10	GG	GG	0.14	< 0.10	< 0.10
Total Copper (mg/L) Intake Daily Maximum	< 0.010	< 0.010	0.012	0.053	0.092	0.056	0.044	< 0.10	0.043	0.018	< 0.010	< 0.010

Compliance History

None

Proposed Effluent Limitations and Monitoring Requirements

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	1/discharge	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/discharge	Grab
Dissolved Oxygen	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/month	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.0	1/discharge	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	11.7	XXX	XXX	10.0	Report	XXX	1/month	Grab
Total Suspended Solids	23.4	46.7	XXX	20.0	40.0	50	1/month	Grab
Total Dissolved Solids	1168	2335	XXX	1000.0	2000.0	2500	1/month	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	² Geo Mean	XXX	XXX	1/month	Grab
Total Nitrogen Intake	Report	XXX	XXX	Report	Report	XXX	1/month	Calculation
Total Nitrogen Effluent Net	0.280	XXX	XXX	0.24	Report	XXX	1/month	Calculation
Total Nitrogen	Report	XXX	XXX	Report	Report	XXX	1/month	Calculation
Ammonia-Nitrogen Intake	Report	XXX	XXX	Report	Report	XXX	1/month	Grab
Ammonia-Nitrogen Effluent Net	0.117	XXX	XXX	0.10	Report	XXX	1/month	Calculation
Ammonia-Nitrogen	Report	XXX	XXX	Report	Report	XXX	1/month	Grab
Total Phosphorus Intake	Report	XXX	XXX	Report	Report	XXX	1/month	Grab
Total Phosphorus	Report	XXX	XXX	Report	Report	XXX	1/month	Grab
Total Phosphorus Effluent Net	0.117	XXX	XXX	0.10	Report	XXX	1/month	Calculation

Outfall001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Aluminum, Total	0.93	1.87	XXX	0.8	1.6	2.1	1/month	Grab
Chromium, Hexavalent	XXX	XXX	XXX	XXX	Report	XXX	1/quarter	Grab
Copper, Total	XXX	XXX	XXX	XXX	Report	XXX	1/month	Grab
Copper, Total Effluent Net	XXX	XXX	XXX	XXX	Report	XXX	1/month	Grab
Copper, Total Intake	XXX	XXX	XXX	XXX	Report	XXX	1/month	Grab
Cyanide, Free	XXX	XXX	XXX	XXX	Report	XXX	1/quarter	Grab
Iron, Dissolved	XXX	XXX	XXX	XXX	Report	XXX	1/quarter	Grab
Iron, Total	2.3	4.7	XXX	2.0	4.0	5	1/month	Grab
Manganese, Total	1.2	2.4	XXX	1.0	2.0	2.5	1/month	Grab
Thallium, Total	XXX	XXX	XXX	XXX	Report	XXX	1/quarter	Grab
Chlorodibromomethane	0.006	0.009	XXX	0.005	0.008	0.012	1/month	Grab
Dichlorobromomethane	0.007	0.011	XXX	0.006	0.009	0.015	1/month	Grab
Chloroform	0.041	0.064	XXX	0.035	0.055	0.088	1/month	Grab

Discharge Information

Instructions **Discharge** Stream

Facility: Rock Run WFP NPDES Permit No.: PA0012416 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Water Treatment Effluent

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h
0.14	106	7.6						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L	308								
	Chloride (PWS)	mg/L	142								
	Bromide	mg/L	< 0.2								
	Sulfate (PWS)	mg/L	16.5								
	Fluoride (PWS)	mg/L	0.23								
Group 2	Total Aluminum	µg/L	< 9								
	Total Antimony	µg/L	< 0.3								
	Total Arsenic	µg/L	< 0.4								
	Total Barium	µg/L	55								
	Total Beryllium	µg/L	< 0.1								
	Total Boron	µg/L	< 4								
	Total Cadmium	µg/L	< 0.1								
	Total Chromium (III)	µg/L	2								
	Hexavalent Chromium	µg/L	1.4								
	Total Cobalt	µg/L	< 0.2								
	Total Copper	µg/L	16								
	Free Cyanide	µg/L	41								
	Total Cyanide	µg/L	39								
	Dissolved Iron	µg/L	20								
	Total Iron	µg/L	906								
	Total Lead	µg/L	< 0.3								
	Total Manganese	µg/L	273								
	Total Mercury	µg/L	< 0.09								
	Total Nickel	µg/L	5								
	Total Phenols (Phenolics) (PWS)	µg/L	< 5								
Total Selenium	µg/L	< 0.5									
Total Silver	µg/L	< 0.2									
Total Thallium	µg/L	< 0.05									
Total Zinc	µg/L	< 4									
Total Molybdenum	µg/L										
Acrolein	µg/L	<									
Acrylamide	µg/L	<									
Acrylonitrile	µg/L	<									
Benzene	µg/L	<									
Bromoform	µg/L	<									

Group 3	Carbon Tetrachloride	µg/L	<																
	Chlorobenzene	µg/L	<																
	Chlorodibromomethane	µg/L	<																
	Chloroethane	µg/L	<																
	2-Chloroethyl Vinyl Ether	µg/L	<																
	Chloroform	µg/L	<																
	Dichlorobromomethane	µg/L	<																
	1,1-Dichloroethane	µg/L	<																
	1,2-Dichloroethane	µg/L	<																
	1,1-Dichloroethylene	µg/L	<																
	1,2-Dichloropropane	µg/L	<																
	1,3-Dichloropropylene	µg/L	<																
	1,4-Dioxane	µg/L	<																
	Ethylbenzene	µg/L	<																
	Methyl Bromide	µg/L	<																
	Methyl Chloride	µg/L	<																
	Methylene Chloride	µg/L	<																
	1,1,2,2-Tetrachloroethane	µg/L	<																
	Tetrachloroethylene	µg/L	<																
	Toluene	µg/L	<																
1,2-trans-Dichloroethylene	µg/L	<																	
1,1,1-Trichloroethane	µg/L	<																	
1,1,2-Trichloroethane	µg/L	<																	
Trichloroethylene	µg/L	<																	
Vinyl Chloride	µg/L	<																	
Group 4	2-Chlorophenol	µg/L	<																
	2,4-Dichlorophenol	µg/L	<																
	2,4-Dimethylphenol	µg/L	<																
	4,6-Dinitro- α -Cresol	µg/L	<																
	2,4-Dinitrophenol	µg/L	<																
	2-Nitrophenol	µg/L	<																
	4-Nitrophenol	µg/L	<																
	p-Chloro-m-Cresol	µg/L	<																
	Pentachlorophenol	µg/L	<																
	Phenol	µg/L	<																
	2,4,6-Trichlorophenol	µg/L	<																
Group 5	Acenaphthene	µg/L	<																
	Acenaphthylene	µg/L	<																
	Anthracene	µg/L	<																
	Benzidine	µg/L	<																
	Benzo(a)Anthracene	µg/L	<																
	Benzo(a)Pyrene	µg/L	<																
	3,4-Benzofluoranthene	µg/L	<																
	Benzo(ghi)Perylene	µg/L	<																
	Benzo(k)Fluoranthene	µg/L	<																
	Bis(2-Chloroethoxy)Methane	µg/L	<																
	Bis(2-Chloroethyl)Ether	µg/L	<																
	Bis(2-Chloroisopropyl)Ether	µg/L	<																
	Bis(2-Ethylhexyl)Phthalate	µg/L	<																
	4-Bromophenyl Phenyl Ether	µg/L	<																
	Butyl Benzyl Phthalate	µg/L	<																
	2-Chloronaphthalene	µg/L	<																
	4-Chlorophenyl Phenyl Ether	µg/L	<																
	Chrysene	µg/L	<																
	Dibenzo(a,h)Anthracene	µg/L	<																
	1,2-Dichlorobenzene	µg/L	<																
	1,3-Dichlorobenzene	µg/L	<																
	1,4-Dichlorobenzene	µg/L	<																
	3,3-Dichlorobenzidine	µg/L	<																
Diethyl Phthalate	µg/L	<																	
Dimethyl Phthalate	µg/L	<																	
Di-n-Butyl Phthalate	µg/L	<																	
2,4-Dinitrotoluene	µg/L	<																	

Group 6	2,6-Dinitrotoluene	µg/L	^																											
	Di-n-Octyl Phthalate	µg/L	^																											
	1,2-Diphenylhydrazine	µg/L	^																											
	Fluoranthene	µg/L	^																											
	Fluorene	µg/L	^																											
	Hexachlorobenzene	µg/L	^																											
	Hexachlorobutadiene	µg/L	^																											
	Hexachlorocyclopentadiene	µg/L	^																											
	Hexachloroethane	µg/L	^																											
	Indeno(1,2,3-cd)Pyrene	µg/L	^																											
	Isophorone	µg/L	^																											
	Naphthalene	µg/L	^																											
	Nitrobenzene	µg/L	^																											
	n-Nitrosodimethylamine	µg/L	^																											
	n-Nitrosodi-n-Propylamine	µg/L	^																											
	n-Nitrosodiphenylamine	µg/L	^																											
	Phenanthrene	µg/L	^																											
	Pyrene	µg/L	^																											
	1,2,4-Trichlorobenzene	µg/L	^																											
	Aldrin	µg/L	^																											
	alpha-BHC	µg/L	^																											
	beta-BHC	µg/L	^																											
	gamma-BHC	µg/L	^																											
	delta BHC	µg/L	^																											
	Chlordane	µg/L	^																											
	4,4-DDT	µg/L	^																											
	4,4-DDE	µg/L	^																											
	4,4-DDD	µg/L	^																											
Dieldrin	µg/L	^																												
alpha-Endosulfan	µg/L	^																												
beta-Endosulfan	µg/L	^																												
Endosulfan Sulfate	µg/L	^																												
Endrin	µg/L	^																												
Endrin Aldehyde	µg/L	^																												
Heptachlor	µg/L	^																												
Heptachlor Epoxide	µg/L	^																												
PCB-1016	µg/L	^																												
PCB-1221	µg/L	^																												
PCB-1232	µg/L	^																												
PCB-1242	µg/L	^																												
PCB-1248	µg/L	^																												
PCB-1254	µg/L	^																												
PCB-1260	µg/L	^																												
PCBs, Total	µg/L	^																												
Toxaphene	µg/L	^																												
2,3,7,8-TCDD	ng/L	^																												
Group 7	Gross Alpha	pCi/L																												
	Total Beta	pCi/L	^																											
	Radium 226/228	pCi/L	^																											
	Total Strontium	µg/L	^																											
	Total Uranium	µg/L	^																											
Osmotic Pressure	mOs/kg																													

Stream / Surface Water Information

Rock Run WFP, NPDES Permit No. PA0012416, Outfall 001

Instructions Discharge **Stream**

Receiving Surface Water Name: _____ No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	000206	1.9	492.11	5.12			Yes
End of Reach 1	000206	0.75	375.97	7.72			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	1.9	0.1	0.114									100	7		
End of Reach 1	0.75	0.1	0.252												

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	1.9														
End of Reach 1	0.75														

Model Results

Rock Run WFP, NPDES Permit No. PA0012416, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Hydrodynamics

Wasteload Allocations

AFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	1,145	
Total Antimony	0	0		0	1,100	1,100	1,679	
Total Arsenic	0	0		0	340	340	519	Chem Translator of 1 applied
Total Barium	0	0		0	21,000	21,000	32,054	
Total Boron	0	0		0	8,100	8,100	12,364	
Total Cadmium	0	0		0	2,091	2,22	3,39	Chem Translator of 0.942 applied
Total Chromium (III)	0	0		0	588.042	1,861	2,840	Chem Translator of 0.316 applied
Hexavalent Chromium	0	0		0	16	16.3	24.9	Chem Translator of 0.982 applied
Total Cobalt	0	0		0	95	95.0	145	
Total Copper	0	0		0	13.936	14.5	22.2	Chem Translator of 0.96 applied
Free Cyanide	0	0		0	22	22.0	33.6	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	67.348	85.8	131	Chem Translator of 0.785 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	1,400	1,65	2,51	Chem Translator of 0.85 applied
Total Nickel	0	0		0	483.761	485	740	Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0		0	3.437	4.04	6.17	Chem Translator of 0.85 applied
Total Thallium	0	0		0	65	65.0	99.2	
Total Zinc	0	0		0	121.072	124	189	Chem Translator of 0.978 applied

CFCCCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	220	220	336	
Total Arsenic	0	0		0	150	150	229	Chem Translator of 1 applied
Total Barium	0	0		0	4,100	4,100	6,258	
Total Boron	0	0		0	1,600	1,600	2,442	
Total Cadmium	0	0		0	0.253	0.28	0.43	Chem Translator of 0.907 applied
Total Chromium (III)	0	0		0	76.492	88.9	136	Chem Translator of 0.86 applied
Hexavalent Chromium	0	0		0	10	10.4	15.9	Chem Translator of 0.962 applied
Total Cobalt	0	0		0	19	19.0	29.0	
Total Copper	0	0		0	9.256	9.64	14.7	Chem Translator of 0.96 applied
Free Cyanide	0	0		0	5.2	5.2	7.94	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	1,500	1,500	2,290	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	2,624	3,34	5.1	Chem Translator of 0.785 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	0.770	0.91	1.38	Chem Translator of 0.85 applied
Total Nickel	0	0		0	53.731	53.9	82.3	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	4,600	4.99	7.62	Chem Translator of 0.922 applied
Total Silver	0	0		0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0		0	13	13.0	19.8	
Total Zinc	0	0		0	122.062	124	189	Chem Translator of 0.986 applied

 THHCCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Fluoride (PWS)	0	0		0	2,000	2,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	5.6	5.6	8.55	
Total Arsenic	0	0		0	10	10.0	15.3	
Total Barium	0	0		0	2,400	2,400	3,663	
Total Boron	0	0		0	3,100	3,100	4,732	

Total Cadmium	0	0		0	N/A	N/A	N/A
Total Chromium (III)	0	0		0	N/A	N/A	N/A
Hexavalent Chromium	0	0		0	N/A	N/A	N/A
Total Cobalt	0	0		0	N/A	N/A	N/A
Total Copper	0	0		0	N/A	N/A	N/A
Free Cyanide	0	0		0	4	4.0	6.11
Dissolved Iron	0	0		0	300	300	458
Total Iron	0	0		0	N/A	N/A	N/A
Total Lead	0	0		0	N/A	N/A	N/A
Total Manganese	0	0		0	1,000	1,000	1,526
Total Mercury	0	0		0	0.050	0.05	0.076
Total Nickel	0	0		0	610	610	931
Total Phenols (Phenolics) (PWS)	0	0		0	5	5.0	N/A
Total Selenium	0	0		0	N/A	N/A	N/A
Total Silver	0	0		0	N/A	N/A	N/A
Total Thallium	0	0		0	0.24	0.24	0.37
Total Zinc	0	0		0	N/A	N/A	N/A

 CRL

 CCT (min):

 PMF:

 Analysis Hardness (mg/l):

 Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	N/A	N/A	N/A	
Total Arsenic	0	0		0	N/A	N/A	N/A	
Total Barium	0	0		0	N/A	N/A	N/A	
Total Boron	0	0		0	N/A	N/A	N/A	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Free Cyanide	0	0		0	N/A	N/A	N/A	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	N/A	N/A	N/A	
Total Nickel	0	0		0	N/A	N/A	N/A	
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	

Total Silver	0	0	0	N/A	N/A	N/A	
Total Thallium	0	0	0	N/A	N/A	N/A	
Total Zinc	0	0	0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Copper	0.017	0.026	14.5	22.2	22.2	µg/L	14.5	AFC	Discharge Conc ≥ 50% WQBEL (RP)
Free Cyanide	0.007	0.011	6.11	9.53	15.3	µg/L	6.11	THH	Discharge Conc ≥ 50% WQBEL (RP)
Total Iron	Report	Report	Report	Report	Report	µg/L	2,290	CFC	Discharge Conc > 10% WQBEL (no RP)
Total Manganese	Report	Report	Report	Report	Report	µg/L	1,526	THH	Discharge Conc > 10% WQBEL (no RP)

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., ≤ Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	PWS Not Applicable
Total Aluminum	N/A	N/A	Discharge Conc < TQL
Total Antimony	N/A	N/A	Discharge Conc < TQL
Total Arsenic	N/A	N/A	Discharge Conc < TQL
Total Barium	3,663	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	2,442	µg/L	Discharge Conc < TQL
Total Cadmium	0.43	µg/L	Discharge Conc < TQL
Total Chromium (III)	136	µg/L	Discharge Conc ≤ 10% WQBEL
Hexavalent Chromium	15.9	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cobalt	29.0	µg/L	Discharge Conc < TQL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	458	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	5.1	µg/L	Discharge Conc < TQL
Total Mercury	0.076	µg/L	Discharge Conc < TQL
Total Nickel	82.3	µg/L	Discharge Conc ≤ 10% WQBEL
Total Phenols (Phenolics) (PWS)		µg/L	Discharge Conc < TQL
Total Selenium	7.62	µg/L	Discharge Conc < TQL

Total Silver	4.04	µg/L	Discharge Conc < TQL
Total Thallium	0.37	µg/L	Discharge Conc < TQL
Total Zinc	124	µg/L	Discharge Conc < TQL