

Application Type Renewal  
Facility Type Municipal  
Major / Minor Major

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0025674  
APS ID 805155  
Authorization ID 1255890

**Applicant and Facility Information**

Applicant Name	<u>Franklin Township Municipal Sanitary Authority</u>	Facility Name	<u>Meadowbrook Rd STP</u>
Applicant Address	<u>3001 Meadowbrook Road</u> <u>Murrysville, PA 15668-1627</u>	Facility Address	<u>3001 Meadowbrook Road</u> <u>Murrysville, PA 15668-1753</u>
Applicant Contact	<u>Nicholas Kerr</u>	Facility Contact	<u>Bob Swarmer</u>
Applicant Phone	<u>(724) 327-1950</u>	Facility Phone	<u>(724) 327-1950</u>
Client ID	<u>5646</u>	Site ID	<u>243535</u>
Ch 94 Load Status	<u>Projected Hydraulic Overload</u>	Municipality	<u>Murrysville Borough</u>
Connection Status	<u>Dept. Imposed Connection Prohibitions</u>	County	<u>Westmoreland</u>
Date Application Received	<u>December 19, 2018</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>December 20, 2018</u>	If No, Reason	<u>Major Facility</u>
Purpose of Application	<u>Application for renewal of an existing NPDES Permit for the discharge of treated sewage effluent with combined sewer overflows (CSOs).</u>		

**Summary of Review**


The permittee has applied for a renewal of NPDES Permit No. PA0025674. PA0025674 was previously issued by the PA Department of Environmental Protection (DEP) on April 23, 2014. It was amended on May 28, 2015 to resolve an appeal. The permit expired on April 30, 2019.

Sewage from this facility is treated by grit removal, primary clarification, trickling filter, nitrification towers, sand filtration, and Ultraviolet (UV) disinfection before discharging to Turtle Creek (ID 37204) which is classified as a Trout Stock Fishery (TSF) in State Watershed No. 19-A.

Meadowbrook STP treats biosolids using thickening, heat treatment, anaerobic digestion, and belt press dewatering. Biosolids are then land applied under permit No. PAG076103. WQM Permit No. 6586418 was issued on January 8, 2024 which approved conversion of the anaerobic digestors to aerobic digesters. After construction is completed, Franklin Township Municipal Sanitary Authority (FTMSA) must terminate their biosolids permit and dispose of solids generated onsite in a landfill.

The following changes are being made this permit term:

- Interim monitoring and final effluent limits have been added for total copper, free cyanide, total zinc, bis(2-Ethylhexyl)Phthalate, chloroform, and dichlorobromomethane as a result of new water quality-based modeling.
- Monitoring has been added for dissolved iron as a result of new water quality-based modeling.
- The monitoring frequency for total iron and total manganese has been changed from 1/quarter to 1/week based on new water quality-based modeling.
- A total phosphorus limit has been added following a three-year compliance period in accordance with 25 PA Code 96.5.

Approve	Deny	Signatures	Date
X		 Stephanie Conrad / Project Manager	January 14, 2026
X		 Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineering Manager	January 30, 2026

### Summary of Review

- The monitoring frequency for total phosphorus and total nitrogen was changed from 1/quarter to 2/week because of in-stream impairment in accordance with the SOPs and Table 6.3 of the Department's Permit Writer's Guidance document.
- Monitoring has been added for total strontium, total uranium, p-cresol, gross alpha, total beta, and total radium in accordance with 25 PA Code 92a.61.
- The monitoring frequency total dissolved solids has been changed from 1/month to 2/week to be consistent with Table 6.3 of the Department's Permit Writer's Guidance document.
- Monthly *E. coli* monitoring has been added in accordance with the SOPs.
- Quarterly PFAS monitoring has been added in accordance with the SOPs.
- CSO related requirements have been added to Parts A, B, and C of the permit.

FTMSA is currently enrolled in and will continue to use eDMR.

The applicant has complied with Act 14 Notifications with letters dated October 23, 2018 and sent to Murrysville Borough and Westmoreland County Commissioners.

FTMSA has seven customer municipalities with one of them, Export Borough, has a combined sewer system permitted under NPDES Permit No. PAG066130. Because Export Borough is a combined sewer system, they need to have a Long Term Control Plan (LTCP) and a Nine Minimum Control (NMC) Plan. Their LTCP was approved on October 1, 2018. They have completed construction and submitted a Post Construction Compliance Monitoring Plan (PCCMP) which is currently under review. While Export owns and operates the sewer system, the five regulators are owned by FTMSA. There are responsibilities within the nine minimum controls that would therefore fall on FTMSA and not Export. For this reason, the Department has added Part C.III. to the permit, requiring FTMSA to create and submit to the Department for approval nine minimum controls plan this permit term. Export has agreed to complete the work necessary to comply with the Long Term Control Plan, therefore Part C language regarding the LTCP will not be included in Part C of the permit.

The permit language in Part A, B, and C have been updated to reflect that the sewer is a combined sewer system. Because FTMSA owns and operates the CSO regulators, the CSO outfalls have been added to this permit and overflow reporting will be their responsibility.

On August 29, 2019, FTMSA, Export Borough, Delmont Borough, Salem Township, Penn Township Sewer Authority, Monroeville Municipal Authority, Municipal Authority of Murrysville, Penn Township, and the Municipality of Monroeville entered into a Consent Order and Agreement (COA) with the Department to resolve sewage related violations to the Clean Streams Law. The sewer system is hydraulically overloaded and the COA requires FTMSA and its customer municipalities to remedy the overload. Among other things, FTMSA was required to complete flow monitoring, develop a hydraulic model, develop and implement an SSO Elimination plan, and repair all Grade 4 and 5 defects. The COA was amended on January 16, 2025 to extend the deadlines.

#### Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

#### Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

**Summary of Review**

Previous limits can be used pursuant to EPA's anti-backsliding regulation 40 CFR 122.44 *(I) Reissued permits. (1) Except as provided in paragraph (I)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.*

No limits have been relaxed in this renewed Draft Permit.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>4.9</u>
Latitude	<u>40° 24' 41.30"</u>	Longitude	<u>-79° 43' 29.82"</u>
Quad Name	_____	Quad Code	_____
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Turtle Creek (TSF)</u>	Stream Code	<u>37204</u>
NHD Com ID	<u>99407378</u>	RMI	<u>11.01</u>
Drainage Area	<u>41.7</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.0189</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.792</u>	Q <sub>7-10</sub> Basis	<u>USGS Stream Stats</u>
Elevation (ft)	<u>826</u>	Slope (ft/ft)	_____
Watershed No.	<u>19-A</u>	Chapter 93 Class.	<u>TSF</u>
Existing Use	_____	Existing Use Qualifier	_____
Exceptions to Use	_____	Exceptions to Criteria	_____
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>NUTRIENTS, SILTATION</u>		
Source(s) of Impairment	<u>URBAN RUNOFF/STORM SEWERS, URBAN RUNOFF/STORM SEWERS</u>		
TMDL Status	<u>Final</u>	Name	<u>Turtle Creek Watershed</u>
Background/Ambient Data		Data Source	
pH (SU)	_____	_____	
Temperature (°F)	_____	_____	
Hardness (mg/L)	_____	_____	
Other:	_____	_____	
Nearest Downstream Public Water Supply Intake	<u>PA American Water- Pittsburgh</u>		
PWS Waters	<u>Monongahela River</u>	Flow at Intake (MGD)	<u>0.69</u>
PWS RMI	<u>4.64</u>	Distance from Outfall (mi)	<u>18.01</u>

Changes Since Last Permit Issuance: None

Comments: None

<b>Treatment Facility Summary</b>		
<b>Treatment Facility Name:</b> Meadowbrook Rd STP		
<b>WQM Permit No.</b>	<b>Issuance Date</b>	<b>Purpose</b>
6586418 A-7	January 26, 2024	Permit issued by PADEP to FTMSA approving converting the existing anaerobic sludge digesters to aerobic digesters. The existing tanks were converted by installing three (3) 1600 cfm blowers, fine bubble non-clog diffusers, and an EnviroMix BioCycle D process controls system. The digester lids will also be removed.
6586418 A-6	December 16, 2021	Permit issued by PADEP to FTMSA approving replacement of the UV disinfection system.
6586418 A-5	July 13, 2021	Permit issued by PADEP to FTMSA approving modification to the influent pump station including: <ul style="list-style-type: none"> <li>• Replacement of two (2) variable speed dry pit submersible pumps. <ul style="list-style-type: none"> <li>• Installation of two (2) new sewage grinders. <ul style="list-style-type: none"> <li>• Replacement of piping.</li> </ul> </li> <li>• Replacement of the pump hoist and lifting.</li> <li>• Replacement of the sump pump control panel.</li> </ul> </li> <li>• Replacement of the chlorine room sensor and alarms. <ul style="list-style-type: none"> <li>• Heating and ventilation upgrades.</li> <li>• Accessway improvements.</li> </ul> </li> </ul>
6586418 A-4	June 25, 2018	Permit issued by PADEP to FTMSA approving treatment plant modifications including replacement of: <ul style="list-style-type: none"> <li>• Two (2) existing sludge belt presses with one (1) 2.2 m belt press.</li> <li>• The existing chlorine solution sand washing system.</li> <li>• Three (3) existing sludge pumps with tow (2) variable speed sludge pumps.</li> </ul>
N/A	August 6, 2008	Plant re-rated from 4.2 MGD to 4.9 MGD during NPDES Permit Renewal.
6586418 A-5	December 9, 2005	Permit issued to FTMSA by DEP amending the Organic Capacity to 10,000 lbs/day.
6586418 A-4	September 21, 2000	Permit Issued by DEP to FTMSA approving upgrades to the biosolids treatment system including: <ul style="list-style-type: none"> <li>• A sludge screening building.</li> <li>• Three (3) Stainless Steel tanks</li> <li>• One (1) 750,000-gallon egg-shaped digester</li> <li>• Three (3) 1,525 sqft covered drying pads</li> </ul> <p>The permit also approved chlorination and dechlorination for the existing sand filter, a new diesel generator, and odor control for the exhaust air from the sludge processing building.</p>
6586418 A-3	August 14, 1991	Permit issued by the Department of Environmental Resources to FTMSA approving a design change from chlorination to UV disinfection. The permit approved installation of 56 UV modules with 8 lamps/module.
658418-A2	September 25, 1990	Permit issued by the Department of Environmental Resources to FTMSA approving unspecified plant upgrades.
6586418 A-1	June 21, 1990	Permit issued by the Department of Environmental Resources to FTMSA approving installation of two (2) biological nitrification towers and two (2) automatic backwash filters
6586418	June 30, 1987	Permit issued to FTMSA by the Department of Environmental Resources approving expansion of the plant to 4.2 MGD including installation of: <ul style="list-style-type: none"> <li>• One (1) 34 ft grit chamber</li> </ul>

		<ul style="list-style-type: none"> <li>• Two (2) 2" manually cleaned bar screens</li> <li>• Two (2) 92,200-gallon primary settling tanks</li> <li>• Two (2) 151,100-gallon final settling tanks</li> <li>• One (1) proposed 9156 sqft tricking filter             <ul style="list-style-type: none"> <li>• Two (2) final clarifiers</li> </ul> </li> <li>• Two (2) 29,000-gallon chlorine contact tanks</li> <li>• Two (2) 53,000-gallon multi-stage sludge digesters             <ul style="list-style-type: none"> <li>• One (1) 706 sq ft gravity thickener                 <ul style="list-style-type: none"> <li>• Two (2) Belt Filters</li> </ul> </li> </ul> </li> </ul>
9405-S	March 24, 1975	Permit cancelled by transfer to FTMSA
468S017	June 19, 1968	<p>Permit issued to FTMSA by the Department of Health approving sewer extensions, the Sloan School Pump Station, Main Sewage Pump Station, and a new 1.8 MGD STP:</p> <ul style="list-style-type: none"> <li>• One (1) 18'x18'x11' equalization tank with hopper bottom</li> <li>• One (1) manually cleaned, 2 5/8" wrought iron bar screen</li> <li>• One (1) manually cleaned, 1 3/16" wrought iron bypass bar screen             <ul style="list-style-type: none"> <li>• One (1) Chicago pump "barminutor" C-12 1.7 MGD Comminutor</li> </ul> </li> <li>• Two (2) 83,4000 gallon primary settling tanks with scum removal and sludge pump</li> <li>• Three (2) 45 gpm primary sludge plunger type ball valve pumps to thickener or vaccume filter</li> <li>• One (1) 9,156 sq ft high rate trickling filter with graded hard limestone</li> <li>• Two (2) final settling tanks 179,000 gallon secondary settling tanks with scum removal and sludge pump</li> <li>• One (1) 130 gpm secondary sludge pump with recycling back to the equalization tank</li> <li>• One (1) 600 gpm secondary sludge pump with recycling back to the equalization tank             <ul style="list-style-type: none"> <li>• Four (4) non-clog 625 gpm secondary liquid recirculation pumps to high rate filters</li> </ul> </li> <li>• Two (2) 10 ' diameter 10' long 30 micron 4.5 stainless steel revolving strainers</li> <li>• Two (2) 300 lbs/day liquid chlorine feeders for pre and post chlorination             <ul style="list-style-type: none"> <li>• One (1) 50,900 gallon chlorine contact tank</li> </ul> </li> <li>• Two (2) stainless steel vacuum filter sludge dewatering units             <ul style="list-style-type: none"> <li>• One (1) 45 gpm thickened sludge plunger type ball valve pumps conveying to vacuum filter</li> </ul> </li> <li>• Ferric Chloride and lime sludge stabilization with appropriate chemical storage area             <ul style="list-style-type: none"> <li>• Belt sludge conveyer</li> </ul> </li> </ul>
9405-S	July 8, 1959	<p>Permit issued by the Department of Health to Franklin Township approving installation of</p> <ul style="list-style-type: none"> <li>• Two (2) trickling filters</li> <li>• Two (2) 1.5" manually cleaned bar screens             <ul style="list-style-type: none"> <li>• Two (2) 1650-gallon primary clarifier                 <ul style="list-style-type: none"> <li>• Two (2) first stage trickling filters</li> <li>• Two (2) second stage tricking filters</li> </ul> </li> </ul> </li> <li>• Two (2) 1650-gallon secondary settling tank             <ul style="list-style-type: none"> <li>• Two (2) 904 cf sludge digesters</li> </ul> </li> <li>• Two (2) 500-gallon chlorine contact tanks             <ul style="list-style-type: none"> <li>• Gas Chlorination</li> </ul> </li> </ul>

<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary With Ammonia Reduction	Trickling Filter With Settling	Ultraviolet	4.9
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
4.9	10,000	Projected Hydraulic Overload	Aerobic Digestion	Land Application

Changes Since Last Permit Issuance:

Other Comments:

**Compliance History**

**Operations Compliance Check Summary Report**

**Facility:** Meadowbrook Road STP

**NPDES Permit No.:** PA0025984

**Compliance Review Period:** 9/23/2020-9/23/2025

**Inspection Summary:**

INSPECTED DATE	INSP TYPE	AGENCY	INSPECTION RESULT DESC	# OF VIOLATIONS
12/04/2024	Combined Sewer Overflow-Non-Sampling	County Health Dept	No Violations Noted	0
07/25/2024	Biosolids Land Appl Site Compl Eval Insp	PA Dept of Environmental Protection	No Violations Noted	0
07/22/2021	Compliance Evaluation	County Health Dept	No Violations Noted	0
07/24/2025	Chapter 94 Inspection	PA Dept of Environmental Protection	Pending	0
08/12/2021	Biosolids Land Appl Site Admin/File Rev	PA Dept of Environmental Protection	No Violations Noted	0
01/29/2021	Administrative/File Review	PA Dept of Environmental Protection	Violation(s) Noted	1
09/15/2022	Biosolids Processor Compliance Eval Insp	County Health Dept	No Violations Noted	0

INSPECTED DATE	INSP TYPE	AGENCY	INSPECTION RESULT DESC	# OF VIOLATIONS
07/25/2024	Combined Sewer Overflow-Non-Sampling	PA Dept of Environmental Protection	No Violations Noted	0
07/25/2024	Biosolids Processor Compliance Eval Insp	PA Dept of Environmental Protection	No Violations Noted	0
09/17/2024	Compliance Evaluation	County Health Dept	No Violations Noted	0
09/21/2022	Compliance Evaluation	County Health Dept	Violation(s) Noted	2
07/25/2024	Compliance Evaluation	County Health Dept	Violation(s) Noted	1
09/02/2021	Combined Sewer Overflow-Non-Sampling	PA Dept of Environmental Protection	No Violations Noted	0
08/31/2023	Compliance Evaluation	County Health Dept	Violation(s) Noted	2
08/12/2021	Biosolids Land Appl Site Admin/File Rev	PA Dept of Environmental Protection	No Violations Noted	0

**Violation Summary:**

VOL ID	VIO DATE	VIO TYPE	VIO TYPE DESC	VOL CODE ID	VOL PROGRAM	RESOLVED DATE	NSP ID	NSP CATEGORY	INSPECTED DATE	NSP TYPE	INSPECTOR	VIO COMMENT
906315	01/29/2021	92A.47(C)	NPDES - illegal discharge to waters of the Commonwealth from a sanitary sewer overflow (SSO)	17295	WPCNP	07/13/2022	3140678	PF	01/29/2021	Administrative/ File Review	KOHUT, JEFFREY	
969550	09/21/2022	92A.44	NPDES - Violation of effluent limits in Part A of permit	17291	WPCNP	09/29/2022	3426262	PF	09/21/2022	Compliance Evaluation	WATKINS, EDWIN	fecal coliform exceedance 3/2
969551	09/21/2022	92A.61(C)	NPDES - Failure to monitor pollutants as required by the NPDES permit	17299	WPCNP	09/29/2022	3426262	PF	09/21/2022	Compliance Evaluation	WATKINS, EDWIN	missed field analysis
8157470	08/31/2023	92A.44	NPDES - Violation of effluent limits in Part A of permit	17291	WPCNP	01/26/2024	3609239	PF	08/31/2023	Compliance Evaluation	WATKINS, EDWIN	Fecal coliform violations
8158046	08/31/2023	CSL201	CSL - Unauthorized, unpermitted discharge of sewage to waters of the Commonwealth	17320	WPCWP	01/26/2024	3609239	PF	08/31/2023	Compliance Evaluation	WATKINS, EDWIN	SSOs & dry weather overflows
8196328	07/25/2024	CSL201	CSL - Unauthorized, unpermitted discharge of sewage to waters of the Commonwealth	17320	WPCWP	09/09/2024	3805576	PF	07/25/2024	Compliance Evaluation	WATKINS, EDWIN	

**Open Violations by Client ID:**

No open violations for Client ID 123978

**Enforcement Summary:**

ENF TYPE DESC	ENF CREATION DATE	EXECUTED DATE	INITIATED DATE	VOL CODE ID	VOL PROGRAM NAME	VIO LATIONS	# OF VIOLATIONS	PENALTY AMOUNT	AMOUNT RECEIVED	TOTAL AMOUNT DUE	ENF FINAL STATUS	ENF CLOSED DATE
Notice of Violation	10/22/2020	10/07/2020		17291	WPCNP	92A.44	1				Administrative Close Out	07/07/2023
Notice of Violation	09/11/2023	09/11/2023		17291	WPCNP	92A.44	1				Administrative Close Out	09/11/2024
Notice of Violation	09/02/2024	09/02/2024		17320	WPCWP	CSL201	1				Administrative Close Out	09/13/2024

**Effluent Violation Summary:**

2/4/2022	3/15/2022	1	Non-Compliance Incident	N		3/14/2022	Violation of permit schedule	Other Violations				
2/4/2022	3/15/2022	1	Non-Compliance Incident	N		3/14/2022	Violation of permit schedule	Other Violations				
2/4/2022	3/15/2022	1	Non-Compliance Incident	N		3/14/2022	Violation of permit schedule	Other Violations				
10/31/2024	1/27/2025	2	Monthly	N		12/6/2024	Late DMR Submission	Other Violations				
3/31/2022	4/22/2022	1	Monthly	N	001 Final Effluent	4/21/2022	Violation of permit condition	Effluent	Fecal Coliform > 129 >	2000	No./100 ml	Average Monthly
2/28/2023	3/23/2023	1	Monthly	N	001 Final Effluent	3/17/2023	Violation of permit condition	Effluent	Fecal Coliform > 60 >	2000	No./100 ml	Average Monthly
4/30/2023	5/25/2023	1	Monthly	N	001 Final Effluent	5/25/2023	Violation of permit condition	Effluent	Fecal Coliform 435 >	400	No./100 ml	Instantaneous Maximum
12/31/2024	1/27/2025	1	Monthly	N	001 Final Effluent	1/27/2025	Violation of permit condition	Effluent	Dissolved Oxygen 4.9 <	5.0	mg/L	Instantaneous Minimum

**Unauthorized Discharges:**

No unauthorized discharges reported in eDMR during review period

**Compliance Status:** Facility is in general compliance

**Completed by:** Howard Dunn **Completed date:** 09/23/2025

Compliance History

DMR Data for Outfall 001 (from November 1, 2024 to October 31, 2025)

Parameter	OCT-25	SEP-25	AUG-25	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24
Flow (MGD) Average Monthly	2.314	2.362	2.401	3.14	3.912	4.254	4.345	2.889	5.59	2.985	3.383	3.016
Flow (MGD) Daily Maximum	3.520	4.290	2.970	8.06	9.05	11.17	10.86	4.62	12.52	7.77	5.82	7.18
pH (S.U.) Minimum	6.1	6.3	6.5	6.8	7.0	6.5	6.5	6.7	6.8	6.7	6.3	6.1
pH (S.U.) Maximum	7.4	7.0	7.2	7.7	7.8	7.9	7.8	7.5	7.7	7.5	7.6	8.1
DO (mg/L) Minimum	7.8	7.1	6.7	7.4	7.7	9.0	6.4	9.9	10.9	10.7	10.0	8.7
TRC (mg/L) Average Monthly	0.02	0.03	0.03	0.02	0.02	0.04	0.03	0.02	0.02	0.02	0.03	0.02
TRC (mg/L) Instantaneous Maximum	0.04	0.08	0.04	0.08	0.06	0.09	0.09	0.07	0.05	0.09	0.09	0.06
CBOD <sub>5</sub> (lbs/day) Average Monthly	109	106	134	220	224	440	315	171	381	242	193	259
CBOD <sub>5</sub> (lbs/day) Weekly Average	114	130	146	326	423	636	471	297	881	342	320	540
CBOD <sub>5</sub> (mg/L) Average Monthly	5.4	5.6	6.7	8.9	7.7	10.9	12.6	7.4	9.8	10	6.8	9.5
CBOD <sub>5</sub> (mg/L) Weekly Average	6.1	6.9	7.9	13.0	11.1	13.9	21.7	9.4	20.9	14.7	10.1	14.4
BOD <sub>5</sub> (lbs/day) Raw Sewage Influent   Average Monthly	2822	3104	3242	4104	4689	4953	4659	4482	4455	4242	4557	6026
BOD <sub>5</sub> (lbs/day) Raw Sewage Influent   Weekly Average	4004	3852	4063	5073	5073	6514	6003	6003	5750	4777	6149	8677
BOD <sub>5</sub> (mg/L) Raw Sewage Influent   Average Monthly	134.5	163.3	158.9	161.7	171.6	149	180.6	196.7	114	181.9	166.5	251.8
BOD <sub>5</sub> (mg/L) Raw Sewage Influent   Weekly Average	164.0	192.0	186.5	202	187.7	192.1	243.3	243.3	187.6	195.4	245.9	355.8

**NPDES Permit Fact Sheet  
Meadowbrook Rd STP**

**NPDES Permit No. PA0025674**

TSS (lbs/day) Average Monthly	72	152	174	151	163	749	301	118	120	188	203	315
TSS (lbs/day) Raw Sewage Influent   Average Monthly	2772	2912	3483	3982	4489	4587	4594	4029	3831	3849	4948	5341
TSS (lbs/day) Raw Sewage Influent   Weekly Average	3279	4355	3882	5073	5019	5236	6572	6572	4316	3925	6023	13666
TSS (lbs/day) Weekly Average	125	203	288	361	298	1322	430	430	140	292	301	573
TSS (mg/L) Average Monthly	3.7	8.0	8.8	5.7	5.7	17.5	10.9	5.0	2.8	7.8	7.4	13.5
TSS (mg/L) Raw Sewage Influent   Average Monthly	137.7	154.0	173.1	155.7	166.9	137.9	180.7	175	101.8	166.1	186.7	236.5
TSS (mg/L) Raw Sewage Influent   Weekly Average	178.0	226.0	196.0	177.3	204.1	168	270	270	170.3	184	278.3	854.2
TSS (mg/L) Weekly Average	8.0	10.5	15.5	13.2	8.8	23.7	14.2	14.2	4.1	9.7	10.3	32.6
Total Dissolved Solids (mg/L) Daily Maximum	459	553	437	950	536	388	390	364	599	774	440	471
Fecal Coliform (CFU/100 ml) Geometric Mean	59	13	289	34	17	15	10	4	4	11	7	10
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	1203	272	1733	687	71	205	313	25	6	1553	165	60
UV Transmittance (%) Minimum	54.3	55.3	55.2	67.5	60.4	54.5	52.6	60.1	64	56.8	37.1	48.7
UV Transmittance (%) Average Monthly	61.1	60.6	64.6	77.3	72	69.2	66.9	69.0	76.3	63.8	65.9	60.9
Total Nitrogen (mg/L) Daily Maximum		17.1			14.1			32.0			23.2	
Ammonia-Nitrogen (lbs/day) Average Monthly	21	16	12	14	7	22	13	7	21	88	29	20
Ammonia-Nitrogen (lbs/day) Weekly Average	48	33	21	25	22	41	17	17	27	195	50	43

**NPDES Permit Fact Sheet  
Meadowbrook Rd STP**

**NPDES Permit No. PA0025674**

Ammonia-Nitrogen (mg/L) Average Monthly	0.9	0.9	0.6	0.5	0.3	0.5	0.5	0.3	0.5	3.9	1.1	0.7
Ammonia-Nitrogen (mg/L) Weekly Average	2.5	1.8	1.1	1.0	0.6	0.8	0.6	0.6	1.0	8.4	1.8	0.9
Total Phosphorus (mg/L) Daily Maximum		3.51			1.43			2.69			3.94	
Total Aluminum (mg/L) Daily Maximum		0.032			0.042			0.039			0.137	
Total Iron (mg/L) Daily Maximum		0.120			0.115			0.245			0.764	
Total Manganese (mg/L) Daily Maximum		0.027			0.025			0.040			0.174	
Sulfate (mg/L) Daily Maximum	59.0	66.8	59.2	56.2	47.1	52.9	43.4	50.8	54.5	59.1	46.6	59.4
Chloride (mg/L) Daily Maximum	106	97.5	106	109	101	129	117	143	209	360	108	135
Bromide (mg/L) Daily Maximum	0.243	0.245	0.339	0.196	0.106	0.140	< 0.200	< 0.500	0.172	0.188	0.172	0.384

**Compliance History**

Effluent Violations for Outfall 001, from: December 1, 2024 To: October 31, 2025

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TRC	05/31/25	Avg Mo	0.04	mg/L	.03	mg/L
CBOD <sub>5</sub>	05/31/25	Avg Mo	440	lbs/day	409	lbs/day
CBOD <sub>5</sub>	05/31/25	Wkly Avg	636	lbs/day	613	lbs/day
CBOD <sub>5</sub>	05/31/25	Avg Mo	10.9	mg/L	10	mg/L
Fecal Coliform	08/31/25	Geo Mean	289	CFU/100 ml	200	CFU/100 ml
Fecal Coliform	08/31/25	IMAX	1733	CFU/100 ml	1000	CFU/100 ml
Ammonia-Nitrogen	01/31/25	Avg Mo	3.9	mg/L	3.4	mg/L
Ammonia-Nitrogen	01/31/25	Wkly Avg	8.4	mg/L	5.1	mg/L

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>4.9</u>
<b>Latitude</b> <u>40° 24' 41.30"</u>	<b>Longitude</b> <u>-79° 43' 29.82"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations (TBELs)**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
Flow	Report	Average Monthly	-	92a.27, 92a.61
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
Total Residual Chlorine	0.5	Average Monthly	-	92a.47.(8) and 92a.48(b)(2)
Ammonia-Nitrogen	25	Average Monthly	-	BPJ
Dissolved Oxygen	4.0	Min	-	BPJ
pH	6.0 – 9.0 S.U.	Min – Max	-	95.2(1)
Total Nitrogen	Report	Average Monthly	-	92a.61
Total Phosphorus	Report	Average Monthly	-	92a.61
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)

**Water Quality-Based Limitations (WQBELs)**

Pursuant to EPA’s approval of Pennsylvania’s 2017 Triennial Review of Water Quality Standards and corresponding regulatory changes published in the *Pennsylvania Bulletin* on July 11, 2020, new water quality criteria for ammonia-nitrogen apply to waters of the commonwealth.

**WQM 7.0 Water Quality Modeling**

DEP’s WQM 7.0 version 1.1 model is a Microsoft Access Program used for sewage dischargers to determine whether TBELs are sufficient to meet in-stream water quality criteria for ammonia-nitrogen, carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), and dissolved oxygen (DO). To accomplish this, the model simultaneously simulates mixing and degradation of ammonia-nitrogen and mixing and consumption of DO through CBOD<sub>5</sub> and ammonia-nitrogen degradation. WQM 7.0 determines the highest pollutant loadings that the stream can assimilate while still meeting water quality criteria under design conditions. More information regarding the model can be found in the Department’s *Technical Reference Guide (TRG) WQM 7.0 for Windows Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen Version 1.0* [Doc. No. 391-2000-007].

The model is a two-step process. The discharge is first remodeled for the summer period (May through October) because warm temperatures are more likely to result in critical loading conditions in the receiving water. Reduced DO levels likely also play a role in ammonia-toxicity and solubility of DO decreases at increased water temperature. If summer modeling determines that WQBELs are appropriate for the summer period, then modeling is completed for the winter period (November through April). This is in accordance with DEP’s *Implementation Guidance of Section 93.7 Ammonia Criteria* [Doc. No. 391-2000-013] (Ammonia Guidance).

River Mile Index (RMI) was measured in eMAP PA as the distance between the facility's outfall to the mouth of Turtle Creek. Discharge point and downstream drainage area and as well as low flow yield at the point of discharge were generated using USGS Stream Stats. USGS Stream Stats output files are provided in Attachment A. Discharge and downstream elevations were measured in Google Earth Pro. In the absence of site-specific data, discharge temperature, stream temperature, and stream pH are assumed to be 20, 25, and 7 in accordance with the Ammonia Guidance. Stream width/depth was assumed to be 10 in accordance with DEP's *Technical Reference Guide (TRG) WQM 7.0 for Windows Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen Version 1* [Doc. No. 391-2000-007]. The effluent CBOD<sub>5</sub>, ammonia-nitrogen, and DO discharge concentrations were set equal to the previous permit limits. The DO goal was set equal to the minimum instream DO criteria defined for a TSF in 25 PA Code Section 93.7 in accordance with DEP's SOP for *Establishing Effluent Limitations for Individual Sewage Permits* [SOP No. BCW-PMT-033 revised March 24, 2021, Version 1.9].

WQM 7.0 summer inputs are documented in the table below:

Discharge Characteristics		Basin/Stream Characteristics	
Parameter	Value	Parameter	Value
River Mile Index (RMI)	11.01	Drainage Area	41.7
Discharge Flow (MGD)	4.9	Q <sub>7-10</sub> (cfs)	0.792
Discharge Temp (°C)	20	Low-flow yield (cfs/mi <sup>2</sup> )	0.0189
Ammonia-Nitrogen (mg/L)	2.0	Elevation (ft)	826
CBOD <sub>5</sub> (mg/L)	10	Stream Width/Depth	10
Dissolved Oxygen (mg/L)	6.0	Stream Temp (°C)	25
DO Goal	5.0	Stream pH (s.u.)	7

The discharge was modeled using WQM 7.0 to evaluate water quality-based limits for ammonia-nitrogen, CBOD<sub>5</sub>, and DO. Modeling confirmed that the previously imposed effluent limits are adequate to protect in-stream water quality.

The Ammonia Guidance documents that when modeling for Winter, the in-stream temperature should be 5 °C and the low flow yield is doubled. The instream dissolved concentration was also changed to 12.51 mg/L and the discharge temperature to 15 °C. Effluent concentrations for CBOD<sub>5</sub> and ammonia-nitrogen were changed to match the winter effluent limitations imposed in the previous permit.

In accordance with DEP's SOP for *Establishing Effluent Limitations for Individual Sewage Permits* [SOP No. BCW-PMT-033 revised March 24, 2021, Version 1.9], winter ammonia-nitrogen limits are assessed by comparing winter WQM 7.0 output value with one calculated by multiplying the summer limit by a multiplier of three. The more restrictive limit is then imposed. For this facility, the winter modeling result is being imposed.

Based on WQM 7.0 modeling, the following effluent limitations will be imposed:

Parameter	Limit (mg/l)	SBC	Basis
Ammonia-Nitrogen Summer (mg/L)	2.0	Average Monthly	WQBEL
Ammonia-Nitrogen Winter (mg/L)	3.4	Average Monthly	WQBEL
CBOD <sub>5</sub> Summer (mg/L)	10	Average Monthly	WQBEL
CBOD <sub>5</sub> Winter (mg/L)	20	Average Monthly	WQBEL
Dissolved Oxygen	6.0	Average Monthly	WQBEL

The Department's *Technical Guidance for the Development and Specification of Effluent Limitations* [Doc No.362-0400-001] stipulates that for sewage related pollutants average weekly and instantaneous maximum limits be calculated by multiplying the average monthly limit by a conversion factor of 1.5 and 2.0, respectively.

There are no changes to the ammonia-nitrogen, CBOD<sub>5</sub>, or DO effluent limitations as a result of WQM 7.0 modeling. WQM 7.0 output files are provided in Attachment B.

**Toxic Management Spreadsheet (TMS) Water Quality Modeling for Toxic Pollutants**

DEP’s Toxics Management Spreadsheet Version 1.3 (TMS) is a Microsoft Excel® spreadsheet that facilitates the evaluation of a single discharger and performs the calculations necessary to complete a reasonable potential analysis and determine WQBELs for dischargers of toxic unconventional pollutants.

The TMS evaluates each pollutant by computing a wasteload allocation for each applicable criterion, determining the most stringent governing WQBEL, and comparing that governing WQBEL to the input discharge concentration to determine whether permit requirements should apply. That decision is made using the following reasonable potential thresholds as documented in the Department’s SOP for *Establishing Water Quality-Based Effluent Limitations (WQBELs) and Permit Conditions for Toxic Pollutants in NPDES Permits for Existing Dischargers* [SOP No. BCW-PMT-037] (*Toxics SOP*):

- Establish limits in the permit where the maximum reported effluent concentration or calculated, average monthly effluent concentration exceeds 50% of the WQBEL. Use the average monthly, maximum daily, and instantaneous maximum (IMAX) limits for the permit as recommended by the TMS.
- For non-conservative pollutants, establish monitoring requirements where the maximum reported effluent concentration or calculated average monthly effluent concentration is between 25-50% of the WQBEL.
- For conservative pollutants, establish monitoring requirements where the maximum reported effluent concentration or calculated average monthly concentration is between 10-50% of the WQBEL.

TMS requires input data including stream code, RMI, elevation, drainage area, Q<sub>7-10</sub> stream flow, discharge hardness and pH, and stream hardness and pH. The same discharge and basin characteristic values are used as for WQM 7.0. Discharge pH and hardness input values were taken from the effluent sample results reported in the application. In the absence of site-specific data, a stream pH default of 7.0 and hardness default of 100 were used in accordance with DEP’s *DEP Toxic Management Spreadsheet (TMS) Instructions*. The application sampling data documented for Pollutant Groups 2-5 did not match the data provided in laboratory reports from the renewal sampling events. Data input into the model was pulled from the laboratory reports. Although required to sample for Pollutant Groups 6 and 7, the renewal sampling did not include these pollutants. Preliminary modeling was therefore conducted just on the results for Groups 1-5.

TMS model inputs are documented in the table below:

Discharge Characteristics		Basin/Stream Characteristics	
Parameter	Value	Parameter	Value
River Mile Index (RMI)	11.01	Drainage Area	41.7
Discharge pH	7.9	Q <sub>7-10</sub> (cfs)	0.792
Discharge Hardness	152	Stream pH	7
Design Flow (MGD)	4.9	Stream Hardness	100
		Elevation (ft)	826
		Stream Width/Depth Ratio	10

A preliminary Reasonable Potential Analysis was conducted using TMS. The model suggested WQBELs for total copper, free cyanide, total zinc, chloroform, dichlorobromomethane, bis(2-ethylhexyl)phthalate, and butyl benzyl phthalate. Monitoring was suggested for total aluminum, hexavalent chromium, dissolved iron, and total iron. A pre-draft letter was sent to FTMSA. Their September 30, 2025 response is provided in Attachment C.

FTMSA elected not to complete additional sampling for total copper, free cyanide, total zinc, chloroform, dichlorobromomethane, bis(2-ethylhexyl)phthalate, butyl benzyl phthalate, total aluminum, dissolved iron, and total iron.

Since the initial modeling was completed and pre-draft modeling was completed, Central office has clarified that because DMR reporting directs permittees to report J qualified data as < Reporting Limit in situations where the reporting limit is less than the Department’s target quantitation limit (TQL), permit writers should use the same input for TMS modeling and the determination of reasonable potential. The butyl benzyl phthalate original results had one non-detect and two J qualified detections. The laboratory Reporting limits were less than the Department’s Target QL (5.0 µg/L), therefore <2.9

µg/L was used as the model input. The updated modeling does not find reasonable potential and does not suggest monitoring.

The application data for hexavalent chromium were all non-detect, with a method detection limit (MDL) of 5.0 µg/L. The TQL is 1.0 µg/L. FTMSA re-sampled with all three results being non-detect at a MDL less than or equal to 0.1 µg/L. In accordance with the *Toxics SOP*, when sampling results are non-detect at or below the TQL, then pollutant may be eliminated as a candidate for WQBELs. No limits or monitoring will therefore be imposed for hexavalent chromium this permit cycle.

Meadowbrook Road STP has a significant categorical user in a category that requires FTMSA to sample for Pollutant Group 6. This sampling was not done with the original application package. FTMSA submitted sampling results for Pollutant Group 6 on October 22, 2025. The model was updated to include the results and assigned limits for chlordane and toxaphene.

The original sampling data for chlordane were all non-detect, with MDLs between 1.17 and 2.25 µg/L. The TQL is 1.0 µg/L. FTMSA re-sampled with all three results being non-detect at an MDL less than or equal to 0.27 µg/L. No limits or monitoring will be imposed for chlordane this permit cycle.

The original sampling data for toxaphene were all non-detect, with MDLs between 0.96 and 1.84 µg/L. The TQL is 0.5 µg/L. FTMSA re-sampled with all three results being non-detect at an MDL less than or equal to 0.19 µg/L. No limits or monitoring will be imposed for toxaphene this permit cycle.

Quarterly monitoring had been imposed for aluminum, iron, and manganese in the previous permit term. 5 years of eDMR data (October 2020 through October 2025) were reviewed for aluminum, iron, and manganese. Total aluminum results ranged from non-detect at 10 µg/L to 260 µg/L. Iron results ranged from 68.7 to 764 µg/L. Manganese results ranged from 8 to 174 µg/L. The historic monitoring data was used to help refine the TMS model.

Each pollutant had four quarterly samples taken a year and there are five years of data. That makes a cumulative data set of 20 each. In accordance with *Establishing Water Quality-Based Effluent Limitations (WQBELs) and Permit Conditions for Toxic Pollutants in NPDES Permits for Existing Dischargers* [SOP No. BCW-PMT-037], for samples sets greater than 10, ToxStats is used to determine the input. ToxStats logic is coded to calculate the 90<sup>th</sup> percentile effluent concentration when all sample results are greater than the laboratory's RL. When sample results are both above and below the RL, ToxStats calculates the median.

ToxStats calculated a median of 0.032 mg/L for total aluminum, a 90<sup>th</sup> percentile effluent concentration of 0.2606 mg/L for total iron, and a 90<sup>th</sup> percent effluent concentration of 0.1105 for total manganese. The TMS input for total aluminum is less than 10% of the governing WQBEL, therefore, there is no reasonable potential, and no monitoring will be imposed. The input for total iron and total manganese were greater than 10% percent of the governing WQBEL, therefore, monitoring will be imposed for total iron and total manganese. The ToxStats input and output files are provided in Attachment D.

TMS output files are provided in Attachment E.

Based on TMS modeling and renewal sampling data, the following effluent limitations will be imposed:

<b>Parameter</b>	<b>Limit (mg/l)</b>	<b>SBC</b>	<b>Basis</b>
Total Copper	0.014	Average Monthly	TMS Version 1.3
Free Cyanide (µg/L)	4.42	Average Monthly	TMS Version 1.3
Dissolved Iron	Report	Average Monthly	TMS Version 1.3
Total Iron	Report	Average Monthly	TMS Version 1.3
Total Manganese	Report	Average Monthly	TMS Version 1.3
Total Zinc	0.17	Average Monthly	TMS Version 1.3
Chloroform (µg/L)	6.29	Average Monthly	TMS Version 1.3
Dichlorobromomethane (µg/L)	1.71	Average Monthly	TMS Version 1.3

Bis(2-Ethylhexyl)Phthalate (µg/L)	0.57	Average Monthly	TMS Version 1.3
-----------------------------------	------	-----------------	-----------------

In response to the pre-draft letter, FTMSA completed the pre-draft survey, indicating that they are unsure of the length of time needed to comply with the new water quality-based effluent limits. In accordance with the *Toxics SOP*, compliance schedules for new toxic WQBELs are generally assigned based on the permittee’s pre-draft response. FTMSA did not provide an estimated time needed to comply. In this situation, the SOP allows the permit writer to use discretion in assigning a compliance period. Permit writers typically provide a two-year compliance period unless the permittee provides justification as to why additional time is needed. A two-year compliance period is therefore being provided for the new toxic WQBELs.

Section III.4. of the *Toxics SOP* requires permittees to conduct site specific studies when default data was used for modeling. Part C.V.B. has therefore been added to the permit. Section III.5.a. of the same SOP requires the permittee to conduct a TRE if they document in the pre-draft survey that they are unaware of the source of the pollutant. FTMSA documented in their pre-draft survey that the source of the pollutants receiving new WQBELs is unknown. Part C.V.C. has therefore been added to the permit.

**Nutrient Impairment**

The receiving stream, Turtle Creek, is impaired for Nutrients. 25 PA Code 96.5 states that “when it is determined that the discharge of phosphorus, alone in combination with the discharge of other pollutants, contributes or threatens to impair existing or designated uses... shall be limited to an average monthly concentration of 2 mg/L”. On May 20, 2021, a Cause-and-Effect Survey was completed in Turtle Creek (Attachment F). The cause-and-effect survey found the stream is severely impaired upstream and downstream of Outfall 001 with concentrations downstream of the outfall being 10x larger than upstream. Additional data collection is anticipated to be collected in winter 2025 and spring 2026.

Based on the data reported in the 2021 cause and the stream’s impairment, total phosphorus limits are being imposed. A monthly average concentration limit of 2 mg/L will be imposed.

In accordance with Table 6-3, Self-Monitoring Requirements for Sewage Discharger, from DEP’s *Technical Guidance for the Development and Specification of Effluent Limitations* [Doc. No. 362-0400-001], monitoring frequency for total phosphorus is changing from 1/quarter to 2/week.

DEP’s *Toxics SOP* documents that a permittee will be considered to be able to comply with a WQBEL without a compliance schedule if historic data demonstrates compliance with the proposed WQBEL at least 90% of the time. Based on data from the last five years, the facility is only able to meet a total phosphorus limit of 2.0 approximately 40% of the time. A three-year compliance period is therefore being provided. Interim compliance deadlines are defined in Part C.II. of the Permit. The *Toxics SOP* documents that compliance periods requested by the permittee will generally be used, where warranted. FTMSA has requested five years to comply with the new limit. The longest compliance schedule DEP can accommodate is a 59 month (4 years and 11 months). The new phosphorus limit will therefore go into effect on the first day of the month that the permit expires.

**Total Dissolved Solids (TDS), Chloride, Bromide, and Total Sulfate**

Total Dissolved Solids (TDS) and its major constituents including sulfate, chloride, and bromide have emerged as contaminants of concern throughout the Commonwealth. These solids are conservative in nature, accumulating in surface waters and in the case of drinking water treatment, bromide has been linked with formation of disinfection byproducts. In response to the growing concern, the Department promulgated PA Code 25 Chapter 95.10 on August 21, 2010 which establishes treatment requirements for new and expanding discharges. Chapter 95.10 (a)(1) documents that “discharge loads of TDS or specific conductivity that were authorized by DEP prior to August 21, 2010 are exempt from the standards”. Meadowbrook Road STP was originally permitted in 1959 under WQM Permit No.1959. The design capacity has not expanded since 2008, therefore, the facility is currently exempt from Chapter 95.10 treatment requirements which requires that new and expanding mass loadings of TDS cannot contain more than 2,000 mg/L as monthly average.

The previous permit imposed monitoring for TDS, Chloride, Bromide, and Total Sulfate using the justification that Meadowbrook Road STP discharges a load of greater than 20,000 lbs/day. The fact sheet did not provide a citation for this metric. DEP’s SOP for *Establishing Effluent Limitations for Individual Sewage Permits* [SOP No. BCW-PMT-033 Version 1.9], a minimum of monitoring should be imposed for TDS for any discharge that exceeds a TDS concentration of 1,000 mg/L. 5 years of eDMR data (October 2020 through October 2025) were reviewed for TDS, and the monthly

sample resulted in one exceedance of 1,000 mg/L. The other monthly results ranged from 250 mg/L to 950 mg/L. The August 2022 sampling result was 2,670 mg/L. Based on this result and the Toxic SOP, monthly TDS monitoring will again be imposed.

eDMR data was also reviewed for the same five-year term for chloride, bromide, and total sulfate. Chloride results ranged from non-detect at 2.0 mg/L to 501 mg/L. Bromide results ranged from non-detect at 0.1 mg/L to 5.18 mg/L. Total sulfate results ranged from non-detect at 2.0 mg/L to 99.8 mg/L.

Constituents for TDS are only defined based on human health standards at public drinking water intakes. The closest drinking water intake is 18 miles downstream, on the Monongahela River. Between Outfall 001 and the public drinking water intake, stream flow increases from 0.792 cfs to 1,130 cfs. TMS does not easily allow to model a discharge and a drinking water intake on two different streams. A copy of the TMS model was completed assuming Meadowbrook Road STP discharged at the mouth of Turtle Creek (RMI 11.67 on the Monongahela River; Attachment G). For all cases, the highest result for chloride, bromide, and total sulfate from the last five years of eDMR data was coded as the input for TMS. This augmented model did not find that there was reasonable potential for TDS or any of its pollutants, nor did it suggest monitoring. Based on the fact that even if Meadowcreek Road STP discharged at the mouth of Turtle Creek, the highest concentrations of chloride, bromide, and total sulfate in the last five years would not have reasonable potential, monitoring for these three constituents will be removed from this permit. While monitoring is not subject to the backsliding regulations in 40 CFR 122.44 (l), the five years of monitoring data would satisfy the exception in 40 CFR 122.44 (l)(2)(i)(B). This section allows for backsliding when information is available which was not available at the time of permit issuance which would have justified the application of a less stringent effluent limitation. Monitoring for TDS will remain in the permit in accordance with Department's SOP as discussed above.

**Turtle Creek TMDL**

Section 303(d) of the Clean Water Act and the U.S. Environmental Protection Agency's Water Quality Planning and Management Regulations (codified at Title 40 of the Code of Federal Regulations Part 130) require states to develop a TMDL for impaired water bodies. A TMDL establishes the amount of a pollutant that a water body can assimilate without exceeding water quality criteria for the pollutant. TMDLs also provide a scientific basis for states to establish water quality-based controls for reducing pollution from both point and non-point sources in order to restore and maintain the quality of the state's water resources (USEPA 1991a). Stream Reaches within the Turtle Creek Watershed were listed on 303 (d) list in 1996, 1998, 2002, and 2008 for metals and pH impairment related to AMD.

A final TMDL for Turtle Creek was completed on June 29, 2009 for the control of acid mine drainage pollutants: aluminum, iron, manganese, and pH. The TMDL defined existing loads and allowable loads, but did not assign Waste Load Allocations. Meadowbrook Road STP was originally permitted in 1987 and therefore pre-dates the Turtle Creek TMDL. NPDES Permit No. PA0025674 was not assigned any wasteload allocations in the TMDL, so no TMDL based effluent limits will be imposed this permit term.

Meadowbrook Road STP discharges in the reach identified as TC4. The TMDL defines existing and allowable loads for iron. Meadowbrook Road's existing long term average load was calculated using the 90<sup>th</sup> Percentile concentration calculated using ToxStats

	Existing Load	Allowable Load	Meadowbrook Road STP Existing long-term average load
Iron (lbs/day)	114.21	51.40	13.96

Weekly monitoring is already being imposed for total iron and total manganese based on water quality, so no additional monitoring is being proposed based on the TMDL. Quarterly total aluminum monitoring will again be imposed based on the TMDL and under the authority of 25 Pa. Code 92a.61.

**Pollutant Group 7**

Although not identified in the Industrial Users Information section of the application, Meadowbrook Road STP accepts hauled in leachate from Valley Landfill. Valley Landfill documented in their 2025 annual report that they accept residual wastes that arise from natural gas drilling. Meadowbrook Road STP therefore receives natural gas wastewaters through indirect discharges by accepting landfill leachate from Valley Landfill. In accordance with the National Pollutant Discharge Elimination System (NPDES) Application for Individual Permit to Discharge Sewage Effluent for Major Sewage Facilities: Instructions (3800-PM-BCW0009a), "Pollutant Group 7 must be analyzed if, during the three years prior to the submission of the application, the facility has received natural gas wastewaters, either hauled-in or through indirect discharges." Meadowbrook Road STP must complete sampling for Pollutant Group 7. The application instructions also require that applicants include pollutants that may be received by the facility and for which 25 PA Code Section 93 defines criteria. 40 CFR Part 445 defines effluent limits guidelines (ELGs) for pollutants of concern for non-hazardous waste landfills, including municipal solid waste landfills. P-cresol is included in the ELGs for landfills and has criteria defined in 25 PA Code Section 93. It therefore needs to be identified in Pollutant Group 7 and analyzed for.

Instead of extending additional pre-draft time for FTMSA to complete this sampling, DEP is imposing monitoring for gross alpha, total beta, total radium, total strontium, and total uranium. This monitoring is imposed under the authority of 25 Pa. Code § 92a.61. The Department is allowing FTMSA the opportunity to sample for these pollutants. They were informed of the opportunity on December 12, 2025 and will have until the 30-day draft comment period ends to submit sample results to DEP. FTMSA must meet all applicable target QLs, which are defined in the renewal application instructions with the exception of p-cresol, which is 20 µg/L. If TMS modeling confirms that there is no reasonable potential and/or does not suggest monitoring, then monitoring may be removed prior to Final permit issuance.

**Permit Effluent Limitations**

In accordance with Section III of DEP’s SOP for *Establishing Effluent limitations for Individual Sewage Permits*, the limits to be imposed, which are provided below, represent the most stringent limitations between the TBELs, WQBELs, BAT, and BPJs.

<b>Parameter</b>	<b>Limit (mg/l)</b>	<b>SBC</b>	<b>Basis</b>
Total Suspended Solids	30	Average Monthly	TBEL
Fecal Coliform (Recreation Season)	200 CFU/mL	Geo Mean	TBEL
Fecal Coliform (Non-Recreation Season)	2,000 CFU/mL	Geo Mean	TBEL
pH	6.0	Instantaneous Minimum	TBEL
pH	9.0	Instantaneous Maximum	TBEL
Ammonia-Nitrogen Summer (mg/L)	2.0	Average Monthly	WQM 7.0 version 1.1
Ammonia-Nitrogen Winter (mg/L)	3.4	Average Monthly	WQM 7.0 version 1.1
CBOD <sub>5</sub> Summer (mg/L)	10	Average Monthly	WQM 7.0 version 1.1
CBOD <sub>5</sub> Winter (mg/L)	20	Average Monthly	WQM 7.0 version 1.1
Dissolved Oxygen	6.0	Average Monthly	WQM 7.0 version 1.1
Total Aluminum	Report	Daily Max	25 Pa. Code 92a.61/Turtle Creek TMDL
Total Copper	0.014	Average Monthly	TMS Version 1.3
Free Cyanide (ug/L)	4.42	Average Monthly	TMS Version 1.3
Dissolved Iron	Report	Average Monthly	TMS Version 1.3
Total Iron	Report	Average Monthly	TMS Version 1.3
Total Manganese	Report	Average Monthly	TMS Version 1.3
Total Zinc	0.17	Average Monthly	TMS Version 1.3

Chloroform (ug/L)	6.29	Average Monthly	TMS Version 1.3
Dichlorobromomethane (ug/L)	1.71	Average Monthly	TMS Version 1.3
Bis(2-Ethylhexyl)Phthalate (ug/L)	0.57	Average Monthly	TMS Version 1.3
Total Phosphorus	2.0	Average Monthly	25 PA Code 96.5
Gross Alpha	Report	Average Monthly	25 Pa. Code 92a.61
Total Beta	Report	Average Monthly	25 Pa. Code 92a.61
Total Radium	Report	Average Monthly	25 Pa. Code 92a.61
Total Strontium	Report	Average Monthly	25 Pa. Code 92a.61
Total Uranium	Report	Average Monthly	25 Pa. Code 92a.61
p-cresol	Report	Average Monthly	25 Pa. Code 92a.61

**Mass Loading Limitations**

Section 1.A of the Department’s SOP, *Establishing Effluent Limitations for Individual Sewage Permits* [SOP No. BCW-PMT-033 Version 1.9] and table 5.3 of the Department’s *Technical Guidance for the Development and Specification of Effluent Limitations* [Doc. No. 362-0400-001] establish mass loading limits for Publicly Owned Treatment Works (POTWs) for ammonia-nitrogen, CBOD<sub>5</sub>, and TSS. Average monthly and average weekly limits will be imposed for ammonia-nitrogen, CBOD<sub>5</sub>, and TSS. Mass loading limits are calculated according to the following equation:

$$\text{mass loading limit } \left( \frac{\text{lbs}}{\text{day}} \right) = \text{average annual flow (MGD)} * \text{concentration limit } \left( \frac{\text{mg}}{\text{L}} \right) * 8.34 \text{ (conversion factor)}$$

The following mass loading limits are being imposed:

Parameter	Average Monthly (lbs/day)	Weekly Average (lbs/day)
Ammonia-Nitrogen Summer (mg/L)	82	123
Ammonia-Nitrogen Winter (mg/L)	139	209
CBOD <sub>5</sub> Summer (mg/L)	405	610
CBOD <sub>5</sub> Winter (mg/L)	815	1225
TSS (mg/L)	1225	1835

**Additional Considerations**

In accordance with Section I.A. of DEP’s SOP for *Establishing Effluent Limitations for Individual Sewage Permits* [SOP No. BCW-PMT-033 Version 1.9], pursuant to EPA’s approval of Pennsylvania’s 2017 Triennial Review of Water Quality Standards and corresponding regulatory changes published in the *Pennsylvania Bulletin* on July 11, 2020 and under the authority of 25 Pa. Code § 93.7(a) and § 92.a.61, sewage dischargers will include monitoring for *E. coli*. For new and reissued permits, a monitoring frequency of 1/month will be imposed for flows ≥ 1 MGD.

Monitoring frequency for the proposed effluent limits are based on Table 6-3, Self-Monitoring Requirements for Sewage Discharger, from DEP’s *Technical Guidance for the Development and Specification of Effluent Limitations* [Doc. No. 362-0400-001]. Please note that the monitoring frequency for total aluminum, total iron, total manganese, total phosphorus, and have changed to be consistent with Table 6.3.

In accordance with Section I.A. of DEP’s SOP for established for *Establishing Effluent Limitations for Individual Sewage Permits* [SOP No. BCW-PMT-033 Version 1.9], and under the authority of 25 Pa. Code § 92a.61(b), nutrient monitoring for total nitrogen and total phosphorus will be imposed for sewage facilities with a design flow greater than 2,000 GPD. The intent of this monitoring is to establish the nutrient load of the wastewater and evaluate the impact that load may have on the quality of the receiving stream. The 2014 permit imposed quarterly monitoring for total nitrogen and total phosphorus. In the last five years, 20 total phosphorus samples ranged from 0.51 mg/L to 5.3 mg/L. One result was non-

detect at a reporting limit of 10 mg/L. In the last five years, 20 total nitrogen samples ranged from 0.99 mg/L to 41.7 mg/L. The SOP documents that nutrient monitoring will be imposed at a frequency equivalent to that imposed for conventional pollutants when discharging to a stream that is impaired for nutrients. The receiving stream, Turtle Creek, is impaired for nutrients. The monitoring frequency for total nitrogen is therefore changing to 2/week. A limit is being imposed for total phosphorus during this permit term, so additional monitoring is not required.

Conventional concentration and mass loading limits are rounded in accordance with the guidelines in Chapter 5 Section C.2. of DEP's *Technical Guidance for the Development and Specification of Effluent Limitations* [Doc. No. 362-0400-001]. Please note that the average monthly and weekly average TSS and summer and winter CBOD<sub>5</sub> limits were all amended to conform with the rounding guidance.

Table 5.3 DEP's *Technical Guidance for the Development and Specification of Effluent Limitations* [DOC. No 362-0400-001] documents that for Publicly Owned Treatment Works (POTW)s, conventional pollutants should receive average monthly, weekly average, and instantaneous maximum concentration limits. 40 CFR 122.45(d)(2) stipulates that unless impractical, weekly average limits will be imposed for POTWs. These limits have been imposed for CBOD<sub>5</sub>, TSS, and Ammonia-Nitrogen.

In accordance with Section I.A. DEP's SOP for *Establishing Effluent Limitations for Individual Sewage Permits* [SOP No. BCW-PMT-033 Version 1.9], when UV disinfection is used, TRC limits are not applicable. Routine UV transmittance (%) monitoring is being imposed at the same monitoring frequency that would be used for TRC.

### **Storm Water**

Meadowbrook Road STP has three storm water outfalls onsite. The previous permit imposed requirements for storm water outfalls 002, 003, and 004. The Application documented three outfalls with the same coordinates, but with names SWA, SWB, and SWC. The outfall names will be changed for this permit term and the requirements in Part C.VIII. have been updated to reflect current stormwater permitting requirements.

### **Influent Monitoring**

Section IV.F.2 of DEP's SOP for *New and Reissuance Sewage Individual NPDES Permit Applications* [SOP No. BCW-PMT-002 Version 2.0] establishes influent BOD<sub>5</sub> and TSS monitoring for POTWs. The intent of influent BOD<sub>5</sub> and TSS monitoring is to verify compliance with the secondary treatment requirement of 85% removal defined in 40 CFR §133.102. The influent monitoring is to be imposed at the same frequency and sample type as is used for the effluent sampling. No changes have been made to the influent monitoring during this permit renewal.

### **Per-and Polyfluoroalkyl Substances (PFAS)**

In February 2024, DEP implemented a new PFAS monitoring initiative consistent with EPA's memorandum that provides guidance for addressing PFAS in treated effluent discharges permitted under the NPDES program. PFAS are a family of synthetic organic chemicals containing a chain of strong carbon-fluorine bonds. PFAS are resistant to biodegradation, photooxidation, direct photolysis, and hydrolysis. Because PFAS does not readily degrade by natural processes, it accumulates over time. According to the United States Department of Health and Human Services' Agency for Toxic Substances and Disease Registry (ATSDR), the environmental persistence and mobility of PFAS, combined with decades of widespread use, have resulted in surface water, groundwater, drinking water, rainwater, solid, sediment, ice caps, outdoor and indoor air, plants, animal tissue, and human blood serum contamination across the globe. ATSDR also reports that exposure to certain PFAS can lead to adverse human health impacts. Due to their durability, toxicity, persistence, and pervasiveness, PFAS have emerged as a potentially significant pollutant of concern for sewage treatment plants.

In accordance with DEP's SOP for *Establishing Effluent Limitations for Individual Sewage Permits* [BCQ-PMT-033] and under the authority of 25 Pa. Code § 92.a.61, DEP is imposing monitoring for a subset of common/well-studied PFAS to help understand the extent of PFAS contamination throughout the Commonwealth and the extent to which point source dischargers under the NPDES program contribute. These PFAS include Perfluorooctanoic Acid (PFOA), Perfluorooctanesulfonic Acid (PFOS), Perfluorobutanesulfonic acid (PFBS), and Hexafluoropropylene Oxide Dimer Acid (HFPO-DA).

FTMSA submitted their NPDES Permit renewal application prior to August 5, 2024 and DEP is therefore electing to waive the required sampling for PFOA, PFOS, PFBS, and HFPO-DA as part of the renewal sampling. Meadowbrook Road STP identified 49 industrial users and also accepts hauled in leachate from a municipal landfill. They accept non-sanitary wastewater from categorical users in industries that EPA has identified may be a source of PFAS. These include Valley Landfill (landfills), Energi Fenestrations Solutions (plastics molding, and forming), and Circuits LLC. (electroplating). Quarterly monitoring for PFOA, PFOS, PFBS, and HFPO-DA is therefore being added to this permit in accordance with 25 Pa. Code § 92a.61. In accordance with Section II.G.3. of DEP's SOP for *Establishing Effluent Limitations for Individual Sewage Permits* [BCQ-PMT-033], a footnote has been added to the permit stating "The permittee may discontinue monitoring for PFOA, PFOS, HFPO-DA, and PFBS if the results in four consecutive monitoring periods indicate non-detect results at or below Quantitation Limits of 4.0 ng/L for PFOA, 3.7 ng/L for PFOS, 3.5 ng/L for PFBS, and 6.4 ng/L for HFPO-DA. When monitoring is discontinued, permittees must enter a No Discharge Indicator (NODI) Code of "GG" on DMRs."

### Whole Effluent Toxicity (WET)

The previous permit required FTMSA to collect discharge samples and perform WET tests to generate chronic survival and reproduction data for the cladoceran (water flea) *Ceriodaphnia dubia* and chronic survival and growth data for the fathead minnow *Pimephales promelas*. The dilution series for the tests was: 24%, 48%, 72%, 96%, and 100%. The Target Instream Waste Concentration (TIWC) used to analyze the results was 96%.

Analysis of the four most recent WET tests, conducted October and November 2022, October and November 2023, November 2024, and November 2025, is provided in Attachment H. Meadowbrook Road STP passed all four tests. There is therefore no reasonable potential, and no WET Test based limits will be imposed in this permit. An annual WET Testing requirement will again be included in Part C.VI of the permit.

Complete mixing time is calculated as a function of discharge flow rate and receiving stream characteristics ( $Q_{7-10}$  flow, velocity, width, depth, and slope). The TMS model calculated a complete mix time of 0.021 minutes.

If the complete mix time is less than 15 minutes, then both the acute and chronic Partial Mix Factors are 1.

Acute Instream Waste Concentration ( $IWC_a$ ) is calculated as a function of discharge flow, stream flow, and  $PMF_a$  using the following equation:

$$IWC_a = \left( \frac{Q_d * 1.547}{Q_{7-10} * PMF_a} \right) + (Q_d * 1.547)$$

$IWC_a$  was calculated to be 0.9054, which is greater than 1%. Chronic tests are therefore required.

Chronic Instream Waste Concentration ( $IWC_c$ ) is calculated as a function of discharge flow, stream flow, and Chronic Partial Mix Factor according to the following equation:

$$IWC_c = \frac{Q_d * 1.547}{(Q_{7-10} * PMF_c) + (Q_d * 1.547)}$$

The Chronic Instream Waste Concentration was calculated to be 0.9054.

Target Chronic Instream Waste Concentration is calculated as a function of Chronic Instream Waste Concentration using the following equation:

$$TIWC_c = \frac{IWC_c}{1} * 100\%$$

Target Chronic Instream Waste Concentration was calculated to be 91%.

The dilution series was determined using Attachment D of the Department's SOP for *Whole Effluent Toxicity (WET)* [SOP No. BPNPSM-PMT-031]. Based on a Target Chronic Instream Waste Concentration of 91%, the dilution series imposed

in this permit will be 23%, 46%, 91%, 96%, and 100%. Please note that the TIWC and dilution series has changed from the last permit.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Two Years Following Permit Issuance through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Total Copper	0.59	0.91	XXX	0.014	0.022	0.022	1/week	24-Hr Composite
Free Cyanide (ug/L)	0.18	0.28	XXX	4.42	6.89	11	1/week	24-Hr Composite
Total Zinc	6.79	7.5	XXX	0.17	0.18	0.18	1/week	24-Hr Composite
Dichlorobromomethane (ug/L)	0.07	0.11	XXX	1.71	2.66	4.27	1/week	24-Hr Composite
Bis(2-Ethyl-hexyl)Phthalate (ug/L)	0.023	0.037	XXX	0.57	0.9	1.44	1/week	24-Hr Composite
Chloroform (ug/L)	0.26	0.4	XXX	6.29	9.82	15.7	1/week	24-Hr Composite

Compliance Sampling Location: Outfall 001

Other Comments: None

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Beginning of 60<sup>th</sup> Month Following Permit Issuance through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Phosphorus	80	XXX	XXX	2.0	XXX	4.0	2/week	Grab

Compliance Sampling Location: Outfall 001

Other Comments: None

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	6.0	XXX	XXX	XXX	1/day	Grab
CBOD <sub>5</sub> Nov 1 - Apr 30	815	1225	XXX	20	30 Wkly Avg	40	2/week	24-Hr Composite
CBOD <sub>5</sub> May 1 - Oct 31	405	610	XXX	10	15 Wkly Avg	20	2/week	24-Hr Composite
BOD <sub>5</sub> Raw Sewage Influent	Report	Report	XXX	Report	Report Wkly Avg	XXX	2/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	Report Wkly Avg	XXX	2/week	24-Hr Composite
TSS	1225	1835	XXX	30	45 Wkly Avg	60	2/week	24-Hr Composite
Total Dissolved Solids	XXX	XXX	XXX	XXX	Report	XXX	1/Week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/week	Grab
<i>E. Coli</i> (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/month	Grab
UV Transmittance (%)	XXX	XXX	Report	Report	XXX	XXX	1/day	Measured

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Total Nitrogen	XXX	XXX	XXX	Report	Report	XXX	2/week	24-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	139	209	XXX	3.4	5.1 Wkly Avg	6.8	2/week	24-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	82	123	XXX	2.0	3.0 Wkly Avg	4	2/week	24-Hr Composite
Total Aluminum	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	1/quarter	24-Hr Composite
Dissolved Iron (ug/L)	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite
Total Iron (ug/L)	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite
Total Manganese	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite
Total Strontium (ug/L)	Report	Report Daily Max	XXX	Report	Report	XXX	1/week	24-Hr Composite
Total Uranium (ug/L)	Report	Report Daily Max	XXX	Report	Report	XXX	1/week	24-Hr Composite
p-Cresol (ug/L)	Report	Report Daily Max	XXX	Report	Report	XXX	1/week	24-Hr Composite
PFOA (ng/L)	XXX	XXX	XXX	XXX	Report	XXX	1/quarter	Grab
PFOS (ng/L)	XXX	XXX	XXX	XXX	Report	XXX	1/quarter	Grab
PFBS (ng/L)	XXX	XXX	XXX	XXX	Report	XXX	1/quarter	Grab
HFPO-DA (ng/L)	XXX	XXX	XXX	XXX	Report	XXX	1/quarter	Grab
Gross Alpha (pCi/L)	XXX	XXX	XXX	Report	Report	XXX	1/week	24-Hr Composite
Total Beta (pCi/L)	XXX	XXX	XXX	Report	Report	XXX	1/week	24-Hr Composite
Ra-226/228, Total (pCi/L)	XXX	XXX	XXX	Report	Report	XXX	1/week	24-Hr Composite

Compliance Sampling Location: Outfall 001

**NPDES Permit Fact Sheet  
Meadowbrook Rd STP**

**NPDES Permit No. PA0025674**

Other Comments: None

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Two Years Following Permit Effective Date**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Total Copper	Report	Report	XXX	Report	Report	XXX	1/week	24-Hr Composite
Free Cyanide (ug/L)	Report	Report	XXX	Report	Report	XXX	1/week	Grab
Total Zinc	Report	Report	XXX	Report	Report	XXX	1/week	24-Hr Composite
Bis(2-Ethyl-hexyl)Phthalate (ug/L)	Report	Report	XXX	Report	Report	XXX	1/week	24-Hr Composite
Chloroform (ug/L)	Report	Report	XXX	Report	Report	XXX	1/week	24-Hr Composite
Dichlorobromomethane (ug/L)	Report	Report	XXX	Report	Report	XXX	1/week	24-Hr Composite

Compliance Sampling Location: Outfall 001

Other Comments: None

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Beginning of 60<sup>th</sup> Month Following Permit Issuance.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Phosphorus	Report	XXX	XXX	Report	XXX	Report	2/week	Grab

Compliance Sampling Location: Outfall 001

Other Comments: None

ATTACHMENT A  
USGS Stream Stats Output Files

Discharge Point Outfall 001  
(RMI 11.01)

## StreamStats Report

Region ID: PA  
 Workspace ID: PA20250815164607128000  
 Clicked Point (Latitude, Longitude): 40.41156, -79.72509  
 Time: 2025-08-15 12:46:33 -0400



Collapse All

### ➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	41.7	square miles
ELEV	Mean Basin Elevation	1132	feet

### ➤ Low-Flow Statistics

#### Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	41.7	square miles	2.26	1400
ELEV	Mean Basin Elevation	1132	feet	1050	2580

#### Low-Flow Statistics Flow Report [Low Flow Region 4]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR^2: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	1.88	ft <sup>3</sup> /s	43	43
30 Day 2 Year Low Flow	3.03	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	0.792	ft <sup>3</sup> /s	66	66
30 Day 10 Year Low Flow	1.27	ft <sup>3</sup> /s	54	54
90 Day 10 Year Low Flow	2.14	ft <sup>3</sup> /s	41	41

*Low-Flow Statistics Citations*

**Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.2


StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

## Down Stream of Discharge Point (RMI 7.37)

## StreamStats Report

**Region ID:** PA  
**Workspace ID:** PA20250815173707455000  
**Clicked Point (Latitude, Longitude):** 40.38948, -79.75102  
**Time:** 2025-08-15 13:37:31 -0400



Collapse All

### > Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	54	square miles
ELEV	Mean Basin Elevation	1128	feet

### > Low-Flow Statistics

#### Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	54	square miles	2.26	1400
ELEV	Mean Basin Elevation	1128	feet	1050	2580

# ATTACHMENT B

## WQM 7.0 Modeling Results

## Summer Modeling

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19A	37204	TURTLE CREEK	11.010	826.00	41.70	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.019	0.00	0.00	0.000	0.000	10.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Meadowbrook	PA0025674	0.0000	4.9000	0.0000	0.000	20.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	10.00	2.00	0.00	1.50
Dissolved Oxygen	6.00	8.24	0.00	0.00
NH3-N	2.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19A	37204	TURTLE CREEK	7.370	781.00	54.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.019	0.00	0.00	0.000	0.000	10.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
19A		37204				TURTLE CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
11.010	0.79	0.00	0.79	7.5803	0.00234	.722	40.61	56.23	0.29	0.780	20.47	7.00
<b>Q1-10 Flow</b>												
11.010	0.50	0.00	0.50	7.5803	0.00234	NA	NA	NA	0.28	0.795	20.31	7.00
<b>Q30-10 Flow</b>												
11.010	1.07	0.00	1.07	7.5803	0.00234	NA	NA	NA	0.29	0.765	20.62	7.00

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 Wasteload Allocations**

**SWP Basin**      **Stream Code**                      **Stream Name**  
19A                      37204                                      TURTLE CREEK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
11.010	Meadowbrook	16.33	4	16.33	4	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
11.010	Meadowbrook	1.81	2	1.81	2	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
11.01	Meadowbrook	10	10	2	2	6	6	0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19A	37204	TURTLE CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
11.010	4.900	20.471	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
40.610	0.722	56.226	0.285	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
9.25	1.442	1.81	0.726	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
6.211	6.419	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.780	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.078	8.24	1.71	5.80
	0.156	7.35	1.62	5.70
	0.234	6.55	1.53	5.78
	0.312	5.84	1.44	5.94
	0.390	5.21	1.37	6.15
	0.468	4.64	1.29	6.37
	0.546	4.14	1.22	6.59
	0.624	3.69	1.15	6.80
	0.702	3.29	1.09	7.00
	0.780	2.93	1.03	7.18

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
19A		37204		TURTLE CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
11.010	Meadowbrook	PA0025674	0.000	CBOD5	10		
				NH3-N	2	4	
				Dissolved Oxygen			6

## Winter Modeling

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19A	37204	TURTLE CREEK	11.010	826.00	41.70	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.038	0.00	0.00	0.000	0.000	10.0	0.00	0.00	5.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Meadowbrook	PA0025674	0.0000	4.9000	0.0000	0.000	15.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	20.00	2.00	0.00	1.50
Dissolved Oxygen	6.00	12.51	0.00	0.00
NH3-N	3.40	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19A	37204	TURTLE CREEK	7.370	781.00	54.00	0.00000	0.00	<input type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.038	0.00	0.00	0.000	0.000	10.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
19A		37204				TURTLE CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
11.010	1.58	0.00	1.58	7.5803	0.00234	.729	41.84	57.36	0.30	0.741	13.27	7.00
<b>Q1-10 Flow</b>												
11.010	1.01	0.00	1.01	7.5803	0.00234	NA	NA	NA	0.29	0.768	13.82	7.00
<b>Q30-10 Flow</b>												
11.010	2.15	0.00	2.15	7.5803	0.00234	NA	NA	NA	0.31	0.717	12.79	7.00

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 Wasteload Allocations**

**SWP Basin**      **Stream Code**                      **Stream Name**  
19A                      37204                                      TURTLE CREEK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
11.010	Meadowbrook	24.1	6.8	24.1	6.8	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
11.010	Meadowbrook	3	3.4	3	3.4	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
11.01	Meadowbrook	20	20	3.4	3.4	6	6	0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19A	37204	TURTLE CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
11.010	4.900	13.275	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
41.844	0.729	57.365	0.300	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
16.89	1.453	2.81	0.417	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.123	5.693	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.741	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.074	15.61	2.73	6.39
	0.148	14.42	2.64	6.04
	0.222	13.33	2.56	5.93
	0.296	12.31	2.49	5.97
	0.371	11.38	2.41	6.09
	0.445	10.51	2.34	6.27
	0.519	9.71	2.27	6.48
	0.593	8.97	2.20	6.70
	0.667	8.29	2.13	6.92
	0.741	7.66	2.07	7.13

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
19A		37204		TURTLE CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
11.010	Meadowbrook	PA0025674	0.000	CBOD5	20		
				NH3-N	3.4	6.8	
				Dissolved Oxygen			6

# ATTACHMENT C

September 30, 2025

Pre-draft Response



Pennsylvania  
**Department of  
Environmental Protection**

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
PRE-DRAFT PERMIT SURVEY FOR TOXIC POLLUTANTS**

Permittee Name: <u>Franklin Township Municipal Sanitary Authority</u> <u>Westmoreland County</u>	Permit No.: <u>PA0025674</u>
Pollutant(s) identified by DEP that may require WQBELs: <u>No</u>	
Is the permittee aware of the source(s) of the pollutant(s)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Suspected	
If Yes or Suspected, describe the known or suspected source(s) of pollutant(s) in the effluent.	
Has the permittee completed any studies in the past to control or treat the pollutant(s)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
If Yes, describe prior studies and results:	
Does the permittee believe it can achieve the proposed WQBELs now? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Uncertain	
If No, describe the activities, upgrades or process changes that would be necessary to achieve the WQBELs, if known.	
Estimated date by which the permittee could achieve the proposed WQBELs: _____ <input checked="" type="checkbox"/> Uncertain	
Will the permittee conduct additional sampling for the pollutant(s) to supplement the application? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Check the appropriate box(es) below to indicate site-specific data that have been collected by the permittee in the past. If any of these data have <u>not</u> been submitted to DEP, please attach to this survey.	
<input type="checkbox"/> Discharge pollutant concentration coefficient(s) of variability	Year(s) Studied:
<input type="checkbox"/> Discharge and background Total Hardness concentrations (metals)	Year(s) Studied:
<input type="checkbox"/> Background / ambient pollutant concentrations	Year(s) Studied:
<input type="checkbox"/> Chemical translator(s) (metals)	Year(s) Studied:
<input type="checkbox"/> Slope and width of receiving waters	Year(s) Studied:
<input type="checkbox"/> Velocity of receiving waters at design conditions	Year(s) Studied:
<input type="checkbox"/> Acute and/or chronic partial mix factors (mixing at design conditions)	Year(s) Studied:
<input type="checkbox"/> Volatilization rates (highly volatile organics)	Year(s) Studied:
<input type="checkbox"/> Site-specific criteria (e.g., Water Effect Ratio or related study)	Year(s) Studied:

Please submit this survey to the DEP regional office that is reviewing the permit application within 30 days of receipt.

# ATTACHMENT D

## ToxStats Files



Instructions Inputs

Facility:	Meadowbrook Road STP	No. Parameters:	3
NPDES #:	PA0025674	No. Samples:	20
Outfall #:	001		
Sample Type*	Effluent		

Parameter Name*	Total Aluminum	Total Iron	Total Manganese	
Units	mg/L	mg/L	mg/L	
Quantitation Limit	0.01			
Sample Date*	Sample Results*	Sample Results*	Sample Results*	Sample Results*
10/1/2020	0.011	0.111	0.025	
1/1/2021	ND	0.0849	0.01	
4/1/2021	0.021	0.11	0.031	
7/1/2021	0.034	0.154	0.104	
10/1/2021	0.02	0.0829	0.017	
1/1/2022	0.027	0.0788	0.008	
4/1/2022	0.065	0.171	0.044	
7/1/2022	0.03	0.109	0.052	
10/1/2022	0.026	0.101	0.021	
1/1/2023	0.023	0.0687	0.009	
4/1/2023	0.056	0.212	0.078	
7/1/2023	0.024	0.0733	0.008	
10/1/2023	0.027	0.132	0.04	
1/1/2024	0.051	0.237	0.105	
4/1/2024	0.26	0.401	0.16	
7/1/2024	0.048	0.151	0.079	
10/1/2024	0.137	0.764	0.174	
1/1/2025	0.039	0.245	0.04	
4/1/2025	0.042	0.115	0.025	
7/1/2025	0.032	0.12	0.027	



**Instructions**      **Results**

<b>Facility:</b>	Meadowbrook Road STP		
<b>NPDES #:</b>	PA0025674		
<b>Outfall #:</b>	001		
<b>Sample Type:</b>	Effluent		
Parameter	Distribution Applied	Daily CV	Concentration
Total Aluminum (mg/L)	Delta-Lognormal	0.85	0.03200
Total Iron (mg/L)	Lognormal	0.66342263	0.26060
Total Manganese (mg/L)	Lognormal	1.23960388	0.11050

# ATTACHMENT E

## TMS Output Files



## Discharge Information

Instructions Discharge Stream

Facility: Meadowbrook STP NPDES Permit No.: PA0025674 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Treated Sewage

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>h</sub>
4.9	152	7.9						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L	436								
	Chloride (PWS)	mg/L	120								
	Bromide	mg/L	0.159								
	Sulfate (PWS)	mg/L	58.9								
	Fluoride (PWS)	mg/L									
Group 2	Total Aluminum	mg/L	0.032								
	Total Antimony	µg/L	< 1								
	Total Arsenic	µg/L	0.99								
	Total Barium	µg/L	49								
	Total Beryllium	µg/L	< 0.3								
	Total Boron	µg/L	161								
	Total Cadmium	µg/L	< 0.16								
	Total Chromium (III)	µg/L	1								
	Hexavalent Chromium	µg/L	< 0.1								
	Total Cobalt	µg/L	2								
	Total Copper	mg/L	22								
	Free Cyanide	µg/L	2.8								
	Total Cyanide	µg/L	< 2.2								
	Dissolved Iron	µg/L	62								
	Total Iron	mg/L	0.2606								
	Total Lead	µg/L	0.53								
	Total Manganese	mg/L	0.1105								
	Total Mercury	µg/L	< 0.04								
	Total Nickel	µg/L	5								
	Total Phenols (Phenolics) (PWS)	µg/L	75								
Total Selenium	µg/L	< 0.66									
Total Silver	µg/L	< 0.33									
Total Thallium	µg/L	< 0.16									
Total Zinc	mg/L	40									
Total Molybdenum	µg/L	6									
Acrolein	µg/L	< 1.9									
Acrylamide	µg/L	<									
Acrylonitrile	µg/L	< 1.2									
Benzene	µg/L	< 0.23									
Bromoform	µg/L	< 0.4									

Group 3	Carbon Tetrachloride	µg/L	<	0.31																	
	Chlorobenzene	µg/L	<	0.19																	
	Chlorodibromomethane	µg/L	<	0.45																	
	Chloroethane	µg/L	<	0.33																	
	2-Chloroethyl Vinyl Ether	µg/L	<	0.38																	
	Chloroform	µg/L		4.5																	
	Dichlorobromomethane	µg/L		1.3																	
	1,1-Dichloroethane	µg/L	<	0.28																	
	1,2-Dichloroethane	µg/L	<	0.32																	
	1,1-Dichloroethylene	µg/L	<	0.29																	
	1,2-Dichloropropane	µg/L	<	0.24																	
	1,3-Dichloropropylene	µg/L	<	0.31																	
	1,4-Dioxane	µg/L	<	0.68																	
	Ethylbenzene	µg/L	<	0.34																	
	Methyl Bromide	µg/L		0.49																	
	Methyl Chloride	µg/L	<	0.31																	
	Methylene Chloride	µg/L	<	0.45																	
	1,1,2,2-Tetrachloroethane	µg/L	<	0.34																	
	Tetrachloroethylene	µg/L	<	0.35																	
	Toluene	µg/L	<	0.5																	
	1,2-trans-Dichloroethylene	µg/L	<	0.26																	
1,1,1-Trichloroethane	µg/L	<	0.22																		
1,1,2-Trichloroethane	µg/L	<	0.33																		
Trichloroethylene	µg/L	<	0.33																		
Vinyl Chloride	µg/L	<	0.3																		
Group 4	2-Chlorophenol	µg/L	<	0.33																	
	2,4-Dichlorophenol	µg/L	<	0.32																	
	2,4-Dimethylphenol	µg/L	<	0.21																	
	4,6-Dinitro- <i>o</i> -Cresol	µg/L	<	0.25																	
	2,4-Dinitrophenol	µg/L	<	2.5																	
	2-Nitrophenol	µg/L	<	0.45																	
	4-Nitrophenol	µg/L	<	1																	
	<i>p</i> -Chloro- <i>m</i> -Cresol	µg/L		0.34																	
	Pentachlorophenol	µg/L	<	1.2																	
	Phenol	µg/L	<	0.23																	
	2,4,6-Trichlorophenol	µg/L	<	0.56																	
Group 5	Acenaphthene	µg/L	<	0.15																	
	Acenaphthylene	µg/L	<	0.19																	
	Anthracene	µg/L	<	0.15																	
	Benzidine	µg/L	<	3.1																	
	Benzo(a)Anthracene	µg/L	<	0.17																	
	Benzo(a)Pyrene	µg/L	<	0.22																	
	3,4-Benzofluoranthene	µg/L	<	0.13																	
	Benzo(ghi)Perylene	µg/L	<	0.22																	
	Benzo(k)Fluoranthene	µg/L	<	0.19																	
	Bis(2-Chloroethoxy)Methane	µg/L	<	0.21																	
	Bis(2-Chloroethyl)Ether	µg/L	<	0.19																	
	Bis(2-Chloroisopropyl)Ether	µg/L	<	0.28																	
	Bis(2-Ethylhexyl)Phthalate	µg/L		16.6																	
	4-Bromophenyl Phenyl Ether	µg/L	<	0.07																	
	Butyl Benzyl Phthalate	µg/L	<	2.9																	
	2-Chloronaphthalene	µg/L	<	0.18																	
	4-Chlorophenyl Phenyl Ether	µg/L	<	0.14																	
	Chrysene	µg/L	<	0.15																	
	Dibenzo(a,h)Anthracene	µg/L	<	0.21																	
	1,2-Dichlorobenzene	µg/L	<	0.38																	
	1,3-Dichlorobenzene	µg/L	<	0.25																	
1,4-Dichlorobenzene	µg/L	<	0.27																		
3,3-Dichlorobenzidine	µg/L	<	0.48																		
Diethyl Phthalate	µg/L	<	0.18																		
Dimethyl Phthalate	µg/L	<	0.14																		
Di- <i>n</i> -Butyl Phthalate	µg/L	<	0.14																		
2,4-Dinitrotoluene	µg/L	<	0.13																		





## Stream / Surface Water Information

Meadowbrook STP, NPDES Permit No. PA0025674, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: \_\_\_\_\_

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	037204	11.01	826	41.7			Yes
End of Reach 1	037204	7.37	781	54			Yes

### Q<sub>7-10</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	11.01	0.0189			10							100	7		
End of Reach 1	7.37	0.0189			10										

### Q<sub>h</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	11.01														
End of Reach 1	7.37														



## Model Results

Meadowbrook STP, NPDES Permit No. PA0025674, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Hydrodynamics

**Q<sub>7-10</sub>**

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
11.01	0.79		0.79	7.58	0.002	0.722	7.223	10.	0.285	0.78	0.021
7.37	1.02		1.0206					10.000			

**Q<sub>h</sub>**

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
11.01	6.03		6.03	7.58	0.002	0.895	7.223	8.072	0.375	0.594	0.343
7.37	7.564		7.56								

Wasteload Allocations

AFC

CCT (min): 0.021

PMF: 1

Analysis Hardness (mg/l): 147.1

Analysis pH: 7.68

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	828	
Total Antimony	0	0		0	1,100	1,100	1,214	
Total Arsenic	0	0		0	340	340	375	Chem Translator of 1 applied
Total Barium	0	0		0	21,000	21,000	23,183	
Total Boron	0	0		0	8,100	8,100	8,942	
Total Cadmium	0	0		0	2,930	3.16	3.49	Chem Translator of 0.928 applied
Total Chromium (III)	0	0		0	781.584	2,473	2,731	Chem Translator of 0.316 applied
Hexavalent Chromium	0	0		0	16	16.3	18.0	Chem Translator of 0.982 applied
Total Cobalt	0	0		0	95	95.0	105	
Total Copper	0	0		0	19.333	20.1	22.2	Chem Translator of 0.96 applied
Free Cyanide	0	0		0	22	22.0	24.3	

Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	98.052	133	147	Chem Translator of 0.735 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	1.400	1.65	1.82	Chem Translator of 0.85 applied
Total Nickel	0	0		0	649.040	650	718	Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0		0	6.248	7.35	8.11	Chem Translator of 0.85 applied
Total Thallium	0	0		0	65	65.0	71.8	
Total Zinc	0	0		0	162.510	166	183	Chem Translator of 0.978 applied
Acrolein	0	0		0	3	3.0	3.31	
Acrylonitrile	0	0		0	650	650	718	
Benzene	0	0		0	640	640	707	
Bromoform	0	0		0	1,800	1,800	1,987	
Carbon Tetrachloride	0	0		0	2,800	2,800	3,091	
Chlorobenzene	0	0		0	1,200	1,200	1,325	
Chlorodibromomethane	0	0		0	N/A	N/A	N/A	
2-Chloroethyl Vinyl Ether	0	0		0	18,000	18,000	19,871	
Chloroform	0	0		0	1,900	1,900	2,098	
Dichlorobromomethane	0	0		0	N/A	N/A	N/A	
1,2-Dichloroethane	0	0		0	15,000	15,000	16,560	
1,1-Dichloroethylene	0	0		0	7,500	7,500	8,280	
1,2-Dichloropropane	0	0		0	11,000	11,000	12,144	
1,3-Dichloropropylene	0	0		0	310	310	342	
Ethylbenzene	0	0		0	2,900	2,900	3,202	
Methyl Bromide	0	0		0	550	550	607	
Methyl Chloride	0	0		0	28,000	28,000	30,911	
Methylene Chloride	0	0		0	12,000	12,000	13,248	
1,1,2,2-Tetrachloroethane	0	0		0	1,000	1,000	1,104	
Tetrachloroethylene	0	0		0	700	700	773	
Toluene	0	0		0	1,700	1,700	1,877	
1,2-trans-Dichloroethylene	0	0		0	6,800	6,800	7,507	
1,1,1-Trichloroethane	0	0		0	3,000	3,000	3,312	
1,1,2-Trichloroethane	0	0		0	3,400	3,400	3,754	
Trichloroethylene	0	0		0	2,300	2,300	2,539	
Vinyl Chloride	0	0		0	N/A	N/A	N/A	
2-Chlorophenol	0	0		0	560	560	618	
2,4-Dichlorophenol	0	0		0	1,700	1,700	1,877	
2,4-Dimethylphenol	0	0		0	660	660	729	
4,6-Dinitro-o-Cresol	0	0		0	80	80.0	88.3	
2,4-Dinitrophenol	0	0		0	660	660	729	
2-Nitrophenol	0	0		0	8,000	8,000	8,832	
4-Nitrophenol	0	0		0	2,300	2,300	2,539	
p-Chloro-m-Cresol	0	0		0	160	160	177	
Pentachlorophenol	0	0		0	17.303	17.3	19.1	
Phenol	0	0		0	N/A	N/A	N/A	
2,4,6-Trichlorophenol	0	0		0	460	460	508	

Acenaphthene	0	0		0	83	83.0	91.6
Anthracene	0	0		0	N/A	N/A	N/A
Benzdine	0	0		0	300	300	331
Benzo(a)Anthracene	0	0		0	0.5	0.5	0.55
Benzo(a)Pyrene	0	0		0	N/A	N/A	N/A
3,4-Benzofluoranthene	0	0		0	N/A	N/A	N/A
Benzo(k)Fluoranthene	0	0		0	N/A	N/A	N/A
Bis(2-Chloroethyl)Ether	0	0		0	30,000	30,000	33,119
Bis(2-Chloroisopropyl)Ether	0	0		0	N/A	N/A	N/A
Bis(2-Ethylhexyl)Phthalate	0	0		0	4,500	4,500	4,968
4-Bromophenyl Phenyl Ether	0	0		0	270	270	298
Butyl Benzyl Phthalate	0	0		0	140	140	155
2-Chloronaphthalene	0	0		0	N/A	N/A	N/A
Chrysene	0	0		0	N/A	N/A	N/A
Dibenzo(a,h)Anthracene	0	0		0	N/A	N/A	N/A
1,2-Dichlorobenzene	0	0		0	820	820	905
1,3-Dichlorobenzene	0	0		0	350	350	386
1,4-Dichlorobenzene	0	0		0	730	730	806
3,3-Dichlorobenzidine	0	0		0	N/A	N/A	N/A
Diethyl Phthalate	0	0		0	4,000	4,000	4,416
Dimethyl Phthalate	0	0		0	2,500	2,500	2,760
Di-n-Butyl Phthalate	0	0		0	110	110	121
2,4-Dinitrotoluene	0	0		0	1,600	1,600	1,766
2,6-Dinitrotoluene	0	0		0	990	990	1,093
1,2-Diphenylhydrazine	0	0		0	15	15.0	16.6
Fluoranthene	0	0		0	200	200	221
Fluorene	0	0		0	N/A	N/A	N/A
Hexachlorobenzene	0	0		0	N/A	N/A	N/A
Hexachlorobutadiene	0	0		0	10	10.0	11.0
Hexachlorocyclopentadiene	0	0		0	5	5.0	5.52
Hexachloroethane	0	0		0	60	60.0	66.2
Indeno(1,2,3-cd)Pyrene	0	0		0	N/A	N/A	N/A
Isophorone	0	0		0	10,000	10,000	11,040
Naphthalene	0	0		0	140	140	155
Nitrobenzene	0	0		0	4,000	4,000	4,416
n-Nitrosodimethylamine	0	0		0	17,000	17,000	18,768
n-Nitrosodi-n-Propylamine	0	0		0	N/A	N/A	N/A
n-Nitrosodiphenylamine	0	0		0	300	300	331
Phenanthrene	0	0		0	5	5.0	5.52
Pyrene	0	0		0	N/A	N/A	N/A
1,2,4-Trichlorobenzene	0	0		0	130	130	144
Aldrin	0	0		0	3	3.0	3.31
alpha-BHC	0	0		0	N/A	N/A	N/A
beta-BHC	0	0		0	N/A	N/A	N/A
gamma-BHC	0	0		0	0.95	0.95	1.05
Chlordane	0	0		0	2.4	2.4	2.65
4,4-DDT	0	0		0	1.1	1.1	1.21
4,4-DDE	0	0		0	1.1	1.1	1.21

4,4-DDD	0	0		0	1.1	1.1	1.21	
Dieldrin	0	0		0	0.24	0.24	0.26	
alpha-Endosulfan	0	0		0	0.22	0.22	0.24	
beta-Endosulfan	0	0		0	0.22	0.22	0.24	
Endosulfan Sulfate	0	0		0	N/A	N/A	N/A	
Endrin	0	0		0	0.086	0.086	0.095	
Endrin Aldehyde	0	0		0	N/A	N/A	N/A	
Heptachlor	0	0		0	0.52	0.52	0.57	
Heptachlor Epoxide	0	0		0	0.5	0.5	0.55	
Toxaphene	0	0		0	0.73	0.73	0.81	

CFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	220	220	243	
Total Arsenic	0	0		0	150	150	166	Chem Translator of 1 applied
Total Barium	0	0		0	4,100	4,100	4,526	
Total Boron	0	0		0	1,600	1,600	1,766	
Total Cadmium	0	0		0	0.322	0.36	0.4	Chem Translator of 0.893 applied
Total Chromium (III)	0	0		0	101.668	118	131	Chem Translator of 0.86 applied
Hexavalent Chromium	0	0		0	10	10.4	11.5	Chem Translator of 0.962 applied
Total Cobalt	0	0		0	19	19.0	21.0	
Total Copper	0	0		0	12.455	13.0	14.3	Chem Translator of 0.96 applied
Free Cyanide	0	0		0	5.2	5.2	5.74	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	1,500	1,500	1,656	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	3,821	5.2	5.74	Chem Translator of 0.735 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	0.770	0.91	1.0	Chem Translator of 0.85 applied
Total Nickel	0	0		0	72.088	72.3	79.8	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	4,600	4.99	5.51	Chem Translator of 0.922 applied
Total Silver	0	0		0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0		0	13	13.0	14.4	
Total Zinc	0	0		0	163.839	166	183	Chem Translator of 0.986 applied
Acrolein	0	0		0	3	3.0	3.31	
Acrylonitrile	0	0		0	130	130	144	
Benzene	0	0		0	130	130	144	
Bromoform	0	0		0	370	370	408	
Carbon Tetrachloride	0	0		0	560	560	618	
Chlorobenzene	0	0		0	240	240	265	

Chlorodibromomethane	0	0		0	N/A	N/A	N/A
2-Chloroethyl Vinyl Ether	0	0		0	3,500	3,500	3,864
Chloroform	0	0		0	390	390	431
Dichlorobromomethane	0	0		0	N/A	N/A	N/A
1,2-Dichloroethane	0	0		0	3,100	3,100	3,422
1,1-Dichloroethylene	0	0		0	1,500	1,500	1,656
1,2-Dichloropropane	0	0		0	2,200	2,200	2,429
1,3-Dichloropropylene	0	0		0	61	61.0	67.3
Ethylbenzene	0	0		0	580	580	640
Methyl Bromide	0	0		0	110	110	121
Methyl Chloride	0	0		0	5,500	5,500	6,072
Methylene Chloride	0	0		0	2,400	2,400	2,650
1,1,2,2-Tetrachloroethane	0	0		0	210	210	232
Tetrachloroethylene	0	0		0	140	140	155
Toluene	0	0		0	330	330	364
1,2-trans-Dichloroethylene	0	0		0	1,400	1,400	1,546
1,1,1-Trichloroethane	0	0		0	610	610	673
1,1,2-Trichloroethane	0	0		0	680	680	751
Trichloroethylene	0	0		0	450	450	497
Vinyl Chloride	0	0		0	N/A	N/A	N/A
2-Chlorophenol	0	0		0	110	110	121
2,4-Dichlorophenol	0	0		0	340	340	375
2,4-Dimethylphenol	0	0		0	130	130	144
4,6-Dinitro-o-Cresol	0	0		0	16	16.0	17.7
2,4-Dinitrophenol	0	0		0	130	130	144
2-Nitrophenol	0	0		0	1,600	1,600	1,766
4-Nitrophenol	0	0		0	470	470	519
p-Chloro-m-Cresol	0	0		0	500	500	552
Pentachlorophenol	0	0		0	13.275	13.3	14.7
Phenol	0	0		0	N/A	N/A	N/A
2,4,6-Trichlorophenol	0	0		0	91	91.0	100
Acenaphthene	0	0		0	17	17.0	18.8
Anthracene	0	0		0	N/A	N/A	N/A
Benidine	0	0		0	59	59.0	65.1
Benzo(a)Anthracene	0	0		0	0.1	0.1	0.11
Benzo(a)Pyrene	0	0		0	N/A	N/A	N/A
3,4-Benzofluoranthene	0	0		0	N/A	N/A	N/A
Benzo(k)Fluoranthene	0	0		0	N/A	N/A	N/A
Bis(2-Chloroethyl)Ether	0	0		0	6,000	6,000	6,624
Bis(2-Chloroisopropyl)Ether	0	0		0	N/A	N/A	N/A
Bis(2-Ethylhexyl)Phthalate	0	0		0	910	910	1,005
4-Bromophenyl Phenyl Ether	0	0		0	54	54.0	59.6
Butyl Benzyl Phthalate	0	0		0	35	35.0	38.6
2-Chloronaphthalene	0	0		0	N/A	N/A	N/A
Chrysene	0	0		0	N/A	N/A	N/A

Dibenzo(a,h)Anthracene	0	0		0	N/A	N/A	N/A
1,2-Dichlorobenzene	0	0		0	160	160	177
1,3-Dichlorobenzene	0	0		0	69	69.0	76.2
1,4-Dichlorobenzene	0	0		0	150	150	166
3,3-Dichlorobenzidine	0	0		0	N/A	N/A	N/A
Diethyl Phthalate	0	0		0	800	800	883
Dimethyl Phthalate	0	0		0	500	500	552
Di-n-Butyl Phthalate	0	0		0	21	21.0	23.2
2,4-Dinitrotoluene	0	0		0	320	320	353
2,6-Dinitrotoluene	0	0		0	200	200	221
1,2-Diphenylhydrazine	0	0		0	3	3.0	3.31
Fluoranthene	0	0		0	40	40.0	44.2
Fluorene	0	0		0	N/A	N/A	N/A
Hexachlorobenzene	0	0		0	N/A	N/A	N/A
Hexachlorobutadiene	0	0		0	2	2.0	2.21
Hexachlorocyclopentadiene	0	0		0	1	1.0	1.1
Hexachloroethane	0	0		0	12	12.0	13.2
Indeno(1,2,3-cd)Pyrene	0	0		0	N/A	N/A	N/A
Isophorone	0	0		0	2,100	2,100	2,318
Naphthalene	0	0		0	43	43.0	47.5
Nitrobenzene	0	0		0	810	810	894
n-Nitrosodimethylamine	0	0		0	3,400	3,400	3,754
n-Nitrosodi-n-Propylamine	0	0		0	N/A	N/A	N/A
n-Nitrosodiphenylamine	0	0		0	59	59.0	65.1
Phenanthrene	0	0		0	1	1.0	1.1
Pyrene	0	0		0	N/A	N/A	N/A
1,2,4-Trichlorobenzene	0	0		0	26	26.0	28.7
Aldrin	0	0		0	0.1	0.1	0.11
alpha-BHC	0	0		0	N/A	N/A	N/A
beta-BHC	0	0		0	N/A	N/A	N/A
gamma-BHC	0	0		0	N/A	N/A	N/A
Chlordane	0	0		0	0.0043	0.004	0.005
4,4-DDT	0	0		0	0.001	0.001	0.001
4,4-DDE	0	0		0	0.001	0.001	0.001
4,4-DDD	0	0		0	0.001	0.001	0.001
Dieldrin	0	0		0	0.056	0.056	0.062
alpha-Endosulfan	0	0		0	0.056	0.056	0.062
beta-Endosulfan	0	0		0	0.056	0.056	0.062
Endosulfan Sulfate	0	0		0	N/A	N/A	N/A
Endrin	0	0		0	0.036	0.036	0.04
Endrin Aldehyde	0	0		0	N/A	N/A	N/A
Heptachlor	0	0		0	0.0038	0.004	0.004
Heptachlor Epoxide	0	0		0	0.0038	0.004	0.004
Toxaphene	0	0		0	0.0002	0.0002	0.0002

NPDES Permit Fact Sheet  
Meadowbrook Rd STP

NPDES Permit No. PA0025674

THH

CCT (min): 0.021

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	5.6	5.6	6.18	
Total Arsenic	0	0		0	10	10.0	11.0	
Total Barium	0	0		0	2,400	2,400	2,650	
Total Boron	0	0		0	3,100	3,100	3,422	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Free Cyanide	0	0		0	4	4.0	4.42	
Dissolved Iron	0	0		0	300	300	331	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	1,000	1,000	1,104	
Total Mercury	0	0		0	0.050	0.05	0.055	
Total Nickel	0	0		0	610	610	673	
Total Phenols (Phenolics) (PWS)	0	0		0	5	5.0	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	
Total Silver	0	0		0	N/A	N/A	N/A	
Total Thallium	0	0		0	0.24	0.24	0.26	
Total Zinc	0	0		0	N/A	N/A	N/A	
Acrolein	0	0		0	3	3.0	3.31	
Acrylonitrile	0	0		0	N/A	N/A	N/A	
Benzene	0	0		0	N/A	N/A	N/A	
Bromoform	0	0		0	N/A	N/A	N/A	
Carbon Tetrachloride	0	0		0	N/A	N/A	N/A	
Chlorobenzene	0	0		0	100	100.0	110	
Chlorodibromomethane	0	0		0	N/A	N/A	N/A	
2-Chloroethyl Vinyl Ether	0	0		0	N/A	N/A	N/A	
Chloroform	0	0		0	5.7	5.7	6.29	
Dichlorobromomethane	0	0		0	N/A	N/A	N/A	
1,2-Dichloroethane	0	0		0	N/A	N/A	N/A	
1,1-Dichloroethylene	0	0		0	33	33.0	36.4	
1,2-Dichloropropane	0	0		0	N/A	N/A	N/A	
1,3-Dichloropropylene	0	0		0	N/A	N/A	N/A	
Ethylbenzene	0	0		0	68	68.0	75.1	
Methyl Bromide	0	0		0	100	100.0	110	

Methyl Chloride	0	0		0	N/A	N/A	N/A
Methylene Chloride	0	0		0	N/A	N/A	N/A
1,1,2,2-Tetrachloroethane	0	0		0	N/A	N/A	N/A
Tetrachloroethylene	0	0		0	N/A	N/A	N/A
Toluene	0	0		0	57	57.0	62.9
1,2-trans-Dichloroethylene	0	0		0	100	100.0	110
1,1,1-Trichloroethane	0	0		0	10,000	10,000	11,040
1,1,2-Trichloroethane	0	0		0	N/A	N/A	N/A
Trichloroethylene	0	0		0	N/A	N/A	N/A
Vinyl Chloride	0	0		0	N/A	N/A	N/A
2-Chlorophenol	0	0		0	30	30.0	33.1
2,4-Dichlorophenol	0	0		0	10	10.0	11.0
2,4-Dimethylphenol	0	0		0	100	100.0	110
4,6-Dinitro-o-Cresol	0	0		0	2	2.0	2.21
2,4-Dinitrophenol	0	0		0	10	10.0	11.0
2-Nitrophenol	0	0		0	N/A	N/A	N/A
4-Nitrophenol	0	0		0	N/A	N/A	N/A
p-Chloro-m-Cresol	0	0		0	N/A	N/A	N/A
Pentachlorophenol	0	0		0	N/A	N/A	N/A
Phenol	0	0		0	4,000	4,000	4,416
2,4,6-Trichlorophenol	0	0		0	N/A	N/A	N/A
Acenaphthene	0	0		0	70	70.0	77.3
Anthracene	0	0		0	300	300	331
Benidine	0	0		0	N/A	N/A	N/A
Benzo(a)Anthracene	0	0		0	N/A	N/A	N/A
Benzo(a)Pyrene	0	0		0	N/A	N/A	N/A
3,4-Benzofluoranthene	0	0		0	N/A	N/A	N/A
Benzo(k)Fluoranthene	0	0		0	N/A	N/A	N/A
Bis(2-Chloroethyl)Ether	0	0		0	N/A	N/A	N/A
Bis(2-Chloroisopropyl)Ether	0	0		0	200	200	221
Bis(2-Ethylhexyl)Phthalate	0	0		0	N/A	N/A	N/A
4-Bromophenyl Phenyl Ether	0	0		0	N/A	N/A	N/A
Butyl Benzyl Phthalate	0	0		0	0.1	0.1	0.11
2-Chloronaphthalene	0	0		0	800	800	883
Chrysene	0	0		0	N/A	N/A	N/A
Dibenzo(a,h)Anthracene	0	0		0	N/A	N/A	N/A
1,2-Dichlorobenzene	0	0		0	1,000	1,000	1,104
1,3-Dichlorobenzene	0	0		0	7	7.0	7.73
1,4-Dichlorobenzene	0	0		0	300	300	331
3,3-Dichlorobenzidine	0	0		0	N/A	N/A	N/A
Diethyl Phthalate	0	0		0	600	600	662
Dimethyl Phthalate	0	0		0	2,000	2,000	2,208
Di-n-Butyl Phthalate	0	0		0	20	20.0	22.1
2,4-Dinitrotoluene	0	0		0	N/A	N/A	N/A
2,6-Dinitrotoluene	0	0		0	N/A	N/A	N/A

1,2-Diphenylhydrazine	0	0		0	N/A	N/A	N/A	
Fluoranthene	0	0		0	20	20.0	22.1	
Fluorene	0	0		0	50	50.0	55.2	
Hexachlorobenzene	0	0		0	N/A	N/A	N/A	
Hexachlorobutadiene	0	0		0	N/A	N/A	N/A	
Hexachlorocyclopentadiene	0	0		0	4	4.0	4.42	
Hexachloroethane	0	0		0	N/A	N/A	N/A	
Indeno(1,2,3-cd)Pyrene	0	0		0	N/A	N/A	N/A	
Isophorone	0	0		0	34	34.0	37.5	
Naphthalene	0	0		0	N/A	N/A	N/A	
Nitrobenzene	0	0		0	10	10.0	11.0	
n-Nitrosodimethylamine	0	0		0	N/A	N/A	N/A	
n-Nitrosodi-n-Propylamine	0	0		0	N/A	N/A	N/A	
n-Nitrosodiphenylamine	0	0		0	N/A	N/A	N/A	
Phenanthrene	0	0		0	N/A	N/A	N/A	
Pyrene	0	0		0	20	20.0	22.1	
1,2,4-Trichlorobenzene	0	0		0	0.07	0.07	0.077	
Aldrin	0	0		0	N/A	N/A	N/A	
alpha-BHC	0	0		0	N/A	N/A	N/A	
beta-BHC	0	0		0	N/A	N/A	N/A	
gamma-BHC	0	0		0	4.2	4.2	4.64	
Chlordane	0	0		0	N/A	N/A	N/A	
4,4-DDT	0	0		0	N/A	N/A	N/A	
4,4-DDE	0	0		0	N/A	N/A	N/A	
4,4-DDD	0	0		0	N/A	N/A	N/A	
Dieldrin	0	0		0	N/A	N/A	N/A	
alpha-Endosulfan	0	0		0	20	20.0	22.1	
beta-Endosulfan	0	0		0	20	20.0	22.1	
Endosulfan Sulfate	0	0		0	20	20.0	22.1	
Endrin	0	0		0	0.03	0.03	0.033	
Endrin Aldehyde	0	0		0	1	1.0	1.1	
Heptachlor	0	0		0	N/A	N/A	N/A	
Heptachlor Epoxide	0	0		0	N/A	N/A	N/A	
Toxaphene	0	0		0	N/A	N/A	N/A	

**CRL**

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	N/A	N/A	N/A	
Total Arsenic	0	0		0	N/A	N/A	N/A	

Total Barium	0	0		0	N/A	N/A	N/A
Total Boron	0	0		0	N/A	N/A	N/A
Total Cadmium	0	0		0	N/A	N/A	N/A
Total Chromium (III)	0	0		0	N/A	N/A	N/A
Hexavalent Chromium	0	0		0	N/A	N/A	N/A
Total Cobalt	0	0		0	N/A	N/A	N/A
Total Copper	0	0		0	N/A	N/A	N/A
Free Cyanide	0	0		0	N/A	N/A	N/A
Dissolved Iron	0	0		0	N/A	N/A	N/A
Total Iron	0	0		0	N/A	N/A	N/A
Total Lead	0	0		0	N/A	N/A	N/A
Total Manganese	0	0		0	N/A	N/A	N/A
Total Mercury	0	0		0	N/A	N/A	N/A
Total Nickel	0	0		0	N/A	N/A	N/A
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A
Total Selenium	0	0		0	N/A	N/A	N/A
Total Silver	0	0		0	N/A	N/A	N/A
Total Thallium	0	0		0	N/A	N/A	N/A
Total Zinc	0	0		0	N/A	N/A	N/A
Acrolein	0	0		0	N/A	N/A	N/A
Acrylonitrile	0	0		0	0.06	0.06	0.11
Benzene	0	0		0	0.58	0.58	1.04
Bromoform	0	0		0	7	7.0	12.6
Carbon Tetrachloride	0	0		0	0.4	0.4	0.72
Chlorobenzene	0	0		0	N/A	N/A	N/A
Chlorodibromomethane	0	0		0	0.8	0.8	1.44
2-Chloroethyl Vinyl Ether	0	0		0	N/A	N/A	N/A
Chloroform	0	0		0	N/A	N/A	N/A
Dichlorobromomethane	0	0		0	0.95	0.95	1.71
1,2-Dichloroethane	0	0		0	9.9	9.9	17.8
1,1-Dichloroethylene	0	0		0	N/A	N/A	N/A
1,2-Dichloropropane	0	0		0	0.9	0.9	1.62
1,3-Dichloropropylene	0	0		0	0.27	0.27	0.48
Ethylbenzene	0	0		0	N/A	N/A	N/A
Methyl Bromide	0	0		0	N/A	N/A	N/A
Methyl Chloride	0	0		0	N/A	N/A	N/A
Methylene Chloride	0	0		0	20	20.0	35.9
1,1,2,2-Tetrachloroethane	0	0		0	0.2	0.2	0.36
Tetrachloroethylene	0	0		0	10	10.0	18.0
Toluene	0	0		0	N/A	N/A	N/A
1,2-trans-Dichloroethylene	0	0		0	N/A	N/A	N/A
1,1,1-Trichloroethane	0	0		0	N/A	N/A	N/A
1,1,2-Trichloroethane	0	0		0	0.55	0.55	0.99
Trichloroethylene	0	0		0	0.6	0.6	1.08
Vinyl Chloride	0	0		0	0.02	0.02	0.036

2-Chlorophenol	0	0		0	N/A	N/A	N/A
2,4-Dichlorophenol	0	0		0	N/A	N/A	N/A
2,4-Dimethylphenol	0	0		0	N/A	N/A	N/A
4,6-Dinitro-o-Cresol	0	0		0	N/A	N/A	N/A
2,4-Dinitrophenol	0	0		0	N/A	N/A	N/A
2-Nitrophenol	0	0		0	N/A	N/A	N/A
4-Nitrophenol	0	0		0	N/A	N/A	N/A
p-Chloro-m-Cresol	0	0		0	N/A	N/A	N/A
Pentachlorophenol	0	0		0	0.030	0.03	0.054
Phenol	0	0		0	N/A	N/A	N/A
2,4,6-Trichlorophenol	0	0		0	1.5	1.5	2.69
Acenaphthene	0	0		0	N/A	N/A	N/A
Anthracene	0	0		0	N/A	N/A	N/A
Benidine	0	0		0	0.0001	0.0001	0.0002
Benzo(a)Anthracene	0	0		0	0.001	0.001	0.002
Benzo(a)Pyrene	0	0		0	0.0001	0.0001	0.0002
3,4-Benzofluoranthene	0	0		0	0.001	0.001	0.002
Benzo(k)Fluoranthene	0	0		0	0.01	0.01	0.018
Bis(2-Chloroethyl)Ether	0	0		0	0.03	0.03	0.054
Bis(2-Chloroisopropyl)Ether	0	0		0	N/A	N/A	N/A
Bis(2-Ethylhexyl)Phthalate	0	0		0	0.32	0.32	0.57
4-Bromophenyl Phenyl Ether	0	0		0	N/A	N/A	N/A
Butyl Benzyl Phthalate	0	0		0	N/A	N/A	N/A
2-Chloronaphthalene	0	0		0	N/A	N/A	N/A
Chrysene	0	0		0	0.12	0.12	0.22
Dibenzo(a,h)Anthracene	0	0		0	0.0001	0.0001	0.0002
1,2-Dichlorobenzene	0	0		0	N/A	N/A	N/A
1,3-Dichlorobenzene	0	0		0	N/A	N/A	N/A
1,4-Dichlorobenzene	0	0		0	N/A	N/A	N/A
3,3-Dichlorobenzidine	0	0		0	0.05	0.05	0.09
Diethyl Phthalate	0	0		0	N/A	N/A	N/A
Dimethyl Phthalate	0	0		0	N/A	N/A	N/A
Di-n-Butyl Phthalate	0	0		0	N/A	N/A	N/A
2,4-Dinitrotoluene	0	0		0	0.05	0.05	0.09
2,6-Dinitrotoluene	0	0		0	0.05	0.05	0.09
1,2-Diphenylhydrazine	0	0		0	0.03	0.03	0.054
Fluoranthene	0	0		0	N/A	N/A	N/A
Fluorene	0	0		0	N/A	N/A	N/A
Hexachlorobenzene	0	0		0	0.00008	0.00008	0.0001
Hexachlorobutadiene	0	0		0	0.01	0.01	0.018
Hexachlorocyclopentadiene	0	0		0	N/A	N/A	N/A
Hexachloroethane	0	0		0	0.1	0.1	0.18
Indeno(1,2,3-cd)Pyrene	0	0		0	0.001	0.001	0.002
Isophorone	0	0		0	N/A	N/A	N/A
Naphthalene	0	0		0	N/A	N/A	N/A

Nitrobenzene	0	0		0	N/A	N/A	N/A	
n-Nitrosodimethylamine	0	0		0	0.0007	0.0007	0.001	
n-Nitrosodi-n-Propylamine	0	0		0	0.005	0.005	0.009	
n-Nitrosodiphenylamine	0	0		0	3.3	3.3	5.93	
Phenanthrene	0	0		0	N/A	N/A	N/A	
Pyrene	0	0		0	N/A	N/A	N/A	
1,2,4-Trichlorobenzene	0	0		0	N/A	N/A	N/A	
Aldrin	0	0		0	0.0000008	8.00E-07	0.000001	
alpha-BHC	0	0		0	0.0004	0.0004	0.0007	
beta-BHC	0	0		0	0.008	0.008	0.014	
gamma-BHC	0	0		0	N/A	N/A	N/A	
Chlordane	0	0		0	0.0003	0.0003	0.0005	
4,4-DDT	0	0		0	0.00003	0.00003	0.00005	
4,4-DDE	0	0		0	0.00002	0.00002	0.00004	
4,4-DDD	0	0		0	0.0001	0.0001	0.0002	
Dieldrin	0	0		0	0.000001	0.000001	0.000002	
alpha-Endosulfan	0	0		0	N/A	N/A	N/A	
beta-Endosulfan	0	0		0	N/A	N/A	N/A	
Endosulfan Sulfate	0	0		0	N/A	N/A	N/A	
Endrin	0	0		0	N/A	N/A	N/A	
Endrin Aldehyde	0	0		0	N/A	N/A	N/A	
Heptachlor	0	0		0	0.000006	0.000006	0.00001	
Heptachlor Epoxide	0	0		0	0.00003	0.00003	0.00005	
Toxaphene	0	0		0	0.0007	0.0007	0.001	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Copper	0.59	0.91	0.014	0.022	0.022	mg/L	0.014	CFC	Discharge Conc ≥ 50% WQBEL (RP)
Free Cyanide	0.18	0.28	4.42	6.89	11.0	µg/L	4.42	THH	Discharge Conc ≥ 50% WQBEL (RP)
Dissolved Iron	Report	Report	Report	Report	Report	µg/L	331	THH	Discharge Conc > 10% WQBEL (no RP)
Total Iron	Report	Report	Report	Report	Report	mg/L	1.66	CFC	Discharge Conc > 10% WQBEL (no RP)
Total Manganese	Report	Report	Report	Report	Report	mg/L	1.1	THH	Discharge Conc > 10% WQBEL (no RP)
Total Zinc	6.79	7.5	0.17	0.18	0.18	mg/L	0.17	AFC	Discharge Conc ≥ 50% WQBEL (RP)
Chloroform	0.26	0.4	6.29	9.82	15.7	µg/L	6.29	THH	Discharge Conc ≥ 50% WQBEL (RP)
Dichlorobromomethane	0.07	0.11	1.71	2.66	4.27	µg/L	1.71	CRL	Discharge Conc ≥ 50% WQBEL (RP)
Bis(2-Ethylhexyl)Phthalate	0.023	0.037	0.57	0.9	1.44	µg/L	0.57	CRL	Discharge Conc ≥ 50% WQBEL (RP)

**Other Pollutants without Limits or Monitoring**

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Total Aluminum	0.75	mg/L	Discharge Conc ≤ 10% WQBEL
Total Antimony	N/A	N/A	Discharge Conc < TQL
Total Arsenic	11.0	µg/L	Discharge Conc ≤ 10% WQBEL
Total Barium	2,650	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	1,766	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cadmium	0.4	µg/L	Discharge Conc < TQL
Total Chromium (III)	131	µg/L	Discharge Conc ≤ 10% WQBEL
Hexavalent Chromium	11.5	µg/L	Discharge Conc < TQL
Total Cobalt	21.0	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cyanide	N/A	N/A	No WQS
Total Lead	5.74	µg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	0.055	µg/L	Discharge Conc < TQL
Total Nickel	79.8	µg/L	Discharge Conc ≤ 10% WQBEL
Total Phenols (Phenolics) (PWS)		µg/L	PWS Not Applicable
Total Selenium	5.51	µg/L	Discharge Conc < TQL
Total Silver	7.35	µg/L	Discharge Conc < TQL
Total Thallium	0.26	µg/L	Discharge Conc < TQL
Total Molybdenum	N/A	N/A	No WQS
Acrolein	3.0	µg/L	Discharge Conc < TQL
Acrylonitrile	0.11	µg/L	Discharge Conc < TQL
Benzene	1.04	µg/L	Discharge Conc < TQL
Bromoform	12.6	µg/L	Discharge Conc < TQL
Carbon Tetrachloride	0.72	µg/L	Discharge Conc < TQL
Chlorobenzene	110	µg/L	Discharge Conc < TQL
Chlorodibromomethane	1.44	µg/L	Discharge Conc < TQL
Chloroethane	N/A	N/A	No WQS
2-Chloroethyl Vinyl Ether	3,864	µg/L	Discharge Conc < TQL
1,1-Dichloroethane	N/A	N/A	No WQS
1,2-Dichloroethane	17.8	µg/L	Discharge Conc < TQL
1,1-Dichloroethylene	36.4	µg/L	Discharge Conc < TQL
1,2-Dichloropropane	1.62	µg/L	Discharge Conc < TQL
1,3-Dichloropropylene	0.48	µg/L	Discharge Conc < TQL
1,4-Dioxane	N/A	N/A	No WQS
Ethylbenzene	75.1	µg/L	Discharge Conc < TQL

Methyl Bromide	110	µg/L	Discharge Conc ≤ 25% WQBEL
Methyl Chloride	6,072	µg/L	Discharge Conc < TQL
Methylene Chloride	35.9	µg/L	Discharge Conc < TQL
1,1,2,2-Tetrachloroethane	0.36	µg/L	Discharge Conc < TQL
Tetrachloroethylene	18.0	µg/L	Discharge Conc < TQL
Toluene	62.9	µg/L	Discharge Conc < TQL
1,2-trans-Dichloroethylene	110	µg/L	Discharge Conc < TQL
1,1,1-Trichloroethane	673	µg/L	Discharge Conc < TQL
1,1,2-Trichloroethane	0.99	µg/L	Discharge Conc < TQL
Trichloroethylene	1.08	µg/L	Discharge Conc < TQL
Vinyl Chloride	0.036	µg/L	Discharge Conc < TQL
2-Chlorophenol	33.1	µg/L	Discharge Conc < TQL
2,4-Dichlorophenol	11.0	µg/L	Discharge Conc < TQL
2,4-Dimethylphenol	110	µg/L	Discharge Conc < TQL
4,6-Dinitro-o-Cresol	2.21	µg/L	Discharge Conc < TQL
2,4-Dinitrophenol	11.0	µg/L	Discharge Conc < TQL
2-Nitrophenol	1,766	µg/L	Discharge Conc < TQL
4-Nitrophenol	519	µg/L	Discharge Conc < TQL
p-Chloro-m-Cresol	160	µg/L	Discharge Conc ≤ 25% WQBEL
Pentachlorophenol	0.054	µg/L	Discharge Conc < TQL
Phenol	4,416	µg/L	Discharge Conc < TQL
2,4,6-Trichlorophenol	2.69	µg/L	Discharge Conc < TQL
Acenaphthene	18.8	µg/L	Discharge Conc < TQL
Acenaphthylene	N/A	N/A	No WQS
Anthracene	331	µg/L	Discharge Conc < TQL
Benzidine	0.0002	µg/L	Discharge Conc < TQL
Benzo(a)Anthracene	0.002	µg/L	Discharge Conc < TQL
Benzo(a)Pyrene	0.0002	µg/L	Discharge Conc < TQL
3,4-Benzofluoranthene	0.002	µg/L	Discharge Conc < TQL
Benzo(ghi)Perylene	N/A	N/A	No WQS
Benzo(k)Fluoranthene	0.018	µg/L	Discharge Conc < TQL
Bis(2-Chloroethoxy)Methane	N/A	N/A	No WQS
Bis(2-Chloroethyl)Ether	0.054	µg/L	Discharge Conc < TQL
Bis(2-Chloroisopropyl)Ether	221	µg/L	Discharge Conc < TQL
4-Bromophenyl Phenyl Ether	59.6	µg/L	Discharge Conc < TQL
Butyl Benzyl Phthalate	0.11	µg/L	Discharge Conc < TQL
2-Chloronaphthalene	883	µg/L	Discharge Conc < TQL
4-Chlorophenyl Phenyl Ether	N/A	N/A	No WQS
Chrysene	0.22	µg/L	Discharge Conc < TQL
Dibenzo(a,h)Anthracene	0.0002	µg/L	Discharge Conc < TQL
1,2-Dichlorobenzene	177	µg/L	Discharge Conc < TQL
1,3-Dichlorobenzene	7.73	µg/L	Discharge Conc < TQL
1,4-Dichlorobenzene	166	µg/L	Discharge Conc < TQL
3,3-Dichlorobenzidine	0.09	µg/L	Discharge Conc < TQL
Diethyl Phthalate	662	µg/L	Discharge Conc < TQL

Dimethyl Phthalate	552	µg/L	Discharge Conc < TQL
Di-n-Butyl Phthalate	22.1	µg/L	Discharge Conc < TQL
2,4-Dinitrotoluene	0.09	µg/L	Discharge Conc < TQL
2,6-Dinitrotoluene	0.09	µg/L	Discharge Conc < TQL
Di-n-Octyl Phthalate	N/A	N/A	No WQS
1,2-Diphenylhydrazine	0.054	µg/L	Discharge Conc < TQL
Fluoranthene	22.1	µg/L	Discharge Conc < TQL
Fluorene	55.2	µg/L	Discharge Conc < TQL
Hexachlorobenzene	0.0001	µg/L	Discharge Conc < TQL
Hexachlorobutadiene	0.018	µg/L	Discharge Conc < TQL
Hexachlorocyclopentadiene	1.1	µg/L	Discharge Conc < TQL
Hexachloroethane	0.18	µg/L	Discharge Conc < TQL
Indeno(1,2,3-cd)Pyrene	0.002	µg/L	Discharge Conc < TQL
Isophorone	37.5	µg/L	Discharge Conc < TQL
Naphthalene	47.5	µg/L	Discharge Conc < TQL
Nitrobenzene	11.0	µg/L	Discharge Conc < TQL
n-Nitrosodimethylamine	0.001	µg/L	Discharge Conc < TQL
n-Nitrosodi-n-Propylamine	0.009	µg/L	Discharge Conc < TQL
n-Nitrosodiphenylamine	5.93	µg/L	Discharge Conc < TQL
Phenanthrene	1.1	µg/L	Discharge Conc < TQL
Pyrene	22.1	µg/L	Discharge Conc < TQL
1,2,4-Trichlorobenzene	0.077	µg/L	Discharge Conc < TQL
Aldrin	0.000001	µg/L	Discharge Conc < TQL
alpha-BHC	0.0007	µg/L	Discharge Conc < TQL
beta-BHC	0.014	µg/L	Discharge Conc < TQL
gamma-BHC	0.95	µg/L	Discharge Conc < TQL
delta BHC	N/A	N/A	No WQS
Chlordane	0.0005	µg/L	Discharge Conc < TQL
4,4-DDT	0.00005	µg/L	Discharge Conc < TQL
4,4-DDE	0.00004	µg/L	Discharge Conc < TQL
4,4-DDD	0.0002	µg/L	Discharge Conc < TQL
Dieldrin	0.000002	µg/L	Discharge Conc < TQL
alpha-Endosulfan	0.062	µg/L	Discharge Conc < TQL
beta-Endosulfan	0.062	µg/L	Discharge Conc < TQL
Endosulfan Sulfate	22.1	µg/L	Discharge Conc < TQL
Endrin	0.033	µg/L	Discharge Conc < TQL
Endrin Aldehyde	1.1	µg/L	Discharge Conc < TQL
Heptachlor	0.00001	µg/L	Discharge Conc < TQL
Heptachlor Epoxide	0.00005	µg/L	Discharge Conc < TQL
Toxaphene	0.0002	µg/L	Discharge Conc < TQL

## ATTACHMENT F

### Turtle Creek Cause and Effect Survey



**MEMO**

**TO** James Vanek  
Environmental Engineer  
Clean Water Program

**FROM** Jamie Detweiler  
Aquatic Biologist 2  
Clean Water Program

**DATE** February 9, 2022

**RE** Cause and Effect Survey  
Turtle Creek  
State Water Plan: 19A  
Hydrologic Unit Code: 05020005  
Stream Code: 37204  
Aquatic Life Use Designation: TSF  
Franklin Township Municipal Sanitary Authority,  
Meadowbrook Road Sewage Treatment Plant  
Municipality of Murrysville, Westmoreland County and Municipality of  
Monroeville, Allegheny County

**INTRODUCTION**

On May 20, 2021, at the request of James Vanek of the Clean Water Program, a cause and effect survey was conducted on Turtle Creek, in the vicinity of the Franklin Township Municipal Sanitary Authority, Meadowbrook Road Sewage Treatment Plant (Meadowbrook Road STP), located in Municipality of Murrysville, Westmoreland County (Figure 1). The previous data collection and assessment efforts indicate that this reach of Turtle Creek is currently not attaining the protected aquatic use as described in the latest 2022 Pennsylvania Integrated Water Quality Monitoring and Assessment Report.

The Meadowbrook Road STP outfall is located at approximately Latitude: 40.41149, Longitude: -79.72491. The water discharges to Turtle Creek along its left descending bank (Figure 2). According to Franklin Township Sanitary Authority's website, "The Treatment plant is an aerobic biological treatment facility with grit removal, primary clarification, trickling filters, secondary clarification, nitrification towers, shallow bed sand filtration units, ultraviolet disinfection, sludge thickening, anaerobic biological sludge stabilization, sludge dewatering, and methane gas utilization facilities. The current permitted hydraulic capacity of the facility is 4,900,000 gallons per day and is an advanced wastewater treatment facility."

According to USGS Stream Stats, at the location where the outfall is located, the drainage area is approximately 41.7 square miles (Figure 3). Land use throughout the basin is approximately 59% forested and approximately 21% urban, and approximately 13% impervious. According to the aerial, the rest of the watershed appears to be agriculture (approximately 15%), and golf course (approximately 5%). Turtle Creek is in the Ohio River, Monongahela River, Turtle Creek State Water Plan (SWP 19A) and the Lower Monongahela Hydrologic Unit

(Hydrologic Unit Code 05020005). Currently, Turtle Creek (Stream Code 37204) is listed as not attaining its designated Aquatic Life Use for Trout Stocked Fishery (TSF).

## **SAMPLING PROTOCOL**

Cause and effect surveys are designed to investigate possible relationships between point or nonpoint sources of conventional pollutants and known or suspected instream water quality problems.

On May 5, 2021, basic water quality (Table 1) and macroinvertebrates (Table 2) were examined at two locations within Turtle Creek (Figure 2). The upstream station was located approximately 240 meters upstream of where the Meadowbrook Road STP's discharge enters Turtle Creek (Figures 4 & 5). The downstream location was approximately 160 meters downstream of the outfall location (Figures 6 & 7).

Basic water quality parameters were examined using a field meter and additional water chemistry and macroinvertebrates were collected and subsampled according to the Department's Water Quality Monitoring Protocols for Streams and Rivers 2021 (Monitoring Book), which can be found by following this link: [http://files.dep.state.pa.us/Water/Drinking%20Water%20and%20Facility%20Regulation/WaterQualityPortalFiles/Technical%20Documentation/MONITORING\\_BOOK.pdf](http://files.dep.state.pa.us/Water/Drinking%20Water%20and%20Facility%20Regulation/WaterQualityPortalFiles/Technical%20Documentation/MONITORING_BOOK.pdf)

The results were analyzed according to the Department's Assessment Methodology for Rivers and Streams 2021 (Assessment Book), which can be found by following this link:

[https://files.dep.state.pa.us/Water/Drinking%20Water%20and%20Facility%20Regulation/WaterQualityPortalFiles/Methodology/2021%20Methodology/ASSESSMENT\\_BOOK\\_2021.pdf](https://files.dep.state.pa.us/Water/Drinking%20Water%20and%20Facility%20Regulation/WaterQualityPortalFiles/Methodology/2021%20Methodology/ASSESSMENT_BOOK_2021.pdf)

## **RESULTS**

### Upstream station

The upstream station was located approximately 240 meters upstream of where the STP's discharge enters Turtle Creek. At this location, the stream is forested on both sides, but with the PA Turnpike running parallel, approximately 30 -100 meters away from the right descending bank. A walking trail (which used to be a railroad bed) runs along the other side, approximately 30-100 meters from the left descending bank. The following water quality parameters were measured with a YSI: temperature was 16.8°C; pH was 8.31; dissolved oxygen was 11.75 mg/L; and specific conductance was 656 umhos/cm. The total habitat score was 151, which does not indicate impairment, and mostly consisted of optimal and sub optimal scores. The lowest scores were due to the impacts to the riparian zone and disruptive pressure. The combined scores of condition of banks and bank vegetation protection (26) are above attainment thresholds (24), but the combined scores of embeddedness and sediment deposition (22) indicate nonattainment caused by siltation.

A total of 8 taxa were identified, with the dominant taxa being Oligochaeta (55.4%). Two mayfly taxa and no stonefly or caddis fly taxa were found in the subsample. At this location, the Index of Biotic Integrity (IBI) was 16.4 (large stream), which indicates that the stream is impaired.

None of the water quality parameters exceeded the Chapter 93 Water Quality Criteria at the upstream station. Sample results for total phosphorus at this location was 0.066 mg/L; dissolved phosphorus was 0.063 mg/L, total nitrogen was 0.38 mg/L, and total suspended solids were below detectable levels. While none of the metals exceeded Chapter 93 Water Quality Criteria, total sulfate was high (125.46 mg/L), which could be indicative of mining impacts.

### Downstream Station

The downstream station was located approximately 160 meters downstream of where the STP's discharge enters Turtle Creek. At this station, the stream is forested on both banks, but the stream is wide enough that the

canopy does not completely cover the stream. The PA Turnpike parallels the right descending bank, approximately 60 meters away. At this location, the temperature taken with the field meter was 17.7°; pH was 8.5; dissolved oxygen was 12.28 mg/L; and specific conductance was 692 umhos/cm. The habitat score was 169, which consisted of optimal and sub optimal scores and is above attainment thresholds. Couplet summations of embeddedness and the sediment deposition (25) and condition of banks and bank vegetation protection (26) are also above attainment thresholds. The lowest scores were due to sediment deposition and the lack of instream cover.

A total of 6 taxa were identified. The dominant taxa were Oligochaeta (65.1%). One mayfly taxa and no stonefly or caddis fly taxa were collected. The IBI score was 13.2 (large stream), which is below attainment thresholds.


None of the water quarter quality parameters exceeded the Chapter 93 Water Quality Criteria at the downstream station. Water chemistry data indicates total phosphorus was 0.664 mg/L; dissolved phosphorus was 0.646 mg/L; total nitrogen was 5.15 mg/L; and total suspended solids were 10mg/L. All four of these parameters are much higher at the downstream location, compared to the upstream station. Specific conductance is also high at this location, which may be related to the sulfate concentration.

#### DISCUSSION AND CONCLUSIONS


The objective of this survey was to determine if the discharge from the Meadowbrook Road STP is affecting the aquatic life, water quality, and/or physical characteristics of Turtle Creek.

Data collected on May 5, 2021 indicates that Turtle Creek is severely impaired upstream and downstream of the Meadowbrook Road STP. Freestone IBI scores for large streams at both the upstream (16.4) and downstream (13.2) stations are well below the attainment threshold (50). The difference in the IBI scores (3.2) is below method precision estimates, indicating a measurable change in water quality is not evident with the macroinvertebrate method. However, levels of total nitrogen, total phosphorus and total suspended solids are approximately 2-13 times higher downstream of the STP outfall, compared to upstream. Therefore, the extremely impaired conditions of Turtle Creek may be preventing the ability to isolate specific impacts from the Meadowbrook Road STP. A eutrophication study could determine if eutrophication is a cause of impairment and could determine if the Meadowbrook STP discharge is further contributing to this impairment.

cc: Stream File – Turtle Creek  
Stacey Greenwald – SWRO, Environmental Group Manager  
Mahbuba Iasmin – SWRO, Environmental Group Manager  
Christopher Kriley – SWRO, Environmental Program Manager  
Michael Lookenbill – CO, Environmental Group Manager



**Figure 1.** United States Geological Survey Topographic Map showing the location of the Meadowbrook Road STP outfall location and the sampling stations.



**Figure 2.** Map of Meadowbrook Road STP outfall location, sampling locations, and Turtle Creek.

### StreamStats Report



**Figure 3.** USGS Streamstats delineation of the drainage area to the point where Meadowbrook Road STP discharges to Turtle Creek.

**Table 1.** Water quality parameters from Turtle Creek at the sampling stations, upstream and downstream of the STP outfall.

Test	Units	Upstream Result	Comment	Downstream result	Comment
Date		5/20/2021		5/20/2021	
Time		1100		1200	
Sequence Number		311		310	
DISSOLVED OXYGEN - FIELD BY MEMBRANE ELECTRODE****	mg/L	11.75		12.28	
PH - FIELD****	pH units	8.31		8.5	
Specific Conductance - Field	umhos/cm	656		692	
TEMPERATURE - FIELD - THERMOMETRIC****	C	16.8		17.7	
Turbidity, Field****	NTU	0.3		0.8	
ALKALINITY AS CaCO3 @ pH 4.5	mg/L	63		57.2	
ALUMINUM, DISSOLVED (WATER & WASTE) BY ICPMS	ug/L	50.5		56	

Test	Units	Upstream Result	Comment	Downstream result	Comment
ALUMINUM, TOTAL (WATER & WASTE) ICPMS	ug/L	121		114	
AMMONIA DISSOLVED AS NITROGEN	mg/L	0.027	Answer Rechecked By Analyst	0.118	
AMMONIA TOTAL AS NITROGEN	mg/L	<0.02	Answer Rechecked By Analyst	0.11	
BARIUM, TOTAL (WATER & WASTE) BY ICP	ug/L	68		62	
BORON, TOTAL (WATER & WASTE) BY ICP	ug/L	<200		<200	
CADMIUM, DISSOLVED (WATER & WASTE) BY ICPMS	ug/L	<0.2		<0.2	
CALCIUM, TOTAL (WATER & WASTE) BY ICP	mg/L	56.6		54.7	
COPPER, DISSOLVED (WATER & WASTE) BY ICPMS	ug/L	<4		5.47	
COPPER, TOTAL (WATER & WASTE) BY ICPMS	ug/L	<4		5.67	
Dissolve Nitrate & Nitrite Nitrogen	mg/L	0.27		4.79	
Dissolve Ortho Phosphorus	mg/L	0.065	Answer Rechecked By Analyst	0.647	Answer Rechecked By Analyst
Dissolved Nitrogen as N	mg/L	0.558	Dissolved result > Total result by more than 10%	5.616	
Dissolved Phosphorus as P	mg/L	0.063		0.646	
HARDNESS, TOTAL (CALCULATED)	mg/L	201	Accredited by NJ only - accreditation not available from PA	193	Accredited by NJ only - accreditation not available from PA
IRON, DISSOLVED (WATER & WASTE) BY ICP	ug/L	<100		<100	
IRON, TOTAL (WATER & WASTE) BY ICP	ug/L	149		131	
LEAD, DISSOLVED (WATER & WASTE) BY ICPMS	ug/L	<1		<1	

Test	Units	Upstream Result	Comment	Downstream result	Comment
LEAD, TOTAL (WATER & WASTE) BY ICPMS	ug/L	<1		<1	
LITHIUM, DISSOLVED (WATER & WASTE) BY ICP	ug/L	<25		<25	
LITHIUM, TOTAL (WATER & WASTE) BY ICP	ug/L	<25		<25	
Low Bromide by IC	ug/L	46.43		49.53	
MAGNESIUM, TOTAL (WATER & WASTE) BY ICP	mg/L	14.4		13.6	
MANGANESE, DISSOLVED (WATER & WASTE) BY ICP	ug/L	80		70	
MANGANESE, TOTAL (WATER & WASTE) BY ICP	ug/L	87		76	
NICKEL, DISSOLVED (WATER & WASTE) BY ICP	ug/L	<50		<50	
NICKEL, TOTAL (WATER & WASTE) BY ICP	ug/L	<50		<50	
OSMOTIC PRESSURE, MOSM/KG	mosm/kg	8		8	
POTASSIUM, TOTAL (WATER & WASTE) BY ICP	mg/L	2.12		3.66	
SELENIUM, TOTAL (WATER & WASTE) BY ICPMS	ug/L	<7		<7	
SODIUM, TOTAL (WATER & WASTE) BY ICP	mg/L	45		52	
STRONTIUM, TOTAL (WATER & WASTE) BY ICP	ug/L	276		259	
Total Chloride-Ion Chromatograph	mg/L	89.83		100.94	
TOTAL DISSOLVED SOLIDS @ 180C BY USGS-I-1750	mg/L	388		402	
Total Nitrate & Nitrite Nitrogen	mg/L	0.26		4.74	

Test	Units	Upstream Result	Comment	Downstream result	Comment
Total Nitrogen as N	mg/L	0.38	Dissolved result > Total result by more than 10%	5.15	
Total Organic Carbon	mg/L	2.09		3.54	
Total Ortho Phosphorus as P	mg/L	0.045	Answer Rechecked By Analyst	0.576	Answer Rechecked By Analyst
Total Phosphorus as P	mg/L	0.066		0.664	
Total Sulfate-Ion Chromatograph	mg/L	125.46		113.6	
TOTAL SUSPENDED SOLIDS	mg/L	<5		10	
ZINC, DISSOLVED (WATER & WASTE) BY ICP	ug/L	<30		<30	
ZINC, TOTAL (WATER & WASTE) BY ICP	ug/L	<30		<30	

< indicates result is below reporting limit

**Table 2.** Aquatic macroinvertebrates observed the sampling locations upstream and downstream of the Meadowbrook Road STP outfall.

TAXA NAME	Family (Common Name)	Upstream Results	Downstream Results
Acentrella	Baetidae (Small Minnow Mayflies)	1	
Baetis	Baetidae (Small Minnow Mayflies)	26	32
Psephenus	Psephenidae (Water Pennies)	1	
Optioservus	Elmidae (Riffle Beetles)	1	
Stenelmis	Elmidae (Riffle Beetles)		2
Pseudolimnophila	Limoniidae (Crane Flies)		1
Dicranota	Pediciidae (Hairy-eyed Crane Flies)	1	
Simulium	Simuliidae (Black Flies)	3	
Chironomidae	Chironomidae (Non-biting Midges)	54	39
Corbiculidae	Corbiculidae (Asiatic Clams)		1
Oligochaeta	Oligochaeta (Segmented Worms)	108	140
Number of grids picked, Pan 1		4	4
Number of grids picked, Pan 2		7	8
Number organisms in the subsample		195	215
IBI (Large Stream)		16.4	13.2

**Figure 4.** Sampling station located upstream of the Meadowbrook Road STP Outfall, facing upstream.



**Figure 5.** Sampling station located upstream of the Meadowbrook Road STP Outfall, facing downstream.



**Figure 6.** Sampling location located downstream of the Meadowbrook Road STP Outfall, facing upstream.



**Figure 7.** Sampling location located downstream of the Meadowbrook Road STP Outfall, facing downstream.



Table 3. Bureau of Clean Water Macroinvertebrate Sample Summary for the station upstream of the Meadowbrook Road STP.



BUREAU OF CLEAN WATER  
MACROINVERTEBRATE SAMPLE SUMMARY  
1/27/2022 9:41:40 AM

Export Taxa to Excel      Export Data to Excel

SAMPLE SUMMARY				
STATION ID: 20210520-1100-jadetweiler	SECONDARY STATION ID: Turtle Creek, Upstream of STP	LATITUDE: 40.41231160	LONGITUDE: -79.727458	
STREAM NAME: Turtle Creek (01189972)		HUC8 05020005 Lower Monongahela, Pennsylvania, West Virginia.		
SURVEY ID: 73202		METHOD: 6-Dframe Composite, 200 subsample		
SUBSAMPLED BY: Jamie Detweiler	IDENTIFIED BY: Jamie Detweiler	QUALITY ASSURED: N	QUALITY ASSURED BY:	PASSED QUALITY ASSURANCE: N
STATION LOCATION COMMENT:				
BIOLOGY / HABITAT COMMENT:				
LAND USE COMMENT:				
IMPAIRMENT COMMENT:				

TAXA					
TAXA NAME	INDIVIDUALS	PTV	FFG	BCG COLD	BCG WARM
# grids from first pan = 4		# grids from second pan = 7		Subsample Size =	195
Acentrella	1	4	SC	3	3
Baetis	26	6	CG	4	5
Psephenus	1	4	SC	4	4
Optioservus	1	4	SC	4	4
Dicranota	1	3	PR	3	3
Simulium	3	6	FC	5	5
Chironomidae	54	6	CG	5	5
Oligochaeta	108	10	CG	5	5

METRICS						
METRIC NAME	RAW VALUE	Freestone Riffle-Run 6D200			MULTIHABITAT POOL GLIDE	LIMESTONE 2009
		2013 SMALL	2013 LARGE	2D100		
Total Richness	8	24.2	25.8		25.8	44.4
Ephemeroptera Richness	2				33.3	
Trichoptera Richness	0				0.0	
EPT Richness	2			13.1	11.8	25.0
Trichoptera Richness (PTV 0-4)	0			0.0		
EPT Richness (PTV 0-4)	1	5.3	6.3			
Becks Index (version 3)	0	0.0	0.0			



BUREAU OF CLEAN WATER  
MACROINVERTEBRATE SAMPLE SUMMARY

1/27/2022 9:41:40 AM

Becks Index (version 4)	4			20.1	18.2	33.3
FC + PR + SH Richness	2			17.2		
Hilsenhoff Biotic Index	8.17	22.6	26.3	27.2		29.7
% Sensitive Individuals (PTV 0-3)	0.50	0.6	0.7			
% Tolerant Individuals (PTV 7-10)	55.40					45.3
Shannon Diversity	1.12	39.2	39.2		46.1	52.6
IBI SCORE		15.3	16.4	15.5	22.5	38.4

% Ephemeroptera	13.8	% Ephemeroptera (PTV 0-4)	0.5	% Dominant Taxon	55.4	BCG Richness Ratio	0.33
% Plecoptera	0.0	Ephemeroptera Richness (PTV 0-4)	1	% Chironomidae	27.7	BCG Individuals Ratio	0.01
% Trichoptera	0.0	Plecoptera Richness	0	% Simuliidae	1.5		
<b>IMPAIRMENT</b>							
Not Impaired	Y	Insufficient Data	Y				

<b>HABITAT</b>							
Instream Cover	12	Substrate / Cover		Frequency of Riffles	15	Bank Vegetation	13
Epifaunal Substrate	13	Velocity/Depth Regimes	18	Channel Flow Status	15	Disruptive Pressure	10
Embeddedness	12	Pool Variability		Channel Alteration	11	Riparian Zone	9
Pool Substrate		Sediment Deposition	10	Condition of Banks	13		
Pool-Glide Assessment?	N	Instream Score =	47	Riparian Score =	35	Total Score =	151

<b>FIELD MEASUREMENTS</b>					
Temperature (°C)	16.8	Dissolved Oxygen (mg/L)	11.75	Flow (CFS)	
pH	8.31	Total Alkalinity (mg/L as CaCO3)		Conductivity (µS/cm)	656

<b>WATER CHEMISTRY</b>			
Collector ID	0725	Sequence Number	311

Table 4. Bureau of Clean Water Macroinvertebrate Sample Summary for the station downstream of the Meadowbrook Road STP Outfall.



BUREAU OF CLEAN WATER  
MACROINVERTEBRATE SAMPLE SUMMARY  
1/14/2022 7:22:12 AM

Export Taxa to Excel    Export Data to Excel

SAMPLE SUMMARY					
<b>STATION ID:</b> 20210520-1200-jadetweiler	<b>SECONDARY STATION ID:</b> Turtle Creek, Downstream from STP	<b>LATITUDE:</b> 40.41040450	<b>LONGITUDE:</b> -79.72360850		
<b>STREAM NAME:</b> Turtle Creek (01189972)		<b>HUC8</b> 05020005 Lower Monongahela, Pennsylvania, West Virginia.			
<b>SURVEY ID:</b> 73201		<b>METHOD:</b> 6-Frame Composite, 200 subsample			
<b>SUB SAMPLED BY:</b> Jamie Detweiler	<b>IDENTIFIED BY:</b> Jamie Detweiler	<b>QUALITY ASSURED:</b> N	<b>QUALITY ASSURED BY:</b>	<b>PASSSED QUALITY ASSURANCE:</b> N	
<b>STATION LOCATION COMMENT:</b>					
<b>BIOLOGY / HABITAT COMMENT:</b>					
<b>LAND USE COMMENT:</b>					
<b>IMPAIRMENT COMMENT:</b> Downstream of STP					

TAXA						
	# grids from first pan = 4		# grids from second pan = 8		Subsample Size =	216
TAXA NAME	INDIVIDUALS	PTV	FFG	BCG COLD	BCG WARM	
Baetis	32	6	CG	4	5	
Stenelmis	2	5	SC	5	5	
<del>Pseudonannochia</del>	1	2	PR	4	4	
Chironomidae	39	6	CG	5	5	
Corbiculidae	1	4	FC	5	5	
Oligochaeta	140	10	CG	5	5	

METRICS						
		Freestone Riffle-Run 8D200				
METRIC NAME	RAW VALUE	2013 SMALL	2013 LARGE	2D100	MULTIHABITAT POOL GLIDE	LIME STONE 2009
Total Richness	6	18.2	19.4		19.4	33.3
Ephemeroptera Richness	1				16.7	
Trichoptera Richness	0				0.0	
EPT Richness	1			6.5	5.9	12.5
Trichoptera Richness (PTV 0-4)	0			0.0		
EPT Richness (PTV 0-4)	0	0.0	0.0			
Beck's Index (version 3)	1	2.6	4.5			
Beck's Index (version 4)	2			10.1	9.1	16.7
FC + PR + 3H Richness	2			17.2		



BUREAU OF CLEAN WATER  
MACROINVERTEBRATE SAMPLE SUMMARY

1/14/2022 7:22:12 AM

Hilsenhoff Biotic Index	8.67	17.6	20.6	21.2		23.2
% Sensitive Individuals (PTV 0-5)	0.60	0.6	0.7			
% Tolerant Individuals (PTV 7-10)	86.10					35.4
Shannon Diversity	0.87	33.9	33.9		39.9	45.5
	IBI SCORE	12.2	13.2	11.0	15.2	27.8

% Ephemeroptera	14.9	% Ephemeroptera (PTV 0-4)	0.0	% Dominant Taxon	65.1	BCG Richness Ratio	
% Plecoptera	0.0	Ephemeroptera Richness (PTV 0-4)	0	% Chironomidae	18.1	BCG Individuals Ratio	
% Trichoptera	0.0	Plecoptera Richness	0	% Simuliidae	0.0		

IMPAIRMENT

Not Impaired	Y	Insufficient Data	Y
--------------	---	-------------------	---

HABITAT

Instream Cover	11	Substrate / Cover		Frequency of Riffles	18	Bank Vegetation	14
Epifaunal Substrate	13	Velocity/Depth Regimes	16	Channel Flow Status	15	Disruptive Pressure	16
Embeddedness	14	Pool Variability		Channel Alteration	13	Riparian Zone	16
Pool Substrate		Sediment Deposition	11	Condition of Banks	12		

Pool-Glide Assessment? N Instream Score = 48 Riparian Score = 42 Total Score = 188

FIELD MEASUREMENTS

Temperature (°C)	17.7	Dissolved Oxygen (mg/L)	12.28	Flow (CF8)	
pH	8.5	Total Alkalinity (mg/L as CaCO3)		Conductivity (µS/cm)	692

WATER CHEMISTRY

Collector ID	0725	Sequence Number	312
--------------	------	-----------------	-----

## ATTACHMENT G

### Augmented TMS to Evaluate TDS limits



## Discharge Information

Instructions Discharge Stream

Facility: Meadowbrook STP NPDES Permit No.: PA0025674 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Treated Sewage

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>h</sub>
4.9	152	7.9						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L	2670								
	Chloride (PWS)	mg/L	501								
	Bromide	mg/L	5.18								
	Sulfate (PWS)	mg/L	99.8								
	Fluoride (PWS)	mg/L									
Group 2	Total Aluminum	µg/L									
	Total Antimony	µg/L									
	Total Arsenic	µg/L									
	Total Barium	µg/L									
	Total Beryllium	µg/L									
	Total Boron	µg/L									
	Total Cadmium	µg/L									
	Total Chromium (III)	µg/L									
	Hexavalent Chromium	µg/L									
	Total Cobalt	µg/L									
	Total Copper	mg/L									
	Free Cyanide	µg/L									
	Total Cyanide	µg/L									
	Dissolved Iron	µg/L									
	Total Iron	µg/L									
	Total Lead	µg/L									
	Total Manganese	µg/L									
	Total Mercury	µg/L									
	Total Nickel	µg/L									
	Total Phenols (Phenolics) (PWS)	µg/L									
	Total Selenium	µg/L									
	Total Silver	µg/L									
Total Thallium	µg/L										
Total Zinc	mg/L										
Total Molybdenum	µg/L										
Acrolein	µg/L	<									
Acrylamide	µg/L	<									
Acrylonitrile	µg/L	<									
Benzene	µg/L	<									
Bromoform	µg/L	<									

Group 3	Carbon Tetrachloride	µg/L	<																			
	Chlorobenzene	µg/L	<																			
	Chlorodibromomethane	µg/L	<																			
	Chloroethane	µg/L	<																			
	2-Chloroethyl Vinyl Ether	µg/L	<																			
	Chloroform	µg/L	<																			
	Dichlorobromomethane	µg/L	<																			
	1,1-Dichloroethane	µg/L	<																			
	1,2-Dichloroethane	µg/L	<																			
	1,1-Dichloroethylene	µg/L	<																			
	1,2-Dichloropropane	µg/L	<																			
	1,3-Dichloropropylene	µg/L	<																			
	1,4-Dioxane	µg/L	<																			
	Ethylbenzene	µg/L	<																			
	Methyl Bromide	µg/L	<																			
	Methyl Chloride	µg/L	<																			
	Methylene Chloride	µg/L	<																			
	1,1,2,2-Tetrachloroethane	µg/L	<																			
	Tetrachloroethylene	µg/L	<																			
	Toluene	µg/L	<																			
	1,2-trans-Dichloroethylene	µg/L	<																			
1,1,1-Trichloroethane	µg/L	<																				
1,1,2-Trichloroethane	µg/L	<																				
Trichloroethylene	µg/L	<																				
Vinyl Chloride	µg/L	<																				
Group 4	2-Chlorophenol	µg/L	<																			
	2,4-Dichlorophenol	µg/L	<																			
	2,4-Dimethylphenol	µg/L	<																			
	4,6-Dinitro- <i>o</i> -Cresol	µg/L	<																			
	2,4-Dinitrophenol	µg/L	<																			
	2-Nitrophenol	µg/L	<																			
	4-Nitrophenol	µg/L	<																			
	<i>p</i> -Chloro- <i>m</i> -Cresol	µg/L	<																			
	Pentachlorophenol	µg/L	<																			
	Phenol	µg/L	<																			
	2,4,6-Trichlorophenol	µg/L	<																			
Group 5	Acenaphthene	µg/L	<																			
	Acenaphthylene	µg/L	<																			
	Anthracene	µg/L	<																			
	Benidine	µg/L	<																			
	Benzo(a)Anthracene	µg/L	<																			
	Benzo(a)Pyrene	µg/L	<																			
	3,4-Benzofluoranthene	µg/L	<																			
	Benzo(ghi)Perylene	µg/L	<																			
	Benzo(k)Fluoranthene	µg/L	<																			
	Bis(2-Chloroethoxy)Methane	µg/L	<																			
	Bis(2-Chloroethyl)Ether	µg/L	<																			
	Bis(2-Chloroisopropyl)Ether	µg/L	<																			
	Bis(2-Ethylhexyl)Phthalate	µg/L	<																			
	4-Bromophenyl Phenyl Ether	µg/L	<																			
	Butyl Benzyl Phthalate	µg/L	<																			
	2-Chloronaphthalene	µg/L	<																			
	4-Chlorophenyl Phenyl Ether	µg/L	<																			
	Chrysene	µg/L	<																			
	Dibenzo(a,h)Anthracene	µg/L	<																			
	1,2-Dichlorobenzene	µg/L	<																			
	1,3-Dichlorobenzene	µg/L	<																			
	1,4-Dichlorobenzene	µg/L	<																			
	3,3-Dichlorobenzidine	µg/L	<																			
Diethyl Phthalate	µg/L	<																				
Dimethyl Phthalate	µg/L	<																				
Di-n-Butyl Phthalate	µg/L	<																				
2,4-Dinitrotoluene	µg/L	<																				





Stream / Surface Water Information

Meadowbrook STP, NPDES Permit No. PA0025674, Outfall 001

Instructions Discharge Stream

Receiving Surface Water Name: Monongahela River No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	037185	11.67	718.7	7335			Yes
End of Reach 1	037185	4.64	718.6	7335.5		0.69	Yes

Q<sub>7-10</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	11.67	0.167			10							100	7		
End of Reach 1	4.64	0.167			10										

Q<sub>h</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	11.67														
End of Reach 1	4.64														



Model Results

Meadowbrook STP, NPDES Permit No. PA0025674, Outfall 001

Instructions 
  Results 
 


 All 
  Inputs 
  Results 
  Limits

Hydrodynamics

**Q<sub>7-10</sub>**

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
11.67	1224.95		1224.95	7.58	0.	1.203	12.033	10.	1.123	0.383	90.479
4.64	1225.03	1.067	1223.96107					10.000			

**Q<sub>h</sub>**

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
11.67	3715.38		3715.38	7.58	0.	1.957	12.033	6.148	2.086	0.206	43.982
4.64	3715.597	1.067	3714.53								

Wasteload Allocations

**AFC** 
 CCT (min):  
 PMF:  
 Analysis Hardness (mg/l):  
 Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	

**CFC** 
 CCT (min):  
 PMF:  
 Analysis Hardness (mg/l):  
 Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	

**THH** 
 CCT (min):  
 THH PMF:  
 Analysis Hardness (mg/l):  
 Analysis pH:  
 PWS PMF:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	81,303,431	WQC applied at RWR 4.04 with a design stream flow of 1229.0209 cfs
Chloride (PWS)	0	0		0	250,000	250,000	40,651,716	WQC applied at RWR 4.04 with a design stream flow of 1229.0209 cfs
Sulfate (PWS)	0	0		0	250,000	250,000	40,651,716	WQC applied at RWR 4.04 with a design stream flow of 1229.0209 cfs

**CRL**      CCT (min):       PMF:       Analysis Hardness (mg/l):       Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	

**Recommended WQBELs & Monitoring Requirements**

No. Samples/Month:

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			

**Other Pollutants without Limits or Monitoring**

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	81,303	mg/L	Discharge Conc ≤ 10% WQBEL
Chloride (PWS)	40,652	mg/L	Discharge Conc ≤ 10% WQBEL
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	40,652	mg/L	Discharge Conc ≤ 10% WQBEL

## ATTACHMENT H

### WET Test Results and Summary

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet						
Type of Test	Chronic		Facility Name			
Species Tested	Ceriodaphnia		Meadowbrook Road STP			
Endpoint	Survival		Permit No.			
TIWC (decimal)	0.96		PA0025674			
No. Per Replicate	1					
TST b value	0.75					
TST alpha value	0.2					
Test Completion Date			Test Completion Date			
10/31/2022			10/30/2023			
Replicate No.	Control	TIWC	Replicate No.	Control	TIWC	
1	1	1	1	1	1	
2	1	1	2	1	1	
3	1	1	3	1	1	
4	1	1	4	1	1	
5	1	1	5	1	1	
6	1	1	6	1	1	
7	1	1	7	1	1	
8	1	1	8	1	1	
9	1	1	9	1	1	
10	1	1	10	1	1	
11			11			
12			12			
13			13			
14			14			
15			15			
Mean	1.000	1.000	Mean	1.000	1.000	
Std Dev.	0.000	0.000	Std Dev.	0.000	0.000	
# Replicates	10	10	# Replicates	10	10	
T-Test Result			T-Test Result			
Deg. of Freedom			Deg. of Freedom			
Critical T Value			Critical T Value			
Pass or Fail	PASS		Pass or Fail	PASS		
Test Completion Date			Test Completion Date			
11/20/2024			11/3/2025			
Replicate No.	Control	TIWC	Replicate No.	Control	TIWC	
1	1	1	1	1	1	
2	1	1	2	1	1	
3	1	1	3	1	1	
4	0	1	4	1	1	
5	1	1	5	1	1	
6	1	1	6	1	1	
7	1	1	7	1	1	
8	1	0	8	1	1	
9	1	1	9	1	1	
10	1	1	10	1	1	
11			11			
12			12			
13			13			
14			14			
15			15			
Mean	0.900	0.900	Mean	1.000	1.000	
Std Dev.	0.316	0.316	Std Dev.	0.000	0.000	
# Replicates	10	10	# Replicates	10	10	
T-Test Result			T-Test Result			
Deg. of Freedom			Deg. of Freedom			
Critical T Value			Critical T Value			
Pass or Fail	PASS		Pass or Fail	PASS		

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet						
Type of Test	Chronic		Facility Name			
Species Tested	Ceriodaphnia		Meadowbrook Road STP			
Endpoint	Reproduction		Permit No.			
TIWC (decimal)	0.96		PA0025674			
No. Per Replicate	1					
TST b value	0.75					
TST alpha value	0.2					
Test Completion Date			Test Completion Date			
Replicate	10/31/2022		Replicate	10/30/2023		
No.	Control	TIWC	No.	Control	TIWC	
1	22	28	1	29	27	
2	19	29	2	30	28	
3	20	30	3	32	25	
4	22	32	4	29	21	
5	23	32	5	23	25	
6	21	25	6	20	18	
7	28	31	7	25	21	
8	29	28	8	22	20	
9	27	31	9	19	15	
10	19	29	10	19	20	
11			11			
12			12			
13			13			
14			14			
15			15			
Mean	23.000	29.500	Mean	24.800	22.000	
Std Dev.	3.712	2.173	Std Dev.	4.894	4.137	
# Replicates	10	10	# Replicates	10	10	
T-Test Result	10.9689		T-Test Result	1.9441		
Deg. of Freedom	17		Deg. of Freedom	17		
Critical T Value	0.8633		Critical T Value	0.8633		
Pass or Fail	PASS		Pass or Fail	PASS		
Test Completion Date			Test Completion Date			
Replicate	11/20/2024		Replicate	11/3/2025		
No.	Control	TIWC	No.	Control	TIWC	
1	25	20	1	21	23	
2	15	22	2	23	25	
3	17	26	3	25	27	
4	0	26	4	25	25	
5	19	23	5	10	23	
6	18	21	6	29	10	
7	26	29	7	23	25	
8	27	8	8	25	18	
9	20	26	9	26	20	
10	27	25	10	21	21	
11			11			
12			12			
13			13			
14			14			
15			15			
Mean	19.400	22.600	Mean	22.800	21.700	
Std Dev.	8.127	5.816	Std Dev.	5.095	4.923	
# Replicates	10	10	# Replicates	10	10	
T-Test Result	3.0217		T-Test Result	2.3343		
Deg. of Freedom	17		Deg. of Freedom	16		
Critical T Value	0.8633		Critical T Value	0.8647		
Pass or Fail	PASS		Pass or Fail	PASS		

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet					
Type of Test	Chronic		Facility Name		
Species Tested	Pimephales		Meadowbrook Road STP		
Endpoint	Survival		Permit No.		
TIWC (decimal)	0.96		PA0025674		
No. Per Replicate	10				
TST b value	0.75				
TST alpha value	0.25				

Test Completion Date			Test Completion Date		
Replicate	11/1/2022		Replicate	10/31/2023	
No.	Control	TIWC	No.	Control	TIWC
1	1	0.9	1	1	0.9
2	1	0.8	2	1	1
3	1	0.9	3	1	1
4	1	1	4	1	1
5			5		
6			6		
7			7		
8			8		
9			9		
10			10		
11			11		
12			12		
13			13		
14			14		
15			15		

Mean	1.000	0.900	Mean	1.000	0.975
Std Dev.	0.000	0.082	Std Dev.	0.000	0.050
# Replicates	4	4	# Replicates	4	4
T-Test Result	8.8407		T-Test Result	17.8623	
Deg. of Freedom	3		Deg. of Freedom	3	
Critical T Value	0.7649		Critical T Value	0.7649	
Pass or Fail	PASS		Pass or Fail	PASS	

Test Completion Date			Test Completion Date		
Replicate	11/20/2024		Replicate	11/4/2025	
No.	Control	TIWC	No.	Control	TIWC
1	1	1	1	1	1
2	1	0.9	2	1	0.9
3	1	1	3	1	1
4	1	1	4	1	1
5			5		
6			6		
7			7		
8			8		
9			9		
10			10		
11			11		
12			12		
13			13		
14			14		
15			15		

Mean	1.000	0.975	Mean	1.000	0.975
Std Dev.	0.000	0.050	Std Dev.	0.000	0.050
# Replicates	4	4	# Replicates	4	4
T-Test Result	17.8623		T-Test Result	17.8623	
Deg. of Freedom	3		Deg. of Freedom	3	
Critical T Value	0.7649		Critical T Value	0.7649	
Pass or Fail	PASS		Pass or Fail	PASS	

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet						
Type of Test	Chronic		Facility Name			
Species Tested	Pimephales		Meadowbrook Road STP			
Endpoint	Growth		Permit No.			
TIWC (decimal)	0.96		PA0025674			
No. Per Replicate	10					
TST b value	0.75					
TST alpha value	0.25					
Test Completion Date			Test Completion Date			
Replicate	11/1/2022		Replicate	10/31/2023		
No.	Control	TIWC	No.	Control	TIWC	
1	0.401	0.404	1	0.422	0.444	
2	0.394	0.362	2	0.372	0.446	
3	0.402	0.472	3	0.424	0.535	
4	0.419	0.452	4	0.456	0.524	
5			5			
6			6			
7			7			
8			8			
9			9			
10			10			
11			11			
12			12			
13			13			
14			14			
15			15			
Mean	0.404	0.423	Mean	0.419	0.487	
Std Dev.	0.011	0.049	Std Dev.	0.035	0.049	
# Replicates	4	4	# Replicates	4	4	
T-Test Result	4.7758		T-Test Result	6.2501		
Deg. of Freedom	3		Deg. of Freedom	5		
Critical T Value	0.7649		Critical T Value	0.7267		
Pass or Fail	PASS		Pass or Fail	PASS		
Test Completion Date			Test Completion Date			
Replicate	11/20/2024		Replicate	11/4/2025		
No.	Control	TIWC	No.	Control	TIWC	
1	0.414	0.425	1	0.469	0.526	
2	0.435	0.377	2	0.44	0.437	
3	0.437	0.447	3	0.418	0.439	
4	0.419	0.42	4	0.416	0.437	
5			5			
6			6			
7			7			
8			8			
9			9			
10			10			
11			11			
12			12			
13			13			
14			14			
15			15			
Mean	0.426	0.417	Mean	0.436	0.460	
Std Dev.	0.011	0.029	Std Dev.	0.025	0.044	
# Replicates	4	4	# Replicates	4	4	
T-Test Result	6.3929		T-Test Result	5.5505		
Deg. of Freedom	4		Deg. of Freedom	4		
Critical T Value	0.7407		Critical T Value	0.7407		
Pass or Fail	PASS		Pass or Fail	PASS		

**WET Summary and Evaluation**

<b>Facility Name</b>	Meadowbrook Road STP
<b>Permit No.</b>	PA0025674
<b>Design Flow (MGD)</b>	4.9
<b>Q<sub>7-10</sub> Flow (cfs)</b>	0.792
<b>PMF<sub>a</sub></b>	1
<b>PMF<sub>c</sub></b>	1

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Ceriodaphnia	Survival	10/31/22	10/30/23	11/20/24	11/3/25
		PASS	PASS	PASS	PASS

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Ceriodaphnia	Reproduction	10/31/22	10/30/23	11/20/24	11/3/25
		PASS	PASS	PASS	PASS

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Pimephales	Survival	11/1/22	10/31/23	11/20/24	11/4/25
		PASS	PASS	PASS	PASS

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Pimephales	Growth	11/1/22	10/31/23	11/20/24	11/4/25
		PASS	PASS	PASS	PASS

**Reasonable Potential?** NO

**Permit Recommendations**

Test Type **Chronic**  
 TIWC **91** % Effluent  
 Dilution Series **23, 46, 91, 96, 100** % Effluent  
 Permit Limit **None**  
 Permit Limit Species

**Whole Effluent Toxicity (WET)**

For Outfall 001,  **Acute**  **Chronic** WET Testing was completed:

- For the permit renewal application (4 tests).
- Quarterly throughout the permit term.
- Quarterly throughout the permit term and a TIE/TRE was conducted.
- Other: **Annually Throughout the Permit Term**

The dilution series used for the tests was: 100%, 96%, 72%, 48%, and 24%. The Target Instream Waste Concentration (TIWC) to be used for analysis of the results is: 96%.

**Summary of Four Most Recent Test Results**

*(NOTE – Enter results into one table, depending on which data analysis method was used).*

TST Data Analysis

*(NOTE – In lieu of recording information below, the application manager may attach the DEP WET Analysis Spreadsheet).*

Test Date	<i>Ceriodaphnia</i> Results (Pass/Fail)		<i>Pimephales</i> Results (Pass/Fail)	
	Survival	Reproduction	Survival	Growth
October 31 through November 1, 2022	PASS	PASS	PASS	PASS
October 30 and 31, 2023	PASS	PASS	PASS	PASS
November 20, 2024	PASS	PASS	PASS	PASS
November 3 and 4, 2025	PASS	PASS	PASS	PASS

\* A "passing" result is that in which the replicate data for the TIWC is not statistically significant from the control condition. This is exhibited when the calculated t value ("T-Test Result") is greater than the critical t value. A "failing" result is exhibited when the calculated t value ("T-Test Result") is less than the critical t value.

Is there reasonable potential for an excursion above water quality standards based on the results of these tests? *(NOTE – In general, reasonable potential is determined anytime there is at least one test failure in the previous four tests).*

YES  NO

**Comments:**

**WET Limits**

Has reasonable potential been determined?  YES  NO

Will WET limits be established in the permit?  YES  NO