

Application Type Renewal
Facility Type Municipal
Major / Minor Major

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0026646
APS ID 30164
Authorization ID 1494576

Applicant and Facility Information

| | | | |
|---------------------------|--|------------------|---|
| Applicant Name | <u>Antietam Valley Municipal Authority- Berks County</u> | Facility Name | <u>Antietam Valley STP</u> |
| Applicant Address | <u>502 Butter Lane Reading, PA 19606-1604</u> | Facility Address | <u>502 Butter Lane Reading, PA 19606-1604</u> |
| Applicant Contact | <u>Michael Scheuing, Superintendent* (610) 779-0150 / avma@comcast.net and/or mikeavma@gmail.com</u> | Facility Contact | <u>Michael Scheuing, Superintendent</u> |
| Applicant Phone | <u></u> | Facility Phone | <u>(610) 779-0150</u> |
| Client ID | <u>77399</u> | Site ID | <u>253991 (PF # 264743)</u> |
| Ch 94 Load Status | <u></u> | Municipality | <u>Saint Lawrence Borough</u> |
| Connection Status | <u></u> | County | <u>Berks</u> |
| Date Application Received | <u>August 4, 2024</u> | EPA Waived? | <u>No</u> |
| Date Application Accepted | <u>June 2, 2025</u> | If No, Reason | <u>Major Facility</u> |
| Purpose of Application | <u>NPDES Renewal for Sewage Treatment Plant</u> | | |

cc: Mary Peters, Sr. Project Manager, Entech Engineering, mpeters@entecheng.com

Summary of Review

The existing permit was issued January 23, 2020, with an expiration date of January 31, 2025. The permit was administratively extended past its expiration date. The renewal application was submitted August 4, 2024 via DEP's electronic upload system (Reference ID # 250805). Additional Whole Effluent Toxicity test results were requested by DEP and submitted via attachments to emails sent on May 5, 2025, and May 19, 2025.

This Sewage Treatment Plant collects wastewater from Mount Penn Borough, Lower Alsace Township, Exeter Township, and smaller amounts from St. Lawrence Borough and the City of Reading.

Design Flow

The existing permit's limits were based on a design flow of 1.225 MGD. The renewal application did not propose an increase in design flow. The eDMR data from January 1, 2023 through November 30, 2025 reported an average monthly flow of 0.844 MGD (see attached). There were 5 months out of 35 in which the monthly average flow was greater than 1.225 MGD.

The facility's most recent Chapter 94 Municipal Wasteload report spreadsheet is attached. It does not indicate a projected increase in flow. Because they are not proposing an increase in design flow, no new Act 537 Sewage Planning Approval is needed.

Combined Sewer: Not Applicable, separate sewers

| Approve | Deny | Signatures | Date |
|---------|------|--|-------------------|
| x | | <i>Bonnie Boylan</i> Bonnie Boylan / Environmental Engineering Specialist | January 22, 2026 |
| x | | <i>Maria D. Bebenek for</i> Daniel W. Martin, P.E. / Environmental Engineer Manager | February 17, 2026 |
| x | | <i>Maria D. Bebenek</i> Maria D. Bebenek, P.E. / Environmental Program Manager | February 17, 2026 |

Summary of Review

Industrial Wastewater

According to their application, there are no industrial users.

Hauled-in Wastes

According to their application, the facility has not received hauled-in wastes in the past 3 years or anticipate accepting hauled-in waste over the next 5 years.

Variances

No variances were requested [40 CFR 122.21(n)].

Sludge use and disposal description and location(s)

Sludge is hauled off-site and disposed at a landfill.

Delaware River Basin Commission (DRBC)

The facility discharges to a waterway within the Delaware River watershed and is thus subject to DRBC requirements. A copy of the draft permit and Fact Sheet will therefore be sent to the DRBC for their review in accordance with State regulations and an interagency agreement. Any comments from DRBC will be considered.

DRBC's online Interactive Map shows the most recent docket for this facility was approved by DRBC September 10, 2025 and expires March 12, 2030: D-1987-045 CP-7.

Unresolved Violations

There are no unresolved violations for this client according to DEP's Compliance History Summary Report.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Discharge, Receiving Waters and Water Supply Information | | | |
|---|--|------------------------------|---|
| Outfall No. | <u>001</u> | Design Flow (MGD) | <u>1.225</u> |
| Latitude | <u>40° 19' 50.88" (40.3308)</u> | Longitude | <u>-75° 52' 24.13" (-75.873369)</u> |
| Quad Name | <u></u> | Quad Code | <u></u> |
| Wastewater Description: <u>Sewage Effluent</u> | | | |
| Receiving Waters | <u>Antietam Creek (CWF, MF)</u> | Stream Code | <u>01790</u> |
| NHD Com ID | <u>25963816</u> | RMI | <u>4.79</u> |
| Drainage Area | <u>10 sq.mi.</u> | Yield (cfs/mi ²) | <u>0.4</u> |
| Q ₇₋₁₀ Flow (cfs) | <u>4 ** (equivalent of 2.59 MGD)</u> | Q ₇₋₁₀ Basis | <u>USGS Stream Stats*</u> |
| Elevation (ft) | <u>Estimated 300'</u> | Slope (ft/ft) | <u></u> |
| Watershed No. | <u>3-C</u> | Chapter 93 Class. | <u>CWF, MF</u> |
| Existing Use | <u>No different existing use</u> | Existing Use Qualifier | <u>-</u> |
| Exceptions to Use | <u>-</u> | Exceptions to Criteria | <u>-</u> |
| Assessment Status | <u>Impaired for Recreational Use (Assessment ID 15806)</u> | | |
| Cause(s) of Impairment | <u>Pathogens</u> | | |
| Source(s) of Impairment | <u>Source Unknown</u> | | |
| TMDL Status | <u>None</u> | Name | <u></u> |
| Secondary Waters: <u>Antietam Creek empties into Schuylkill River (WWF) at approx. RMI 66.5; Schuylkill River is subject to a TMDL for PCBs</u> | | | |
| Background/Ambient Data | <u>- Not available</u> | Data Source | <u>- no WQNs upstream</u> |
| Nearest Downstream Public Water Supply Intake | <u>Pottstown Borough Water Authority</u> | | |
| PWS Waters | <u>Schuylkill River</u> | Flow at Intake (cfs) | <u>Approx.15, matches last FS</u> |
| PWS RMI | <u>57</u> | Distance from Outfall (mi) | <u>15 miles per appl.</u> |

*<https://streamstats.usgs.gov/ss/>.

**DEP models estimate the 30-day (Q₃₀₋₁₀) and acute (Q₁₋₁₀) stream flows for the discharge point based on the Q₇₋₁₀ stream flow, as follows:

$$Q_{30-10} = 1.36 * 4 \text{ cfs} = 5.4 \text{ cfs}$$

$$Q_{1-10} = 0.64 * 4 \text{ cfs} = 2.6 \text{ cfs}$$

Other Comments:

-Receiving Water = Trout Natural Reproduction (not Class A Wild Trout)

-No upstream or downstream sewage dischargers to include in modeling

-Q_s : Q_d = 2.1 : 1 which is < 3:1 (If this were a new STP or before approving design flow increases, DEP's Standard Operating Procedure 'Establishing Effluent Limitations for Individual Sewage Permits' recommends considering more stringent limits as per guidance document **386-2000-013**---if the discharge meets the criteria in the guidance.)

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|--|------------------------|---|
| Outfall No. | <u>002</u> | Design Flow (MGD) | <u>0</u> |
| Latitude | <u>40° 19' 51" (40.330833)</u> | Longitude | <u>-75° 52' 30" (75.875)</u> |
| Quad Name | <u></u> | Quad Code | <u></u> |
| Wastewater Description: | <u>Stormwater</u> | | |
| Receiving Waters | <u>Antietam Creek per application</u> | Stream Code | <u>UNT 01801 to Antietam Creek (CWF, MF), or 01790 Antietam Creek</u> |
| Watershed No. | <u>3-C</u> | Chapter 93 Class. | <u>CWF, MF</u> |
| Existing Use | <u>None</u> | Existing Use Qualifier | <u>-</u> |
| Exceptions to Use | <u>-</u> | Exceptions to Criteria | <u>-</u> |
| Assessment Status | <u>Impaired for Recreational Use (Assessment ID 15806)</u> | | |
| Cause(s) of Impairment | <u>Pathogens</u> | | |
| Source(s) of Impairment | <u>Source Unknown</u> | | |
| TMDL Status | <u>None</u> | Name | <u></u> |

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|--|------------------------|---------------------------------|
| Outfall No. | <u>003</u> | Design Flow (MGD) | <u>0</u> |
| Latitude | <u>40° 19' 52" (40.331111)</u> | Longitude | <u>-75° 52' 23" (75.873056)</u> |
| Quad Name | <u></u> | Quad Code | <u></u> |
| Wastewater Description: | <u>Stormwater</u> | | |
| Receiving Waters | <u>Antietam Creek per application</u> | Stream Code | <u>01790</u> |
| Watershed No. | <u>3-C</u> | Chapter 93 Class. | <u>CWF, MF</u> |
| Existing Use | <u>None</u> | Existing Use Qualifier | <u>-</u> |
| Exceptions to Use | <u>-</u> | Exceptions to Criteria | <u>-</u> |
| Assessment Status | <u>Impaired for Recreational Use (Assessment ID 15806)</u> | | |
| Cause(s) of Impairment | <u>Pathogens</u> | | |
| Source(s) of Impairment | <u>Source Unknown</u> | | |
| TMDL Status | <u>None</u> | Name | <u></u> |

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|--|------------------------|---|
| Outfall No. | <u>004</u> | Design Flow (MGD) | <u>0</u> |
| Latitude | <u>40° 19' 50" (40.330556)</u> | Longitude | <u>-75° 52' 25" (75.87361)</u> |
| Quad Name | <u></u> | Quad Code | <u></u> |
| Wastewater Description: <u>Stormwater</u> | | | |
| Receiving Waters | <u>Antietam Creek per application</u> | Stream Code | <u>UNT 01801 to Antietam Creek (CWF, MF), or 01790 Antietam Creek</u> |
| Watershed No. | <u>3-C</u> | Chapter 93 Class. | <u>CWF, MF</u> |
| Existing Use | <u>None</u> | Existing Use Qualifier | <u>-</u> |
| Exceptions to Use | <u>-</u> | Exceptions to Criteria | <u>-</u> |
| Assessment Status | <u>Impaired for Recreational Use (Assessment ID 15806)</u> | | |
| Cause(s) of Impairment | <u>Pathogens</u> | | |
| Source(s) of Impairment | <u>Source Unknown</u> | | |
| TMDL Status | <u>None</u> | Name | <u></u> |

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|---|------------------------|---|
| Outfall No. | <u>005</u> | Design Flow (MGD) | <u>0</u> |
| Latitude | <u>40° 19' 51" (40.330833)</u> | Longitude | <u>-75° 52' 31" (75.87528)</u> |
| Quad Name | <u></u> | Quad Code | <u></u> |
| Wastewater Description: <u>Stormwater</u> | | | |
| Receiving Waters | <u>Antietam Creek per application</u> | Stream Code | <u>UNT 01801 to Antietam Creek (CWF, MF), or 01790 Antietam Creek</u> |
| Watershed No. | <u>3-C</u> | Chapter 93 Class. | <u>CWF, MF</u> |
| Existing Use | <u>None</u> | Existing Use Qualifier | <u>-</u> |
| Exceptions to Use | <u>-</u> | Exceptions to Criteria | <u>-</u> |
| Assessment Status | <u>UNT 01801 also Impaired for Recreational Use (Assessment ID 15806)</u> | | |
| Cause(s) of Impairment | <u>Pathogens</u> | | |
| Source(s) of Impairment | <u>Source Unknown</u> | | |
| TMDL Status | <u>None</u> | Name | <u></u> |

| Treatment Facility Summary | | | | |
|---|-----------------------------------|----------------------|----------------------------|-------------------------------|
| Treatment Facility Name: Antietam Valley STP | | | | |
| WQM Permit No. | | Issuance Date | | |
| 667S059 A-4 | | 12/17/2025 | | |
| 667S059 A-3 | | 5/30/2025 | | |
| 667S059 11-1 | | 11/29/2011 | | |
| 667S059 06-1 | | 7/21/2006 | | |
| 667S059 T-2 | | 2/25/1983 | | |
| 667S059 T-1 | | 5/27/1968 | | |
| 667S059 | | 4/30/1968 | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Secondary With Ammonia Reduction | Oxidation Ditch | Gas Chlorine (and dechlor) | 1.225 |
| a | | | | |
| a | | | | |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 2.45 | 2050 | | Aerobic Digestion | Landfill |

Changes Since Last Permit Issuance:

-WQM permit 667S059 Amendment 3 was issued for the conversion of the facility's anaerobic digester to an aerobic digester and the upgrade of the existing aerobic digester as well as new diffusers, blowers, and some new pumps.

-WQM permit 667S059 Amendment 4 was issued for a new vertical influent screen.

Per renewal application:

The existing AVMA WWTP will continue to utilize three different processes, including mix-activated sludge treatment, contact stabilization treatment, and oxidation ditch treatment. Treated effluent from systems 1 and 2 combine and are treated by system 3, which utilizes an oxidation ditch treatment system that provides for nitrification and is followed by chlorination for disinfection.

EXISTING PERMIT LIMITS, Outfall 001:

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|--|----------------------|------------------|-----------------------|------------------|----------------|------------------|-------------------------------|----------------------|
| | Mass Units (lbs/day) | | Concentrations (mg/L) | | | | Minimum Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Instant Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/day | Grab |
| Dissolved Oxygen | XXX | XXX | 5.0 | XXX | XXX | XXX | 1/day | Grab |
| Total Residual Chlorine (TRC) | XXX | XXX | XXX | 0.21 | XXX | 0.68 | 1/day | Grab |
| Carbonaceous Biochemical Oxygen Demand (CBOD5) | 255 | 383 | XXX | 25.0 | 40.0 | 50 | 2/week | 24-Hr Composite |
| Biochemical Oxygen Demand (BOD5) Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 2/week | 24-Hr Composite |
| Total Suspended Solids Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 2/week | 24-Hr Composite |
| Total Suspended Solids | 306 | 460 | XXX | 30.0 | 45.0 | 60 | 2/week | 24-Hr Composite |
| Total Dissolved Solids | XXX | Report Daily Max | XXX | 1000.0 Daily Max | XXX | XXX | 1/quarter | 24-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | 10000 | 2/week | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 2/week | Grab |
| Total Nitrogen | Report | XXX | XXX | Report | XXX | XXX | 2/week | 24-Hr Composite |
| Ammonia-Nitrogen Nov 1 - Apr 30 | 77.0 | XXX | XXX | 7.5 | XXX | 15 | 2/week | 24-Hr Composite |
| Ammonia-Nitrogen May 1 - Oct 31 | 26.0 | XXX | XXX | 2.5 | XXX | 5 | 2/week | 24-Hr Composite |
| Total Phosphorus | Report | XXX | XXX | Report | XXX | XXX | 2/week | 24-Hr Composite |
| Copper, Total (mg/L) | 0.36 | XXX | XXX | 0.036 | XXX | 0.072 | 1/week | 24-Hr Composite |
| Cyanide, Free (ug/L) | Report | XXX | XXX | Report | XXX | Report | 1/week | 24-Hr Composite |
| Lead, Total (ug/L) | Report | XXX | XXX | Report | XXX | Report | 1/week | 24-Hr Composite |
| Dibromochloromethane (ug/L) | Report | XXX | XXX | Report | XXX | Report | 1/week | 24-Hr Composite |

Compliance History

Discharge Monitoring Reports (DMR) Data for Outfall 001 (from December 1, 2024 to November 30, 2025)

| Parameter | NOV-25 | OCT-25 | SEP-25 | AUG-25 | JUL-25 | JUN-25 | MAY-25 | APR-25 | MAR-25 | FEB-25 | JAN-25 | DEC-24 |
|---|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.634 | 0.627 | 0.675 | 0.685 | 1.155 | 1.067 | 1.345 | 1.1 | 0.703 | 0.758 | 0.623 | 0.709 |
| Flow (MGD) Daily Maximum | 0.898 | 1.338 | 1.544 | 0.921 | 5.002 | 3.052 | 3.466 | 2.489 | 1.991 | 2.198 | 0.953 | 1.791 |
| pH (S.U.) Instantaneous Minimum | 6.9 | 6.7 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 6.9 |
| pH (S.U.) Instantaneous Maximum | 7.2 | 7.3 | 7.2 | 7.2 | 7.3 | 7.8 | 7.4 | 7.4 | 7.4 | 7.3 | 7.3 | 7.3 |
| DO (mg/L) Instantaneous Minimum | 5.9 | 5.3 | 5.1 | 5.3 | 5.2 | 5.4 | 5.3 | 5.8 | 5.6 | 6.0 | 5.8 | 6.0 |
| TRC (mg/L) Average Monthly | 0.05 | 0.04 | 0.08 | 0.08 | 0.07 | 0.06 | 0.10 | 0.06 | 0.10 | 0.12 | 0.08 | 0.07 |
| TRC (mg/L) Instantaneous Maximum | 0.15 | 0.13 | 0.33 | 0.21 | 0.30 | 2.00 | 0.35 | 0.20 | 0.31 | 0.36 | 0.39 | 0.28 |
| CBOD5 (lbs/day) Average Monthly | < 12 | < 10 | < 11 | < 11.0 | 36 | 18 | < 26 | < 28 | < 11 | < 17 | < 13 | < 15 |
| CBOD5 (lbs/day) Weekly Average | 16 | < 12 | < 11 | < 12.0 | 117 | 22 | 36 | 66 | < 11 | 26 | < 15 | < 23 |
| CBOD5 (mg/L) Average Monthly | < 2.2 | < 2.0 | < 2.1 | < 2.0 | 2.3 | < 2.1 | < 2.6 | < 2.7 | < 2.0 | < 2.7 | 2.4 | < 2.6 |
| CBOD5 (mg/L) Weekly Average | 2.6 | < 2.1 | < 2.2 | < 2.0 | 3.1 | < 2.3 | 3.2 | 5.0 | < 2.1 | 4.6 | 0.14 | < 4.1 |
| BOD5 (lbs/day) Raw Sewage Influent Average Monthly | 833 | 788 | 805 | 615 | 624 | 564 | 760 | 884 | 900 | 1005 | 1039 | 1110 |
| BOD5 (lbs/day) Raw Sewage Influent Daily Maximum | 971 | 1000 | 1240 | 779 | 755 | 751 | 1235 | 1266 | 1007 | 1378 | 1264 | 2155 |
| BOD5 (mg/L) Raw Sewage Influent Average Monthly | 159.1 | 155 | 153.7 | 111.8 | 81.1 | 64.9 | 89.3 | 102.1 | 170 | 163.7 | 197 | 202 |

**NPDES Permit Fact Sheet
Antietam Valley STP**

NPDES Permit No. PA0026646

| | | | | | | | | | | | | |
|--|-------|--------|--------|--------|-------|--------|---------|--------|--------|--------|-------|-------|
| TSS (lbs/day) Average Monthly | < 21 | < 21 | < 21 | < 23.0 | 56 | < 35 | < 44 | 41 | < 21 | < 26 | < 21 | < 23 |
| TSS (lbs/day) Raw Sewage Influent Average Monthly | 332 | 333 | 328 | 499 | 387 | 278 | 285 | 400 | 270 | 456 | 469 | 539 |
| TSS (lbs/day) Raw Sewage Influent Daily Maximum | 424 | 654 | 632 | 937 | 722 | 463 | 355 | 875 | 416 | 833 | 1016 | 1239 |
| TSS (lbs/day) Weekly Average | < 25 | < 24 | < 22 | < 25.0 | 161 | < 43 | < 58 | < 63 | < 23 | < 35 | < 29 | < 29 |
| TSS (mg/L) Average Monthly | < 4.0 | < 4.0 | < 4.0 | < 4.0 | 4.2 | < 4.0 | < 4.4 | < 4.1 | < 4.0 | < 4.0 | < 4.0 | < 4.0 |
| TSS (mg/L) Raw Sewage Influent Average Monthly | 62.6 | 65.3 | 62.8 | 90 | 47.5 | 31.5 | 33 | 42 | 50.4 | 75 | 91.7 | 96.9 |
| TSS (mg/L) Weekly Average | < 4.0 | < 5.0 | < 4.0 | < 5.0 | 4.5 | < 4.0 | < 5.2 | < 4.6 | < 4.0 | < 4.0 | < 4.0 | < 4.0 |
| Total Dissolved Solids (lbs/day) Daily Maximum | | | 3180 | | | 2529 | | | 2123 | | | 2135 |
| Total Dissolved Solids (mg/L) Daily Maximum | | | 360.0 | | | 420.0 | | | 406.0 | | | 409.0 |
| Fecal Coliform (No./100 ml) Geometric Mean | 10 | 4.0 | 6 | 5.0 | 23 | < 24 | < 100 | < 5 | < 2 | < 2.0 | < 2 | < 6.0 |
| Fecal Coliform (No./100 ml) Instantaneous Maximum | 240 | 136.0 | 28 | 14.0 | 7200 | 665 | < 20000 | 45 | 44 | 5 | 13 | 41 |
| Total Nitrogen (lbs/day) Average Monthly | 116 | 105 | 110 | 103 | 128 | 101 | 105 | 96 | 112 | 109 | 109 | 105 |
| Total Nitrogen (mg/L) Average Monthly | 21.4 | 20.4 | 20.8 | 18.7 | 12.96 | 11.8 | 11.52 | 11.57 | 0.21 | 18.08 | 20.71 | 18.88 |
| Ammonia (lbs/day) Average Monthly | < 0.6 | < 0.5 | < 0.6 | < 0.7 | 17.0 | < 3.0 | < 7.0 | < 14.0 | < 1.0 | < 3.0 | < 0.5 | < 0.6 |
| Ammonia (mg/L) Average Monthly | < 0.1 | < 0.11 | < 0.11 | < 0.12 | 0.7 | < 0.24 | < 0.54 | < 1.05 | < 0.27 | < 0.39 | < 0.1 | < 0.1 |
| Total Phosphorus (lbs/day) Average Monthly | 16 | 14 | 16 | 13.0 | 19 | 14 | 17 | 19 | 15 | 14 | 10 | 11 |

**NPDES Permit Fact Sheet
Antietam Valley STP**

NPDES Permit No. PA0026646

| | | | | | | | | | | | | |
|--|---------|---------|-------|---------|-------|-------|---------|---------|---------|---------|---------|---------|
| Total Phosphorus (mg/L) Average Monthly | 3.01 | 2.72 | 3.08 | 2.42 | 1.68 | 1.62 | 1.85 | 2.31 | 2.87 | 2.35 | 1.93 | 1.99 |
| Total Copper (lbs/day) Average Monthly | < 0.03 | 0.03 | 0.04 | 0.04 | 0.07 | 0.03 | 0.03 | < 0.03 | 0.02 | 0.03 | 0.03 | 0.04 |
| Total Copper (mg/L) Average Monthly | < 0.006 | 0.007 | 0.007 | 0.008 | 0.005 | 0.004 | 0.004 | < 0.004 | 0.004 | 0.005 | 0.006 | 0.007 |
| Free Cyanide (lbs/day) Average Monthly | < 0.03 | < 0.03 | < 30 | < 0.03 | 0.007 | < 4.0 | < 0.07 | < 0.05 | < 0.03 | < 0.04 | < 0.03 | < 0.03 |
| Free Cyanide (ug/L) Average Monthly | < 5 | < 5 | < 5 | < 0.005 | 5 | < 5.0 | < 5 | < 5 | < 5 | < 7 | < 7 | < 5 |
| Free Cyanide (ug/L) Instantaneous Maximum | < 5 | < 5 | < 5 | < 0.005 | 5 | 5.0 | < 5 | < 5 | < 6 | 9 | 12 | < 5 |
| Total Lead (lbs/day) Average Monthly | < 0.006 | < 0.005 | < 5 | < 0.005 | 0.01 | < 8 | < 0.009 | < 0.009 | < 0.005 | < 0.006 | < 0.005 | < 0.006 |
| Total Lead (ug/L) Average Monthly | < 1 | < 1 | < 1 | < 0.001 | 1 | < 1.0 | < 1 | < 1 | < 1 | 1 | < 1 | < 1 |
| Total Lead (ug/L) Instantaneous Maximum | < 1 | < 1 | < 1 | < 0.001 | 1 | < 1.0 | < 1 | < 1 | < 1 | 1 | < 1 | < 1 |
| Dibromochloro- methane (lbs/day) Average Monthly | < 0.003 | < 0.003 | < 3 | < 3 | 0.007 | < 4.0 | < 0.005 | < 0.05 | < 0.03 | < 0.03 | < 0.02 | < 0.03 |
| Dibromochloro- methane (ug/L) Average Monthly | < 0.5 | < 5 | < 0.5 | < 0.5 | 0.5 | < 0.5 | < 0.5 | < 5 | < 5 | < 5 | < 5 | < 5 |
| Dibromochloro- methane (ug/L) Instantaneous Maximum | < 0.5 | < 5 | < 0.5 | < 0.5 | 0.5 | 0.5 | < 0.5 | < 7 | < 5 | < 5 | < 5 | < 5 |

Compliance History

Effluent Violations for Outfall 001, from: January 1, 2025 To: November 30, 2025

| Parameter | Date | Statistical Base Code (SBC) | DMR Value | Units | Limit Value | Units |
|----------------|----------|-----------------------------|-----------|------------|-------------|------------|
| TRC | 06/30/25 | IMAX | 2.00 | mg/L | 0.68 | mg/L |
| Fecal Coliform | 07/31/25 | IMAX | 7200 | No./100 ml | 1000 | No./100 ml |
| Fecal Coliform | 05/31/25 | IMAX | < 20000 | No./100 ml | 1000 | No./100 ml |
| Fecal Coliform | 07/31/25 | IMAX | 7200 | No./100 ml | 1000 | No./100 ml |

Summary of Inspections:

July 10, 2023 – Violation – discharge of sewage from the collection system at Butter Lane Pump Station (PS) due to extreme weather conditions. Damage from rain event included controls for backup pump station at Butter Lane PS, chlorine scales, chlorine alarm system. Also ordered to record change of operator-in-charge using DEP website.

July 1, 2021 – No violations – acquiring a standby power source is recommended. Submit Sewage Sludge/Biosolids supplemental form in eDMR system.

March 1, 2021 – No violations – Experienced high flows due to snowmelt and storm events. Submit a non-compliance report with the February eDMR for partial bypass of treatment units during high flow mode/storm mode.

Development of Effluent Limitations

| | |
|---|---|
| Outfall No. <u>001</u> | Design Flow (MGD) <u>1.225</u> |
| Latitude <u>40° 19' 50.88"</u> | Longitude <u>-75° 52' 24.13"</u> |
| Wastewater Description: <u>Sewage Effluent</u> | |

Permit limits can be Technology Based Effluent Limitations or Water Quality Based Effluent Limitations. Both are discussed in this Fact Sheet, in separate sections. Existing permit limits can also be carried forward such as to comply with anti-backsliding requirements and federal regulations.

Technology-Based Effluent Limitations (TBELs)

The following technology-based limitations apply, subject to water quality analysis and Best Professional Judgement (BPJ) where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation | DRBC* |
|---------------------------------------|-----------------|---|--------------------|------------------|--|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) | |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) | |
| CBOD ₅ or BOD ₅ | 85% Removal | Minimum | | 92a.47(a)(3) | 18 CFR Part 410** ¶ 3.10.4.A & ¶ 3.10.6.D. |
| Total Suspended Solids (TSS) | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) | 18 CFR Part 410** ¶ 3.10.4.D.1. |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) | |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) | |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) | 18 CFR Part 410** ¶ 4.30.4 |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) | |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) | |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) | |
| Total Residual Chlorine (TRC) | 0.5 | Average Monthly | - | 92a.48(b)(2) | |
| Ammonia as N | 20 | Average Monthly | | | 18 CFR Part 410** ¶ 4.30.5.D |
| Total Dissolved Solids (TDS) | 1000*** | Minimum monitoring frequency of Quarterly | | | DRBC docket or 18 CFR Part 410** ¶ 3.10.4.D.2. |

*Pa Code § 92a.12. Treatment requirements:

(b) When interstate or international agencies under an interstate compact or international agreement establish applicable effluent limitations or standards for dischargers of this Commonwealth to surface waters that are more stringent than those required by this title, the more stringent standards and limitations apply.

**Administrative Manual-Part III Water Quality Regulations 18 CFR Part 410

***Or a concentration established by the DRBC which is compatible with designated water uses and stream quality objectives and recognizes the need for reserve capacity to serve future dischargers (i.e. a limit based on a TDS Determination submitted to DRBC proving that the discharge will not cause the TDS in the receiving water to exceed the lesser of 500 mg/l or 133% of background. The DRBC docket for this facility does not include such a TDS variance).

The above TBELs for **CBOD₅, TSS, pH, Fecal Coliform, and TDS** are included as limits in the draft renewal permit and are the same limits as in the existing permit. The mass loading limits for CBOD₅ and TSS are also the same in the draft renewal permit as in the existing permit.

The requirement for a minimum of 85% removal for **CBOD₅ or BOD₅** is satisfied by DEP's narrative condition in Part A of NPDES permits, following the limits tables.

The existing permit and the draft renewal permit include more stringent limits for **Ammonia** and **TRC** than the TBELs shown in the preceding TBEL table; these permit limits were based on WQBELs and are discussed in the WQBEL section of the Fact Sheet.

Best Professional Judgment (BPJ) Limitations, a type of TBEL

None

Water Quality-Based Effluent Limitations (WQBELs)

Total Maximum Daily Loads (TMDLs):

There are no TMDLs for Antietam Creek.

WQBELs other than TMDLs:

DEP uses a model known as **WQM 7.0** to determine appropriate limits for CBOD₅, Ammonia (NH₃-N), and Dissolved Oxygen (DO). DEP's 'Implementation Guidance for Section 93.7 Ammonia Criteria', document #386-2000-022, provides the methods and calculations contained in the WQM 7.0 model for conducting wasteload allocation and for determining recommended NPDES effluent limits for point source discharges. For more explanation of the WQM 7.0 model, see 'Technical Reference Guide WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen', document #386-2000-016. Because there are no other nearby sewage treatment plants on Antietam Creek, no other discharges were included in the model simulation.

The source of the River Mile Indices (RMI's) and elevations that were used in the WM 7.0 model (and TMS model discussed below) was DEP's eMapPA while the source of the Drainage Areas and stream design low-flows (Q7-10, the lowest consecutive 7 days of stream flow over a 10-year period) was the USGS PA Stream Stats online tool (see attached). Low Flow Yield (LFY) is calculated as stream low-flow Q7-10 divided by Drainage Area.

The receiving stream has been classified as 'Trout Natural Reproduction'. Because this is an existing facility who is not increasing their design flow, the WQM model was not re-run for Dissolved Oxygen (DO) levels of 8 mg/l for the protection of early life stages of salmonids, consistent with DEP's Standard Operating Procedure (SOP) 'Establishing Effluent Limitations for Individual Sewage Permits'.

DEP's uses a **TRC model** (Excel spreadsheet) to determine WQBELs for TRC: the model utilizes the equations and calculations provided in DEP's 'Implementation Guidance Total Residual Chlorine (TRC) Regulation' for TRC, document #386-2000-011.

The WQM 7.0 and TRC model results indicated that the existing permit limits for **CBOD₅, TSS, DO, Ammonia, and TRC** are protective of water quality. The existing permit limits for these parameters are being carried forward in the draft renewal permit in accordance with anti-backsliding provisions. The facility has been meeting these existing permit limits according to a review of their DMR data from January 1, 2023, through November 30, 2025.

Note: the WQM model defaulted to the TBELs for CBOD₅ and TSS, meaning no more stringent WQBELs are necessary to protect the receiving water.

Note: Because Ammonia is less toxic in cold water, DEP typically allows less stringent Ammonia limits during cold-weather months. The existing permit included Ammonia limits during cold months that applied a seasonal multiplier of 3 to the

average monthly limit for warm months, consistent with the DEP's SOP 'Establishing Effluent Limitations for Individual Sewage permits'. The same was allowed for the draft renewal permit.

DEP uses a model called the **Toxics Management Spreadsheet (TMS)** for toxic pollutants. It is a macro-enabled Excel version of DEP's former PENTOX model. It evaluates the reasonable potential for discharges to cause in-stream exceedances of water quality criteria and recommends WQBELs as permit limits, as needed, or monitoring requirements to better evaluate 'reasonable potential' to cause an in-stream exceedance of a water quality criteria for some parameters. For more explanation of the TMS / PENTOX model, see Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, document #386-2000-015.

The TMS is coded to recommend limits in the draft permit when the discharge concentration equals or exceeds 50% of the calculated WQBEL. The TMS is coded to recommend a monitoring requirement in the draft permit when the discharge concentration is between 25% and 50% of the WQBEL in the case of non-conservative pollutants or between 10% and 50% of the WQBEL in the case of conservative pollutants.

Some default values were used in the models in the absence of reliable site-specific data including:

- Stream Temperature = 20°C
- Stream pH = 7 s.u.
- Background CBOD5 in stream = 2 mg/l
- Background Ammonia in stream = 0 mg/l
- Background DO in stream = 8.24 mg/l
- Background stream concentrations for toxic parameters = 0 ug/l
- Stream chlorine demand = 0.3
- Discharge chlorine demand = 0
- Discharge Temperature = 25°C
- Discharge pH = 7 s.u.
- Coefficient of Variability in data = 0.5

In addition the WQM 7.0 and TMS models estimated the stream width, depth, and velocity.

When there are less than 10 data points, the *maximum* effluent concentrations of the available data (such as from the permit application and from DMRs) are used by DEP as the discharge concentration input value in the TMS, with the exception of discharge Hardness for which the average effluent concentration is typically used. When there are more than 10 discrete data points (i.e. not statistically manipulated data), DEP may use a statistical spreadsheet known as **ToxStats** to derive the discharge concentration to use in the TMS model. DEP is in the process of replacing the previously used TOXCONC statistical spreadsheet with ToxStats, after testing and validation. For this draft permit, the permit writer used Excel functions to find the 90th percentiles and median values, consistent with DEP's SOP 'Establishing WQBELs and Permit Conditions for Toxic Pollutants in NPDES Permits', from discrete sample results reported on the facility's Daily Effluent Supplemental forms submitted in the eDMR system: a) the median value of effluent concentrations when there are undetected concentrations or b) the 90th percentile of effluent concentrations when there are detected concentrations..

There were more than 10 data points available for Total Copper, Total Lead, Free Cyanide, Dibromochloromethane, and TDS. The statistical analysis for Total Copper and Free Cyanide are attached. However, it was not necessary to find the 90th percentile or median values from discrete samples for the other 3 parameters (which is labor-intensive):

TDS--- the maximum concentration from the application (3 samples) was 695 mg/l ; the maximum concentration from 3 years of DMRs was 505 mg/l. Neither of these discharge concentrations caused the model to recommend limits or a monitoring requirement.

Total Lead -- the maximum concentration from the application (3 samples) was <1 ug/l ; the maximum concentration from 3 years of DMRs was 1 ug/l. Neither of these discharge concentrations caused the model to recommend limits or a monitoring requirement.

Dibromochloromethane--- the maximum concentration from the application (3 samples) was <0.5 ug/l ; the maximum concentration from 3 years of DMRs was <9 ug/l. However, a more stringent reporting level began to be used in 2025: 23 out of 23 discrete samples from the Daily Effluent Supplemental Forms in the eDMR system between July1, 2025 and

November 30, 2025 were <0.5 ug/l. The discharge concentration of <0.5 ug/l did not cause the model to recommend limits or a monitoring requirement.

| | Maximum concentration in application (3 data points) | 90 th percentile discrete data (mostly detects) | Median of discrete data (mostly under reporting level) | # of data points used in statistical calculation |
|---------------------|--|--|--|--|
| T. Copper (mg/l) | 0.007 | 0.007 | | 49 |
| Free Cyanide (ug/l) | <1.0 | | <5 | 48 |

The TMS input values and results are attached. The results are also shown here:

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|----------------|---------------|---------------|----------------------|--------|--------|-------|-----------------|-------------|------------------------------------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| Total Aluminum | Report | Report | Report | Report | Report | µg/L | 1,495 | AFC | Discharge Conc > 10% WQBEL (no RP) |
| Total Copper | Report | Report | Report | Report | Report | mg/L | 0.061 | CFC | Discharge Conc > 10% WQBEL (no RP) |
| Free Cyanide | Report | Report | Report | Report | Report | µg/L | 12.4 | THH | Discharge Conc > 25% WQBEL (no RP) |

Therefore, the existing permit limits for **Total Copper** have been dropped in the draft renewal permit; the existing permit's monitoring requirements for **Total Lead and Dibromochloromethane** have been dropped in the draft renewal permit; and monitoring has been required for **Total Aluminum, Total Copper, and Free Cyanide** as recommended by the TMS.

The model inputs and results are attached.

Dropping the Total Copper limit from the permit does not violate anti-backsliding provisions:

The draft permit issued in 2019 had proposed monitoring for Total Copper "given the limited data set provided" instead of establishing limits [source: 2019 Fact sheet]. EPA commented on the draft, recommending WQBELs be imposed in the final permit for **Total Copper** which they were. However, that recommendation was made based on limited monitoring data. Five years' worth of monitoring is now available for Total Copper. Using DEP procedures and models, the monitoring data do not indicate a reasonable potential exists for the discharge to cause an exceedance of water quality criteria in the receiving stream.

DEP's SOP 'Establishing WQBELs and Permit Conditions for Toxic Pollutants in NPDES Permits' provides that existing WQBELs for toxic parameters can be relaxed or eliminated if no Reasonable Potential is demonstrated and if one of the anti-backsliding exceptions apply. One of the exceptions is new information that was not available at the time the limit was previously imposed, for example monitoring data. [Clean Water Act § 402(o)(2)(B)(i)]. Additionally, there is no TMDL for Antietam Creek nor has it been assessed as impaired for Total Copper nor is it a designated High Quality or Exceptional Value water. The designated uses of the receiving water, Cold Water Fishes and Migratory Fish, will be maintained. The elimination of the Total Copper permit limits will not result in a violation of a water quality standard applicable to the receiving water or the downstream water. Therefore, the existing permit limits for **Total Copper** have been dropped in the draft renewal permit but a monitoring requirement has been included.

Anti-Backsliding

The existing permit limits for Total Copper were eliminated as already discussed and justified. No other limits in the draft renewal permit are less stringent than in the existing permit.

Mass Load vs. Concentration Limits

Consistent with DEP's Technical Guidance for the Development and Specification of Effluent Limitations, document #386-0400-001, and DEP's SOP 'Establishing Effluent Limitations for Individual Sewage Permits', average monthly mass loading limits have been established for CBOD₅, TSS, and Ammonia (NH₃), and average weekly mass loading limits have additionally been established for CBOD₅ and TSS.

Sample Types and Monitoring Frequencies

Sample types and monitoring frequencies are consistent with DEP's Technical Guidance for the Development and Specification of Effluent Limitations, document #386-0400-001, and/or carried forward from the previous permit when deemed appropriate. When monitoring is for the purpose of collecting data for future reasonable potential determinations rather than for verifying compliance with permit limits, less frequent monitoring can be proposed.

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

Influent BOD & TSS Monitoring

The existing influent monitoring reporting requirement for BOD₅ and TSS will be maintained in the renewal permit, consistent with the permits of other municipal wastewater treatment facilities.

E. Coli Monitoring

Consistent with DEP's SOP 'Establishing Effluent Limitations for Individual Sewage Permits' and due to the regulatory change in the State Water Quality Standards, PA Code Chapter 93, E. Coli monitoring has been included. The statutory basis for this requirement is provided at PA Code § 92a.61. The sampling frequency of once per month is consistent with DEP's SOP 'Establishing Effluent Limitations for Individual Sewage Permits'.

Total Nitrogen (TN) and Total Phosphorus (TP) Monitoring

In an effort to understand nutrient loading on PA streams, sewage dischargers with design flows greater than 2000 gpd are being required to monitor for TN and TP in new and reissued permits. The statutory basis for this requirement is provided at PA Code § 92a.61. Because Antietam Creek has not been identified as nutrient-impaired water, monitoring has been required on weekly basis rather than more frequently.

TN and TP monthly monitoring were included in the existing permit. The Discharge Monitoring Reports (DMR) data from January 1, 2023 through November 30, 2025 indicate an average TN concentration in the effluent of 17.7 mg/l and an average TN load of 118 lbs/day. The DMR data from January 1, 2023 through November 30, 2025 indicate an average TP concentration in the effluent of 2.4 mg/l and an average TP load of 16 lbs/day.

Per- and Polyfluoroalkyl Substances (PFAS) Monitoring

Given the concern over PFAS in waterways, DEP has initiated a policy to identify PFAS in discharges using 4 indicator parameters: Perfluorooctanoic acid (PFOA), Perfluorooctane sulfonic acid (PFOS), Perfluorobutane sulfonic acid (PFBS), and Hexafluoropropylene oxide dimer acid (HFPO-DA). A discharge monitoring requirement for these 4 indicator parameters is now routinely included in NPDES permits for Major Sewage facilities, with a footnote allowing the monitoring to be discontinued if 4 consecutive monitoring periods indicate non-detect results at or below specified sufficiently sensitive Quantitation Limits (QLs).

The renewal application indicated that there were detects of PFOA, PFOS, and PFBS in 3 out of 3 effluent samples. For HFPO-DA, there were no detected concentrations in 3 out of 3 effluent samples. Due to the detections of PFAS indicator

parameters, quarterly monitoring for all 4 PFAS indicator parameters has been required in the draft renewal permit, consistent with DEP's SOP 'Establishing Effluent Limitations for Individual Sewage Permits'.

The permit application's effluent sampling results for outfall 001 were as follows:

| Pollutant | Units | Maximum Concentration | # of Detects out of # samples | EPA Method Used |
|-----------|-------|-----------------------|-------------------------------|-----------------------------------|
| PFOA | ng/l | 9.90 | 3 / 3 | 537 Isotope Dilution, M.J. Reider |
| PFOS | ng/l | 3.80 | 3 / 3 | 537 Isotope Dilution, M.J. Reider |
| PFBS | ng/l | 5.20 | 2 / 3 | 537 Isotope Dilution, M.J. Reider |
| HFPO-DA | ng/l | <1.90 | 0 / 3 | 537 Isotope Dilution, M.J. Reider |

| Pollutant | Units | Maximum Concentration | # of Detects out of # samples | EPA Method Used* |
|-----------|-------|--|-------------------------------|---------------------|
| PFOA | ng/l | 6.57 Qualifier: high TDS 5.98 without Qualifiers | 3 / 3 | 1633, Suburban Labs |
| PFOS | ng/l | 5.66 Qualifier: high TDS 5.58 without Qualifiers | 3 / 3 | 1633, Suburban Labs |
| PFBS | ng/l | <3.54 Qualifier: high TDS 2.73 without Qualifiers | 1 / 3 | 1633, Suburban Labs |
| HFPO-DA | ng/l | < 4.0 Qualifier: high TDS <1.9 without Qualifiers | 0 / 3 | 1633, Suburban Labs |

The draft renewal permit also has language in Part B.I.D. relevant to PFAS, shown below. While the facility does not accept industrial wastewater currently, the permittee should be aware, such as for planning purposes, that this language is now included in NPDES permits for Major Sewage facilities.

Each POTW without an approved Pretreatment Program shall, within six (6) months of the permit effective date, develop a list of Industrial Users (IUs) in industry categories expected or suspected of per- and polyfluoroalkyl substance (PFAS) discharges to the POTW and submit the list to EPA at EPA_R3_Pretreatment@epa.gov and to DEP at RA-EPNPDES_PERMITS@pa.gov. These industry categories shall include airports; centralized waste treatment; electroplating; electric and electronic components; fire training; landfills; leather tanning & finishing; metal finishing; organic chemicals, plastics & synthetic fibers (OCPSF); paint formulating; plastics molding & forming; pulp, paper & paperboard; textile mills; sites known or suspected of PFAS contamination; and any other sources expected or suspected of PFAS discharges. The list must contain the names, addresses, NAICS codes, and industry categories (as listed above) of any IUs identified.

Total Dissolved Solids

The facility's DMR data for TDS from January 1, 2023 through November 30, 2025 are attached. Their renewal application indicated an average concentration of 445 mg/l and an average load of 2959 lbs/day based on 8 samples.

TDS data needs to be collected and documented given that future TDS variance requests on stream segments pursuant to Title 25 Pa Code § 95.10 would require DEP to analyze multiple dischargers' TDS loads.

Antidegradation Requirements

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality or Exceptional Value waters are impacted by this discharge.

303(d) Listed Streams – Impaired Waters

Section 303(d) of the federal Clean Water Act requires states to provide a list of impaired waters to EPA and to establish a Total Maximum Daily Load (TMDL) for all pollutants identified as preventing attainment of water quality standards. The receiving water, Antietam Creek, has been assessed as impaired for Recreational Uses due to pathogens. No TMDL has been developed. This permit imposes Fecal Coliform limits as a control on pathogens so that the discharge will not contribute to the impairment. The permittee has been meeting their Fecal Coliform limits.

Class A Trout Fisheries

The receiving water (and downstream waters) are not considered Class A Trout Waters.

Trout Natural Reproduction Waters

The receiving water is considered Trout Natural Reproduction Waters. As discussed in the WQBEL section of the Fact Sheet, a model simulation was not run for salmonid early life stages with a higher stream Dissolved Oxygen concentration because the facility is an existing discharger.

Whole Effluent Toxicity (WET)

The existing permit required (1) quarterly WET testing be conducted for the first year; and (2) if four consecutive quarterly WET tests had passing results, the WET testing frequency could be reduced to annually. The requirement for quarterly sampling was explained thus in the Fact Sheet associated with the existing permit:

WET testing for this renewal was conducted by QC laboratories (Eurofins QC). Per the email from Maria Schumack [DEP Bureau of Clean Water] on October 26, 2017, it is assumed that all tests performed by Eurofins QC should be considered invalid. Quarterly sampling for the first year of the permit term and annual sampling will be resumed in the second year provided they pass all 4 quarterly tests.

The first four tests were conducted quarterly with passing results and allowed for the facility to reduce their testing frequency to annual. However, the facility neglected to conduct WET testing after 2020. For the renewal application, they were required to conduct more recent WET tests in order to assess Reasonable Potential based on 4 WET test results. Because EPA would be reviewing the draft permit, EPA was consulted by DEP to ensure their agreement. See the attached emails.

For Outfall 001: Acute Chronic WET Testing was completed:

- For the permit renewal application (4 tests).
- Quarterly throughout the permit term.
- Quarterly throughout the permit term and a TIE/TRE was conducted.
- Other:

The dilution series used for the tests was: 100%, 66%, 32%, 16% and 8%. The Target Instream Waste Concentration (TIWC) used for analysis of the results: 32%.

Summary of Four Most Recent Test Results

TST Data Analysis

(See the attached DEP WET Analysis Spreadsheets, prepared by the analyzing labs and submitted to DEP).

| Test Date | Ceriodaphnia Results (Pass/Fail) | | Pimephales Results (Pass/Fail) | |
|----------------------------|----------------------------------|--------------|--------------------------------|--------|
| | Survival | Reproduction | Survival | Growth |
| 4/29/2025 (re-test) | - | - | Pass | Pass |
| 3/24/2025 & 3/25/2025 | Pass | Pass | Fail | Fail |
| 12/10/2024 | Pass | Pass | Pass | Pass |
| 8/27/2024 | Pass | Pass | Pass | Pass |
| 12/14/2020 & 12/15/2020 | Pass | Pass | Pass | Pass |

* A "passing" result is that in which the replicate data for the TIWC is not statistically significant from the control condition. This is exhibited when the calculated t value ("T-Test Result") is greater than the critical t value. A "failing" result is exhibited when the calculated t value ("T-Test Result") is less than the critical t value.

Is there reasonable potential for an excursion above water quality standards based on the results of these tests? (NOTE – In general, reasonable potential is determined anytime there is at least one test failure in the previous four tests).

YES NO

Evaluation of Test Type, IWC and Dilution Series for Renewed Permit

Acute Partial Mix Factor (PMFa): 1 Chronic Partial Mix Factor (PMFc): 1 (PMFs from TMS model results)

1. Determine IWC – Acute (IWCa):

$$(Q_d \times 1.547) / ((Q_{7-10} \times \text{PMFa}) + (Q_d \times 1.547))$$

$$[(1.225 \text{ MGD} \times 1.547) / ((4 \text{ cfs} \times 1) + (1.225 \text{ MGD} \times 1.547))] \times 100 = \text{IWCa}\% = 32\%$$

Is IWCa < 1%? YES NO (YES - Acute Tests Required OR NO - Chronic Tests Required)

Type of Test for Permit Renewal: Chronic

2. Determine Target IWCc (If Chronic Tests Required)

$$(Q_d \times 1.547) / (Q_{7-10} \times \text{PMFc}) + (Q_d \times 1.547)$$

$$[(1.225 \text{ MGD} \times 1.547) / ((4 \text{ cfs} \times 1) + (1.225 \text{ MGD} \times 1.547))] \times 100 = \text{TIWCc}\% = 32\%$$

3. Determine Dilution Series

(NOTE – check Attachment C of WET SOP for dilution series based on TIWCa or TIWCc, whichever applies).

Dilution Series = 100%, 66%, 32%, 16%, and 8%.

WET Limits

Has reasonable potential been determined? YES NO

Will WET limits be established in the permit? YES NO

Stormwater

The application represented that there were four stormwater-only outfalls discharging to Antietam Creek, identified as 002, 003, 004, and 005:

| Outfall No. | Latitude | Longitude |
|--------------------|-----------------|------------------|
| 002 | 40° 19' 51" | 75° 52' 30" |
| 003 | 40° 19' 52" | 75° 52' 23" |
| 004 | 40° 19' 50" | 75° 52' 25" |
| 005 | 40° 19' 51" | 75° 52' 31" |

The area drained for each outfall was not provided in the application (or in the existing permit). DEP's application does not ask for descriptions of the areas drained.

See the attached map of the stormwater outfall locations.

As with the existing NPDES permit, no monitoring requirement is included in the permit for the stormwater outfalls but Best Management Practices as well as a Preparedness, Prevention, and Contingency Plan are required in Part C of the draft renewal permit. Routine inspections once per year are also required in Part C.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality as needed and BPJ. Instantaneous Maximum (IMAX) limits are generally determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|----------------------|------------------|-----------------------|-----------------|------------------|------------------|-------------------------------|----------------------|
| | Mass Units (lbs/day) | | Concentrations (mg/L) | | | | Minimum Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Instant. Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/day | Grab |
| DO | XXX | XXX | 5.0 | XXX | XXX | XXX | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.21 | XXX | 0.68 | 1/day | Grab |
| CBOD5 | 255 | 383 | XXX | 25.0 | 40.0 | 50 | 2/week | 24-Hr Composite |
| BOD5 Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 2/week | 24-Hr Composite |
| TSS Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 2/week | 24-Hr Composite |
| TSS | 306 | 460 | XXX | 30.0 | 45.0 | 60 | 2/week | 24-Hr Composite |
| Total Dissolved Solids | XXX | Report Daily Max | XXX | XXX | 1000.0 Daily Max | XXX | 1/quarter | 24-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | 10,000 | 2/week | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 2/week | Grab |
| E. Coli (No./100 mL) | XXX | XXX | XXX | XXX | XXX | Report | 1/month | Grab |
| Nitrate-Nitrite* | Report | XXX | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|----------------------|----------------|-----------------------|-----------------|------------------|------------------|-------------------------------|----------------------|
| | Mass Units (lbs/day) | | Concentrations (mg/L) | | | | Minimum Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Instant. Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Total Kjeldahl* | Report | XXX | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| Total Nitrogen* | Report | XXX | XXX | Report | XXX | XXX | 1/month | Calculation |
| Ammonia Nov 1 - Apr 30 | 77.0 | XXX | XXX | 7.5 | XXX | 15 | 2/week | 24-Hr Composite |
| Ammonia May 1 - Oct 31 | 26.0 | XXX | XXX | 2.5 | XXX | 5 | 2/week | 24-Hr Composite |
| Total Phosphorus | Report | XXX | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| Total Aluminum | Report | XXX | XXX | Report | Report Daily Max | XXX | 1/week | 24-Hr Composite |
| Total Copper | Report | XXX | XXX | Report | Report Daily Max | XXX | 1/week | 24-Hr Composite |
| Cyanide, Free (ug/L) | Report | XXX | XXX | Report | XXX | Report | 1/week | Grab |
| Perfluorooctanoic acid (PFOA) (ng/L)** | XXX | XXX | XXX | XXX | XXX | Report ** | 1/quarter | Grab |
| Perfluorooctanesulfonic acid (PFOS) (ng/L)** | XXX | XXX | XXX | XXX | XXX | Report ** | 1/quarter | Grab |
| Perfluorobutanesulfonic acid (PFBS) (ng/L)** | XXX | XXX | XXX | XXX | XXX | Report ** | 1/quarter | Grab |
| Hexafluoropropylene oxide dimer acid (HFPO-DA) (ng/L)** | XXX | XXX | XXX | XXX | XXX | Report ** | 1/quarter | Grab |

*Total Nitrogen is the sum of Total Kjeldahl Nitrogen (TKN) plus Nitrite-Nitrate as N (NO₂+NO₃-N), where TKN and NO₂+NO₃-N are measured in the same sample.

** The permittee may discontinue monitoring for PFOA, PFOS, HFPO-DA, and PFBS if the results in 4 consecutive quarters indicate non-detect results at or below Quantitation Limits of 4.0 ng/L for PFOA, 3.7 ng/L for PFOS, 3.5 ng/L for PFBS and 6.4 ng/L for HFPO-DA. When monitoring is discontinued, permittees must enter a No Discharge Indicator (NODI) Code of "GG" on DMRs.

Compliance Sampling Location: at outfall 001

| Tools and References Used to Develop Permit | |
|---|--|
| <input checked="" type="checkbox"/> | WQM for Windows Model (see Attachment) |
| <input checked="" type="checkbox"/> | Toxics Management Spreadsheet (see Attachment) |
| <input checked="" type="checkbox"/> | TRC Model Spreadsheet (see Attachment) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment) |
| <input checked="" type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input checked="" type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 386-2000-002, 9/08. |
| <input type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97. |
| <input checked="" type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97. |
| <input checked="" type="checkbox"/> | Implementation Guidance Design Conditions, 386-2000-007, 9/97. |
| <input checked="" type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99. |
| <input checked="" type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004. |
| <input checked="" type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97. |
| <input checked="" type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008. |
| <input checked="" type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999. |
| <input checked="" type="checkbox"/> | Design Stream Flows, 386-2000-003, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97. |
| <input type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input checked="" type="checkbox"/> | SOP: New and Reissuance Sewage Individual NPDES Permit Applications, Version 2.0, Revised 2/3/2022 |
| <input checked="" type="checkbox"/> | SOP: Establishing Effluent Limitations for Individual Sewage Permits, Version 2.0, Revised 2/5/2024 |
| <input checked="" type="checkbox"/> | SOP: Establishing Water Quality-Based Effluent Limitations (WQBELs) and Permit Conditions for Toxic Pollutants in NPDES Permits for Existing Dischargers, Version 1.7, Revised 12/18/2025 |



PADEP Chapter 94 Spreadsheet
Sewage Treatment Plants

Reporting Year: 2024

Facility Name: Antietam Valley Municipal Authority WWTP

Permit No.: PA0026646

Persons/EDU: 2.57

Existing Hydraulic Design Capacity: 2.45 MGD
 Upgrade Planned in Next 5 Years? NO Year:
 Future Hydraulic Design Capacity: MGD

Existing Organic Design Capacity: 2,050 lbs BOD5/day
 Upgrade Planned in Next 5 Years? NO Year:
 Future Organic Design Capacity: lbs BOD5/day

Monthly Average Flows for Past Five Years (MGD)

| Month | 2020 | 2021 | 2022 | 2023 | 2024 |
|-------------------|---------|---------|---------|---------|---------|
| January | 0.936 | 0.807 | 0.668 | 0.939 | 1.577 |
| February | 0.9 | 0.993 | 0.885 | 0.68 | 0.897 |
| March | 0.904 | 1.117 | 0.734 | 0.734 | 1.371 |
| April | 1.054 | 0.813 | 1.239 | 0.698 | 1.358 |
| May | 0.874 | 0.637 | 0.961 | 0.643 | 0.776 |
| June | 0.661 | 0.616 | 0.68 | 0.588 | 0.667 |
| July | 0.725 | 0.683 | 0.667 | 0.975 | 0.835 |
| August | 0.85 | 0.704 | 0.601 | 0.666 | 0.923 |
| September | 0.634 | 1.124 | 0.612 | 0.746 | 0.611 |
| October | 0.652 | 0.662 | 0.905 | 0.632 | 0.554 |
| November | 0.728 | 0.616 | 0.624 | 0.648 | 0.573 |
| December | 0.986 | 0.537 | 0.918 | 1.357 | 0.709 |
| Annual Avg | 0.825 | 0.776 | 0.791 | 0.776 | 0.904 |
| Max 3-Mo Avg | 0.953 | 0.974 | 0.978 | 0.879 | 1.282 |
| Max : Avg Ratio | 1.16 | 1.26 | 1.24 | 1.13 | 1.42 |
| Existing EDUs | 3,689.0 | 3,693.0 | 3,693.0 | 3,693.0 | 3,694.0 |
| Flow/EDU (GPD) | 223.6 | 210.1 | 214.2 | 210.1 | 244.7 |
| Flow/Capita (GPD) | 87.0 | 81.8 | 83.3 | 81.8 | 95.2 |
| Exist. Overload? | NO | NO | NO | NO | NO |

Monthly Average BOD5 Loads for Past Five Years (lbs/day)

| Month | 2020 | 2021 | 2022 | 2023 | 2024 |
|------------------|-------|-------|-------|-------|-------|
| January | 1,624 | 1,777 | 1,407 | 895 | 668 |
| February | 1,599 | 1,956 | 1,172 | 1,216 | 886 |
| March | 2,119 | 1,489 | 1,039 | 905 | 840 |
| April | 2,207 | 1,545 | 1,603 | 736 | 725 |
| May | 1,457 | 1,325 | 1,076 | 783 | 800 |
| June | 1,366 | 982 | 1,442 | 890 | 759 |
| July | 1,426 | 958 | 1,123 | 764 | 694 |
| August | 1,495 | 854 | 1,133 | 650 | 679 |
| September | 1,559 | 1,075 | 1,364 | 713 | 852 |
| October | 1,216 | 991 | 1,284 | 726 | 901 |
| November | 1,563 | 1,022 | 2,075 | 964 | 848 |
| December | 1,727 | 1,052 | 1,237 | 881 | 1,110 |
| Annual Avg | 1,613 | 1,252 | 1,330 | 844 | 814 |
| Max Mo Avg | 2,207 | 1,956 | 2,075 | 1,216 | 1,110 |
| Max : Avg Ratio | 1.37 | 1.56 | 1.56 | 1.44 | 1.36 |
| Existing EDUs | 3,689 | 3,693 | 3,693 | 3,693 | 3,694 |
| Load/EDU | 0.437 | 0.339 | 0.360 | 0.228 | 0.220 |
| Load/Capita | 0.170 | 0.132 | 0.140 | 0.089 | 0.086 |
| Exist. Overload? | YES | NO | YES | NO | NO |

Projected Flows for Next Five Years (MGD)

| | 2025 | 2026 | 2027 | 2028 | 2029 |
|--------------------|--------|--------|--------|--------|--------|
| New EDUs | 10.0 | 1.0 | 1.0 | 1.0 | 1.0 |
| New EDU Flow | 0.0022 | 0.0002 | 0.0002 | 0.0002 | 0.0002 |
| Proj. Annual Avg | 0.817 | 0.8172 | 0.8174 | 0.8176 | 0.8178 |
| Proj. Max 3-Mo Avg | 1.013 | 1.013 | 1.013 | 1.013 | 1.014 |
| Proj. Overload? | NO | NO | NO | NO | NO |

Projected BOD5 Loads for Next Five Years (lbs/day)

| | 2025 | 2026 | 2027 | 2028 | 2029 |
|------------------|-------|-------|-------|-------|-------|
| New EDUs | 10 | 1 | 1 | 1 | 1 |
| New EDU Load | 3.170 | 0.317 | 0.317 | 0.317 | 0.317 |
| Proj. Annual Avg | 1,174 | 1,174 | 1,174 | 1,175 | 1,175 |
| Proj. Max Avg | 1,713 | 1,713 | 1,714 | 1,714 | 1,715 |
| Proj. Overload? | NO | NO | NO | NO | NO |

Discharge Monitoring Report data:

| | | | | | | | | | | | | | | |
|---|-----------|-----------|------------|---|-----|----------------|------|-----|-------|-----------------|-------------|-------|-----------|---------------|
| 7 | PA0026646 | 1/1/2023 | 1/31/2023 | 1 | 001 | Final Effluent | Flow | MGD | 0.939 | Monitor a | Average Mon | 1.99 | Monitor a | Daily Maximum |
| 3 | PA0026646 | 2/1/2023 | 2/28/2023 | 1 | 001 | Final Effluent | Flow | MGD | 0.68 | Monitor a | Average Mon | 0.788 | Monitor a | Daily Maximum |
| 3 | PA0026646 | 3/1/2023 | 3/31/2023 | 1 | 001 | Final Effluent | Flow | MGD | 0.734 | Monitor a | Average Mon | 1.376 | Monitor a | Daily Maximum |
| 0 | PA0026646 | 4/1/2023 | 4/30/2023 | 1 | 001 | Final Effluent | Flow | MGD | 0.698 | Monitor a | Average Mon | 3.119 | Monitor a | Daily Maximum |
| 1 | PA0026646 | 5/1/2023 | 5/31/2023 | 4 | 001 | Final Effluent | Flow | MGD | 0.643 | Monitor a | Average Mon | 1.536 | Monitor a | Daily Maximum |
| 2 | PA0026646 | 6/1/2023 | 6/30/2023 | 1 | 001 | Final Effluent | Flow | MGD | 0.588 | Monitor a | Average Mon | 0.668 | Monitor a | Daily Maximum |
| 3 | PA0026646 | 7/1/2023 | 7/31/2023 | 1 | 001 | Final Effluent | Flow | MGD | 0.975 | Monitor a | Average Mon | 4.875 | Monitor a | Daily Maximum |
| 4 | PA0026646 | 8/1/2023 | 8/31/2023 | 1 | 001 | Final Effluent | Flow | MGD | 0.666 | Monitor a | Average Mon | 1.24 | Monitor a | Daily Maximum |
| 5 | PA0026646 | 9/1/2023 | 9/30/2023 | 1 | 001 | Final Effluent | Flow | MGD | 0.746 | Monitor a | Average Mon | 1.92 | Monitor a | Daily Maximum |
| 3 | PA0026646 | 10/1/2023 | 10/31/2023 | 1 | 001 | Final Effluent | Flow | MGD | 0.632 | Monitor a | Average Mon | 1.101 | Monitor a | Daily Maximum |
| 7 | PA0026646 | 11/1/2023 | 11/30/2023 | 1 | 001 | Final Effluent | Flow | MGD | 0.648 | Monitor a | Average Mon | 1.572 | Monitor a | Daily Maximum |
| 3 | PA0026646 | 12/1/2023 | 12/31/2023 | 1 | 001 | Final Effluent | Flow | MGD | 1.357 | Monitor a | Average Mon | 4.122 | Monitor a | Daily Maximum |
| 3 | PA0026646 | 1/1/2024 | 1/31/2024 | 1 | 001 | Final Effluent | Flow | MGD | 1.577 | Monitor a | Average Mon | 5.186 | Monitor a | Daily Maximum |
| 1 | PA0026646 | 2/1/2024 | 2/29/2024 | 1 | 001 | Final Effluent | Flow | MGD | 0.897 | Monitor a | Average Mon | 1.136 | Monitor a | Daily Maximum |
| | PA0026646 | 3/1/2024 | 3/31/2024 | 1 | 001 | Final Effluent | Flow | MGD | 1.371 | Monitor a | Average Mon | 3.052 | Monitor a | Daily Maximum |
| : | PA0026646 | 4/1/2024 | 4/30/2024 | 1 | 001 | Final Effluent | Flow | MGD | 1.358 | Monitor a | Average Mon | 5.394 | Monitor a | Daily Maximum |
| : | PA0026646 | 5/1/2024 | 5/31/2024 | 1 | 001 | Final Effluent | Flow | MGD | 0.776 | Monitor a | Average Mon | 1.133 | Monitor a | Daily Maximum |
| . | PA0026646 | 6/1/2024 | 6/30/2024 | 1 | 001 | Final Effluent | Flow | MGD | 0.667 | Monitor a | Average Mon | 1.045 | Monitor a | Daily Maximum |
| : | PA0026646 | 7/1/2024 | 7/31/2024 | 1 | 001 | Final Effluent | Flow | MGD | 0.835 | Monitor a | Average Mon | 2.105 | Monitor a | Daily Maximum |
| : | PA0026646 | 8/1/2024 | 8/31/2024 | 1 | 001 | Final Effluent | Flow | MGD | 0.923 | Monitor a | Average Mon | 2.962 | Monitor a | Daily Maximum |
| : | PA0026646 | 9/1/2024 | 9/30/2024 | 1 | 001 | Final Effluent | Flow | MGD | 0.611 | Monitor a | Average Mon | 0.755 | Monitor a | Daily Maximum |
| : | PA0026646 | 10/1/2024 | 10/31/2024 | 1 | 001 | Final Effluent | Flow | MGD | 0.554 | Monitor a | Average Mon | 0.626 | Monitor a | Daily Maximum |
| 1 | PA0026646 | 11/1/2024 | 11/30/2024 | 1 | 001 | Final Effluent | Flow | MGD | 0.573 | Monitor a | Average Mon | 0.945 | Monitor a | Daily Maximum |
| 0 | PA0026646 | 12/1/2024 | 12/31/2024 | 1 | 001 | Final Effluent | Flow | MGD | 0.709 | Monitor a | Average Mon | 1.791 | Monitor a | Daily Maximum |
| 1 | PA0026646 | 1/1/2025 | 1/31/2025 | 1 | 001 | Final Effluent | Flow | MGD | 0.623 | Monitor a | Average Mon | 0.953 | Monitor a | Daily Maximum |
| 2 | PA0026646 | 2/1/2025 | 2/28/2025 | 1 | 001 | Final Effluent | Flow | MGD | 0.758 | Monitor a | Average Mon | 2.198 | Monitor a | Daily Maximum |
| 3 | PA0026646 | 3/1/2025 | 3/31/2025 | 1 | 001 | Final Effluent | Flow | MGD | 0.703 | Monitor a | Average Mon | 1.991 | Monitor a | Daily Maximum |
| 4 | PA0026646 | 4/1/2025 | 4/30/2025 | 1 | 001 | Final Effluent | Flow | MGD | 1.1 | Monitor a | Average Mon | 2.489 | Monitor a | Daily Maximum |
| 5 | PA0026646 | 5/1/2025 | 5/31/2025 | 1 | 001 | Final Effluent | Flow | MGD | 1.345 | Monitor a | Average Mon | 3.466 | Monitor a | Daily Maximum |
| 3 | PA0026646 | 6/1/2025 | 6/30/2025 | 1 | 001 | Final Effluent | Flow | MGD | 1.067 | Monitor a | Average Mon | 3.052 | Monitor a | Daily Maximum |
| 7 | PA0026646 | 7/1/2025 | 7/31/2025 | 1 | 001 | Final Effluent | Flow | MGD | 1.155 | Monitor a | Average Mon | 5.002 | Monitor a | Daily Maximum |
| 3 | PA0026646 | 8/1/2025 | 8/31/2025 | 1 | 001 | Final Effluent | Flow | MGD | 0.685 | Monitor a | Average Mon | 0.921 | Monitor a | Daily Maximum |
| 3 | PA0026646 | 9/1/2025 | 9/30/2025 | 1 | 001 | Final Effluent | Flow | MGD | 0.675 | Monitor a | Average Mon | 1.544 | Monitor a | Daily Maximum |
| 0 | PA0026646 | 10/1/2025 | 10/31/2025 | 1 | 001 | Final Effluent | Flow | MGD | 0.627 | Monitor a | Average Mon | 1.338 | Monitor a | Daily Maximum |
| 1 | PA0026646 | 11/1/2025 | 11/30/2025 | 1 | 001 | Final Effluent | Flow | MGD | 0.634 | Monitor a | Average Mon | 0.898 | Monitor a | Daily Maximum |
| 2 | | | | | | | | | 0.844 | Average | | | | |
| 3 | | | | | | | | | 0.709 | Median | | 1.572 | Median | |
| 4 | | | | | | | | | 1.352 | 90th Percentile | | 5.394 | Maximum | |
| 5 | | | | | | | | | | | | | | |

| PERMIT | MONITORING_DATE | MONITORING_PERIOD | MR_VERS | OUTFALL | MONITORING_LOC | PARAMETER | LOAD_UNITS | LOAD_2_V | LOAD_2 | LOAD_2_SBC | CONC_UN | CONC_2 | CONC_2_L | CONC_2_SBC | SAMPLE_F | SAMPLE_TYPE |
|-----------|-----------------|-------------------|---------|---------|----------------|------------------------|------------|----------|--------------|---------------|---------|--------|--------------|---------------|-----------|-----------------|
| PA0026646 | 1/1/2023 | 3/31/2023 | 1 | 001 | Final Effluent | Total Dissolved Solids | lbs/day | 2225 | Monitor | Daily Maximum | mg/L | 380 | 1000 | Daily Maximum | 1/quarter | 24-Hr Composite |
| PA0026646 | 4/1/2023 | 6/30/2023 | 1 | 001 | Final Effluent | Total Dissolved Solids | lbs/day | 2290 | Monitor | Daily Maximum | mg/L | 480 | 1000 | Daily Maximum | 1/quarter | 24-Hr Composite |
| PA0026646 | 7/1/2023 | 9/30/2023 | 1 | 001 | Final Effluent | Total Dissolved Solids | lbs/day | 2665 | Monitor | Daily Maximum | mg/L | 394 | 1000 | Daily Maximum | 1/quarter | 24-Hr Composite |
| PA0026646 | 10/1/2023 | 12/31/2023 | 1 | 001 | Final Effluent | Total Dissolved Solids | lbs/day | 2627 | Monitor | Daily Maximum | mg/L | 493 | 1000 | Daily Maximum | 1/quarter | 24-Hr Composite |
| PA0026646 | 1/1/2024 | 3/31/2024 | 1 | 001 | Final Effluent | Total Dissolved Solids | lbs/day | 3395 | Monitor | Daily Maximum | mg/L | 358 | 1000 | Daily Maximum | 1/quarter | 24-Hr Composite |
| PA0026646 | 4/1/2024 | 6/30/2024 | 1 | 001 | Final Effluent | Total Dissolved Solids | lbs/day | 2258 | Monitor | Daily Maximum | mg/L | 414 | 1000 | Daily Maximum | 1/quarter | 24-Hr Composite |
| PA0026646 | 7/1/2024 | 9/30/2024 | 1 | 001 | Final Effluent | Total Dissolved Solids | lbs/day | 2637 | Monitor | Daily Maximum | mg/L | 505 | 1000 | Daily Maximum | 1/quarter | 24-Hr Composite |
| PA0026646 | 10/1/2024 | 12/31/2024 | 1 | 001 | Final Effluent | Total Dissolved Solids | lbs/day | 2135 | Monitor | Daily Maximum | mg/L | 409 | 1000 | Daily Maximum | 1/quarter | 24-Hr Composite |
| PA0026646 | 1/1/2025 | 3/31/2025 | 1 | 001 | Final Effluent | Total Dissolved Solids | lbs/day | 2123 | Monitor | Daily Maximum | mg/L | 406 | 1000 | Daily Maximum | 1/quarter | 24-Hr Composite |
| PA0026646 | 4/1/2025 | 6/30/2025 | 1 | 001 | Final Effluent | Total Dissolved Solids | lbs/day | 2529 | Monitor | Daily Maximum | mg/L | 420 | 1000 | Daily Maximum | 1/quarter | 24-Hr Composite |
| PA0026646 | 7/1/2025 | 9/30/2025 | 1 | 001 | Final Effluent | Total Dissolved Solids | lbs/day | 3180 | Monitor | Daily Maximum | mg/L | 360 | 1000 | Daily Maximum | 1/quarter | 24-Hr Composite |
| PA0026646 | 10/1/2025 | 12/31/2025 | 1 | 001 | Final Effluent | Total Dissolved Solids | lbs/day | 2180 | Monitor | Daily Maximum | mg/L | 450 | 1000 | Daily Maximum | 1/quarter | 24-Hr Composite |
| | | | | | | | | 2520 | AVG of D.Max | | | 422 | AVG of D.Max | | | |
| | | | | | | | | 3395 | D.Max | | | 505 | D.Max | | | |

| StreamStats Output Report - Antietam Valley STP 001 | | | | | |
|--|--|--------------------|--------------|-----------|-----------|
| State/Region ID | PA | | | | |
| Latitude | 40.33084 | | | | |
| Longitude | -75.87317 | | | | |
| Time | 1/13/2026 2:56:24 PM | | | | |
| Basin Characteristics | | | | | |
| Parameter Code | Parameter Description | Value | Unit | | |
| BSLOPD | Mean basin slope measured in degrees | 7.7057 | degrees | | |
| DRNAREA | Area that drains to a point on a stream | 9.99 | square miles | | |
| ROCKDEP | Depth to rock | 5.11 | feet | | |
| URBAN | Percentage of basin with urban development | 10.9575 | percent | | |
| Low-Flow Statistics Parameter 100.0 Percent Low Flow Region 1 | | | | | |
| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
| BSLOPD | Mean Basin Slope degrees | 7.7057 | degrees | 1.7 | 6.4 |
| DRNAREA | Drainage Area | 9.99 | square miles | 4.78 | 1150 |
| ROCKDEP | Depth to Rock | 5.11 | feet | 4.13 | 5.21 |
| URBAN | Percent Urban | 10.9575 | percent | 0 | 89 |
| Low-Flow Statistics Flow Parameter 100.0 Percent Low Flow Region 1 | | | | | |
| Statistic | Value | Unit | | | |
| 7 Day 2 Year Low Flow | 6.3 | ft ³ /s | | | |
| 30 Day 2 Year Low Flow | 6.97 | ft ³ /s | | | |
| 7 Day 10 Year Low Flow | 3.96 | ft ³ /s | | | |
| 30 Day 10 Year Low Flow | 4.4 | ft ³ /s | | | |
| 90 Day 10 Year Low Flow | 5 | ft ³ /s | | | |
| USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the requirements of the National Information Standards Organization (ANSI) Z39.18-1986 (Permanence of Paper) and ANSI Z39.18-1986 (Permanence of Paper) and related materials are considered to satisfy the requirements of the National Information Standards Organization (ANSI) Z39.18-1986 (Permanence of Paper) and related materials are considered to satisfy the requirements of the National Information Standards Organization (ANSI) Z39.18-1986 (Permanence of Paper). | | | | | |
| USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software is provided as is, it is not intended to be used for legal or regulatory purposes. | | | | | |
| USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not constitute an endorsement of the named product. | | | | | |
| Application Version: 4.30.0 | | | | | |

Low Flow Yield = Q7-10 / Drainage Area = 3.96 cfs/ 9.99 sq.mi. = 0.4 cfs/sq.mi.

Stream Stats just before confluence of Antietam Creek and UNT 01799, downstream of outfall 001:

| StreamStats Output Report- at confluence of Antietam Crk and UNT 01799 | | | | | |
|---|---|---------|--------------|-----------|-----------|
| State/Region ID | PA | | | | |
| Latitude | 40.31815 | | | | |
| Longitude | -75.86251 | | | | |
| Time | 1/13/2026 3:26:33 PM | | | | |
| Basin Characteristics | | | | | |
| Parameter Code | Parameter Description | Value | Unit | | |
| BSLOPD | Mean basin slope measured in degrees | 7.7432 | degrees | | |
| DRNAREA | Area that drains to a point on a stream | 11.8 | square miles | | |
| ROCKDEP | Depth to rock | 5.15 | feet | | |
| URBAN | Percentage of basin with urban developm | 19.4944 | percent | | |
| Low-Flow Statistics Param 100.0 Percent Low Flow Region 1 | | | | | |
| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
| BSLOPD | Mean Basin Slope degrees | 7.7432 | degrees | 1.7 | 6.4 |
| DRNAREA | Drainage Area | 11.8 | square mil | 4.78 | 1150 |
| ROCKDEP | Depth to Rock | 5.15 | feet | 4.13 | 5.21 |
| URBAN | Percent Urban | 19.4944 | percent | 0 | 89 |
| Low-Flow Statistics Flow R 100.0 Percent Low Flow Region 1 | | | | | |
| Statistic | Value | Unit | | | |
| 7 Day 2 Year Low Flow | 8.99 | ft^3/s | | | |
| 30 Day 2 Year Low Flow | 9.87 | ft^3/s | | | |
| 7 Day 10 Year Low Flow | 5.96 | ft^3/s | | | |
| 30 Day 10 Year Low Flow | 6.53 | ft^3/s | | | |
| 90 Day 10 Year Low Flow | 7.28 | ft^3/s | | | |
| USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality s | | | | | |
| USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the so | | | | | |
| USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply | | | | | |
| Application Version: 4.30.0 | | | | | |
| SSHhydro Services Version: 1.0.0 | | | | | |
| SSDelineate Services Version: 1.0.0 | | | | | |
| NSS Services Version: 2.2.1 | | | | | |
| GageStats Services Version: 1.2.1 | | | | | |
| Pourpoint Services Version: 1.2.0 | | | | | |
| Batch Processor Services Version: 1.6.0 | | | | | |

Low Flow Yield = Q7-10 / Drainage Area = 5.96 cfs/ 11.8 sq.mi. = 0.505 cfs/sq.mi.

Input Data WQM 7.0

General Data

| General | | Stream | | | Discharge and Parameters | | | |
|-------------|-------|----------------|-----------------------|------------|--------------------------|----------------|-------------------------------------|--|
| Stream Code | RMI | Elevation (ft) | Drainage Area (sq mi) | LFY (cfsm) | Slope (ft/ft) | PWS With (mgd) | Apply FC | |
| ▶ 1790 | 4.790 | 300 | 10 | 0.4 | 0 | 0 | <input checked="" type="checkbox"/> | |
| 1790 | 3.570 | 255 | 11.8 | 0.505 | 0 | 0 | <input checked="" type="checkbox"/> | |

Add Record
Delete Record

Input Data WQM 7.0

Stream Data

| General | | Stream | | | Discharge and Parameters | | | | | | |
|---|-----------------|-------------------|-----------------------|---------------------|--------------------------|-----------------|-----------------|---------------------|------|------------------|------|
| Design Condition | | | | | | | | | | | |
| <input checked="" type="radio"/> Q7-10 <input type="radio"/> Q1-10 <input type="radio"/> Q30-10 | | | | | | | | | | | |
| RMI | Trib Flow (cfs) | Stream Flow (cfs) | Rich Trav Time (days) | Rich Velocity (fps) | WD Ratio | Rich Width (ft) | Rich Depth (ft) | Tributary Temp (°C) | pH | Stream Temp (°C) | pH |
| ▶ 4.790 | 0.00 | 0.00 | 0.000 | 0.00 | 0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.000 | 0.00 |
| 3.570 | 0.00 | 0.00 | 0.000 | 0.00 | 0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.000 | 0.00 |

Input Data WQM 7.0

Discharge and Parameter Data

| General | | Stream | | | Discharge and Parameters | | | | |
|----------------|-----------------|---------------|--------------------------|---------------------------|--------------------------|----------------|----------------|---------|--|
| Discharge Data | | | | | | | | | |
| RMI | Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH | |
| 4.790 | Antietam Valley | PA0026646 | 0.0000 | 1.2250 | 0.0000 | 0.000 | 25.00 | 7.00 | |

| Parameter Data | | | | | |
|------------------|------------------|------------------|--------------------|-------------------|--|
| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/day) | |
| ▶ CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 | |
| NH3-N | 2.50 | 0.00 | 0.00 | 0.70 | |
| Dissolved Oxygen | 5.00 | 8.24 | 0.00 | 0.00 | |

Record: 1 of 2 No Filter Search

Input Data WQM 7.0

Discharge and Parameter Data

General
Stream
Discharge and Parameters

| Discharge Data | | | | | | | | |
|----------------|-----------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| RMI | Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
| 3.570 | Antietm/UNT1799 | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 20.00 | 7.00 |

| Parameter Data | | | | |
|------------------|------------------|------------------|--------------------|-------------------|
| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/day) |
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| NH3-N | 20.00 | 0.00 | 0.00 | 0.70 |
| Dissolved Oxygen | 5.00 | 8.24 | 0.00 | 0.00 |

Record: 2 of 2 No Filter Search

Modeling Specifications WQM 7.0

Select Parameters

NH3-N

Dissolved Oxygen

Both

Select WLA Method

Uniform Treatment

EMPR

D.O. Simulation

Q1-10 and Q30-10 Data

Use input Q1-10 and Q30-10 data

Q1-10/Q7-10 ratio:

Q30-10/Q7-10 ratio:

WQAM 6.3 Comparison

Input reach W/D ratios * Input reach travel times *

Temperature Adjust Kr**

* Check to duplicate WQAM 6.3 results
** Uncheck to duplicate WQAM 6.3 results

Dissolved Oxygen

DO Goal:

DO Saturation Percent:

Use Balanced Technology

Analysis Results WQM 7.0

Hydrodynamics | **NH3-N Allocations** | D.O. Allocations | D.O. Simulation | Effluent Limitations

Design Condition: Q7-10 Q1-10 Q30-10

| RMI | Stream Flow (cfs) | PWS With (cfs) | Net Stream Flow (cfs) | Disc Flow (cfs) | Reach Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Reach Trav Time (days) | Analysis Temp (°C) | Analysis pH |
|-------|-------------------|----------------|-----------------------|-----------------|---------------------|------------|------------|-----------|----------------|------------------------|--------------------|-------------|
| 4.790 | 4.00 | 0.00 | 4.00 | 1.8951 | 0.00699 | .652 | 25.73 | 39.48 | 0.352 | 0.212 | 21.61 | 7.00 |

Analysis Results WQM 7.0

Hydrodynamics | NH3-N Allocations | D.O. Allocations | **D.O. Simulation** | Effluent Limitations

| RMI | Total Discharge Flow (mgd) | Analysis Temperature (°C) | Analysis pH |
|--------------------------|----------------------------|---------------------------|------------------------|
| 4.790 | 1.225 | 21.607 | 7.000 |
| Reach Width (ft) | Reach Depth (ft) | Reach W/D Ratio | Reach Velocity (fps) |
| 25.730 | 0.652 | 39.476 | 0.352 |
| Reach C-BOD5 (mg/L) | Reach Kc (1/days) | Reach NH3-N (mg/L) | Reach Kn (1/days) |
| 9.39 | 1.249 | 0.80 | 0.792 |
| Reach D.O. (mg/L) | Reach Kr (1/days) | Kr Equation | Reach D.O. Goal (mg/L) |
| 7.200 | 24.240 | Tsivoglou | 6 |
| Reach Travel Time (days) | 0.212 | | |

| Subreach Results | | | |
|------------------|--------------|--------------|-------------|
| TravTime (days) | CBOD5 (mg/L) | NH3-N (mg/L) | D.O. (mg/L) |
| 0.021 | 9.13 | 0.79 | 7.52 |
| 0.042 | 8.87 | 0.78 | 7.73 |
| 0.064 | 8.62 | 0.76 | 7.86 |
| 0.085 | 8.38 | 0.75 | 7.94 |
| 0.106 | 8.15 | 0.74 | 8.00 |
| 0.127 | 7.92 | 0.73 | 8.00 |
| 0.148 | 7.69 | 0.71 | 8.00 |
| 0.170 | 7.48 | 0.70 | 8.00 |
| 0.191 | 7.27 | 0.69 | 8.00 |
| 0.212 | 7.06 | 0.68 | 8.00 |

Analysis Results WQM 7.0

Hydrodynamics | NH3-N Allocations | D.O. Allocations | D.O. Simulation | **Effluent Limitations**

| RMI | Discharge Name | Permit Number | Disc Flow (mgd) |
|------|-----------------|---------------|-----------------|
| 4.79 | Antietam Valley | PA0026646 | 0.0000 |

| Parameter | Effluent Limit 30 Day Average (mg/L) | Effluent Limit Maximum (mg/L) | Effluent Limit Minimum (mg/L) |
|------------------|--------------------------------------|-------------------------------|-------------------------------|
| CBOD5 | 25 | | |
| NH3-N | 2.5 | 5 | |
| Dissolved Oxygen | | | 5 |

Record: 1 of 1 | No Filter | Search

| A | B | C | D | E | F | G |
|---|--------------------------------|------------------------------------|-----|--------------------------------------|---|------------------|
| TRC EVALUATION | | | | | | |
| Input appropriate values in A3:A9 and D3:D9 | | | | | | |
| 4 | = Q stream (cfs) | | 0.5 | = CV Daily | | |
| 1.225 | = Q discharge (MGD) | | 0.5 | = CV Hourly | | |
| 30 | = no. samples | | 1 | = AFC_Partial Mix Factor | | |
| 0.3 | = Chlorine Demand of Stream | | 1 | = CFC_Partial Mix Factor | | |
| 0 | = Chlorine Demand of Discharge | | 15 | = AFC_Criteria Compliance Time (min) | | |
| 0.5 | = BAT/BPJ Value | | 720 | = CFC_Criteria Compliance Time (min) | | |
| 0 | = % Factor of Safety (FOS) | | | = Decay Coefficient (K) | | |
| Source | | Reference | | AFC Calculations | | Reference |
| TRC | | 1.3.2.iii | | WLA afc = 0.692 | | 1.3.2.iii |
| PENTOXSD TRG | | 5.1a | | LTAMULT afc = 0.373 | | 5.1c |
| PENTOXSD TRG | | 5.1b | | LTA_afc= 0.258 | | 5.1d |
| Source | | Effluent Limit Calculations | | | | |
| PENTOXSD TRG | | 5.1f | | | | |
| PENTOXSD TRG | | 5.1g | | | | |
| | | AML MULT = 1.231 | | | | |
| | | AVG MON LIMIT (mg/l) = 0.318 | | | | |
| | | INST MAX LIMIT (mg/l) = 1.038 | | | | |
| <p>WLA afc $(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$</p> <p>LTAMULT afc $EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$</p> <p>LTA_afc $wla_afc*LTAMULT_afc$</p> <p>WLA_cfc $(.011/e(-k*CFC_tc) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$</p> <p>LTAMULT_cfc $EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$</p> <p>LTA_cfc $wla_cfc*LTAMULT_cfc$</p> <p>AML MULT $EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$</p> <p>AVG MON LIMIT $MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)$</p> <p>INST MAX LIMIT $1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$</p> | | | | | | |
| <p>$(0.011/EXP(-K*CFC_tc/1440))+((CFC_Yc*Qs*0.011)/(1.547*Qd))....$</p> <p>$....*EXP(-K*CFC_tc/1440))+Xd+(CFC_Yc*Qs*Xs/1.547*Qd)]*(1-FOS/100)$</p> | | | | | | |

Statistical Analysis of Daily Effluent Supplemental DMR data, discrete samples, for TMS inputs:

| | Total Copper (mg/l) | | Free Cyanide (mg/l) |
|-----------------|------------------------|---|------------------------|
| Jan-25 | 0.006 | < | 0.005 |
| | 0.005 | < | 0.005 |
| | 0.006 | < | 0.005 |
| | 0.005 | | 0.012 |
| | 0.006 | < | 0.005 |
| Feb-25 | 0.006 | | 0.009 |
| | 0.004 | | 0.007 |
| | 0.003 | | 0.007 |
| | 0.005 | < | 0.005 |
| Mar-25 | 0.006 | < | 0.005 |
| | 0.004 | | 0.06 |
| | 0.003 | < | 0.005 |
| | 0.004 | < | 0.005 |
| Apr-25 | 0.004 | < | 0.005 |
| | < 0.002 | < | 0.005 |
| | < 0.002 | < | 0.005 |
| | 0.004 | < | 0.005 |
| | 0.006 | < | 0.005 |
| May-25 | 0.005 | < | 0.005 |
| | 0.003 | < | 0.005 |
| | 0.003 | < | 0.005 |
| | 0.004 | < | 0.005 |
| Jun-25 | 0.002 | < | 0.005 |
| | 0.005 | < | 0.005 |
| | 0.005 | | 0.06 |
| Jul-25 | 0.005 | < | 0.005 |
| | 0.005 | < | 0.005 |
| | 0.004 | < | 0.005 |
| | 0.006 | < | 0.005 |
| | 0.006 | < | 0.005 |
| Aug-25 | 0.006 | < | 0.005 |
| | 0.007 | < | 0.005 |
| | 0.009 | < | 0.005 |
| | 0.008 | < | 0.005 |
| Sep-25 | 0.008 | < | 0.005 |
| | 0.006 | < | 0.005 |
| | 0.007 | < | 0.005 |
| | 0.007 | < | 0.005 |
| | 0.007 | < | 0.005 |
| Oct-25 | 0.007 | < | 0.005 |
| | 0.008 | < | 0.005 |
| | 0.006 | < | 0.005 |
| | 0.007 | < | 0.005 |
| | 0.007 | < | 0.005 |
| Nov-25 | < 0.002 | < | 0.005 |
| | 0.006 | < | 0.005 |
| | 0.007 | < | 0.005 |
| | 0.008 | < | 0.005 |
| 90th percentile | 0.007 | < | 0.007 |
| Median | 0.006 | < | 0.005 |

Antietam Valley Municipal Authority
NPDES Permit Renewal Sampling - Effluent
Pollutant Group 2

| POLLUTANT GROUP 2 PARAMETERS | Sample Date: 5/30/2024 | | | Sample Date: 6/6/2024 | | | Sample Date: 6/13/2024 | | | CONCENTRATION / MASS PRESENT | | | | No. Analyses | No. "Non-Detect" Results | Average QL Used | Method Used |
|------------------------------|------------------------|----------------|---------|-----------------------|----------------|---------|------------------------|----------------|---------|------------------------------|----------------|---------|----------------|--------------|--------------------------|-----------------|-------------------|
| | Daily Flow: 0.659 | | QL Used | Daily Flow: 0.823 | | QL Used | Daily Flow: 0.616 | | QL Used | Maximum | | Average | | | | | |
| | Conc | Mass (lbs/day) | | Conc | Mass (lbs/day) | | Conc | Mass (lbs/day) | | Conc | Mass (lbs/day) | Conc | Mass (lbs/day) | | | | |
| Aluminum, Total (µg/L) | 120.00 | 0.6595 | 20.00 | 230.00 | 1.5787 | 20.00 | 220.00 | 1.1302 | 20.00 | 230.00 | 1.579 | 190.00 | 1.123 | 3 | 0 | 20.0 | EPA 200.8 Rev 5.4 |
| Antimony, Total (µg/L) | < 0.30 | 0.0016 | 3.00 | 0.40 | 0.0027 | 3.00 | < 0.30 | 0.0015 | 3.00 | 0.40 | 0.003 | 0.33 | 0.002 | 3 | 2 | 3.0 | EPA 200.8 Rev 5.4 |
| Arsenic, Total (µg/L) | < 1.00 | 0.0055 | 1.00 | < 1.00 | 0.0069 | 1.00 | < 1.00 | 0.0051 | 1.00 | 1.00 | 0.007 | 1.00 | 0.006 | 3 | 3 | 1.0 | EPA 200.8 Rev 5.4 |
| Barium, Total (µg/L) | 59.00 | 0.3243 | 5.00 | 55.00 | 0.3775 | 5.00 | 76.00 | 0.3904 | 5.00 | 76.00 | 0.390 | 63.33 | 0.364 | 3 | 0 | 5.0 | EPA 200.8 Rev 5.4 |
| Beryllium, Total (µg/L) | < 1.00 | 0.0055 | 1.00 | < 1.00 | 0.0069 | 1.00 | < 1.00 | 0.0051 | 1.00 | 1.00 | 0.007 | 1.00 | 0.006 | 3 | 3 | 1.0 | EPA 200.8 Rev 5.4 |
| Boron, Total (µg/L) | 200.00 | 1.0992 | 200.00 | < 200.00 | 1.3728 | 200.00 | < 200.00 | 1.0275 | 200.00 | 200.00 | 1.373 | 200.00 | 1.166 | 3 | 2 | 200.0 | EPA 200.7 Rev 4.4 |
| Cadmium, Total (µg/L) | < 0.20 | 0.0011 | 1.00 | < 0.20 | 0.0014 | 1.00 | < 0.20 | 0.0010 | 1.00 | 0.20 | 0.001 | 0.20 | 0.001 | 3 | 3 | 1.0 | EPA 200.8 Rev 5.4 |
| Chromium, Total (µg/L) | < 1.00 | 0.0055 | 1.00 | < 1.00 | 0.0069 | 1.00 | < 1.00 | 0.0051 | 1.00 | 1.00 | 0.007 | 1.00 | 0.006 | 3 | 3 | 1.0 | EPA 200.8 Rev 5.4 |
| Chromium, Hexavalent (µg/L) | < 0.25 | 0.0014 | 0.25 | < 0.10 | 0.0007 | 0.10 | < 0.25 | 0.0013 | 0.25 | 0.25 | 0.001 | 0.20 | 0.001 | 3 | 3 | 0.2 | EPA 218.6 Rev 3.3 |
| Cobalt, Total (µg/L) | 0.40 | 0.0022 | 5.00 | 0.40 | 0.0027 | 5.00 | 0.40 | 0.0021 | 5.00 | 0.40 | 0.003 | 0.40 | 0.002 | 3 | 0 | 5.0 | EPA 200.8 Rev 5.4 |
| Copper, Total (µg/L) | 6.000 | 0.033 | 1.000 | 7.000 | 0.048 | 1.000 | 7.000 | 0.036 | 1.000 | 7.00 | 0.048 | 6.67 | 0.039 | 3 | 0 | 1.0 | EPA 200.8 Rev 5.4 |
| Cyanide, Free (µg/L) | < 1.00 | 0.0055 | 1.00 | < 1.00 | 0.0069 | 1.00 | < 1.00 | 0.0051 | 1.00 | 1.00 | 0.007 | 1.00 | 0.006 | 3 | 3 | 1.0 | Kelada-01 Rev 1.2 |
| Cyanide, Total (µg/L) | < 6.00 | 0.0330 | 10.00 | < 6.00 | 0.0412 | 10.00 | < 6.00 | 0.0308 | 10.00 | 6.00 | 0.041 | 6.00 | 0.035 | 3 | 3 | 10.0 | Kelada-01 Rev 1.2 |
| Iron, Total (µg/L) | 30.00 | 0.1649 | 20.00 | 20.00 | 0.1373 | 20.00 | < 20.00 | 0.1027 | 20.00 | 30.00 | 0.165 | 23.33 | 0.135 | 3 | 1 | 20.0 | EPA 200.7 Rev 4.4 |
| Iron, Dissolved (µg/L) | 20.00 | 0.1099 | 20.00 | < 20.00 | 0.1373 | 20.00 | < 20.00 | 0.1027 | 20.00 | 20.00 | 0.137 | 20.00 | 0.117 | 3 | 2 | 20.0 | EPA 200.7 Rev 4.4 |
| Lead, Total (µg/L) | < 1.000 | 0.005 | 1.000 | < 1.000 | 0.007 | 1.000 | < 1.000 | 0.005 | 1.000 | 1.00 | 0.007 | 1.000 | 0.006 | 3 | 3 | 1.0 | EPA 200.8 Rev 5.4 |
| Manganese, Total (µg/L) | 9.00 | 0.0495 | 1.00 | 10.00 | 0.0686 | 1.00 | 10.00 | 0.0514 | 1.00 | 10.00 | 0.069 | 9.67 | 0.056 | 3 | 0 | 1.0 | EPA 200.8 Rev 5.4 |
| Mercury, Total (µg/L) | < 0.20 | 0.0011 | 0.20 | < 0.20 | 0.0014 | 0.20 | < 0.20 | 0.0010 | 0.20 | 0.20 | 0.001 | 0.20 | 0.001 | 3 | 3 | 0.2 | EPA 245.1 Rev 3.0 |
| Nickel, Total (µg/L) | 3.00 | 0.0165 | 1.00 | 3.10 | 0.0213 | 1.00 | 2.90 | 0.0149 | 1.00 | 3.10 | 0.021 | 3.00 | 0.018 | 3 | 0 | 1.0 | EPA 200.8 Rev 5.4 |
| Phenols, Total (µg/L) | 30.00 | 0.1649 | 2.00 | 178.00 | 1.2218 | 2.00 | 1080.00 | 5.5484 | 20.00 | 1080.00 | 5.548 | 429.33 | 2.312 | 3 | 0 | 8.0 | EPA 625.1 |
| Selenium, Total (µg/L) | 1.00 | 0.0055 | 1.00 | 1.00 | 0.0069 | 1.00 | 1.00 | 0.0051 | 1.00 | 1.00 | 0.007 | 1.00 | 0.006 | 3 | 0 | 1.0 | EPA 200.8 Rev 5.4 |
| Silver, Total (µg/L) | < 0.40 | 0.0022 | 1.00 | < 0.40 | 0.0027 | 1.00 | < 0.40 | 0.0021 | 1.00 | 0.40 | 0.003 | 0.40 | 0.002 | 3 | 3 | 1.0 | EPA 200.8 Rev 5.4 |
| Thallium, Total (µg/L) | < 0.30 | 0.0016 | 3.00 | < 0.30 | 0.0021 | 3.00 | < 0.30 | 0.0015 | 3.00 | 0.30 | 0.002 | 0.30 | 0.002 | 3 | 3 | 3.0 | EPA 200.8 Rev 5.4 |
| Zinc, Total (µg/L) | 37.000 | 0.203 | 5.000 | 30.000 | 0.206 | 5.000 | 35.000 | 0.180 | 5.000 | 37.00 | 0.206 | 34.00 | 0.196 | 3 | 0 | 5.0 | EPA 200.8 Rev 5.4 |
| Molybdenum (µg/L) | 5.00 | 0.0275 | 3.00 | 6.00 | 0.0412 | 3.00 | 6.00 | 0.0308 | 3.00 | 6.00 | 0.041 | 5.67 | 0.033 | 3 | 0 | 3.0 | EPA 200.8 Rev 5.4 |

Mass Loading = Concentration (µg/L) * (1 mg / 1000 µg) * 8.34 * Flow (MGD)



Discharge Information

Instructions Discharge Stream

Facility: Antietam Valley NPDES Permit No.: PA0026646 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: domestic ww

| Discharge Characteristics | | | | | | | | |
|---------------------------|------------------|----------|----------------------------|-----|-----|-----|--------------------------|----------------|
| Design Flow (MGD)* | Hardness (mg/l)* | pH (SU)* | Partial Mix Factors (PMFs) | | | | Complete Mix Times (min) | |
| | | | AFC | CFC | THH | CRL | Q _{T-10} | Q _h |
| 1.225 | 295 | 7 | | | | | | |

| Discharge Pollutant | Units | Max Discharge Conc | 0 if left blank | | 0.5 if left blank | | 0 if left blank | | | 1 if left blank | |
|---------------------------------|-------|--------------------|-----------------|-------------|-------------------|-----------|-----------------|------------|-----|-----------------|-------------|
| | | | Trib Conc | Stream Conc | Daily CV | Hourly CV | Stream CV | Fate Coeff | FOS | Criteria Mod | Chem Transl |
| Group 1 | | | | | | | | | | | |
| Total Dissolved Solids (PWS) | mg/L | 695 | | | | | | | | | |
| Chloride (PWS) | mg/L | 325 | | | | | | | | | |
| Bromide | mg/L | 0.15 | | | | | | | | | |
| Sulfate (PWS) | mg/L | 38.9 | | | | | | | | | |
| Fluoride (PWS) | mg/L | | | | | | | | | | |
| Group 2 | | | | | | | | | | | |
| Total Aluminum | µg/L | 230 | | | | | | | | | |
| Total Antimony | µg/L | 0.4 | | | | | | | | | |
| Total Arsenic | µg/L | < 1 | | | | | | | | | |
| Total Barium | µg/L | 76 | | | | | | | | | |
| Total Beryllium | µg/L | < 1 | | | | | | | | | |
| Total Boron | µg/L | 200 | | | | | | | | | |
| Total Cadmium | µg/L | < 0.2 | | | | | | | | | |
| Total Chromium (III) | µg/L | < 1 | | | | | | | | | |
| Hexavalent Chromium | µg/L | < 0.25 | | | | | | | | | |
| Total Cobalt | µg/L | 0.4 | | | | | | | | | |
| Total Copper | mg/L | 0.007 | | | | | | | | | |
| Free Cyanide | µg/L | < 5 | | | | | | | | | |
| Total Cyanide | µg/L | < 6 | | | | | | | | | |
| Dissolved Iron | µg/L | 20 | | | | | | | | | |
| Total Iron | µg/L | 30 | | | | | | | | | |
| Total Lead | µg/L | 1 | | | | | | | | | |
| Total Manganese | µg/L | 10 | | | | | | | | | |
| Total Mercury | µg/L | < 0.2 | | | | | | | | | |
| Total Nickel | µg/L | 3.1 | | | | | | | | | |
| Total Phenols (Phenolics) (PWS) | µg/L | 1080 | | | | | | | | | |
| Total Selenium | µg/L | 1 | | | | | | | | | |
| Total Silver | µg/L | < 0.4 | | | | | | | | | |
| Total Thallium | µg/L | < 0.3 | | | | | | | | | |
| Total Zinc | mg/L | 0.037 | | | | | | | | | |
| Total Molybdenum | µg/L | 6 | | | | | | | | | |
| Acrolein | µg/L | < 2 | | | | | | | | | |
| Acrylamide | µg/L | < | | | | | | | | | |
| Acrylonitrile | µg/L | < 2 | | | | | | | | | |
| Benzene | µg/L | < 0.5 | | | | | | | | | |
| Bromoform | µg/L | < 0.5 | | | | | | | | | |



Stream / Surface Water Information

Antietam Valley, NPDES Permit No. PA0026646, Outfall 001

Instructions Discharge **Stream**

Receiving Surface Water Name: Antietam Creek

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

| Location | Stream Code* | RMI* | Elevation (ft)* | DA (mi ²)* | Slope (ft/ft) | PWS Withdrawal (MGD) | Apply Fish Criteria* |
|--------------------|--------------|------|-----------------|------------------------|---------------|----------------------|----------------------|
| Point of Discharge | 001790 | 4.7 | 300 | 10 | | | Yes |
| End of Reach 1 | 001790 | 3.57 | 255 | 11.8 | | | Yes |

Q₇₋₁₀

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|-----------|-----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 4.7 | 0.4 | 4 | | | | | | | | | 211 | 7 | | |
| End of Reach 1 | 3.57 | 0.505 | 5.96 | | | | | | | | | | | | |

Q_h

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|----------|----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness | pH | Hardness | pH |
| Point of Discharge | 4.7 | | | | | | | | | | | | | | |
| End of Reach 1 | 3.57 | | | | | | | | | | | | | | |



Model Results

Antietam Valley, NPDES Permit No. PA0026646, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Hydrodynamics

Wasteload Allocations

AFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 0 | 0 | | 0 | 750 | 750 | 2,333 | |
| Total Antimony | 0 | 0 | | 0 | 1,100 | 1,100 | 3,422 | |
| Total Arsenic | 0 | 0 | | 0 | 340 | 340 | 1,058 | Chem Translator of 1 applied |
| Total Barium | 0 | 0 | | 0 | 21,000 | 21,000 | 65,325 | |
| Total Boron | 0 | 0 | | 0 | 8,100 | 8,100 | 25,197 | |
| Total Cadmium | 0 | 0 | | 0 | 4.675 | 5.15 | 16.0 | Chem Translator of 0.908 applied |
| Total Chromium (III) | 0 | 0 | | 0 | 1159.087 | 3.668 | 11,410 | Chem Translator of 0.316 applied |
| Hexavalent Chromium | 0 | 0 | | 0 | 16 | 16.3 | 50.7 | Chem Translator of 0.982 applied |
| Total Cobalt | 0 | 0 | | 0 | 95 | 95.0 | 296 | |
| Total Copper | 0 | 0 | | 0 | 30.422 | 31.7 | 98.6 | Chem Translator of 0.96 applied |
| Free Cyanide | 0 | 0 | | 0 | 22 | 22.0 | 68.4 | |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | 163.650 | 246 | 766 | Chem Translator of 0.665 applied |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | 1.400 | 1.65 | 5.12 | Chem Translator of 0.85 applied |
| Total Nickel | 0 | 0 | | 0 | 975.110 | 977 | 3,039 | Chem Translator of 0.998 applied |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | Chem Translator of 0.922 applied |
| Total Silver | 0 | 0 | | 0 | 14.294 | 16.8 | 52.3 | Chem Translator of 0.85 applied |
| Total Thallium | 0 | 0 | | 0 | 65 | 65.0 | 202 | |
| Total Zinc | 0 | 0 | | 0 | 244.306 | 250 | 777 | Chem Translator of 0.978 applied |
| Acrolein | 0 | 0 | | 0 | 3 | 3.0 | 9.33 | |

| | | | | | | |
|-----------------------------|---|---|---|--------|--------|--------|
| Acrylonitrile | 0 | 0 | 0 | 650 | 650 | 2,022 |
| Benzene | 0 | 0 | 0 | 640 | 640 | 1,991 |
| Bromoform | 0 | 0 | 0 | 1,800 | 1,800 | 5,599 |
| Carbon Tetrachloride | 0 | 0 | 0 | 2,800 | 2,800 | 8,710 |
| Chlorobenzene | 0 | 0 | 0 | 1,200 | 1,200 | 3,733 |
| Chlorodibromomethane | 0 | 0 | 0 | N/A | N/A | N/A |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | 0 | 18,000 | 18,000 | 55,993 |
| Chloroform | 0 | 0 | 0 | 1,900 | 1,900 | 5,910 |
| Dichlorobromomethane | 0 | 0 | 0 | N/A | N/A | N/A |
| 1,2-Dichloroethane | 0 | 0 | 0 | 15,000 | 15,000 | 46,661 |
| 1,1-Dichloroethylene | 0 | 0 | 0 | 7,500 | 7,500 | 23,331 |
| 1,2-Dichloropropane | 0 | 0 | 0 | 11,000 | 11,000 | 34,218 |
| 1,3-Dichloropropylene | 0 | 0 | 0 | 310 | 310 | 964 |
| Ethylbenzene | 0 | 0 | 0 | 2,900 | 2,900 | 9,021 |
| Methyl Bromide | 0 | 0 | 0 | 550 | 550 | 1,711 |
| Methyl Chloride | 0 | 0 | 0 | 28,000 | 28,000 | 87,101 |
| Methylene Chloride | 0 | 0 | 0 | 12,000 | 12,000 | 37,329 |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | 0 | 1,000 | 1,000 | 3,111 |
| Tetrachloroethylene | 0 | 0 | 0 | 700 | 700 | 2,178 |
| Toluene | 0 | 0 | 0 | 1,700 | 1,700 | 5,288 |
| 1,2-trans-Dichloroethylene | 0 | 0 | 0 | 6,800 | 6,800 | 21,153 |
| 1,1,1-Trichloroethane | 0 | 0 | 0 | 3,000 | 3,000 | 9,332 |
| 1,1,2-Trichloroethane | 0 | 0 | 0 | 3,400 | 3,400 | 10,576 |
| Trichloroethylene | 0 | 0 | 0 | 2,300 | 2,300 | 7,155 |
| Vinyl Chloride | 0 | 0 | 0 | N/A | N/A | N/A |
| 2-Chlorophenol | 0 | 0 | 0 | 560 | 560 | 1,742 |
| 2,4-Dichlorophenol | 0 | 0 | 0 | 1,700 | 1,700 | 5,288 |
| 2,4-Dimethylphenol | 0 | 0 | 0 | 660 | 660 | 2,053 |
| 4,6-Dinitro-o-Cresol | 0 | 0 | 0 | 80 | 80.0 | 249 |
| 2,4-Dinitrophenol | 0 | 0 | 0 | 660 | 660 | 2,053 |
| 2-Nitrophenol | 0 | 0 | 0 | 8,000 | 8,000 | 24,886 |
| 4-Nitrophenol | 0 | 0 | 0 | 2,300 | 2,300 | 7,155 |
| p-Chloro-m-Cresol | 0 | 0 | 0 | 160 | 160 | 498 |
| Pentachlorophenol | 0 | 0 | 0 | 8.723 | 8.72 | 27.1 |
| Phenol | 0 | 0 | 0 | N/A | N/A | N/A |
| 2,4,6-Trichlorophenol | 0 | 0 | 0 | 460 | 460 | 1,431 |
| Acenaphthene | 0 | 0 | 0 | 83 | 83.0 | 258 |
| Anthracene | 0 | 0 | 0 | N/A | N/A | N/A |
| Benzidine | 0 | 0 | 0 | 300 | 300 | 933 |
| Benzo(a)Anthracene | 0 | 0 | 0 | 0.5 | 0.5 | 1.56 |
| Benzo(a)Pyrene | 0 | 0 | 0 | N/A | N/A | N/A |
| 3,4-Benzofluoranthene | 0 | 0 | 0 | N/A | N/A | N/A |
| Benzo(k)Fluoranthene | 0 | 0 | 0 | N/A | N/A | N/A |
| Bis(2-Chloroethyl)Ether | 0 | 0 | 0 | 30,000 | 30,000 | 93,322 |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | 0 | N/A | N/A | N/A |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | 0 | 4,500 | 4,500 | 13,998 |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | 0 | 270 | 270 | 840 |
| Butyl Benzyl Phthalate | 0 | 0 | 0 | 140 | 140 | 436 |

| | | | | | | | |
|---------------------------|---|---|---|--------|--------|--------|--|
| 2-Chloronaphthalene | 0 | 0 | 0 | N/A | N/A | N/A | |
| Chrysene | 0 | 0 | 0 | N/A | N/A | N/A | |
| Dibenzo(a,h)Anthracene | 0 | 0 | 0 | N/A | N/A | N/A | |
| 1,2-Dichlorobenzene | 0 | 0 | 0 | 820 | 820 | 2,551 | |
| 1,3-Dichlorobenzene | 0 | 0 | 0 | 350 | 350 | 1,089 | |
| 1,4-Dichlorobenzene | 0 | 0 | 0 | 730 | 730 | 2,271 | |
| 3,3-Dichlorobenzidine | 0 | 0 | 0 | N/A | N/A | N/A | |
| Diethyl Phthalate | 0 | 0 | 0 | 4,000 | 4,000 | 12,443 | |
| Dimethyl Phthalate | 0 | 0 | 0 | 2,500 | 2,500 | 7,777 | |
| Di-n-Butyl Phthalate | 0 | 0 | 0 | 110 | 110 | 342 | |
| 2,4-Dinitrotoluene | 0 | 0 | 0 | 1,600 | 1,600 | 4,977 | |
| 2,6-Dinitrotoluene | 0 | 0 | 0 | 990 | 990 | 3,080 | |
| 1,2-Diphenylhydrazine | 0 | 0 | 0 | 15 | 15.0 | 46.7 | |
| Fluoranthene | 0 | 0 | 0 | 200 | 200 | 622 | |
| Fluorene | 0 | 0 | 0 | N/A | N/A | N/A | |
| Hexachlorobenzene | 0 | 0 | 0 | N/A | N/A | N/A | |
| Hexachlorobutadiene | 0 | 0 | 0 | 10 | 10.0 | 31.1 | |
| Hexachlorocyclopentadiene | 0 | 0 | 0 | 5 | 5.0 | 15.6 | |
| Hexachloroethane | 0 | 0 | 0 | 60 | 60.0 | 187 | |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | 0 | N/A | N/A | N/A | |
| Isophorone | 0 | 0 | 0 | 10,000 | 10,000 | 31,107 | |
| Naphthalene | 0 | 0 | 0 | 140 | 140 | 436 | |
| Nitrobenzene | 0 | 0 | 0 | 4,000 | 4,000 | 12,443 | |
| n-Nitrosodimethylamine | 0 | 0 | 0 | 17,000 | 17,000 | 52,882 | |
| n-Nitrosodi-n-Propylamine | 0 | 0 | 0 | N/A | N/A | N/A | |
| n-Nitrosodiphenylamine | 0 | 0 | 0 | 300 | 300 | 933 | |
| Phenanthrene | 0 | 0 | 0 | 5 | 5.0 | 15.6 | |
| Pyrene | 0 | 0 | 0 | N/A | N/A | N/A | |
| 1,2,4-Trichlorobenzene | 0 | 0 | 0 | 130 | 130 | 404 | |

CFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trnb Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | 0 | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | 0 | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | 0 | 0 | N/A | N/A | N/A | |
| Total Aluminum | 0 | 0 | 0 | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | 0 | 0 | 220 | 220 | 684 | |
| Total Arsenic | 0 | 0 | 0 | 0 | 150 | 150 | 467 | Chem Translator of 1 applied |
| Total Barium | 0 | 0 | 0 | 0 | 4,100 | 4,100 | 12,754 | |
| Total Boron | 0 | 0 | 0 | 0 | 1,600 | 1,600 | 4,977 | |
| Total Cadmium | 0 | 0 | 0 | 0 | 0.449 | 0.51 | 1.6 | Chem Translator of 0.873 applied |
| Total Chromium (III) | 0 | 0 | 0 | 0 | 150.773 | 175 | 545 | Chem Translator of 0.86 applied |
| Hexavalent Chromium | 0 | 0 | 0 | 0 | 10 | 10.4 | 32.3 | Chem Translator of 0.962 applied |
| Total Cobalt | 0 | 0 | 0 | 0 | 19 | 19.0 | 59.1 | |
| Total Copper | 0 | 0 | 0 | 0 | 18.789 | 19.6 | 60.9 | Chem Translator of 0.96 applied |

| | | | | | | | |
|---------------------------------|---|---|---|---------|-------|--------|----------------------------------|
| Free Cyanide | 0 | 0 | 0 | 5.2 | 5.2 | 16.2 | |
| Dissolved Iron | 0 | 0 | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | 0 | 1,500 | 1,500 | 4,666 | WQC = 30 day average; PMF = 1 |
| Total Lead | 0 | 0 | 0 | 6.377 | 9.59 | 29.8 | Chem Translator of 0.665 applied |
| Total Manganese | 0 | 0 | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | 0 | 0.770 | 0.91 | 2.82 | Chem Translator of 0.85 applied |
| Total Nickel | 0 | 0 | 0 | 108.305 | 109 | 338 | Chem Translator of 0.997 applied |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | 0 | 4.600 | 4.99 | 15.5 | Chem Translator of 0.922 applied |
| Total Silver | 0 | 0 | 0 | N/A | N/A | N/A | Chem Translator of 1 applied |
| Total Thallium | 0 | 0 | 0 | 13 | 13.0 | 40.4 | |
| Total Zinc | 0 | 0 | 0 | 246.304 | 250 | 777 | Chem Translator of 0.986 applied |
| Acrolein | 0 | 0 | 0 | 3 | 3.0 | 9.33 | |
| Acrylonitrile | 0 | 0 | 0 | 130 | 130 | 404 | |
| Benzene | 0 | 0 | 0 | 130 | 130 | 404 | |
| Bromoform | 0 | 0 | 0 | 370 | 370 | 1,151 | |
| Carbon Tetrachloride | 0 | 0 | 0 | 560 | 560 | 1,742 | |
| Chlorobenzene | 0 | 0 | 0 | 240 | 240 | 747 | |
| Chlorodibromomethane | 0 | 0 | 0 | N/A | N/A | N/A | |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | 0 | 3,500 | 3,500 | 10,888 | |
| Chloroform | 0 | 0 | 0 | 390 | 390 | 1,213 | |
| Dichlorobromomethane | 0 | 0 | 0 | N/A | N/A | N/A | |
| 1,2-Dichloroethane | 0 | 0 | 0 | 3,100 | 3,100 | 9,643 | |
| 1,1-Dichloroethylene | 0 | 0 | 0 | 1,500 | 1,500 | 4,666 | |
| 1,2-Dichloropropane | 0 | 0 | 0 | 2,200 | 2,200 | 6,844 | |
| 1,3-Dichloropropylene | 0 | 0 | 0 | 61 | 61.0 | 190 | |
| Ethylbenzene | 0 | 0 | 0 | 580 | 580 | 1,804 | |
| Methyl Bromide | 0 | 0 | 0 | 110 | 110 | 342 | |
| Methyl Chloride | 0 | 0 | 0 | 5,500 | 5,500 | 17,109 | |
| Methylene Chloride | 0 | 0 | 0 | 2,400 | 2,400 | 7,466 | |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | 0 | 210 | 210 | 653 | |
| Tetrachloroethylene | 0 | 0 | 0 | 140 | 140 | 436 | |
| Toluene | 0 | 0 | 0 | 330 | 330 | 1,027 | |
| 1,2-trans-Dichloroethylene | 0 | 0 | 0 | 1,400 | 1,400 | 4,355 | |
| 1,1,1-Trichloroethane | 0 | 0 | 0 | 610 | 610 | 1,898 | |
| 1,1,2-Trichloroethane | 0 | 0 | 0 | 680 | 680 | 2,115 | |
| Trichloroethylene | 0 | 0 | 0 | 450 | 450 | 1,400 | |
| Vinyl Chloride | 0 | 0 | 0 | N/A | N/A | N/A | |
| 2-Chlorophenol | 0 | 0 | 0 | 110 | 110 | 342 | |
| 2,4-Dichlorophenol | 0 | 0 | 0 | 340 | 340 | 1,058 | |
| 2,4-Dimethylphenol | 0 | 0 | 0 | 130 | 130 | 404 | |
| 4,6-Dinitro-o-Cresol | 0 | 0 | 0 | 16 | 16.0 | 49.8 | |
| 2,4-Dinitrophenol | 0 | 0 | 0 | 130 | 130 | 404 | |
| 2-Nitrophenol | 0 | 0 | 0 | 1,600 | 1,600 | 4,977 | |
| 4-Nitrophenol | 0 | 0 | 0 | 470 | 470 | 1,462 | |

| | | | | | | |
|-----------------------------|---|---|---|-------|-------|--------|
| p-Chloro-m-Cresol | 0 | 0 | 0 | 500 | 500 | 1,555 |
| Pentachlorophenol | 0 | 0 | 0 | 6.693 | 6.69 | 20.8 |
| Phenol | 0 | 0 | 0 | N/A | N/A | N/A |
| 2,4,6-Trichlorophenol | 0 | 0 | 0 | 91 | 91.0 | 283 |
| Acenaphthene | 0 | 0 | 0 | 17 | 17.0 | 52.9 |
| Anthracene | 0 | 0 | 0 | N/A | N/A | N/A |
| Benzidine | 0 | 0 | 0 | 59 | 59.0 | 184 |
| Benzo(a)Anthracene | 0 | 0 | 0 | 0.1 | 0.1 | 0.31 |
| Benzo(a)Pyrene | 0 | 0 | 0 | N/A | N/A | N/A |
| 3,4-Benzofluoranthene | 0 | 0 | 0 | N/A | N/A | N/A |
| Benzo(k)Fluoranthene | 0 | 0 | 0 | N/A | N/A | N/A |
| Bis(2-Chloroethyl)Ether | 0 | 0 | 0 | 6,000 | 6,000 | 18,664 |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | 0 | N/A | N/A | N/A |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | 0 | 910 | 910 | 2,831 |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | 0 | 54 | 54.0 | 168 |
| Butyl Benzyl Phthalate | 0 | 0 | 0 | 35 | 35.0 | 109 |
| 2-Chloronaphthalene | 0 | 0 | 0 | N/A | N/A | N/A |
| Chrysene | 0 | 0 | 0 | N/A | N/A | N/A |
| Dibenzo(a,h)Anthracene | 0 | 0 | 0 | N/A | N/A | N/A |
| 1,2-Dichlorobenzene | 0 | 0 | 0 | 160 | 160 | 498 |
| 1,3-Dichlorobenzene | 0 | 0 | 0 | 69 | 69.0 | 215 |
| 1,4-Dichlorobenzene | 0 | 0 | 0 | 150 | 150 | 467 |
| 3,3-Dichlorobenzidine | 0 | 0 | 0 | N/A | N/A | N/A |
| Diethyl Phthalate | 0 | 0 | 0 | 800 | 800 | 2,489 |
| Dimethyl Phthalate | 0 | 0 | 0 | 500 | 500 | 1,555 |
| Di-n-Butyl Phthalate | 0 | 0 | 0 | 21 | 21.0 | 65.3 |
| 2,4-Dinitrotoluene | 0 | 0 | 0 | 320 | 320 | 995 |
| 2,6-Dinitrotoluene | 0 | 0 | 0 | 200 | 200 | 622 |
| 1,2-Diphenylhydrazine | 0 | 0 | 0 | 3 | 3.0 | 9.33 |
| Fluoranthene | 0 | 0 | 0 | 40 | 40.0 | 124 |
| Fluorene | 0 | 0 | 0 | N/A | N/A | N/A |
| Hexachlorobenzene | 0 | 0 | 0 | N/A | N/A | N/A |
| Hexachlorobutadiene | 0 | 0 | 0 | 2 | 2.0 | 6.22 |
| Hexachlorocyclopentadiene | 0 | 0 | 0 | 1 | 1.0 | 3.11 |
| Hexachloroethane | 0 | 0 | 0 | 12 | 12.0 | 37.3 |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | 0 | N/A | N/A | N/A |
| Isophorone | 0 | 0 | 0 | 2,100 | 2,100 | 6,533 |
| Naphthalene | 0 | 0 | 0 | 43 | 43.0 | 134 |
| Nitrobenzene | 0 | 0 | 0 | 810 | 810 | 2,520 |
| n-Nitrosodimethylamine | 0 | 0 | 0 | 3,400 | 3,400 | 10,576 |
| n-Nitrosodi-n-Propylamine | 0 | 0 | 0 | N/A | N/A | N/A |
| n-Nitrosodiphenylamine | 0 | 0 | 0 | 59 | 59.0 | 184 |
| Phenanthrene | 0 | 0 | 0 | 1 | 1.0 | 3.11 |
| Pyrene | 0 | 0 | 0 | N/A | N/A | N/A |
| 1,2,4-Trichlorobenzene | 0 | 0 | 0 | 26 | 26.0 | 80.9 |

THH

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | 500,000 | 500,000 | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | 5.6 | 5.6 | 17.4 | |
| Total Arsenic | 0 | 0 | | 0 | 10 | 10.0 | 31.1 | |
| Total Barium | 0 | 0 | | 0 | 2,400 | 2,400 | 7,466 | |
| Total Boron | 0 | 0 | | 0 | 3,100 | 3,100 | 9,643 | |
| Total Cadmium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Chromium (III) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexavalent Chromium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cobalt | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Free Cyanide | 0 | 0 | | 0 | 4 | 4.0 | 12.4 | |
| Dissolved Iron | 0 | 0 | | 0 | 300 | 300 | 933 | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Manganese | 0 | 0 | | 0 | 1,000 | 1,000 | 3,111 | |
| Total Mercury | 0 | 0 | | 0 | 0.050 | 0.05 | 0.16 | |
| Total Nickel | 0 | 0 | | 0 | 610 | 610 | 1,898 | |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | 5 | 5.0 | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Thallium | 0 | 0 | | 0 | 0.24 | 0.24 | 0.75 | |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Acrolein | 0 | 0 | | 0 | 3 | 3.0 | 9.33 | |
| Acrylonitrile | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Benzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Bromoform | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Carbon Tetrachloride | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chlorobenzene | 0 | 0 | | 0 | 100 | 100.0 | 311 | |
| Chlorodibromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloroform | 0 | 0 | | 0 | 5.7 | 5.7 | 17.7 | |
| Dichlorobromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichloroethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,1-Dichloroethylene | 0 | 0 | | 0 | 33 | 33.0 | 103 | |
| 1,2-Dichloropropane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,3-Dichloropropylene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Ethylbenzene | 0 | 0 | | 0 | 68 | 68.0 | 212 | |

| | | | | | | | |
|-----------------------------|---|---|--|---|--------|--------|--------|
| Methyl Bromide | 0 | 0 | | 0 | 100 | 100.0 | 311 |
| Methyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| Methylene Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| Tetrachloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Toluene | 0 | 0 | | 0 | 57 | 57.0 | 177 |
| 1,2-trans-Dichloroethylene | 0 | 0 | | 0 | 100 | 100.0 | 311 |
| 1,1,1-Trichloroethane | 0 | 0 | | 0 | 10,000 | 10,000 | 31,107 |
| 1,1,2-Trichloroethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| Trichloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Vinyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2-Chlorophenol | 0 | 0 | | 0 | 30 | 30.0 | 93.3 |
| 2,4-Dichlorophenol | 0 | 0 | | 0 | 10 | 10.0 | 31.1 |
| 2,4-Dimethylphenol | 0 | 0 | | 0 | 100 | 100.0 | 311 |
| 4,6-Dinitro-o-Cresol | 0 | 0 | | 0 | 2 | 2.0 | 6.22 |
| 2,4-Dinitrophenol | 0 | 0 | | 0 | 10 | 10.0 | 31.1 |
| 2-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 4-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| p-Chloro-m-Cresol | 0 | 0 | | 0 | N/A | N/A | N/A |
| Pentachlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| Phenol | 0 | 0 | | 0 | 4,000 | 4,000 | 12,443 |
| 2,4,6-Trichlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| Acenaphthene | 0 | 0 | | 0 | 70 | 70.0 | 218 |
| Anthracene | 0 | 0 | | 0 | 300 | 300 | 933 |
| Benzidine | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(a)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(a)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 3,4-Benzofluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(k)Fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Chloroethyl)Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | | 0 | 200 | 200 | 622 |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Butyl Benzyl Phthalate | 0 | 0 | | 0 | 0.1 | 0.1 | 0.31 |
| 2-Chloronaphthalene | 0 | 0 | | 0 | 800 | 800 | 2,489 |
| Chrysene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Dibenzo(a,h)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2-Dichlorobenzene | 0 | 0 | | 0 | 1,000 | 1,000 | 3,111 |
| 1,3-Dichlorobenzene | 0 | 0 | | 0 | 7 | 7.0 | 21.8 |
| 1,4-Dichlorobenzene | 0 | 0 | | 0 | 300 | 300 | 933 |
| 3,3-Dichlorobenzidine | 0 | 0 | | 0 | N/A | N/A | N/A |
| Diethyl Phthalate | 0 | 0 | | 0 | 600 | 600 | 1,866 |
| Dimethyl Phthalate | 0 | 0 | | 0 | 2,000 | 2,000 | 6,221 |
| Di-n-Butyl Phthalate | 0 | 0 | | 0 | 20 | 20.0 | 62.2 |
| 2,4-Dinitrotoluene | 0 | 0 | | 0 | N/A | N/A | N/A |

| | | | | | | |
|---------------------------|---|---|---|------|------|------|
| 2,6-Dinitrotoluene | 0 | 0 | 0 | N/A | N/A | N/A |
| 1,2-Diphenylhydrazine | 0 | 0 | 0 | N/A | N/A | N/A |
| Fluoranthene | 0 | 0 | 0 | 20 | 20.0 | 62.2 |
| Fluorene | 0 | 0 | 0 | 50 | 50.0 | 156 |
| Hexachlorobenzene | 0 | 0 | 0 | N/A | N/A | N/A |
| Hexachlorobutadiene | 0 | 0 | 0 | N/A | N/A | N/A |
| Hexachlorocyclopentadiene | 0 | 0 | 0 | 4 | 4.0 | 12.4 |
| Hexachloroethane | 0 | 0 | 0 | N/A | N/A | N/A |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | 0 | N/A | N/A | N/A |
| Isophorone | 0 | 0 | 0 | 34 | 34.0 | 106 |
| Naphthalene | 0 | 0 | 0 | N/A | N/A | N/A |
| Nitrobenzene | 0 | 0 | 0 | 10 | 10.0 | 31.1 |
| n-Nitrosodimethylamine | 0 | 0 | 0 | N/A | N/A | N/A |
| n-Nitrosodi-n-Propylamine | 0 | 0 | 0 | N/A | N/A | N/A |
| n-Nitrosodiphenylamine | 0 | 0 | 0 | N/A | N/A | N/A |
| Phenanthrene | 0 | 0 | 0 | N/A | N/A | N/A |
| Pyrene | 0 | 0 | 0 | 20 | 20.0 | 62.2 |
| 1,2,4-Trichlorobenzene | 0 | 0 | 0 | 0.07 | 0.07 | 0.22 |

CRL CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Arsenic | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Barium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Boron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cadmium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Chromium (III) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexavalent Chromium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cobalt | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Free Cyanide | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Nickel | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | |

| | | | | | | |
|----------------------------|---|---|---|--------|--------|-------|
| Total Silver | 0 | 0 | 0 | N/A | N/A | N/A |
| Total Thallium | 0 | 0 | 0 | N/A | N/A | N/A |
| Total Zinc | 0 | 0 | 0 | N/A | N/A | N/A |
| Acrolein | 0 | 0 | 0 | N/A | N/A | N/A |
| Acrylonitrile | 0 | 0 | 0 | 0.06 | 0.06 | 0.85 |
| Benzene | 0 | 0 | 0 | 0.58 | 0.58 | 8.22 |
| Bromoform | 0 | 0 | 0 | 7 | 7.0 | 99.2 |
| Carbon Tetrachloride | 0 | 0 | 0 | 0.4 | 0.4 | 5.67 |
| Chlorobenzene | 0 | 0 | 0 | N/A | N/A | N/A |
| Chlorodibromomethane | 0 | 0 | 0 | 0.8 | 0.8 | 11.3 |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | 0 | N/A | N/A | N/A |
| Chloroform | 0 | 0 | 0 | N/A | N/A | N/A |
| Dichlorobromomethane | 0 | 0 | 0 | 0.95 | 0.95 | 13.5 |
| 1,2-Dichloroethane | 0 | 0 | 0 | 9.9 | 9.9 | 140 |
| 1,1-Dichloroethylene | 0 | 0 | 0 | N/A | N/A | N/A |
| 1,2-Dichloropropane | 0 | 0 | 0 | 0.9 | 0.9 | 12.8 |
| 1,3-Dichloropropylene | 0 | 0 | 0 | 0.27 | 0.27 | 3.83 |
| Ethylbenzene | 0 | 0 | 0 | N/A | N/A | N/A |
| Methyl Bromide | 0 | 0 | 0 | N/A | N/A | N/A |
| Methyl Chloride | 0 | 0 | 0 | N/A | N/A | N/A |
| Methylene Chloride | 0 | 0 | 0 | 20 | 20.0 | 283 |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | 0 | 0.2 | 0.2 | 2.83 |
| Tetrachloroethylene | 0 | 0 | 0 | 10 | 10.0 | 142 |
| Toluene | 0 | 0 | 0 | N/A | N/A | N/A |
| 1,2-trans-Dichloroethylene | 0 | 0 | 0 | N/A | N/A | N/A |
| 1,1,1-Trichloroethane | 0 | 0 | 0 | N/A | N/A | N/A |
| 1,1,2-Trichloroethane | 0 | 0 | 0 | 0.55 | 0.55 | 7.79 |
| Trichloroethylene | 0 | 0 | 0 | 0.6 | 0.6 | 8.5 |
| Vinyl Chloride | 0 | 0 | 0 | 0.02 | 0.02 | 0.28 |
| 2-Chlorophenol | 0 | 0 | 0 | N/A | N/A | N/A |
| 2,4-Dichlorophenol | 0 | 0 | 0 | N/A | N/A | N/A |
| 2,4-Dimethylphenol | 0 | 0 | 0 | N/A | N/A | N/A |
| 4,6-Dinitro-o-Cresol | 0 | 0 | 0 | N/A | N/A | N/A |
| 2,4-Dinitrophenol | 0 | 0 | 0 | N/A | N/A | N/A |
| 2-Nitrophenol | 0 | 0 | 0 | N/A | N/A | N/A |
| 4-Nitrophenol | 0 | 0 | 0 | N/A | N/A | N/A |
| p-Chloro-m-Cresol | 0 | 0 | 0 | N/A | N/A | N/A |
| Pentachlorophenol | 0 | 0 | 0 | 0.030 | 0.03 | 0.43 |
| Phenol | 0 | 0 | 0 | N/A | N/A | N/A |
| 2,4,6-Trichlorophenol | 0 | 0 | 0 | 1.5 | 1.5 | 21.3 |
| Acenaphthene | 0 | 0 | 0 | N/A | N/A | N/A |
| Anthracene | 0 | 0 | 0 | N/A | N/A | N/A |
| Benzidine | 0 | 0 | 0 | 0.0001 | 0.0001 | 0.001 |
| Benzo(a)Anthracene | 0 | 0 | 0 | 0.001 | 0.001 | 0.014 |
| Benzo(a)Pyrene | 0 | 0 | 0 | 0.0001 | 0.0001 | 0.001 |

| | | | | | | |
|-----------------------------|---|---|---|---------|---------|-------|
| 3,4-Benzofluoranthene | 0 | 0 | 0 | 0.001 | 0.001 | 0.014 |
| Benzo(k)Fluoranthene | 0 | 0 | 0 | 0.01 | 0.01 | 0.14 |
| Bis(2-Chloroethyl)Ether | 0 | 0 | 0 | 0.03 | 0.03 | 0.43 |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | 0 | N/A | N/A | N/A |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | 0 | 0.32 | 0.32 | 4.53 |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | 0 | N/A | N/A | N/A |
| Butyl Benzyl Phthalate | 0 | 0 | 0 | N/A | N/A | N/A |
| 2-Chloronaphthalene | 0 | 0 | 0 | N/A | N/A | N/A |
| Chrysene | 0 | 0 | 0 | 0.12 | 0.12 | 1.7 |
| Dibenzo(a,h)Anthracene | 0 | 0 | 0 | 0.0001 | 0.0001 | 0.001 |
| 1,2-Dichlorobenzene | 0 | 0 | 0 | N/A | N/A | N/A |
| 1,3-Dichlorobenzene | 0 | 0 | 0 | N/A | N/A | N/A |
| 1,4-Dichlorobenzene | 0 | 0 | 0 | N/A | N/A | N/A |
| 3,3-Dichlorobenzidine | 0 | 0 | 0 | 0.05 | 0.05 | 0.71 |
| Diethyl Phthalate | 0 | 0 | 0 | N/A | N/A | N/A |
| Dimethyl Phthalate | 0 | 0 | 0 | N/A | N/A | N/A |
| Di-n-Butyl Phthalate | 0 | 0 | 0 | N/A | N/A | N/A |
| 2,4-Dinitrotoluene | 0 | 0 | 0 | 0.05 | 0.05 | 0.71 |
| 2,6-Dinitrotoluene | 0 | 0 | 0 | 0.05 | 0.05 | 0.71 |
| 1,2-Diphenylhydrazine | 0 | 0 | 0 | 0.03 | 0.03 | 0.43 |
| Fluoranthene | 0 | 0 | 0 | N/A | N/A | N/A |
| Fluorene | 0 | 0 | 0 | N/A | N/A | N/A |
| Hexachlorobenzene | 0 | 0 | 0 | 0.00008 | 0.00008 | 0.001 |
| Hexachlorobutadiene | 0 | 0 | 0 | 0.01 | 0.01 | 0.14 |
| Hexachlorocyclopentadiene | 0 | 0 | 0 | N/A | N/A | N/A |
| Hexachloroethane | 0 | 0 | 0 | 0.1 | 0.1 | 1.42 |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | 0 | 0.001 | 0.001 | 0.014 |
| Isophorone | 0 | 0 | 0 | N/A | N/A | N/A |
| Naphthalene | 0 | 0 | 0 | N/A | N/A | N/A |
| Nitrobenzene | 0 | 0 | 0 | N/A | N/A | N/A |
| n-Nitrosodimethylamine | 0 | 0 | 0 | 0.0007 | 0.0007 | 0.01 |
| n-Nitrosodi-n-Propylamine | 0 | 0 | 0 | 0.005 | 0.005 | 0.071 |
| n-Nitrosodiphenylamine | 0 | 0 | 0 | 3.3 | 3.3 | 46.8 |
| Phenanthrene | 0 | 0 | 0 | N/A | N/A | N/A |
| Pyrene | 0 | 0 | 0 | N/A | N/A | N/A |
| 1,2,4-Trichlorobenzene | 0 | 0 | 0 | N/A | N/A | N/A |

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|----------------|---------------|---------------|----------------------|--------|--------|-------|-----------------|-------------|------------------------------------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| Total Aluminum | Report | Report | Report | Report | Report | µg/L | 1,495 | AFC | Discharge Conc > 10% WQBEL (no RP) |

| Pollutants | Mass Limits | | Concentration Limits | | | Units | Governing WQBEL | WQBEL Basis | Comments |
|----------------|------------------|------------------|----------------------|--------|--------|-------|--------------------|----------------|------------------------------------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | | | | |
| Total Aluminum | Report | Report | Report | Report | Report | µg/L | 1,495 | AFC | Discharge Conc > 10% WQBEL (no RP) |

Model Results

1/21/2026

Page 14

| | | | | | | | | | |
|--------------|--------|--------|--------|--------|--------|------|-------|-----|------------------------------------|
| Total Copper | Report | Report | Report | Report | Report | mg/L | 0.061 | CFC | Discharge Conc > 10% WQBEL (no RP) |
| Free Cyanide | Report | Report | Report | Report | Report | µg/L | 12.4 | THH | Discharge Conc > 25% WQBEL (no RP) |

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

| Pollutants | Governing WQBEL | Units | Comments |
|---------------------------------|--------------------|-------|----------------------------|
| Total Dissolved Solids (PWS) | N/A | N/A | PWS Not Applicable |
| Chloride (PWS) | N/A | N/A | PWS Not Applicable |
| Bromide | N/A | N/A | No WQS |
| Sulfate (PWS) | N/A | N/A | PWS Not Applicable |
| Total Antimony | 17.4 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Arsenic | N/A | N/A | Discharge Conc < TQL |
| Total Barium | 7,466 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Beryllium | N/A | N/A | No WQS |
| Total Boron | 4,977 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Cadmium | 1.6 | µg/L | Discharge Conc < TQL |
| Total Chromium (III) | 545 | µg/L | Discharge Conc < TQL |
| Hexavalent Chromium | 32.3 | µg/L | Discharge Conc < TQL |
| Total Cobalt | 59.1 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Cyanide | N/A | N/A | No WQS |
| Dissolved Iron | 933 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Iron | 4,666 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Lead | 29.8 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Manganese | 3,111 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Mercury | 0.16 | µg/L | Discharge Conc < TQL |
| Total Nickel | 338 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Phenols (Phenolics) (PWS) | | µg/L | PWS Not Applicable |
| Total Selenium | 15.5 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Silver | 33.5 | µg/L | Discharge Conc < TQL |
| Total Thallium | 0.75 | µg/L | Discharge Conc < TQL |
| Total Zinc | 0.5 | mg/L | Discharge Conc ≤ 10% WQBEL |
| Total Molybdenum | N/A | N/A | No WQS |
| Acrolein | 5.98 | µg/L | Discharge Conc < TQL |
| Acrylonitrile | 0.85 | µg/L | Discharge Conc < TQL |
| Benzene | 8.22 | µg/L | Discharge Conc < TQL |
| Bromoform | 99.2 | µg/L | Discharge Conc < TQL |
| Carbon Tetrachloride | 5.67 | µg/L | Discharge Conc < TQL |
| Chlorobenzene | 311 | µg/L | Discharge Conc < TQL |
| Chlorodibromomethane | 11.3 | µg/L | Discharge Conc < TQL |
| Chloroethane | N/A | N/A | No WQS |
| 2-Chloroethyl Vinyl Ether | 10,888 | µg/L | Discharge Conc < TQL |
| Chloroform | 17.7 | µg/L | Discharge Conc < TQL |

Model Results

1/21/2026

Page 15

| | | | |
|-----------------------------|--------|------|----------------------------|
| Dichlorobromomethane | 13.5 | µg/L | Discharge Conc < TQL |
| 1,1-Dichloroethane | N/A | N/A | No WQS |
| 1,2-Dichloroethane | 140 | µg/L | Discharge Conc < TQL |
| 1,1-Dichloroethylene | 103 | µg/L | Discharge Conc < TQL |
| 1,2-Dichloropropane | 12.8 | µg/L | Discharge Conc < TQL |
| 1,3-Dichloropropylene | 3.83 | µg/L | Discharge Conc < TQL |
| 1,4-Dioxane | N/A | N/A | No WQS |
| Ethylbenzene | 212 | µg/L | Discharge Conc < TQL |
| Methyl Bromide | 311 | µg/L | Discharge Conc < TQL |
| Methyl Chloride | 17,109 | µg/L | Discharge Conc < TQL |
| Methylene Chloride | 283 | µg/L | Discharge Conc < TQL |
| 1,1,2,2-Tetrachloroethane | 2.83 | µg/L | Discharge Conc < TQL |
| Tetrachloroethylene | 142 | µg/L | Discharge Conc < TQL |
| Toluene | 177 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,2-trans-Dichloroethylene | 311 | µg/L | Discharge Conc < TQL |
| 1,1,1-Trichloroethane | 1,898 | µg/L | Discharge Conc < TQL |
| 1,1,2-Trichloroethane | 7.79 | µg/L | Discharge Conc < TQL |
| Trichloroethylene | 8.5 | µg/L | Discharge Conc < TQL |
| Vinyl Chloride | 0.28 | µg/L | Discharge Conc < TQL |
| 2-Chlorophenol | 93.3 | µg/L | Discharge Conc < TQL |
| 2,4-Dichlorophenol | 31.1 | µg/L | Discharge Conc < TQL |
| 2,4-Dimethylphenol | 311 | µg/L | Discharge Conc < TQL |
| 4,6-Dinitro-o-Cresol | 6.22 | µg/L | Discharge Conc < TQL |
| 2,4-Dinitrophenol | 31.1 | µg/L | Discharge Conc < TQL |
| 2-Nitrophenol | 4,977 | µg/L | Discharge Conc < TQL |
| 4-Nitrophenol | 1,462 | µg/L | Discharge Conc < TQL |
| p-Chloro-m-Cresol | 319 | µg/L | Discharge Conc < TQL |
| Pentachlorophenol | 0.43 | µg/L | Discharge Conc < TQL |
| Phenol | 12,443 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 2,4,6-Trichlorophenol | 21.3 | µg/L | Discharge Conc < TQL |
| Acenaphthene | 52.9 | µg/L | Discharge Conc < TQL |
| Acenaphthylene | N/A | N/A | No WQS |
| Anthracene | 933 | µg/L | Discharge Conc < TQL |
| Benzidine | 0.001 | µg/L | Discharge Conc < TQL |
| Benzo(a)Anthracene | 0.014 | µg/L | Discharge Conc < TQL |
| Benzo(a)Pyrene | 0.001 | µg/L | Discharge Conc < TQL |
| 3,4-Benzofluoranthene | 0.014 | µg/L | Discharge Conc < TQL |
| Benzo(ghi)Perylene | N/A | N/A | No WQS |
| Benzo(k)Fluoranthene | 0.14 | µg/L | Discharge Conc < TQL |
| Bis(2-Chloroethoxy)Methane | N/A | N/A | No WQS |
| Bis(2-Chloroethyl)Ether | 0.43 | µg/L | Discharge Conc < TQL |
| Bis(2-Chloroisopropyl)Ether | 622 | µg/L | Discharge Conc < TQL |
| Bis(2-Ethylhexyl)Phthalate | 4.53 | µg/L | Discharge Conc < TQL |
| 4-Bromophenyl Phenyl Ether | 168 | µg/L | Discharge Conc < TQL |
| Butyl Benzyl Phthalate | 0.31 | µg/L | Discharge Conc < TQL |

| | | | |
|-----------------------------|-------|------|----------------------------|
| 2-Chloronaphthalene | 2,489 | µg/L | Discharge Conc < TQL |
| 4-Chlorophenyl Phenyl Ether | N/A | N/A | No WQS |
| Chrysene | 1.7 | µg/L | Discharge Conc < TQL |
| Dibenzo(a,h)Anthracene | 0.001 | µg/L | Discharge Conc < TQL |
| 1,2-Dichlorobenzene | 498 | µg/L | Discharge Conc < TQL |
| 1,3-Dichlorobenzene | 21.8 | µg/L | Discharge Conc < TQL |
| 1,4-Dichlorobenzene | 467 | µg/L | Discharge Conc < TQL |
| 3,3-Dichlorobenzidine | 0.71 | µg/L | Discharge Conc < TQL |
| Diethyl Phthalate | 1,866 | µg/L | Discharge Conc < TQL |
| Dimethyl Phthalate | 1,555 | µg/L | Discharge Conc < TQL |
| Di-n-Butyl Phthalate | 62.2 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 2,4-Dinitrotoluene | 0.71 | µg/L | Discharge Conc < TQL |
| 2,6-Dinitrotoluene | 0.71 | µg/L | Discharge Conc < TQL |
| Di-n-Octyl Phthalate | N/A | N/A | No WQS |
| 1,2-Diphenylhydrazine | 0.43 | µg/L | Discharge Conc < TQL |
| Fluoranthene | 62.2 | µg/L | Discharge Conc < TQL |
| Fluorene | 156 | µg/L | Discharge Conc < TQL |
| Hexachlorobenzene | 0.001 | µg/L | Discharge Conc < TQL |
| Hexachlorobutadiene | 0.14 | µg/L | Discharge Conc < TQL |
| Hexachlorocyclopentadiene | 3.11 | µg/L | Discharge Conc < TQL |
| Hexachloroethane | 1.42 | µg/L | Discharge Conc < TQL |
| Indeno(1,2,3-cd)Pyrene | 0.014 | µg/L | Discharge Conc < TQL |
| Isophorone | 106 | µg/L | Discharge Conc < TQL |
| Naphthalene | 134 | µg/L | Discharge Conc < TQL |
| Nitrobenzene | 31.1 | µg/L | Discharge Conc < TQL |
| n-Nitrosodimethylamine | 0.01 | µg/L | Discharge Conc < TQL |
| n-Nitrosodi-n-Propylamine | 0.071 | µg/L | Discharge Conc < TQL |
| n-Nitrosodiphenylamine | 46.8 | µg/L | Discharge Conc < TQL |
| Phenanthrene | 3.11 | µg/L | Discharge Conc < TQL |
| Pyrene | 62.2 | µg/L | Discharge Conc < TQL |
| 1,2,4-Trichlorobenzene | 0.22 | µg/L | Discharge Conc < TQL |
| | | | |

| DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet | | | | | |
|--|------------|-----------------|----------------------|---------|-------|
| Type of Test | Chronic | Facility Name | | | |
| Species Tested | Pimephales | Antietam Valley | | | |
| Endpoint | Survival | Permit No. | | | |
| TIWC (decimal) | 0.32 | | | | |
| No. Per Replicate | 10 | | | | |
| TST b value | 0.75 | | | | |
| TST alpha value | 0.25 | | | | |
| Test Completion Date | | | Test Completion Date | | |
| 8/27/2024 | | | 3/25/2025 | | |
| Replicate No. | Control | TIWC | Replicate No. | Control | TIWC |
| 1 | 1 | 1 | 1 | 1 | 0.9 |
| 2 | 1 | 0.9 | 2 | 0.9 | 0.9 |
| 3 | 0.9 | 1 | 3 | 1 | 0.4 |
| 4 | 1 | 1 | 4 | 1 | 0.2 |
| 5 | | | 5 | | |
| 6 | | | 6 | | |
| 7 | | | 7 | | |
| 8 | | | 8 | | |
| 9 | | | 9 | | |
| 10 | | | 10 | | |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |
| Mean | 0.975 | 0.975 | Mean | 0.975 | 0.600 |
| Std Dev. | 0.050 | 0.050 | Std Dev. | 0.050 | 0.356 |
| # Replicates | 4 | 4 | # Replicates | 4 | 4 |
| T-Test Result | 14.8898 | | T-Test Result | 0.0011 | |
| Deg. of Freedom | 5 | | Deg. of Freedom | 3 | |
| Critical T Value | 0.7267 | | Critical T Value | 0.7649 | |
| Pass or Fail | PASS | | Pass or Fail | FAIL | |
| Test Completion Date | | | Test Completion Date | | |
| 4/29/2025 | | | | | |
| Replicate No. | Control | TIWC | Replicate No. | Control | TIWC |
| 1 | 0.8 | 1 | 1 | | |
| 2 | 0.9 | 0.9 | 2 | | |
| 3 | 1 | 1 | 3 | | |
| 4 | 0.7 | 1 | 4 | | |
| 5 | | | 5 | | |
| 6 | | | 6 | | |
| 7 | | | 7 | | |
| 8 | | | 8 | | |
| 9 | | | 9 | | |
| 10 | | | 10 | | |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |
| Mean | 0.850 | 0.975 | Mean | | |
| Std Dev. | 0.129 | 0.050 | Std Dev. | | |
| # Replicates | 4 | 4 | # Replicates | | |
| T-Test Result | 9.9031 | | T-Test Result | | |
| Deg. of Freedom | 5 | | Deg. of Freedom | | |
| Critical T Value | 0.7267 | | Critical T Value | | |
| Pass or Fail | PASS | | Pass or Fail | | |

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

| | |
|-------------------|------------|
| Type of Test | Chronic |
| Species Tested | Pimephales |
| Endpoint | Growth |
| TIWC (decimal) | 0.32 |
| No. Per Replicate | 10 |
| TST b value | 0.75 |
| TST alpha value | 0.25 |

| | |
|---------------|-----------------|
| Facility Name | Antietam Valley |
|---------------|-----------------|

| | |
|------------|--|
| Permit No. | |
|------------|--|

| Test Completion Date | | |
|----------------------|-----------|-------|
| Replicate | 8/27/2024 | |
| No. | Control | TIWC |
| 1 | 0.276 | 0.229 |
| 2 | 0.308 | 0.245 |
| 3 | 0.246 | 0.265 |
| 4 | 0.266 | 0.27 |
| 5 | | |
| 6 | | |
| 7 | | |
| 8 | | |
| 9 | | |
| 10 | | |
| 11 | | |
| 12 | | |
| 13 | | |
| 14 | | |
| 15 | | |

| | | |
|--------------|-------|-------|
| Mean | 0.274 | 0.252 |
| Std Dev. | 0.026 | 0.019 |
| # Replicates | 4 | 4 |

| | |
|------------------|-------------|
| T-Test Result | 3.4415 |
| Deg. of Freedom | 5 |
| Critical T Value | 0.7267 |
| Pass or Fail | PASS |

| Test Completion Date | | |
|----------------------|-----------|-------|
| Replicate | 3/25/2025 | |
| No. | Control | TIWC |
| 1 | 0.297 | 0.265 |
| 2 | 0.339 | 0.342 |
| 3 | 0.297 | 0.09 |
| 4 | 0.293 | 0.224 |
| 5 | | |
| 6 | | |
| 7 | | |
| 8 | | |
| 9 | | |
| 10 | | |
| 11 | | |
| 12 | | |
| 13 | | |
| 14 | | |
| 15 | | |

| | | |
|--------------|-------|-------|
| Mean | 0.307 | 0.230 |
| Std Dev. | 0.022 | 0.106 |
| # Replicates | 4 | 4 |

| | |
|------------------|-------------|
| T-Test Result | 0.0070 |
| Deg. of Freedom | 3 |
| Critical T Value | 0.7649 |
| Pass or Fail | FAIL |

| Test Completion Date | | |
|----------------------|-----------|-------|
| Replicate | 4/29/2025 | |
| No. | Control | TIWC |
| 1 | 0.449 | 0.542 |
| 2 | 0.483 | 0.472 |
| 3 | 0.432 | 0.507 |
| 4 | 0.371 | 0.452 |
| 5 | | |
| 6 | | |
| 7 | | |
| 8 | | |
| 9 | | |
| 10 | | |
| 11 | | |
| 12 | | |
| 13 | | |
| 14 | | |
| 15 | | |

| | | |
|--------------|-------|-------|
| Mean | 0.434 | 0.493 |
| Std Dev. | 0.047 | 0.040 |
| # Replicates | 4 | 4 |

| | |
|------------------|-------------|
| T-Test Result | 6.3359 |
| Deg. of Freedom | 5 |
| Critical T Value | 0.7267 |
| Pass or Fail | PASS |

| Test Completion Date | | |
|----------------------|---------|------|
| Replicate | | |
| No. | Control | TIWC |
| 1 | | |
| 2 | | |
| 3 | | |
| 4 | | |
| 5 | | |
| 6 | | |
| 7 | | |
| 8 | | |
| 9 | | |
| 10 | | |
| 11 | | |
| 12 | | |
| 13 | | |
| 14 | | |
| 15 | | |

| | | |
|--------------|--|--|
| Mean | | |
| Std Dev. | | |
| # Replicates | | |

| | |
|------------------|--|
| T-Test Result | |
| Deg. of Freedom | |
| Critical T Value | |
| Pass or Fail | |

| DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet | | | | | |
|--|--------------|-------|-----------------------------------|---------|-------|
| Type of Test | Chronic | | Facility Name | | |
| Species Tested | Ceriodaphnia | | Connellsville Municipal Authority | | |
| Endpoint | Survival | | Permit No. | | |
| TIWC (decimal) | 0.32 | | | | |
| No. Per Replicate | 1 | | | | |
| TST b value | 0.75 | | | | |
| TST alpha value | 0.2 | | | | |
| Test Completion Date | | | Test Completion Date | | |
| 8/27/2024 | | | 3/24/2025 | | |
| Replicate No. | Control | TIWC | Replicate No. | Control | TIWC |
| 1 | 1 | 1 | 1 | 1 | 1 |
| 2 | 1 | 1 | 2 | 1 | 1 |
| 3 | 1 | 1 | 3 | 1 | 1 |
| 4 | 0 | 1 | 4 | 1 | 1 |
| 5 | 1 | 1 | 5 | 1 | 1 |
| 6 | 1 | 1 | 6 | 1 | 1 |
| 7 | 1 | 1 | 7 | 1 | 1 |
| 8 | 0 | 0 | 8 | 1 | 1 |
| 9 | 1 | 1 | 9 | 1 | 1 |
| 10 | 1 | 1 | 10 | 1 | 1 |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |
| Mean | 0.800 | 0.900 | Mean | 1.000 | 1.000 |
| Std Dev. | 0.422 | 0.316 | Std Dev. | 0.000 | 0.000 |
| # Replicates | 10 | 10 | # Replicates | 10 | 10 |
| T-Test Result | | | T-Test Result | | |
| Deg. of Freedom | | | Deg. of Freedom | | |
| Critical T Value | | | Critical T Value | | |
| Pass or Fail | PASS | | Pass or Fail | PASS | |

| DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet | | | | | |
|--|--------------|--------|-----------------------------------|---------|--------|
| Type of Test | Chronic | | Facility Name | | |
| Species Tested | Ceriodaphnia | | Connellsville Municipal Authority | | |
| Endpoint | Reproduction | | Permit No. | | |
| TIWC (decimal) | 0.32 | | | | |
| No. Per Replicate | 1 | | | | |
| TST b value | 0.75 | | | | |
| TST alpha value | 0.2 | | | | |
| Test Completion Date | | | Test Completion Date | | |
| 8/27/2024 | | | 3/24/2025 | | |
| Replicate No. | Control | TIWC | Replicate No. | Control | TIWC |
| 1 | 24 | 24 | 1 | 43 | 28 |
| 2 | 21 | 6 | 2 | 36 | 38 |
| 3 | 23 | 21 | 3 | 35 | 40 |
| 4 | 19 | 20 | 4 | 36 | 34 |
| 5 | 22 | 24 | 5 | 37 | 23 |
| 6 | 24 | 22 | 6 | 35 | 18 |
| 7 | 15 | 30 | 7 | 36 | 16 |
| 8 | 13 | 3 | 8 | 31 | 37 |
| 9 | 21 | 19 | 9 | 38 | 36 |
| 10 | 27 | 27 | 10 | 37 | 36 |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |
| Mean | 20.900 | 19.600 | Mean | 36.400 | 30.600 |
| Std Dev. | 4.264 | 8.631 | Std Dev. | 2.989 | 8.758 |
| # Replicates | 10 | 10 | # Replicates | 10 | 10 |
| T-Test Result | 1.3489 | | T-Test Result | 1.1543 | |
| Deg. of Freedom | 13 | | Deg. of Freedom | 12 | |
| Critical T Value | 0.8702 | | Critical T Value | 0.8726 | |
| Pass or Fail | PASS | | Pass or Fail | PASS | |

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

| | | |
|-------------------|------------|-----------------|
| Type of Test | Chronic | Facility Name |
| Species Tested | Pimephales | Antietam Valley |
| Endpoint | Survival | Permit No. |
| TIWC (decimal) | 0.32 | PA0026646 |
| No. Per Replicate | 10 | |
| TST b value | 0.75 | |
| TST alpha value | 0.25 | |

| Test Completion Date | | | Test Completion Date | | |
|----------------------|------------|------|----------------------|---------|------|
| Replicate | 12/10/2024 | | Replicate | | |
| No. | Control | TIWC | No. | Control | TIWC |
| 1 | 10 | 10 | 1 | | |
| 2 | 10 | 10 | 2 | | |
| 3 | 10 | 10 | 3 | | |
| 4 | 10 | 9 | 4 | | |
| 5 | | | 5 | | |
| 6 | | | 6 | | |
| 7 | | | 7 | | |
| 8 | | | 8 | | |
| 9 | | | 9 | | |
| 10 | | | 10 | | |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |

| | | | | | |
|--------------|--------|-------|--------------|-------|-------|
| Mean | 10.000 | 9.750 | Mean | 0.000 | 0.000 |
| Std Dev. | 0.000 | 0.500 | Std Dev. | | |
| # Replicates | 4 | 4 | # Replicates | | |

| | | | |
|------------------|--------|------------------|--|
| T-Test Result | 7.6643 | T-Test Result | |
| Deg. of Freedom | 3 | Deg. of Freedom | |
| Critical T Value | 0.7649 | Critical T Value | |
| Pass or Fail | PASS | Pass or Fail | |

| Test Completion Date | | | Test Completion Date | | |
|----------------------|---------|------|----------------------|---------|------|
| Replicate | | | Replicate | | |
| No. | Control | TIWC | No. | Control | TIWC |
| 1 | | | 1 | | |
| 2 | | | 2 | | |
| 3 | | | 3 | | |
| 4 | | | 4 | | |
| 5 | | | 5 | | |
| 6 | | | 6 | | |
| 7 | | | 7 | | |
| 8 | | | 8 | | |
| 9 | | | 9 | | |
| 10 | | | 10 | | |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |

| | | | | | |
|--------------|-------|-------|--------------|--|--|
| Mean | 0.000 | 0.000 | Mean | | |
| Std Dev. | | | Std Dev. | | |
| # Replicates | | | # Replicates | | |

| | | | |
|------------------|--|------------------|--|
| T-Test Result | | T-Test Result | |
| Deg. of Freedom | | Deg. of Freedom | |
| Critical T Value | | Critical T Value | |
| Pass or Fail | | Pass or Fail | |

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

Type of Test: Chronic
 Species Tested: Pimephales
 Endpoint: Growth
 TIWC (decimal): 0.32
 No. Per Replicate: 10
 TST b value: 0.75
 TST alpha value: 0.25

Facility Name: Antietam Valley
 Permit No.: PA0026646

Test Completion Date: 12/10/2024

| Replicate No. | Control | TIWC |
|---------------|---------|-------|
| 1 | 0.323 | 0.341 |
| 2 | 0.316 | 0.318 |
| 3 | 0.366 | 0.355 |
| 4 | 0.33 | 0.276 |
| 5 | | |
| 6 | | |
| 7 | | |
| 8 | | |
| 9 | | |
| 10 | | |
| 11 | | |
| 12 | | |
| 13 | | |
| 14 | | |
| 15 | | |

Mean: 0.334 0.323
 Std Dev.: 0.022 0.035
 # Replicates: 4 4

T-Test Result: 3.7630
 Deg. of Freedom: 4
 Critical T Value: 0.7407
 Pass or Fail: **PASS**

Test Completion Date:

| Replicate No. | Control | TIWC |
|---------------|---------|------|
| 1 | | |
| 2 | | |
| 3 | | |
| 4 | | |
| 5 | | |
| 6 | | |
| 7 | | |
| 8 | | |
| 9 | | |
| 10 | | |
| 11 | | |
| 12 | | |
| 13 | | |
| 14 | | |
| 15 | | |

Mean: 0.000 0.000
 Std Dev.:
 # Replicates:

T-Test Result:
 Deg. of Freedom:
 Critical T Value:
 Pass or Fail:

Test Completion Date:

| Replicate No. | Control | TIWC |
|---------------|---------|------|
| 1 | | |
| 2 | | |
| 3 | | |
| 4 | | |
| 5 | | |
| 6 | | |
| 7 | | |
| 8 | | |
| 9 | | |
| 10 | | |
| 11 | | |
| 12 | | |
| 13 | | |
| 14 | | |
| 15 | | |

Mean: 0.000 0.000
 Std Dev.:
 # Replicates:

T-Test Result:
 Deg. of Freedom:
 Critical T Value:
 Pass or Fail:

Test Completion Date:

| Replicate No. | Control | TIWC |
|---------------|---------|------|
| 1 | | |
| 2 | | |
| 3 | | |
| 4 | | |
| 5 | | |
| 6 | | |
| 7 | | |
| 8 | | |
| 9 | | |
| 10 | | |
| 11 | | |
| 12 | | |
| 13 | | |
| 14 | | |
| 15 | | |

Mean:
 Std Dev.:
 # Replicates:

T-Test Result:
 Deg. of Freedom:
 Critical T Value:
 Pass or Fail:

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

| | | |
|-------------------|--------------|-----------------|
| Type of Test | Chronic | Facility Name |
| Species Tested | Ceriodaphnia | Antietam Valley |
| Endpoint | Survival | |
| TIWC (decimal) | 0.32 | |
| No. Per Replicate | 1 | Permit No. |
| TST b value | 0.75 | PA0026646 |
| TST alpha value | 0.2 | |

| Test Completion Date | | | Test Completion Date | | |
|----------------------|------------|------|----------------------|---------|------|
| Replicate | 12/10/2024 | | Replicate | | |
| No. | Control | TIWC | No. | Control | TIWC |
| 1 | 1 | 1 | 1 | | |
| 2 | 1 | 1 | 2 | | |
| 3 | 1 | 1 | 3 | | |
| 4 | 1 | 1 | 4 | | |
| 5 | 1 | 1 | 5 | | |
| 6 | 1 | 1 | 6 | | |
| 7 | 1 | 1 | 7 | | |
| 8 | 1 | 1 | 8 | | |
| 9 | 1 | 1 | 9 | | |
| 10 | 1 | 1 | 10 | | |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |

| | | | | | |
|--------------|-------|-------|--------------|-------|-------|
| Mean | 1.000 | 1.000 | Mean | 0.000 | 0.000 |
| Std Dev. | 0.000 | 0.000 | Std Dev. | | |
| # Replicates | 10 | 10 | # Replicates | | |

| | | |
|------------------|-------------|------------------|
| T-Test Result | | T-Test Result |
| Deg. of Freedom | | Deg. of Freedom |
| Critical T Value | | Critical T Value |
| Pass or Fail | PASS | Pass or Fail |

| Test Completion Date | | | Test Completion Date | | |
|----------------------|---------|------|----------------------|---------|------|
| Replicate | | | Replicate | | |
| No. | Control | TIWC | No. | Control | TIWC |
| 1 | | | 1 | | |
| 2 | | | 2 | | |
| 3 | | | 3 | | |
| 4 | | | 4 | | |
| 5 | | | 5 | | |
| 6 | | | 6 | | |
| 7 | | | 7 | | |
| 8 | | | 8 | | |
| 9 | | | 9 | | |
| 10 | | | 10 | | |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |

| | | | | | |
|--------------|-------|-------|--------------|--|--|
| Mean | 0.000 | 0.000 | Mean | | |
| Std Dev. | | | Std Dev. | | |
| # Replicates | | | # Replicates | | |

| | | |
|------------------|--|------------------|
| T-Test Result | | T-Test Result |
| Deg. of Freedom | | Deg. of Freedom |
| Critical T Value | | Critical T Value |
| Pass or Fail | | Pass or Fail |

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

| | | |
|-------------------|--------------|-----------------|
| Type of Test | Chronic | Facility Name |
| Species Tested | Ceriodaphnia | Antietam Valley |
| Endpoint | Reproduction | Permit No. |
| TIWC (decimal) | 0.32 | PA0026646 |
| No. Per Replicate | 1 | |
| TST b value | 0.75 | |
| TST alpha value | 0.2 | |

| Test Completion Date | | | Test Completion Date | | |
|----------------------|------------|------|----------------------|---------|------|
| Replicate | 12/10/2024 | | Replicate | | |
| No. | Control | TIWC | No. | Control | TIWC |
| 1 | 48 | 42 | 1 | | |
| 2 | 38 | 44 | 2 | | |
| 3 | 38 | 41 | 3 | | |
| 4 | 41 | 37 | 4 | | |
| 5 | 38 | 40 | 5 | | |
| 6 | 44 | 42 | 6 | | |
| 7 | 37 | 36 | 7 | | |
| 8 | 39 | 43 | 8 | | |
| 9 | 39 | 43 | 9 | | |
| 10 | 38 | 37 | 10 | | |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |

| | | | | | |
|--------------|--------|--------|--------------|-------|-------|
| Mean | 40.000 | 40.500 | Mean | 0.000 | 0.000 |
| Std Dev. | 3.464 | 2.877 | Std Dev. | | |
| # Replicates | 10 | 10 | # Replicates | | |

| | | | |
|------------------|--------|------------------|--|
| T-Test Result | 8.5653 | T-Test Result | |
| Deg. of Freedom | 17 | Deg. of Freedom | |
| Critical T Value | 0.8633 | Critical T Value | |
| Pass or Fail | PASS | Pass or Fail | |

| Test Completion Date | | | Test Completion Date | | |
|----------------------|---------|------|----------------------|---------|------|
| Replicate | | | Replicate | | |
| No. | Control | TIWC | No. | Control | TIWC |
| 1 | | | 1 | | |
| 2 | | | 2 | | |
| 3 | | | 3 | | |
| 4 | | | 4 | | |
| 5 | | | 5 | | |
| 6 | | | 6 | | |
| 7 | | | 7 | | |
| 8 | | | 8 | | |
| 9 | | | 9 | | |
| 10 | | | 10 | | |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |

| | | | | | |
|--------------|-------|-------|--------------|--|--|
| Mean | 0.000 | 0.000 | Mean | | |
| Std Dev. | | | Std Dev. | | |
| # Replicates | | | # Replicates | | |

| | | | |
|------------------|--|------------------|--|
| T-Test Result | | T-Test Result | |
| Deg. of Freedom | | Deg. of Freedom | |
| Critical T Value | | Critical T Value | |
| Pass or Fail | | Pass or Fail | |

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

| | | |
|-------------------|------------|-----------------|
| Type of Test | Chronic | Facility Name |
| Species Tested | Pimephales | Antietam Valley |
| Endpoint | Survival | Permit No. |
| TIWC (decimal) | 0.32 | PA0026646 |
| No. Per Replicate | 10 | |
| TST b value | 0.75 | |
| TST alpha value | 0.25 | |

| Replicate No. | Test Completion Date | | Replicate No. | Test Completion Date | |
|---------------|----------------------|------|---------------|----------------------|------|
| | Control | TIWC | | Control | TIWC |
| | 12/15/2020 | | | 12/15/2020 | |
| 1 | 10 | 10 | 1 | | |
| 2 | 10 | 10 | 2 | | |
| 3 | 10 | 10 | 3 | | |
| 4 | 10 | 10 | 4 | | |
| 5 | | | 5 | | |
| 6 | | | 6 | | |
| 7 | | | 7 | | |
| 8 | | | 8 | | |
| 9 | | | 9 | | |
| 10 | | | 10 | | |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |

| | | | | | |
|--------------|--------|--------|--------------|-------|-------|
| Mean | 10.000 | 10.000 | Mean | 0.000 | 0.000 |
| Std Dev. | 0.000 | 0.000 | Std Dev. | | |
| # Replicates | 4 | 4 | # Replicates | | |

| | | | | | |
|------------------|------|--|------------------|--|--|
| T-Test Result | | | T-Test Result | | |
| Deg. of Freedom | | | Deg. of Freedom | | |
| Critical T Value | | | Critical T Value | | |
| Pass or Fail | PASS | | Pass or Fail | | |

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

| | | |
|-------------------|------------|-----------------|
| Type of Test | Chronic | Facility Name |
| Species Tested | Pimephales | Antietam Valley |
| Endpoint | Growth | Permit No. |
| TIWC (decimal) | 0.32 | PA0026646 |
| No. Per Replicate | 10 | |
| TST b value | 0.75 | |
| TST alpha value | 0.25 | |

| Replicate No. | Test Completion Date | | Replicate No. | Test Completion Date | |
|---------------|----------------------|-------|---------------|----------------------|------|
| | Control | TIWC | | Control | TIWC |
| | 12/15/2020 | | | 12/15/2020 | |
| 1 | 0.332 | 0.409 | 1 | | |
| 2 | 0.427 | 0.389 | 2 | | |
| 3 | 0.365 | 0.448 | 3 | | |
| 4 | 0.398 | 0.453 | 4 | | |
| 5 | | | 5 | | |
| 6 | | | 6 | | |
| 7 | | | 7 | | |
| 8 | | | 8 | | |
| 9 | | | 9 | | |
| 10 | | | 10 | | |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |

| | | | | | |
|--------------|-------|-------|--------------|-------|-------|
| Mean | 0.381 | 0.427 | Mean | 0.000 | 0.000 |
| Std Dev. | 0.041 | 0.034 | Std Dev. | | |
| # Replicates | 4 | 4 | # Replicates | | |

| | | | | | |
|------------------|--------|--|------------------|--|--|
| T-Test Result | 6.1667 | | T-Test Result | | |
| Deg. of Freedom | 5 | | Deg. of Freedom | | |
| Critical T Value | 0.7267 | | Critical T Value | | |
| Pass or Fail | PASS | | Pass or Fail | | |

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

| | | |
|--------------------------|--------------|----------------------|
| Type of Test | Chronic | Facility Name |
| Species Tested | Ceriodaphnia | Antietam Valley |
| Endpoint | Survival | |
| TIWC (decimal) | 0.32 | Permit No. |
| No. Per Replicate | 1 | PA0026646 |
| TST b value | 0.75 | |
| TST alpha value | 0.2 | |

| Replicate No. | Test Completion Date | | Replicate No. | Test Completion Date | |
|---------------|----------------------|------|---------------|----------------------|------|
| | Control | TIWC | | Control | TIWC |
| | 12/14/2020 | | | | |
| 1 | 1 | 1 | 1 | | |
| 2 | 1 | 1 | 2 | | |
| 3 | 1 | 1 | 3 | | |
| 4 | 1 | 1 | 4 | | |
| 5 | 1 | 1 | 5 | | |
| 6 | 1 | 1 | 6 | | |
| 7 | 1 | 1 | 7 | | |
| 8 | 1 | 1 | 8 | | |
| 9 | 1 | 1 | 9 | | |
| 10 | 1 | 1 | 10 | | |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |

| | | | | | |
|--------------|-------|-------|--------------|-------|-------|
| Mean | 1.000 | 1.000 | Mean | 0.000 | 0.000 |
| Std Dev. | 0.000 | 0.000 | Std Dev. | | |
| # Replicates | 10 | 10 | # Replicates | | |

| | | | | | |
|------------------|------|--|------------------|--|--|
| T-Test Result | | | T-Test Result | | |
| Deg. of Freedom | | | Deg. of Freedom | | |
| Critical T Value | | | Critical T Value | | |
| Pass or Fail | PASS | | Pass or Fail | | |

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

| | | |
|--------------------------|--------------|----------------------|
| Type of Test | Chronic | Facility Name |
| Species Tested | Ceriodaphnia | Antietam Valley |
| Endpoint | Reproduction | |
| TIWC (decimal) | 0.32 | Permit No. |
| No. Per Replicate | 1 | PA0026646 |
| TST b value | 0.75 | |
| TST alpha value | 0.2 | |

| Replicate No. | Test Completion Date | | Replicate No. | Test Completion Date | |
|---------------|----------------------|------|---------------|----------------------|------|
| | Control | TIWC | | Control | TIWC |
| | 12/14/2020 | | | | |
| 1 | 36 | 42 | 1 | | |
| 2 | 40 | 37 | 2 | | |
| 3 | 34 | 42 | 3 | | |
| 4 | 44 | 26 | 4 | | |
| 5 | 24 | 18 | 5 | | |
| 6 | 20 | 34 | 6 | | |
| 7 | 30 | 29 | 7 | | |
| 8 | 30 | 28 | 8 | | |
| 9 | 31 | 36 | 9 | | |
| 10 | 16 | 28 | 10 | | |
| 11 | | | 11 | | |
| 12 | | | 12 | | |
| 13 | | | 13 | | |
| 14 | | | 14 | | |
| 15 | | | 15 | | |

| | | | | | |
|--------------|--------|--------|--------------|-------|-------|
| Mean | 30.500 | 32.200 | Mean | 0.000 | 0.000 |
| Std Dev. | 8.683 | 7.729 | Std Dev. | | |
| # Replicates | 10 | 10 | # Replicates | | |

| | | | | | |
|------------------|--------|--|------------------|--|--|
| T-Test Result | 2.9178 | | T-Test Result | | |
| Deg. of Freedom | 17 | | Deg. of Freedom | | |
| Critical T Value | 0.8633 | | Critical T Value | | |
| Pass or Fail | PASS | | Pass or Fail | | |

NPDES Permit Fact Sheet Antietam Valley STP

NPDES Permit No. PA0026646

○ Hales, Dana <Hales.Dana@epa.gov>
To ● Boylan, Bonnie; ○ Moncavage, Carissa; ○ Sanchez Gonzalez, Natalie
📌 You replied to this message on 5/30/2025 1:39 PM.

😊 Reply Reply All Forward ...
Fri 5/30/2025 1:19 PM

ATTENTION: This email message is from an external sender. Do not open links or attachments from unknown senders. To report suspicious email, use the [Report Phishing button in Outlook](#).

Hi Bonnie,

I'm so sorry, thank for bugging me. I was supposed to finish my response to you this week, and I just got sidetracked. I do appreciate you reaching out with the question. Natalie and I spoke about this last week and think that while a 4th WET test (from July 2025) would be ideal, I'm not sure it's necessary here. I think the fact sheet could acknowledge what occurred and explain why PADEP is accepting the available WET tests, with some reassurance in the fact sheet that with the reissued permit the testing frequency would be corrected.

One thing that would be useful in the fact sheet is to also explain why quarterly testing was required in the last permit. Quarterly testing can be required for a few reasons, but if it's because there was RP for WET and a WET limit was imposed in the permit, the fact sheet of course would need to address any removal of that limit in this draft permit.

With regards to the "consecutive" testing comment: 40 CFR 122.21(j)(5)(iv)(A) requires, as one option, that permit applications contain a minimum of four quarterly tests for a year (from the year preceding the permit application), so the regulation doesn't say consecutive quarters but four quarterly tests for a year I think implies consecutive.

Thanks,
Dana

Dana Hales
U.S. Environmental Protection Agency
Water Division, Clean Water Branch
Permits Section
Four Penn Center (Mail Code 3WD41)
1600 John F Kennedy Blvd
Philadelphia, PA 19103-2852

From: Boylan, Bonnie <bboylan@pa.gov>
Sent: Friday, May 30, 2025 12:50 PM
To: Moncavage, Carissa <Moncavage.Carissa@epa.gov>; Sanchez Gonzalez, Natalie <sanchez-gonzalez.natalie@epa.gov>; Hales, Dana <Hales.Dana@epa.gov>
Subject: FW: Major POTW with WET testing requirement

I've received no responses to below email. I was hoping to avoid a situation where I sent a draft permit to you with 4 WET test results and you objected to the dates or frequency of the WET tests. At this time, I have results of the POTW's "most recent" WET tests: 1st Qtr 2020, 2nd Qtr 2020, 3rd Qtr 2020, 4th Qtr 2020, then a break where no tests conducted followed by 3rd Qtr 2024, 4th Qtr 2024, 1st Qtr 2025. They are passing, indicating no Reasonable Potential for toxicity. Would EPA find these tests acceptable or would EPA ask for another quarterly WET test in 2025 for determining RP?

From: Boylan, Bonnie
Sent: Tuesday, May 20, 2025 11:55 AM
To: Moncavage, Carissa (she/her/hers) <moncavage.carissa@epa.gov>; sanchez-gonzalez.natalie@epa.gov; Hales, Dana <Hales.Dana@epa.gov>
Subject: Major POTW with WET testing requirement

Hello. Can I get your input, please? You will eventually be reviewing the draft renewal permit and Fact Sheet for this facility, a major POTW. Their permit includes a condition that they must conduct WET tests quarterly until they have 4 passing quarterly tests after which the testing frequency can be reduced to annually. They conducted 4 consecutive quarterly WET tests in 2020 which were passing and would have allowed reduced frequency to annual testing, but then they neglected to conduct any WET tests subsequent to December 2020. DEP's application instructions say to attach the four most recent WET test results. Their 2024 renewal application included the four 2020 WET test results.

The permit does not say '4 consecutive quarters' nor do the federal regulations specify 'consecutive'.

They cannot go back in time and get annual WET tests for 2021, 2022, 2023, and 2024. So should I require 4 consecutive quarterly tests so that I have 4 recent WET test results to base the renewal on? Or can I use the 4th Qtr 2020 quarterly test result and the three WET tests they conducted in 3rd Qtr 2024, 4th Qtr 2024, and 1st Qtr 2025 after I sent them an application incomplete letter?

If you say we should require 4 consecutive quarterly tests and not use the 2020 test results, can they conduct their next WET test in July 2025 as they have proposed instead of the 2nd Qtr of 2025 (April, May, June)?

Thank you.

Bonnie J. Boylan | Permits Section
Department of Environmental Protection | Clean Water Program
Southcentral Region
909 Elmerton Avenue | Harrisburg, PA 17110

