

Application Type Renewal  
 Facility Type Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0027081  
 APS ID 827529  
 Authorization ID 1353511

**Applicant and Facility Information**

Applicant Name	<u>Lackawanna River Basin Sewer Authority</u>	Facility Name	<u>LRBSA Clinton Township WWTP</u>
Applicant Address	<u>PO Box 280 Olyphant, PA 18447-0280</u>	Facility Address	<u>1100 Main Street Browndale Clinton Township, PA 18421</u>
Applicant Contact	<u>Mike Matechak, Executive Director</u>	Facility Contact	<u>Glenn Butler, Plant Operator</u>
Applicant Phone	<u>(570) 489-7563</u>	Facility Phone	<u>(570) 785-5671</u>
Client ID	<u>90054</u>	Site ID	<u>262689</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Clinton Township</u>
Connection Status	<u>-</u>	County	<u>Wayne</u>
Date Application Received	<u>May 7, 2021</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>May 20, 2021</u>	If No, Reason	<u>Significant CB Discharge</u>
Purpose of Application	<u>Renewal of NPDES permit for discharge of treated sewage.</u>		

**Summary of Review**

The applicant is requesting the renewal of an NPDES permit to discharge up to 0.7 MGD of treated sewage into the Lackawanna River, High Quality, Cold-Water Fishery, Migratory Fish (HQ-CWF, MF) receiving stream in State Water Plan Basin 5-A (Lackawanna River). As per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than its designated use. This stream segment is designated as a naturally reproducing trout stream as per PA Fish & Boat Commission. This discharge is not expected to affect public water supplies.

Limitations for pH, Dissolved Oxygen (DO), CBOD<sub>5</sub>, Total Suspended Solids (TSS), and Fecal Coliform are technology-based and carried over from the previous permit.

Limitations for Ammonia-Nitrogen are water quality-based and carried over from the previous permit. WQM 7.0 modeling did not recommend stricter limits.

Wintertime monitoring and reporting was added for Ammonia-Nitrogen (Nov 1 – Feb 28). The previous permit already required the monitoring for Chesapeake Bay reporting.

Per current Standard Operating Procedures for Publicly Owned Treatment Plants, the raw sewage influent monitoring/reporting for TSS and BOD<sub>5</sub> has been maintained in the permit.

The Total Residual Chlorine (TRC) Calculation Spreadsheet recommends stricter limitations than the previous permit. The permittee will be required to meet the new technology quality-based limits for TRC starting three years after the effective date of the permit (see Part C.III.). TRC limitations from the previously issued permit are in effect for the first three years after the permit effective date.

Approve	Deny	Signatures	Date
X		/s/ Allison Seyfried Zukosky / Project Manager	June 3, 2025
X		/s/ Edward Dudick, P.E. / Environmental Engineer Manager	June 3, 2025

### Summary of Review

Sewage discharges now require monitoring and reporting for E. Coli. A monitoring frequency of 1/month for design flows  $\geq 1$  MGD, 1/quarter for design flows  $\geq 0.05$  and  $< 1$  MGD, 1/year for design flows of 0.002 – 0.05 MGD will be utilized. The sewer system does not have any industrial or commercial users that discharge to the WWTP.

A final Total Maximum Daily Load (TMDL) exists for the Lackawanna River. The TMDL addresses metals (iron, manganese, and aluminum) and pH associated with acid mine drainage (AMD). There are no approved Waste Load Allocations (WLA) for this facility. Since this is a sewage discharge with no industrial contributors, no appreciable quantities of these metals are expected to be present in the effluent.

For this permit renewal, all monitoring frequencies for parameters with limitations are consistent with the Department's *Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits* (document no. 362-0400-001).

24-hour composite sampling is now required in place of 8-hour composite sampling.

This is a Phase 3 Chesapeake Bay facility with annual net mass limits for Total Nitrogen and Total Phosphorus. The monitoring/reporting for Total Kjeldahl Nitrogen (TKN), Nitrate-Nitrite as N, and Ammonia-Nitrogen has also been maintained in this permit.

Data for the modeling of the discharge from this facility was obtained from different sources. The results were compared to determine what the most accurate representation of the stream could be.

First, data from the upstream stream gage 1534300 (Lackawanna River near Forest City, PA) was used to model the discharge, resulting in a low flow yield (LFY) of 0.044 cfs/mi<sup>2</sup> and Q<sub>7-10</sub> of 1.94 cfs.

Second, data from the downstream stream gage 15345000 (Lackawanna River at Archbald, PA) was used to model the discharge, resulting in a low flow yield (LFY) of 0.17 cfs/mi<sup>2</sup> and Q<sub>7-10</sub> of 7.48 cfs.

Third, USGS StreamStats was used to model the discharge, resulting in a low flow yield (LFY) of 0.099 cfs/mi<sup>2</sup> and Q<sub>7-10</sub> of 4.36 cfs.

All three methods used the same RMI values that were obtained using the "PA Historic Streams" feature of eMapPA, the drainage areas that were delineated using USGS's StreamStats Interactive Map, and elevations that were obtained using the elevation profile feature of StreamStats. The data/calculations for all three methods can be observed on pages 9-12 of this fact sheet.

Ultimately, the data from StreamStats was used to model the discharge because it appeared to be an average of the other two methods. The LFY of 0.099 cfs/mi<sup>2</sup> is also very close to the state-wide default LFY of 0.1 cfs/mi<sup>2</sup>. The previous permit carried over modeling from the permit before which used a LFY of 0.19 cfs/mi<sup>2</sup> and Q<sub>7-10</sub> of 8.4 cfs. Therefore, the data used for this permit was more conservative than previous permits.

The permit application identifies 3 combined sewer overflow (CSO) Outfalls: 002, 009, and 010. The locations of the CSOs are listed in the table in Part A.I.E. in the draft NPDES Permit. The Annual CSO Report (dated February 2025) included with the Chapter 94 Annual Report states that Clinton WWTP system has reduced the number of permitted CSOs from 9 to 3. The Vandling Pump Station Gravity Bypass Interceptor construction project was completed in 2023. This project constructed a new gravity interceptor sewer that allowed flow previously conveyed by the Vandling Pump Station to be transported entirely by gravity flow to the Clinton WWTP. Construction of this line allowed for the elimination of the existing CSO that was associated with it. Therefore, CSO 009 was removed from this permit renewal. The feasibility of eliminating additional CSOs continues to be evaluated on a case-by-case basis and will be implemented whenever possible.

The Chapter 94 Annual Report for 2024 (dated March 21, 2025) was reviewed as part of this permit renewal. In 2024, LRBSA continued its sewer maintenance program by inspecting and cleaning problem areas of the system. The sewer mapping GIS conversion program is also being continued. 1,038 LF of pipe was repaired/replaced in 2024 in Vandling Borough. The Report indicates there are no extensions of the collection system proposed. No areas of the system are hydraulically overloaded. The construction of any new CSOs is prohibited and the municipalities must take "all practical steps to prevent stormwater from entering the Authority's facilities".

**Summary of Review**

A Post Construction Monitoring Plan (PCMP) was submitted with the permit renewal application for review by the Department. The Plan will provide DEP and EPA data to evaluate the performance of the implemented CSO controls and determine if LRBSA – Clinton Township is meeting their pollution reduction goals. The PCMP includes three tasks: data collection, data evaluation, and annual reporting.

Receiving water quality data (E. coli concentrations) will be gathered and compared to state water quality standards for bacteria. A minimum of three (3) years of data should be gathered before evaluating the effectiveness of the LTCP in meeting water quality goals. This time period is warranted to ensure the CSO program is evaluated against annual average conditions, and not biased by an abnormally dry or wet year.

The proposed PCMP schedule submitted by the permittee can be seen below:

Task	Year 1				Year 2				Year 3				Year 4
	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1
<b>Data Collection</b>													
<b>Data Analysis</b>													
<b>Annual Report</b>													

This proposed schedule and the E. Coli data collection period discussed above was used to create the Implementation Schedule that can be seen in Part C.II.C. of the draft NPDES Permit.

The PCMP Plan is approved by the Department.

The existing permit expired on November 30, 2021 and the application for renewal was received on time.

A Water Management System Inspection query indicated that on August 28, 2024 a Compliance Evaluation was performed.

There are currently no open violations for this client that warrant withholding issuance of this permit.

Sludge use and disposal description and location(s): As per the permittee’s NPDES Renewal Application, sludge is hauled to LRBSA Archbald WWTP located in Jermyn, PA by Russell Reid.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP’s discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.7</u>
Latitude	<u>41° 38' 45.07"</u>	Longitude	<u>-75° 27' 40.17"</u>
Quad Name	<u>Forest City</u>	Quad Code	<u>0542</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Lackawanna River (HQ-CWF)</u>	Stream Code	<u>28374</u>
NHD Com ID	<u>65629201</u>	RMI	<u>35.71</u>
Drainage Area	<u>44 mi<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u>0.099</u>
Q <sub>7-10</sub> Flow (cfs)	<u>4.36</u>	Q <sub>7-10</sub> Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u>1,412.40</u>	Slope (ft/ft)	<u>-</u>
Watershed No.	<u>5-A</u>	Chapter 93 Class.	<u>HQ-CWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>Danville Water Authority</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	<u>-</u>
PWS RMI	<u>122.58</u>	Distance from Outfall (mi)	<u>~ 95</u>

Treatment Facility Summary				
<b>Treatment Facility Name:</b> LRBSA Clinton Township WWTP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>	<b>Scope</b>		
6423401	11/21/2023	WWTP Upgrades		
350401	4/28/2021	Vandling Gravity Main Project		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration Activated Sludge	Chlorination	0.40 (2024)
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.7	2,000	Not Overloaded	Holding Tanks	Hauled

Compliance History

DMR Data for Outfall 001 (from April 1, 2024 to March 31, 2025)

Parameter	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24
Flow (MGD) Average Monthly	0.5	0.39	0.33	0.56	0.34	0.16	0.21	0.53	0.44	0.25	0.42	0.44
Flow (MGD) Daily Maximum	0.84	0.78	0.84	0.92	0.87	0.61	0.73	0.81	1.38	0.90	0.87	0.96
pH (S.U.) Minimum	6.48	6.30	6.32	6.37	6.49	6.54	6.40	6.47	6.29	6.11	6.42	6.42
pH (S.U.) Instantaneous Maximum	7.20	7.09	7.14	7.10	7.22	7.24	7.37	7.25	7.21	7.12	7.24	7.03
DO (mg/L) Minimum	6.83	9.39	8.34	8.84	6.69	6.87	6.45	6.57	6.61	6.46	7.62	7.66
TRC (mg/L) Average Monthly	0.52	0.46	0.42	0.68	0.38	0.42	0.42	0.39	0.4	0.52	0.47	0.42
TRC (mg/L) Instantaneous Maximum	0.86	1.02	1.07	1.2	1.15	1.1	0.89	1.44	0.9	0.95	0.90	0.86
CBOD5 (lbs/day) Average Monthly	20	19	12	17	10	6	7	32	18	11	22	13
CBOD5 (lbs/day) Weekly Average	31	28	28	27	26	8	11	21	42	17	47	17
CBOD5 (mg/L) Average Monthly	5	6	4.0	4	4.0	4.0	4	5	3	5.0	5	4.0
CBOD5 (mg/L) Weekly Average	6	8	5.0	6	5.0	5.0	5	6	5	6.0	7	4.0
BOD5 (lbs/day) Influent   Average Monthly	405	406	410	506	290	227	229	436	345	350	347	498
BOD5 (lbs/day) Influent   Daily Maximum	617	608	579	863	487	525	377	1096	1022	933	782	732
BOD5 (mg/L) Influent   Average Monthly	107	154	172	123	182	164	140	95	101	174	101	119
TSS (lbs/day) Average Monthly	27	42	15	23	29	6	8	25	20	11	47	34

**NPDES Permit Fact Sheet  
LRBSA Clinton Township WWTP**

**NPDES Permit No. PA0027081**

TSS (lbs/day) Influent   Average Monthly	359	384	391	377	246	231	278	314	273	350	368	381
TSS (lbs/day) Influent   Daily Maximum	418	846	726	718	315	451	597	813	462	636	855	433
TSS (lbs/day) Weekly Average	45	114	35	39	103	10	12	18	46	12	100	59
TSS (mg/L) Average Monthly	6	12	6.0	5	7	5.0	5	4	4	6.0	8	9.0
TSS (mg/L) Influent   Average Monthly	96	135	171	98	160	171	168	73	95	177	106	97
TSS (mg/L) Weekly Average	8	23	8.0	6	14	6.0	7	5	5	10.0	14	10.0
Fecal Coliform (CFU/100 ml) Geometric Mean	19	33	15	7	44	20	14	17	18	21	18	16
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	1986.3	7945.2	56.3	18.5	816.4	96	58.3	770.1	42	108.1	153.9	248.1
Nitrate-Nitrite (mg/L) Average Monthly	< 13.1554	< 17.7527	< 18.3856 9	< 12.6929 8	< 30.4177 3	< 29.8596	< 23.0263	< < 12.959	< 15.2174	< 19.7152	< 19.0492	< 14.2546
Nitrate-Nitrite (lbs) Total Monthly	< 1517.2	< 1347.1	< 1400.8	< 1625.4	< 1698.9	< 1299.3	< 1128.5	< 1688.2	< 1653.4	< 2701.5	< 2553.9	< 1218.8
Total Nitrogen (mg/L) Average Monthly	< 13.9878 4	< 18.2184 5	< 18.7976 9	< 13.5054 2	< 31.4117 3	< 30.8536	< 24.0203	< 13.9536	< 16.2114	< 20.7092	< 20.0432	< 15.2486
Total Nitrogen (lbs) Effluent Net   Total Monthly	< 1633.8	< 1383.2	< 1437.8	< 1727	< 1778.2	< 1342.7	< 1179.9	< 1825.5	< 1785.9	< 2837.7	< 2694.1	< 1323.5
Total Nitrogen (lbs) Total Monthly	< 1633.8	< 1383.2	< 1437.8	< 1727	< 1778.2	< 1342.9	< 1179.9	< 1825.5	< 1785.9	< 2837.7	< 2694.1	< 1323.5
Total Nitrogen (lbs) Effluent Net   Total Annual							< 12786					
Total Nitrogen (lbs) Total Annual							< 20526					
Ammonia (lbs/day) Average Monthly	< 1.377					< 0.47	< 1.71	< 1.34	< 1.29	< 1.37	< 1.23	< 1.05
Ammonia (mg/L) Average Monthly	< 0.37	< 0.3	< 0.03	< 0.3	< 0.3	< 0.33	< 0.32	< 0.03	< 0.3	< 0.3	< 0.3	< 0.3

**NPDES Permit Fact Sheet  
LRBSA Clinton Township WWTP**

**NPDES Permit No. PA0027081**

Ammonia (lbs) Total Monthly	< 42.7	< 23.5	< 27.0	< 40.2	< 23.9	< 14.6	< 16	< 41.5	< 40	< 41.1	< 38.2	< 31.6
Ammonia (lbs) Total Annual							< 394					
TKN (mg/L) Average Monthly	< 0.776	< 0.466	< 0.412	< 0.812	< 0.994	< 0.994	< 0.994	< 0.994	< 0.994	< 0.994	< 0.994	< 0.994
TKN (lbs) Total Monthly	< 112.2	< 36.1	< 37	< 101.7	< 79.3	< 43.4	< 51.4	< 137.3	< 132.5	< 136.2	< 140.2	< 104.7
Total Phosphorus (mg/L) Average Monthly	1.046	1.734	1.58	1.142	2.97	< 3.13	2.511	1.424	1.718	2.41	1.112	1.105
Total Phosphorus (lbs) Effluent Net   Total Monthly	< 125.2	132.1	123.7	149.8	158.3	134.1	121.6	< 185.5	192	330.2	153.7	108.4
Total Phosphorus (lbs) Total Monthly	125.2	132.1	123.7	149.8	158.3	134.1	121.6	185.5	192	330.2	< 140.2	108.4
Total Phosphorus (lbs) Effluent Net   Total Annual							1705					
Total Phosphorus (lbs) Total Annual							1939					



Outfall No. 001  
Latitude 41° 38' 45.34"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.7  
Longitude -75° 27' 40.59"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25.0	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40.0	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
	50.0	IMAX	-	-
Total Suspended Solids	30.0	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45.0	Average Weekly	133.102(b)(2)	92a.47(a)(2)
	60.0	IMAX	-	-
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
	1.6	IMAX	-	-
Dissolved Oxygen	5.0	Minimum	-	BPJ
E. Coli	Report	Average Quarterly	-	92a.61

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling:

Parameter	Limit (mg/l)	SBC	Model
Ammonia-Nitrogen Mar 1 - Oct 31	10.0	Monthly Average	Previous Modeling
	20.0	IMAX	
Ammonia-Nitrogen Nov 1 - Feb 28	Report	Average Monthly	
Biochemical Oxygen Demand (BOD <sub>5</sub> ) Influent	Report	Average Monthly	POTW Requirement
Total Suspended Solids Influent	Report	Average Monthly	Chesapeake Bay Requirements
Kjeldahl--N	Report	Average Monthly	
Nitrate-Nitrite as N	Report	Average Monthly	
Total Phosphorus	Report	Average Monthly	
Net Total Phosphorus (lbs/day)	12,786	Annual	
Total Nitrogen	Report	Average Monthly	
Net Total Nitrogen (lbs/day)	1,705	Annual	

**Anti-Backsliding**

No limitations were made less stringent.

**Modeling Using USGS Stream Gages**

Stream Gage: 01534300 – Lackawanna River near Forest City, PA

Name	Value
USGS Station Number	01534300
Station Name	Lackawanna River near Forest City, PA
Station Type	Gaging Station, continuous record
Latitude	41.67981
Longitude	-75.47185
NWIS Latitude	41.67980547
NWIS Longitude	-75.47184988
Is regulated?	true
Agency	United States Geological Survey
NWIS Discharge Period of Record	10/01/1958 - 05/29/2025

Characteristic Name	Value	Units
Drainage Area	38.8	square miles

Statistic Name	Value	Units	Preferred?	Years of Record	Standard Error, percent	Citation	Comments
1 Day 10 Year Low Flow	1.1	cubic feet per second	✓	49		49	Statistic Date Range 4/1/1959 - 3/31/2008
7 Day 2 Year Low Flow	5.1	cubic feet per second	✓	49		49	Statistic Date Range 4/1/1959 - 3/31/2008
7 Day 10 Year Low Flow	1.7	cubic feet per second	✓	49		49	Statistic Date Range 4/1/1959 - 3/31/2008

$$\text{Low Flow Yield using StreamStats Gage Data} = \frac{1.7 \text{ ft}^3/\text{sec}}{38.8 \text{ mi}^2} = \mathbf{0.044} \frac{\text{ft}^3/\text{sec}}{\text{mi}^2}$$

$$Q_{7-10} \text{ at Outfall 001 using StreamStats Gage Data} = 0.04 \frac{\text{ft}^3/\text{sec}}{\text{mi}^2} \times 44 \text{ mi}^2 = \mathbf{1.94 \text{ cfs}}$$

Stream Gage: 01534500 – Lackawanna River at Archbald, PA

Name	Value
USGS Station Number	01534500
Station Name	Lackawanna River at Archbald, PA
Station Type	Gaging Station, continuous record
Latitude	41.50452
Longitude	-75.54213
NWIS Latitude	
NWIS Longitude	
Is regulated?	true
Agency	United States Geological Survey
NWIS Discharge Period of Record	Undefined

Characteristic Name	Value	Units
Drainage Area	108	square miles

Controlled 1 Day 10 Year Low Flow	16.7	cubic feet per second	✓	48	49	Statistic Date Range 4/1/1960 - 3/31/2008
Controlled 7 Day 2 Year Low Flow	29.2	cubic feet per second	✓	48	49	Statistic Date Range 4/1/1960 - 3/31/2008
Controlled 7 Day 10 Year Low Flow	18.8	cubic feet per second	✓	48	49	Statistic Date Range 4/1/1960 - 3/31/2008

$$\text{Low Flow Yield using StreamStats Gage Data} = \frac{18.8 \text{ ft}^3/\text{sec}}{108 \text{ mi}^2} = 0.17 \frac{\text{ft}^3/\text{sec}}{\text{mi}^2}$$

$$Q_{7-10} \text{ at Outfall 001 using StreamStats Gage Data} = 0.17 \frac{\text{ft}^3/\text{sec}}{\text{mi}^2} \times 44 \text{ mi}^2 = 7.48 \text{ cfs}$$

### Modeling Using USGS StreamStats Data:


At Outfall 001 on the Lackawanna River:

RMI	Elevation (ft)	Drainage Area (mi <sup>2</sup> )	Q <sub>7-10</sub> Flow (cfs)
35.71	1,412.40	44	4.36

$$\text{Low Flow Yield using StreamStats} = \frac{4.36 \text{ ft}^3/\text{sec}}{44 \text{ mi}^2} = 0.099 \frac{\text{ft}^3/\text{sec}}{\text{mi}^2}$$

## StreamStats Report

Region ID: PA  
 Workspace ID: PA20211202151640589000  
 Clicked Point (Latitude, Longitude): 41.64584, -75.46123  
 Time: 2021-12-02 10:17:00 -0500



Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	44	square miles

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	8.56	ft <sup>3</sup> /s	38	38
30 Day 2 Year Low Flow	11.1	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	4.36	ft <sup>3</sup> /s	51	51

At confluence with Unnamed Tributary to Lackawanna River (28603):

RMI	Elevation (ft)	Drainage Area (mi <sup>2</sup> )
32.044	1,205.46	56.2

StreamStats Report

Region ID: PA  
 Workspace ID: PA20250603130643934000  
 Clicked Point (Latitude, Longitude): 41.60363, -75.46925  
 Time: 2025-06-03 09:07:09 -0400



Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units
CARBON	Percent Carbonate	0	percent
DRNAREA	Drainage Area	56.2	square miles

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
05A	28374	LACKAWANNA RIVER					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
35.710	LRBSA Clinton	PA0027081	0.700	CBOD5	25		
				NH3-N	11.73	23.46	
				Dissolved Oxygen			3

TRC EVALUATION				
Input appropriate values in A3:A9 and D3:D9				
4.36	= Q stream (cfs)		0.5	= CV Daily
0.7	= Q discharge (MGD)		0.5	= CV Hourly
30	= no. samples		1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)			= Decay Coefficient (K)
Source	Reference	AFC Calculations		Reference
TRC	1.3.2.iii	WLA afc = 1.303		1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT afc = 0.373		5.1c
PENTOXSD TRG	5.1b	LTA_afc = 0.486		5.1d
				WLA cfc = 1.263
				LTAMULT cfc = 0.581
				LTA_cfc = 0.734
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635		
WLA afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots$ $\dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA_afc	wla_afc * LTAMULT_afc			
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots$ $\dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$			
LTA_cfc	wla_cfc * LTAMULT_cfc			
AML MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$			
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)			
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)			



Post Construction  
Monitoring Plan.pdf



2024 Chapter 94  
Annual Report - Clir



WQM 7.0.pdf