

Application Type Amendment, Major
 Facility Type Municipal
 Major / Minor Major

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0027367 A-1
 APS ID 1153062
 Authorization ID 1553536

Applicant and Facility Information

Applicant Name	<u>Aqua PA Wastewater Inc.</u>	Facility Name	<u>Greenville Sanitary Authority STP</u>
Applicant Address	<u>665 S Dock Street</u> <u>Sharon, PA 16146-1835</u>	Facility Address	<u>183 Hamburg Road</u> <u>Greenville, PA 16125-1527</u>
Applicant Contact	<u>Steve Clark</u>	Facility Contact	<u>Steve Clark</u>
Applicant Phone	<u>(570) 647-0358</u>	Facility Phone	<u>(570) 647-0358</u>
Client ID	<u>62614</u>	Site ID	<u>518891</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Hempfield Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Mercer</u>
Date Application Received	<u>December 29, 2025</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u></u>	If No, Reason	<u>Major Facility</u>
Purpose of Application	<u>Municipal to non-municipal sewage permit amendment</u>		

Summary of Review

On December 29, 2025, the Department received a transfer application for Individual NPDES Permit No. PA0027367 and WQM permits No. 4391412 and 4323416. The NPDES permit is being amended from a municipal sewage permit to a non-municipal sewage permit to reflect the ownership status of Greenville Sanitary Authority STP since it is now owned by Aqua PA.

All effluent limitations and part C conditions all remain the same.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Carlee Wilson Carlee Wilson / Environmental Engineering Specialist	January 15, 2026
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	January 22, 2026

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.19	XXX	0.62	1/day	Grab
CBOD5	667.0	1000.0	XXX	20.0	30.0	40	2/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
TSS	1000.0	1500.0	XXX	30.0	45.0	60	2/week	24-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/month	Grab
Total Nitrogen	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
Ammonia Nov 1 - Apr 30	700.0	XXX	XXX	21.0	XXX	42	2/week	24-Hr Composite
Ammonia May 1 - Oct 31	233.0	XXX	XXX	7.0	XXX	14	2/week	24-Hr Composite
Total Phosphorus	33.0	XXX	XXX	1.0	XXX	2	2/week	24-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Aluminum	36.0	XXX	XXX	1.08	XXX	2.16	1/month	24-Hr Composite
Total Copper	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Free Cyanide	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Dissolved Zinc	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite

Compliance Sampling Location: Outfall 001, after disinfection