

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0028452  
APS ID 1110462  
Authorization ID 1478676

**Applicant and Facility Information**

Applicant Name	<u>Dunkard Township &amp; Bobtown Municipal Authority</u>	Facility Name	<u>Dunkard Bobtown STP</u>
Applicant Address	<u>PO Box 352 Bobtown, PA 15315-0352</u>	Facility Address	<u>State Route 2008, 455 Plant Road Dilliner, PA 15327</u>
Applicant Contact	<u>Frank Greenwood</u>	Facility Contact	<u>Frank Greenwood</u>
Applicant Phone	<u>(724) 998-5982</u>	Facility Phone	<u>(724) 998-5982</u>
Client ID	<u>65653</u>	Site ID	<u>442724</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Dunkard Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Greene</u>
Date Application Received	<u>March 28, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u></u>	If No, Reason	<u></u>
Purpose of Application	<u>Permit Renewal</u>		

**Summary of Review**

Applicant requests renewal of an NPDES permit to discharge treated sewage from Dunkard Bobtown STP.

Sewage from Dunkard Township is collected and treated with primary settling, trickling filtration, clarification and UV disinfection.

No upgrades are proposed at this renewal.

Last year's DMR data shows the discharge is in compliance with the permit effluent limitations except one-time Ammonia exceedance. According to the Operations Section, currently there are no open violations or pending enforcements. However, based on the compliance check summary report there were multiple effluent limit violations of Ammonia Nitrogen reported during the current permit term. Operations Section will be addressing these issues accordingly.

No industrial dischargers are listed in the application.

Sludge use and disposal description and location(s): Sludge is disposed at Landfill. CBF Landfill is listed as the site name.

X		<i>Sara Abraham</i> Sara Reji Abraham, E.I.T. / Project Manager	May 7, 2024
X		<i>Pravin Patel</i> Pravin C. Patel, P.E. / Environmental Engineer Manager	05/07/2024

**Summary of Review**

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Act 14 Notifications:

Dunkard Township - February 26, 2024  
Greene County - February 26, 2024

Permit Conditions:

- A. No Stormwater
- B. Acquire Necessary Property Rights
- C. Proper Sludge Disposal
- D. Chlorine Optimization
- E. Operator Notification
- F. Solids Management

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.15</u>
Latitude	<u>39° 44' 41.41"</u>	Longitude	<u>-79° 59' 19.78"</u>
Quad Name	<u>Morgantown North</u>	Quad Code	<u>2106</u>
Wastewater Description: <u>Treated Sewage Effluent</u>			
Receiving Waters	<u>Dunkard Creek (WWF)</u>	Stream Code	<u>41420</u>
NHD Com ID	<u>99418898</u>	RMI	<u>6.82</u>
Drainage Area	<u>225.78 sq.mi.</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.00568</u>
Q <sub>7-10</sub> Flow (cfs)	<u>1.2824</u>	Q <sub>7-10</sub> Basis	<u>Previous fact sheet</u>
Elevation (ft)	<u>838.3</u>	Slope (ft/ft)	<u>0.0017</u>
Watershed No.	<u>19-G</u>	Chapter 93 Class.	<u>WWF</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>mercury, non-native fish/shellfish/zooplankton, osmotic pressure, total dissolved solids (TDS)</u>		
Source(s) of Impairment	<u>source unknown, subsurface (hardrock)</u>		
TMDL Status	<u>Final</u>	Name	<u>Dunkard Creek</u>
Nearest Downstream Public Water Supply Intake	<u>Dunkard Valley Water Authority</u>		
PWS Waters	<u>Monongahela River</u>	Flow at Intake (cfs)	<u>12.5</u>

Treatment Facility Summary				
Treatment Facility Name: Dunkard Bobtown STP				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Trickling Filter With Solids Removal	UV	0.15
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.15	250	Not Overloaded		

Compliance History

DMR Data for Outfall 001 (from March 1, 2023 to February 29, 2024)

Parameter	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23	MAR-23
Flow (MGD) Average Monthly	0.05164	0.11405	0.04981	0.04208	0.04745	0.02589	0.05784	0.03978	0.03894	0.03679	0.02901	0.07209
Flow (MGD) Daily Maximum	0.20802	0.46507	0.22832	0.31342	0.19587	0.06190	0.37632	0.19461	0.17422	0.0881	0.06463	0.39782
pH (S.U.) Instantaneous Minimum	6.5	6.8	6.2	6.3	6.2	6.3	6.3	6.3	6.3	6.3	6.2	6.2
pH (S.U.) Instantaneous Maximum	7.5	7.8	7.7	7.7	7.3	7.1	7.5	7.3	7.3	7.5	7.0	7.3
DO (mg/L) Instantaneous Minimum	5.1	7.0	4.6	4.8	4.2	4.2	4.2	4.4	4.3	4.5	5.9	6.8
CBOD5 (lbs/day) Average Monthly	3.2	4.4	4.9	1.9	3.7	1.9	4.4	3.0	4.1	2.5	0.8	1.9
CBOD5 (lbs/day) Weekly Average	6.0	6.5	8.4	2.0	10.2	2.4	8.8	6.7	8.2	4.5	1.0	3.8
CBOD5 (mg/L) Average Monthly	6.0	9.3	8.9	9.6	8.5	9.0	11.2	7.7	8.2	6.6	3.7	5.1
CBOD5 (mg/L) Weekly Average	7.1	17.1	13.4	12.0	10.5	10.4	14.1	10.5	10.2	7.9	4.7	6.5
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	86.6	61.5	61.9	48.1	66.9	62.9	35.8	54.1	82.7	51.2	94.8	88.6
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	102.2	103.9	137.7	63.2	104.4	75.9	49.1	109.4	178.9	67.2	151.2	95.3
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	223.6	115.3	119.2	247.1	220.7	310.0	115.9	150.7	251.0	185.9	423.8	266.4
TSS (lbs/day) Average Monthly	3.1	5.7	10.1	1.5	3.8	2.8	6.0	4.1	12.4	3.5	1.3	1.9

**NPDES Permit Fact Sheet  
Dunkard Bobtown STP**

**NPDES Permit No. PA0028452**

TSS (lbs/day) Raw Sewage Influent   Average Monthly	87.9	49.5	56.4	40.6	40.2	49.4	30.7	41.9	43.7	57.8	43.8	47.8
TSS (lbs/day) Raw Sewage Influent   Daily Maximum	138.7	69.5	95.8	64.8	62.5	60.9	59.9	69.1	68.7	140.9	53.4	58.2
TSS (lbs/day) Weekly Average	6.4	11.5	17.5	1.8	10.2	3.8	18.0	7.1	26.9	4.8	1.6	3.3
TSS (mg/L) Average Monthly	5.3	12.4	15.5	7.8	9.0	13.1	12.2	12.3	24.8	11.8	5.8	5.0
TSS (mg/L) Raw Sewage Influent   Average Monthly	253.5	97.2	103.5	221.5	151.2	254.0	84.0	121.0	137.6	153.0	197.0	140.8
TSS (mg/L) Weekly Average	6.0	30.0	26.0	12.0	17.0	19.5	18.0	23.0	35.0	19.0	6.0	5.0
Fecal Coliform (No./100 ml) Geometric Mean	3	6	9	4	8	11	24	5	10	24	2	3
Fecal Coliform (No./100 ml) Instantaneous Maximum	5	75	87	18	94	74	57	21	65	445	6	19
Total Nitrogen (mg/L) Daily Maximum			55.2									
Ammonia (lbs/day) Average Monthly	1.6	3.1	2.5	1.2	0.8	0.9	1.3	0.7	0.9	1.5	0.3	0.6
Ammonia (lbs/day) Weekly Average	3.1	6.7	6.0	2.1	2.1	1.7	2.7	0.9	1.5	2.7	1.0	1.3
Ammonia (mg/L) Average Monthly	4.6	7.2	5.3	6.8	3.9	4.2	4.1	2.5	3.5	5.0	1.3	2.3
Ammonia (mg/L) Weekly Average	6.8	17.6	9.5	14.2	11.7	6.8	6.2	4.2	5.8	7.9	3.6	6.3
Total Phosphorus (mg/L) Daily Maximum			8.8									
UV Dosage (mjoules/cm <sup>2</sup> ) Average Monthly	76	79	73	78	74	75	74	74	73	71	76	78

**Compliance History**

**Effluent Violations for Outfall 001, from: April 1, 2023 To: February 29, 2024**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Ammonia	10/31/23	Wkly Avg	11.7	mg/L	8.3	mg/L

**Development of Effluent Limitations**

Outfall No. 001 Design Flow (MGD) .15  
 Latitude 39° 44' 42.00" Longitude -79° 59' 20.00"  
 Wastewater Description: Treated Sewage Effluent

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine*	0.5	Average Monthly	-	92a.48(b)(2)

Comments: TRC is not required since disinfection is via UV radiation.

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
NH <sub>3</sub> -N	7.38	Average Monthly	WQM 7.0
CBOD <sub>5</sub>	25	Average Monthly	WQM 7.0
DO	3.0	Average Monthly	WQM 7.0

\* Previous WQM 7.0 report is attached. Also, the original Pollution Report is attached for Reference.

**Best Professional Judgment (BPJ) Limitations**

Dissolved Oxygen minimum limitation of 4.0 mg/L will be implemented based on the SOP/ best professional judgment. This limit was in the previous permit.

**Anti-Backsliding**

The limits for NH<sub>3</sub>N will remain at 5.5 due to anti-backsliding. The DO limit will remain at 4.0 mg/l due to anti-backsliding.

**Disinfection**

UV radiation is the method of disinfection. UV dosage shall be reported in millijoules/cm<sup>2</sup>.

**Total Dissolved Solids (TDS)**

TDS discharge concentration is reported as 467 mg/l (which is < 1000 mg/l) and is not a concern and monitoring is not included similar to the existing permit.

**Mass Loadings**

Mass loading limits are applicable for publicly owned treatment works. The existing average monthly and average weekly mass loading limits are continued for CBOD5, TSS, and NH<sub>3</sub>-N in the draft permit.

**TN and TP Monitoring**

Nutrient monitoring is required to establish the nutrient load from the waste water treatment facility and the impacts that load may have on the quality of the receiving stream(s). Sewage discharges with design flows > 2,000 gpd require monitoring, at a minimum, for Total Nitrogen and Total Phosphorus in new and reissued permits. The existing monitoring is continued in the draft permit.

**E. Coli Monitoring**

E. Coli monitoring (quarterly) is included in the draft permit based on DEP SOP/ Chapter 92a.61. This is a new requirement.

**Monitoring Frequency Considerations**

For pH, Dissolved Oxygen (DO) and Ultraviolet dosage (UV), a monitoring frequency of 1/day has been imposed similar to the existing permit. The daily monitoring frequencies are consistent with current policy and Table 6-3 of DEP's Technical Guidance for the Development and Specification of Effluent Limitations.

**Influent Monitoring**

For POTWs with design flows greater than 2,000 GPD, influent BOD5 and TSS monitoring must be established in the permit, and the monitoring should be consistent with the same frequency and sample type as is used for other effluent parameters. The existing requirement is continued in the draft permit.

NPDES Permit Fact Sheet  
PA0028452  
Dunkard Bobtown STP

POLLUTION REPORT

NPDES Permit No.

(I) Project Description

New Discharge (POINT)  
Existing Discharge

Change  
Preliminary

A. NPDES Application/Permit No. PA0028452  
Part II permit Nos. 3073404

B. Applicant, Case Name or Permittee: DUNKARD BOBTOWN MUNICIPAL AUTHORITY

Municipality: DUNKARD TWP  
County: GREENE

C. Type Waste

- Sewage
- Industrial
- Mine

D. Source and characteristics

TREATED SEWAGE FROM THE DUNKARD  
BOBTOWN STP

E. USGS Quad: MORGANTOWN NORTH

F. Latitude (or in. N) 21.7" PROPOSED RELOCATION  
Longitude (or in. W) 15.9" OUTFALL 001 39°45'16"  
79°59'20"

(II) Water Uses and Criteria

A. Receiving waters DUNKARD CRK Stream code 41420  
Chapter 93 classification WWF R.M.I. 6.818  
D.A. 225.78 sq.mi. Yield .00568 cfs/sq.mi.  
Flow 1.2824 cfs. Based on data from BVL 12 P385 DUNKARD  
CREEK AT SHANNON 03072000  
Elevation 838.3 ft.

Exceptions to standard  
water use lists: None  
Add \_\_\_\_\_  
Delete \_\_\_\_\_

Water Quality Criteria-Exceptions  
to Specific Criteria: None  
Add \_\_\_\_\_  
Delete \_\_\_\_\_

Impoundment N/A  
Special Downstream Uses: \_\_\_\_\_

B. Secondary Waters MONONGAHELA RIVER R.M.I. \_\_\_\_\_  
Distance from discharge 6.818 mi. Ch. 93 classification WWF  
D.A. \_\_\_\_\_ sq.mi. Yield \_\_\_\_\_ cfs/sq.mi.  
Flow 480 cfs. Based on data from U.S. ARMY CORP  
OF ENGINEERS  
Elevation 778 ft. Stream Code 37185

Exceptions to standard  
water use lists: \_\_\_\_\_  
Add \_\_\_\_\_  
Delete \_\_\_\_\_

Water Quality Criteria-Exceptions  
to Specific Criteria: \_\_\_\_\_  
Add \_\_\_\_\_  
Delete \_\_\_\_\_

Impoundment \_\_\_\_\_  
Special Downstream Uses: \_\_\_\_\_  
Downstream PWS: location \_\_\_\_\_  
distance from discharge \_\_\_\_\_ mi. intake \_\_\_\_\_ mgd.  
stream flow at intake \_\_\_\_\_ cfs.

NPDES Permit Fact Sheet  
PA0028452  
Dunkard Bobtown STP

NPDES Permit No.

5

EVALUATION OF THE PROPOSED  
RELOCATION OF THE DBMA STP OUTFALL -  
DISCHARGE TO DUNKARD CRK  
DISCHARGE FLOW = 150,000 GPD

WQM 6.3  
MODEL  
ANALYSIS

"EMPR MODE"


NPDES Permit Fact Sheet  
PA0028452  
Dunkard Bobtown STP

NPDES Permit No.

DISCHARGES WITH POSSIBLE INTERACTION TO THE DBMA STP,

8

<u>FACILITY</u>	<u>NPDES #</u>	<u>STREAM</u>	<u>Flow</u>
① MT MORRIS STP	PA0096512	DUNKARD CRK	.10MGD



NPDES Permit Fact Sheet  
PA0028452  
Dunkard Bobtown STP

NPDES Permit No.

SLOPES & ELEVATIONS

①

SLOPE BETWEEN MT MORRIS & DBMA STP

$$\Delta S \frac{880 - 860_{\text{CONTOUR}}}{15000'} = .00133 \text{ ft/ft}$$

$$\Delta S \frac{860_{\text{CONTOUR}} - 840_{\text{CONTOUR}}}{11,500} = .00174 \text{ ft/ft}$$

$$\begin{aligned} &.00133 \\ &+ .00174 \\ &\hline &.00307 \div 2 = .0015 \text{ ft/ft} \\ &\text{AVERAGE} \end{aligned}$$

ELEVATION AT DBMA STP

UPSTREAM CONTOUR = 840    SLOPE = .00174    DISTANCE = 1000'

$$1000' \times .00174 = 1.7' \quad 840 - 1.7' = \boxed{838.3'}$$

ELEVATION AT MT MORRIS = 880'

ELEVATION AT DBMA STP = 838.3'

41.7 DROP

DISTANCE BETWEEN DISCHARGES = 27,500'

Avg SLOPE =  $41.7' / 27,500' = \boxed{.0015 \text{ ft/ft}}$

SLOPE BETWEEN DBMA STP & MONONGAHELA RIVER

ELEVATION AT DBMA STP = 838.3'

ELEVATION of RIVER = 778 (POOL ELEVATION)

60.3

DISTANCE = 36,000'

SLOPE =  $\frac{60.3}{36,000} = \boxed{.0017 \text{ ft/ft}}$

NPDES Permit Fact Sheet  
PA0028452  
Dunkard Bobtown STP

NPDES Permit No.

(10)

## DRAINAGE AREAS

### MT MORRIS STP

FROM PAST POLLUTION REPORT D.A. DETERMINED  
BY PLANIMETERING D.A. BETWEEN THE DISCHARGE PT  
AND GAGING STATION AT SHANNOPIN, PA.

GAGING STATION D.A. = 229 mi<sup>2</sup>

LESS PLANIMETERED AREA = -7.5 mi<sup>2</sup>

UPSTREAM DA = 201.5

### DUNKARD BOBTOWN STP

TOTAL DRAINAGE AREA TO GAGING STATION 229 mi<sup>2</sup>  
PLANIMETER AREA BETWEEN DBMA STP DISCHARGE  
AND GAGING STATION TO SUBTRACT OUT.

LESS AREA PLANNETERED = -3.22

GAGING STATION D.A. = 229

- 3.22

UPSTREAM D.A. DBMA STP = 225.78 mi<sup>2</sup>

NPDES Permit Fact Sheet  
PA0028452  
Dunkard Bobtown STP

NPDES Permit No.

## VELOCITIES AND TRAVEL TIMES

⑩

DATA FROM THE USGS FIELD RECORDS FOR STATION 03072000 DUNKARD CRK AT SHANNOPIN PA WAS OBTAINED BY TELEPHONE FROM JOE LEZINSKI on 4/8/85 BY HAL SNYDER. THE DATA IS CONTAINED IN APPENDIX D AND WAS USED TO ESTABLISH A Q<sup>7-10</sup> VELOCITY AND TRAVEL TIME FOR THE MT-MORRIS STP DISCHARGE. THIS DATA WILL BE USED TO ESTABLISH VELOCITIES AND TRAVEL TIMES FOR THE FOLLOWING STREAM SEGMENTS

- ① MT MORRIS STP TO DUNKARD-BOBTOWN STP
- ② DUNKARD BOBTOWN STP TO MONONGAHELA RIVER

FROM SOLVED EQUATION IN APPENDIX D

$$\begin{aligned} y &= a x^b && -1.1824 \\ y &= 1.5784 x \end{aligned}$$

Y = VELOCITY  
X = FLOW

NPDES Permit Fact Sheet  
PA0028452  
Dunkard Bobtown STP

NPDES Permit No.

## VELOCITIES AND TRAVEL TIMES (12)

### MT MORRIS STP TO DBMA STP

REACH (1)

$$\text{TOTAL FLOW} = \text{TOTAL DAILY YIELD} + \text{MT MORRIS FLOW}$$
$$\text{TOTAL FLOW} = 201.5 \times .00568 + (1.55 \times .1)$$
$$\text{TOTAL FLOW} = 1.30 \text{ CFS}$$

$$V = 1.5784 (1.30)^{-1.1824}$$

$$\text{VELOCITY} = \boxed{1.1574 \text{ FPS AFTER DISCHARGE}}$$

$$\text{DISTANCE TO DBMA STP} = 27,500 \text{ ft}$$

$$\text{TRAVEL TIME} = \frac{27,500' / 1.1574 \text{ FPS}}{86,400 \text{ Sec/DAY}} = \boxed{.2750 \text{ days}}$$

### DUNKARD BOBTOWN STP TO MONONGAHELA R.

REACH (2)

$$\text{TOTAL FLOW} = \text{TOTAL DAILY YIELD} + \text{MT MORRIS FLOW} + \text{DBMA STP FLOW}$$
$$\text{TOTAL FLOW} = (225.78 \times .00568) + .155 + .155$$
$$\text{TOTAL FLOW} = 1.5924 \text{ CFS}$$

$$V = 1.5784 (1.5924)^{-1.1824}$$

$$\text{VELOCITY} = \boxed{.9105 \text{ FPS AFTER DISCHARGE}}$$

$$\text{DISTANCE TO MONONGAHELA RIVER} = 36,000'$$

$$\text{TRAVEL TIME} = \frac{36,000' / .9105 \text{ FPS}}{86,400 \text{ Sec/DAY}} = \boxed{.4576 \text{ DAYS}}$$

NPDES Permit Fact Sheet  
 PA0028452  
 Dunkard Bobtown STP

NPDES Permit No.

SUMMER

DEPTHS

(3)

```

*****
*
*   LEAST SQUARES EXPONENTIAL REGRESSION   *
*   Y=A*EXP(B*X)                           *
*
*****
    
```

DETERMINATION of Q7-10 DEPTHS AT Q7-10 FLOWS BELOW FACIT DISCHARGE

X = FLOW Y = DEPTH

INPUT LIST

#	--X--	--Y--
1	1.2	.1764
2	1.76	.2689
3	2.1	.29565

FROM USGS DATA APPENDIX D

THE COEFFICIENTS FOR THE EXPRESSION

$$Y = A * EXP(B * X)$$

WERE COMPUTED AS FOLLOWS:

A = 8.890652E-02  
 AND B = .5916035

THE CORRELATION COEFFICIENT, R, WAS FOUND TO BE .9780284

THE FOLLOWING SOLVES FOR Y USING THE VALUE ' 1.3 ' FOR X :

$$Y = A * EXP(B * X)$$

$$= 8.890652E-02 * EXP(.5916035 * 1.3)$$

DEPTH = .1918416 JUST BELOW MT MORRIS

THE FOLLOWING SOLVES FOR Y USING THE VALUE ' 1.5924 ' FOR X :

$$Y = A * EXP(B * X)$$

$$= 8.890652E-02 * EXP(.5916035 * 1.5924)$$

DEPTH = .2280705 JUST BELOW DUNKARD BOBTOWN STP

NPDES Permit Fact Sheet  
PA0028452  
Dunkard Bobtown STP

NPDES Permit No.

14

## COMPUTED W/D RATIOS AFTER DISCHARGES

① AT MT MORRIS STP (JUST BELOW DISCHARGE)

$$\text{Flow} = 1.30 \text{ CFS}$$

$$\text{Velocity} = 1.1574 \text{ FPS}$$

$$\text{Depth} = .19184 \text{ (PREVIOUS POLLUTION REPORT USED .1936')}$$

$$1.30 \text{ CFS} = 1.1574 (.19184') (W)$$

$$W = 5.855' \text{ PREVIOUS POLLUTION REPORT USED } 5.8'$$

$$W/D = 5.855' / .19184 = \boxed{30.5 \text{ TO } 1}$$

② AT DUNKARD BOBTOWN STP (JUST BELOW DISCHARGE)

$$\text{Flow} = 1.5924 \text{ CFS}$$

$$\text{Velocity} = .9105 \text{ FPS}$$

$$\text{Depth} = .22807'$$

$$1.5924 = .9105 (.22807' \times W)$$

$$W = 7.67'$$

$$W/D = 7.67' / .22807 = \boxed{33.62 \text{ TO } 1}$$

NPDES Permit Fact Sheet  
PA0028452  
Dunkard Bobtown STP

NPDES Permit No.

## AVAILABLE STREAM DATA

(15)

A PRIORITY WATER BODY SURVEY WAS CONDUCTED ON DUNKARD CREEK. THE REPORT IS DATED SEPT 1985. DATA FROM SAMPLING STATION 1 WILL BE USED AS STREAM BACKGROUND QUALITY. STATION 1, REFER TO APPENDIX C, IS UPSTREAM OF MOUNT MORRIS.

NOTE. STATIONS 1 THRU 4 INDICATE HIGH pH VALUES:

STATION 1	7.8
" 2	8.1
" 3	7.9
" 4	6.9

SEVERAL TREATED MINE DISCHARGES ENTER DUNKARD CRIC. MANY OF THESE DISCHARGES HAVE A HIGH pH due to THE ADDITION of ALKALINE SUBSTANCES USED TO PRECIPITATE METALS.

FROM STATION 3 <sup>4</sup> AMD BEGINS TO AFFECT DUNKARD CREEK.

AMD = ACID MINE DRAINAGE

**NPDES Permit Fact Sheet  
 PA0028452  
 Dunkard Bobtown STP**

**NPDES Permit No.**

DUNKARD CREEK EVALUATION FROM MOUTH TO FERRY ELEMENTARY SCHOOL STP  
 FILE: DUNKARD CREEK.WQM6.3

HEADWATERS AND TRIBUTARY DATA

NO. OF REACHES : 2

RH	Q7-10 (CFS)	T (C)	PH	DO (MG/L)	CBOD5 (MG/L)	NH3-N (MG/L)
HW	1.144	25	7.8	7.12	.5	.07
1	0					
2	.1379	25	7.8	7.12	.5	.07

STREAM CHARACTERISTICS

RCH	Q7-10 CFS	T (C)	PH	DO MG/L	CBOD5 MG/L	NH3-N MG/L
1	1.14	25	7.8	7.12	.5	.07
2	1.28	25	7.8	7.12	.5	.07

Q 1-10/Q 7-10 = .64  
 Q30-10/Q 7-10 = 1.46

**NPDES Permit Fact Sheet  
 PA0028452  
 Dunkard Bobtown STP**

**NPDES Permit No.**

DUNKARD CREEK EVALUATION FROM MOUTH TO PERRY ELEMENTARY SCHOOL STP  
 FILE: DUNKARD CREEK.WQM6.3

DISCHARGER DATA  
 Q7-10 DESIGN CONDITIONS

RH	Q MGD	T (C)	PH	DO MG/L	CBOD5 MG/L	NH3-N MG/L	KC
1	.1	20	7	2	25	25	1.5
2	.15	20	7	2	25	25	1.5

REACH CHARACTERISTICS

RH	D.O. GOAL	KN (/D)	RCH. SL. (FT/FT)	RCH. LEN. (FT.)	DRAIN AREA (MI^2)	W/D
1	5	.6	1.5E-03	27500	201.530.5	
2	5	.6	1.7E-03	36000	225.733.6	

NPDES Permit Fact Sheet  
 PA0028452  
 Dunkard Bobtown STP

NPDES Permit No.

DUNKARD CREEK EVALUATION FROM MOUTH TO PERRY ELEMENTARY SCHOOL STP  
 FILE: DUNKARD CREEK.WQM6.3

REACH CHARACTERISTICS

RH	KR (/D)	TT (DAYS)
1	0	.275
2	0	.4576

NH3-N DISCHARGE ALLOCATIONS AT Q30-10

DIS	Q (MGD)	IND. CONC. (MG/L)	ALL. CONC. (MG/L)	CRIT. RCH.	PCT. RED. (%)
1	.1	10.57	7.35	2	30.5
2	.15	8.4	5.84	2	30.5

**NPDES Permit Fact Sheet**  
**PA0028452**  
**Dunkard Bobtown STP**

**NPDES Permit No.**

DUNKARD CREEK EVALUATION FROM MOUTH TO PERRY ELEMENTARY SCHOOL STP  
 FILE: DUNKARD CREEK.WQM6.3

NH3-N DISCHARGE ALLOCATIONS AT Q1-10

DIS	Q (MGD)	IND. CONC. (MG/L)	ALL. CONC. (MG/L)	CRIT. RCH.	PCT. RED. (%)
1	.1	24.19	20.03	2	17.2
2	.15	20.86	17.27	2	17.2

MULTIPLE DISCHARGE LIMITATIONS

(TOTAL) DISCHARGE = .1 MGD  
 TEMP = 24.4 PH = 7.6  
 CBOD-5 = 3.42 NH3-N = .94 D.O. = 6.51  
 KC = 1.259 KN = .6 D.O.GOAL = 5  
 KR = 16.5 (TSIVOGLOU)  
 DIS. 1 RCH. 1 TRVL TIME = .275

TR. TM. (DAYS)	CBOD-5 (MG/L)	NH3-N (MG/L)	D.O. (MG/L)
.028	3.28	.92	6.97
.055	3.14	.89	7.12
.083	3.01	.87	7.12
.11	2.89	.85	7.12
.138	2.77	.83	7.12
.165	2.65	.82	7.12
.193	2.54	.8	7.12
.22	2.44	.78	7.12
.248	2.33	.76	7.12
.275	2.24	.74	7.12

**NPDES Permit Fact Sheet  
 PA0028452  
 Dunkard Bobtown STP**

**NPDES Permit No.**

DUNKARD CREEK EVALUATION FROM MOUTH TO PERRY ELEMENTARY SCHOOL STP  
 FILE: DUNKARD CREEK.WQM6.3

MULTIPLE DISCHARGE LIMITATIONS  
 (TOTAL) DISCHARGE = .25 MGD  
 TEMP = 23.8 PH = 7.5  
 CBOD-5= 5.26 NH3-N= 1.4 D.O. = 6.41  
 KC' = 1.338 KN= .6 D.O.GOAL = 5  
 KR= 14.712 (TSIV0GLOU)  
 DIS. 2 RCH. 2 TRVL TIME:.458

TR. TM. (DAYS)	CBOD-5 (MG/L)	NH3-N (MG/L)	D.O. (MG/L)
.046	4.89	1.35	6.88
.092	4.54	1.3	7.12
.137	4.22	1.25	7.12
.183	3.93	1.21	7.12
.229	3.65	1.16	7.12
.275	3.39	1.12	7.12
.32	3.15	1.08	7.12
.366	2.93	1.04	7.12
.412	2.73	1	7.12
.458	2.53	.97	7.12

EFFLUENT LIMITATIONS DISPLAY

DIS #	Q MGD	NH3-N TOX.		DISS. OXYGEN		
		1 DAY	30 DAY	C-BOD5 30-DAY	NH3-N 30-DAY	EFF. D.O.
1	.1	14.7	7.3	25	7.3	2
2	.15	11.7	5.8	25	5.8	2

**NPDES Permit Fact Sheet  
PA0028452  
Dunkard Bobtown STP**

**NPDES Permit No.**

DUNKARD CREEK EVALUATION FROM MOUTH TO PERRY ELEMENTARY SCHOOL STP  
FILE: DUNKARD CRK2.WDM6.3

*WINTER*

HEADWATERS AND TRIBUTARY DATA

NO. OF REACHES : 2

RH	Q7-10 (CFS)	T (C)	PH	DO (MG/L)	CBOD5 (MG/L)	NH3-N (MG/L)
HW	2.289	5	7.8	10.5	.5	.07
1	0					
2	.2758	5	7.8	10.5	.5	.07

STREAM CHARACTERISTICS

RCH	Q7-10 CFS	T (C)	PH	DO MG/L	CBOD5 MG/L	NH3-N MG/L
1	2.29	5	7.8	10.5	.5	.07
2	2.56	5	7.8	10.5	.5	.07

Q 1-10/Q 7-10 = .64  
Q30-10/Q 7-10 = 1.46

NPDES Permit Fact Sheet  
 PA0028452  
 Dunkard Bobtown STP

NPDES Permit No.

DUNKARD CREEK EVALUATION FROM MOUTH TO FERRY ELEMENTARY SCHOOL STP  
 FILE: DUNKARD CRK2.WQM6.3

DISCHARGER DATA  
 Q7-10 DESIGN CONDITIONS

RH	Q MGD	T (C)	PH	DO MG/L	CBOD5 MG/L	NH3-N MG/L	KC
1	.1	15.7	7.2	2	25	25	1.5
2	.15	15.7	7.2	2	25	25	1.5

REACH CHARACTERISTICS

RH	D.O. GOAL	KN (/D)	RCH. SL. (FT/FT)	RCH. LEN. (FT.)	DRAIN AREA (MI^2)	W/D
1	5	.6	1.5E-03	27500	201.531	
2	5	.6	1.7E-03	36000	225.726.7	

NPDES Permit Fact Sheet  
 PA0028452  
 Dunkard Bobtown STP

NPDES Permit No.

DUNKARD CREEK EVALUATION FROM MOUTH TO PERRY ELEMENTARY SCHOOL STP  
 FILE: DUNKARD CRK2.WQM6.3

REACH CHARACTERISTICS

RH	KR (/D)	TT (DAYS)
1	0	.5801
2	0	.9201

NH3-N DISCHARGE ALLOCATIONS AT Q30-10

DIS	Q (MGD)	IND. CONC. (MG/L)	ALL. CONC. (MG/L)	CRIT. RCH.	PCT. RED. (%)
1	.1	25	25	0	0
2	.15	25	25	0	0

**NPDES Permit Fact Sheet  
PA0028452  
Dunkard Bobtown STP**

**NPDES Permit No.**

DUNKARD CREEK EVALUATION FROM MOUTH TO PERRY ELEMENTARY SCHOOL STP  
FILE: DUNKARD CRK2.WQM6.3

NH3-N DISCHARGE ALLOCATIONS AT 01-10

DIS	Q (MGD)	IND. CONC. (MG/L)	ALL. CONC. (MG/L)	CRIT. RCH.	PCT. RED. (%)
1	.1	50	50	0	0
2	.15	50	50	0	0

MULTIPLE DISCHARGE LIMITATIONS

(TOTAL) DISCHARGE = .1 MGD  
 TEMP = 5.6 PH = 7.7  
 CBOD-5 = 2.05 NH3-N = 1.65 D.O. = 9.96  
 KC = 1.093 KN = .6 D.O. GOAL = 5  
 KR = 7.822 (TSIV06LOU)  
 DIS. 1 RCH. 1 TRVL TIME: .58

TR. TM. (DAYS)	CBOD-5 (MG/L)	NH3-N (MG/L)	D.O. (MG/L)
.058	1.98	1.63	10.5
.116	1.92	1.61	10.5
.174	1.86	1.59	10.5
.232	1.8	1.57	10.5
.29	1.74	1.56	10.5
.348	1.68	1.54	10.5
.406	1.63	1.52	10.5
.464	1.58	1.5	10.5
.522	1.53	1.49	10.5
.58	1.48	1.47	10.5

**NPDES Permit Fact Sheet**  
**PA0028452**  
**Dunkard Bobtown STP**

**NPDES Permit No.**

DUNKARD CREEK EVALUATION FROM MOUTH TO PERRY ELEMENTARY SCHOOL STP  
FILE: DUNKARD CRK2.WQM6.3

MULTIPLE DISCHARGE LIMITATIONS  
(TOTAL) DISCHARGE = .25 MGD  
TEMP = 6.3 PH = 7.6  
CBOD-5= 3.24 NH3-N= 3.19 D.O. = 9.83  
KC' = 1.222 KN= .6 D.O.GOAL = 5  
KR= 7.317 (TSIVOGLOU)  
DIS. 2 RCH. 2 TRVL TIME: .92

TR. TM. (DAYS)	CBOD-5 (MG/L)	NH3-N (MG/L)	D.O. (MG/L)
.092	3.05	3.13	10.5
.184	2.87	3.07	10.5
.276	2.7	3.01	10.5
.368	2.55	2.95	10.5
.46	2.4	2.9	10.5
.552	2.26	2.84	10.5
.644	2.13	2.79	10.5
.736	2	2.73	10.5
.828	1.89	2.68	10.5
.92	1.78	2.63	10.5

EFFLUENT LIMITATIONS DISPLAY

DIS #	Q MGD	NH3-N TOX.		DISS. OXYGEN		
		1 DAY	30 DAY	C-BOD5 30-DAY	NH3-N 30-DAY	EFF. D.O.
1	.1	50	25	25	25	2
2	.15	50	25	25	25	2

NPDES Permit Fact Sheet  
Dunkard Bobtown STP

NPDES Permit No. PA0028452

III. Effluent Limitations:

A. Outfall 001 @ DUNKARD CREEK B. Discharge Volume .150

Parameter (Sewage)	lbs/day			mg/l		
	Monthly Avg.	Weekly Avg.	Daily Max.	Monthly Avg.	Weekly Avg.	Instan. Max.
(Industrial Waste)	Daily Avg.		Daily Max.	Daily Avg.	Daily Max.	Instan. Max.
1. CBOD <sub>5</sub>	31.3	46.9		25	38	50
2. TSS	37.5	56.3		30	45	60
3. NH <sub>3</sub> -N						
4. 5/1 to 10/31	6.8	10.3		5.5	8.3	11.0
5. 11/1 to 4/30	20.6	30.9		16.5	24.8	33.0
6. pH				6.0	7.0	9.0
7. Fecal Coliforms						
8. 5/1 to 9/30				200/100 mL		
9. 10/1 to 4/30				<del>10</del> /100 mL		REF
10.				2000/100 mL		
11.						
12.						

Effluent Limitation Rational

- EPA Guidelines \_\_\_\_\_
- Regulation: WQM 6.3
- Water Quality Criteria CHAPT 93

Approvals

Reviewer Planning/WQ Raymond E. Lattum RENEWAL

2/25/02 REF  
11/17/07 REF  
Date 06/27/97

Geologist or Aquatic Biologist \_\_\_\_\_ Date \_\_\_\_\_

Chief Planning/WQ JRB RENEWAL

Date 7/10/97

JRB 3/6/02  
DOT 2/20/07

## WQM7.0 OUTPUT

**NPDES Permit Fact Sheet  
PA0028452  
Dunkard Bobtown STP**

**NPDES Permit No.**

SUMMER

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19G	41420	DUNKARD CREEK	12.030	880.00	201.50	0.00150	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.006	0.00	0.00	0.275	1.157	30.5	5.90	0.20	20.00	7.80	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Mt Morris STP	PA0096512	0.1000	0.1000	0.1000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**NPDES Permit Fact Sheet  
PA0028452  
Dunkard Bobtown STP**

**NPDES Permit No.**

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19G	41420	DUNKARD CREEK	0.100	778.10	251.00	0.00170	0.00	<input checked="" type="checkbox"/>

Design Cond.	LFY (cfs)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	35.0	0.00	0.00	20.00	7.80	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**NPDES Permit Fact Sheet**  
**PA0028452**  
**Dunkard Bobtown STP**

**NPDES Permit No.**

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
19G		41420				DUNKARD CREEK						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
12.030	1.21	0.00	1.21	.1547	0.00150	.2	5.89	29.46	1.16	0.276	20.57	7.60
6.810	1.35	0.00	1.35	.3868	0.00170	.23	8.31	36.14	0.91	0.450	21.11	7.46
<b>Q1-10 Flow</b>												
12.030	0.77	0.00	0.77	.1547	0.00150	NA	NA	NA	0.79	0.405	20.83	7.52
6.810	0.87	0.00	0.87	.3868	0.00170	NA	NA	NA	0.71	0.577	21.54	7.38
<b>Q30-10 Flow</b>												
12.030	1.64	0.00	1.64	.1547	0.00150	NA	NA	NA	1.52	0.209	20.43	7.64
6.810	1.84	0.00	1.84	.3868	0.00170	NA	NA	NA	1.26	0.324	20.87	7.52

**NPDES Permit Fact Sheet**  
**PA0028452**  
**Dunkard Bobtown STP**

**NPDES Permit No.**

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	85.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**NPDES Permit Fact Sheet**  
**PA0028452**  
**Dunkard Bobtown STP**

**NPDES Permit No.**

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
19G	41420	DUNKARD CREEK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	12.030 Mt Morris STP	5.33	32	5.33	24.9	2	22
	6.810 DBMA STP	5.62	26.62	6.1	20.71	2	22

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	12.030 Mt Morris STP	1.29	14.96	1.29	9.48	2	37
	6.810 DBMA STP	1.3	11.65	1.33	7.38	2	37

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	12.03 Mt Morris STP	25	25	9.48	9.48	3	3	0	0
	6.81 DBMA STP	25	25	7.38	7.38	3	3	0	0



**NPDES Permit Fact Sheet**  
**PA0028452**  
**Dunkard Bobtown STP**

**NPDES Permit No.**

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
19G		41420		DUNKARD CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
12.030	Mt Morris STP	PA0096512	0.100	CBOD5	25		
				NH3-N	9.48	18.96	
				Dissolved Oxygen			3
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
6.810	DBMA STP	PA0028452	0.150	CBOD5	25		
				NH3-N	7.38	14.76	
				Dissolved Oxygen			3

**NPDES Permit Fact Sheet**  
**PA0028452**  
**Dunkard Bobtown STP**

**NPDES Permit No.**

WINTER  
**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19G	41420	DUNKARD CREEK	12.030	880.00	201.50	0.00150	0.00	<input checked="" type="checkbox"/>

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.012	0.00	0.00	0.275	1.157	30.5	5.90	0.20	5.00	7.80	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Mt Morris STP	PA0096512	0.1000	0.1000	0.1000	0.000	20.00	7.00

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**NPDES Permit Fact Sheet**  
**PA0028452**  
**Dunkard Bobtown STP**

**NPDES Permit No.**

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19G	41420	DUNKARD CREEK	0.100	778.10	251.00	0.00170	0.00	<input checked="" type="checkbox"/>

Design Cond.	Stream Data											
	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Tributary pH	Stream Temp (°C)	Stream pH
Q7-10	0.100	0.00	0.00	0.000	0.000	35.0	0.00	0.00	5.00	7.80	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	20.00	7.00

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**NPDES Permit Fact Sheet**  
**PA0028452**  
**Dunkard Bobtown STP**

**NPDES Permit No.**

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
19G		41420				DUNKARD CREEK						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
12.030	2.42	0.00	2.42	.1547	0.00150	.2	11.11	55.57	1.16	0.276	5.90	7.68
6.810	2.71	0.00	2.71	.3868	0.00170	.23	14.78	64.25	0.91	0.450	6.87	7.58
<b>Q1-10 Flow</b>												
12.030	1.55	0.00	1.55	.1547	0.00150	NA	NA	NA	1.44	0.221	6.36	7.63
6.810	1.73	0.00	1.73	.3868	0.00170	NA	NA	NA	1.20	0.341	7.74	7.51
<b>Q30-10 Flow</b>												
12.030	3.29	0.00	3.29	.1547	0.00150	NA	NA	NA	2.92	0.109	5.67	7.71
6.810	3.69	0.00	3.69	.3868	0.00170	NA	NA	NA	2.31	0.178	6.42	7.62

**NPDES Permit Fact Sheet**  
**PA0028452**  
**Dunkard Bobtown STP**

**NPDES Permit No.**

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	85.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**NPDES Permit Fact Sheet  
PA0028452  
Dunkard Bobtown STP**

**NPDES Permit No.**

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
19G	41420	DUNKARD CREEK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	12.030 Mt Morris STP	10.31	50	10.31	50	0	0
	6.810 DBMA STP	10.95	50	12.31	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	12.030 Mt Morris STP	2.66	25	2.66	25	0	0
	6.810 DBMA STP	2.73	25	2.83	25	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	12.03 Mt Morris STP	25	25	25	25	3	3	0	0
	6.81 DBMA STP	25	25	25	25	3	3	0	0

**NPDES Permit Fact Sheet**  
**PA0028452**  
**Dunkard Bobtown STP**

**NPDES Permit No.**

**WQM 7.0 D.O. Simulation**

SWP Basin	Stream Code	Stream Name	
19G	41420	DUNKARD CREEK	

RMI	Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH
12.030	0.100	5.902	7.680
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
11.114	0.200	55.571	1.157
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
3.38	0.627	1.50	0.237
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
7.928	11.808	Tsivoglou	6
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>		
0.276	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)
			D.O. (mg/L)
	0.028	3.35	1.49
	0.055	3.32	1.48
	0.083	3.29	1.47
	0.110	3.26	1.46
	0.138	3.23	1.46
	0.165	3.20	1.45
	0.193	3.18	1.44
	0.220	3.15	1.43
	0.248	3.12	1.42
	0.276	3.09	1.41

RMI	Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH
6.810	0.250	6.874	7.579
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
14.778	0.230	64.250	0.911
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
4.63	0.866	3.04	0.255
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
7.850	10.779	Tsivoglou	6
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>		
0.450	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)
			D.O. (mg/L)
	0.045	4.53	3.01
	0.090	4.44	2.97
	0.135	4.34	2.94
	0.180	4.25	2.91
	0.225	4.16	2.87
	0.270	4.07	2.84
	0.315	3.99	2.81
	0.360	3.90	2.78
	0.405	3.82	2.75
	0.450	3.74	2.71

**NPDES Permit Fact Sheet**  
**PA0028452**  
**Dunkard Bobtown STP**

**NPDES Permit No.**

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
19G	41420	DUNKARD CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
12.030	Mt Morris STP	PA0096512	0.100	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
6.810	DBMA STP	PA0028452	0.150	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	0.15	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	31.3	47.6	XXX	25.0	38.0	50	1/week	8-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	1/week	8-Hr Composite
Total Suspended Solids	37.6	56.3	XXX	30.0	45.0	60	1/week	8-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Total Nitrogen	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	8-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date )

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia-Nitrogen Nov 1 - Apr 30	20.7	31.0	XXX	16.5	24.8	33	1/week	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	6.9	10.3	XXX	5.5	8.3	11	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	8-Hr Composite
Ultraviolet light dosage (mjoules/cm <sup>2</sup> )	XXX	XXX	XXX	Report	XXX	XXX	1/day	Measured

