

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0030597
APS ID 29413
Authorization ID 1346207

Applicant and Facility Information

| | | | |
|---------------------------|---|------------------|---|
| Applicant Name | <u>Franklin County General Authority</u> | Facility Name | <u>South Patrol Road STP</u> |
| Applicant Address | <u>5540 Coffey Avenue</u> <u>Chambersburg, PA 17201-4113</u> | Facility Address | <u>4759 Inovation Drive</u> <u>Chambersburg, PA 17201-4113</u> |
| Applicant Contact | <u>Ron Artley</u> | Facility Contact | <u>John Fetterhoff</u> |
| Applicant Phone | <u>(717) 267-6025</u> | Facility Phone | <u>(717) 267-6025</u> |
| Client ID | <u>119241</u> | Site ID | <u>532837</u> |
| Ch 94 Load Status | <u>Existing Organic Overload</u> | Municipality | <u>Letterkenny Township</u> |
| Connection Status | <u>No Limitations</u> | County | <u>Franklin</u> |
| Date Application Received | <u>March 16, 2021</u> | EPA Waived? | <u>No</u> |
| Date Application Accepted | <u>March 29, 2021</u> | If No, Reason | <u>Significant CB Discharge</u> |
| Purpose of Application | <u>NPDES Renewal.</u> | | |

Summary of Review

Franklin County General Authority (FCGA) has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on December 27, 2016 and became effective on January 1, 2017. The permit was amended on August 30, 2018 to correct the BOD loading specified in the original permit renewal. The permit will expire on December 31, 2021.

Based on the review, it is recommended that the permit be drafted.

Sludge use and disposal description and location(s): Sludge is treated onsite and then sent to a landfill

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Approve | Deny | Signatures | Date |
|---------|------|--|----------------|
| X | | <i>Jinsu Kim</i> Jinsu Kim / Environmental Engineering Specialist | August 2, 2021 |
| X | | Maria D. Bebenek for Daniel W. Martin Daniel W. Martin, P.E. / Environmental Engineer Manager | August 9, 2021 |
| X | | Maria D. Bebenek Maria D. Bebenek, P.E. / Program Manager | August 9, 2021 |

Discharge, Receiving Waters and Water Supply Information

| | | | |
|---|---------------------------|------------------------------|-------------------|
| Outfall No. | 001 | Design Flow (MGD) | .25 |
| Latitude | 39° 58' 58.47" | Longitude | -77° 41' 17.83" |
| Quad Name | Chambersburg | Quad Code | 1924 |
| Wastewater Description: Sewage Effluent | | | |
| Receiving Waters | Rocky Spring Branch (TSF) | Stream Code | 60038 |
| NHD Com ID | 49479816 | RMI | 2.78 |
| Drainage Area | 3.32 sq.mi | Yield (cfs/mi ²) | 0.111 |
| Q ₇₋₁₀ Flow (cfs) | See comments below | Q ₇₋₁₀ Basis | USGS gage 0614500 |
| Elevation (ft) | 583 | Slope (ft/ft) | |
| Watershed No. | 13-C | Chapter 93 Class. | TSF |
| Existing Use | None | Existing Use Qualifier | None |
| Exceptions to Use | None | Exceptions to Criteria | None |
| Assessment Status | Non-Attaining | | |
| Cause(s) of Impairment | See comments below | | |
| Source(s) of Impairment | See comments below | | |
| TMDL Status | | Name | |
| Nearest Downstream Public Water Supply Intake | Hagerstown, MD | | |
| PWS Waters | Potomac River | Flow at Intake (cfs) | |
| PWS RMI | | Distance from Outfall (mi) | 43.2 |

Drainage Area

The discharge is to Rocky Spring Branch at RM 2.78. A drainage area upstream of the discharge point is estimated to be 3.32 sq.mi. according to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

Streamflow

USGS StreamStats produced a Q₇₋₁₀ flow of 0.0323 cfs at the point of discharge. However, the estimated drainage area is lower than the required value to be used in regression equation, resulting in potential errors in calculations. Presumably, this is the reason a low flow yield method was used in the last permit renewal. This low flow yield method is shown below.

Nearest USGS Streamgage is 0614500 on Conococheague Creek near Fairview, MD. Recent stream flow retrievals resulted in a Q₇₋₁₀, Q₁₋₁₀, and Q₃₀₋₁₀ of 55.0 cfs, 48.1 cfs, and 65.3 cfs, respectively at this gage for record period of 1930-2008. The drainage area is reported to be 494 mi². These values were obtained from the latest USGS streamflow report. The drainage area at discharge point was found to be 3.35 mi² from StreamStats Version 3.0 Flow Statistics Ungaged Site Report on June 20, 2016.

$$\begin{aligned}
 Q_{7-10} \text{ runoff rate} &= 55.0/494 = 0.111 \text{ cfs/mi}^2 \\
 Q_{30-10}:Q_{7-10} &= 65.3/55 = 1.187:1 \\
 Q_{1-10}:Q_{7-10} &= 48.1/55 = 0.87:1 \\
 Q_{7-10} &= 0.111 * 3.35 = 0.372 \text{ cfs}
 \end{aligned}$$

This is a reasonable approach; although the drainage area used in this method is slightly different than the drainage area obtained during this renewal, this 3.35 sq.mi. will be used in this renewal for consistency purposes.

Rocky Spring Branch

Under 25 Pa Code §93.9z, Rocky Spring Branch is designated as trout stocking fishes and supports migratory fishes. No special protection waters are therefore impacted by this discharge. No Class A Wild Trout Fishery is impacted by this discharge. DEP's latest integrated water quality report issued in 2020 indicates that Rocky Spring Branch nearby the discharge point is impaired for siltation due to the rural area condition, agricultural activities and surface mining activities. The stream is also impaired for turbidity due to an unknown source. A TMDL has not yet been developed to address these impairments.

Public Water Supply Intake

The fact sheet developed for the last permit renewal indicates that the nearest downstream PWS is the Hagerstown intake located on the Potomac River, south of Williamsport, Maryland. The discharge is greater than 43.2 miles upstream from the intake. Given the distance, the discharge is not expected to impact the water supply.

| Treatment Facility Summary | | | | |
|---|-----------------------------------|---------------------------|----------------------------|-------------------------------|
| Treatment Facility Name: South Patrol Road STP | | | | |
| WQM Permit No. | Issuance Date | | | |
| 2810401 | February 11, 2011 | | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Secondary | Contact Stabilization | Ultraviolet | 0.25 |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.25 | 600 | Existing Organic Overload | Aerobic Digestion | Landfill |

FCGA owns and operates a sanitary wastewater treatment plant located at 2326 South Patrol Road Chambersburg in Greene/Letterkenny Townships, Franklin County. The plant serves Green Township (75%) and Letterkenny Township (25%) and all sewer systems are 100% separated. The plant also receives sanitary wastewater from certain buildings within the Letterkenny Army Depot. With the annual average design flow and hydraulic design capacity of 0.25 MGD, the plant utilizes an Aero-mod Sequox BNR system consisting of an EQ basin, fermentation tanks (2), fine aeration tanks (2), coarse aeration tanks (2), clarifiers (2), UV disinfection and outfall structure.

Digesters (2) and drying beds (4) are available for solids treatment. Solids are then sent to a landfill (Advance Disposal) for ultimate disposal. Caustic Soda and Alum are used for pH adjustment and phosphorus removal, respectively.

There are two (2) industrial/commercial users contributing wastewater into the sewer system; Volvo (0.008 MGD) and Access Lift (0.0045 MGD). The application indicates that the facility does not have an EPA-approved pretreatment program.

| Compliance History | |
|--------------------------------|--|
| Summary of DMRs: | A summary of past 12-month DMR data is presented on the next page. |
| Summary of Inspections: | 11/21/19 – Brandon Bettinger, DEP Water Quality Specialist, conducted an administrative inspection pertaining to a Chesapeake Bay TMDL monitoring results. Several errors/issues were noted and requested the permittee to resubmit the forms. No violation was noted at the time of inspection. 07/12/18 – Pat Bowen, former DEP Water Quality Specialist, conducted a routine inspection and noted that all treatment units appeared to be on-line and effluent appeared to be clear. No violation was noted at the time of inspection. 10/24/17 – Pat Bowen conducted a routine inspection and noted that no abnormal conditions were observed. No violation was noted at the time of inspection. |
| Other Comments: | DEP’s database revealed that there is no open violation associated with the permittee or facility. |

Effluent Date

DMR Data for Outfall 001 (from June 1, 2020 to May 31, 2021)

| Parameter | MAY-21 | APR-21 | MAR-21 | FEB-21 | JAN-21 | DEC-20 | NOV-20 | OCT-20 | SEP-20 | AUG-20 | JUL-20 | JUN-20 |
|--|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| Flow (MGD) Average Monthly | 0.08917 | 0.09687 | 0.12065 | 0.07543 | 0.07051 | 0.09323 | 0.07488 | 0.0775 | 0.09889 | 0.07989 | 0.06766 | 0.07409 |
| Flow (MGD) Daily Maximum | 0.17934 | 0.28513 | 0.40277 | 0.22046 | 0.16051 | 0.30855 | 0.16674 | 0.15965 | 0.1636 | 0.16341 | 0.11148 | 0.10318 |
| pH (S.U.) Daily Minimum | 6.9 | 7.0 | 6.8 | 6.8 | 6.6 | 6.6 | 6.2 | 6.8 | 6.7 | 6.7 | 6.9 | 6.8 |
| pH (S.U.) Instantaneous Maximum | 7.5 | 7.4 | 7.4 | 7.2 | 7.3 | 7.4 | 7.7 | 7.3 | 7.5 | 7.5 | 7.7 | 7.4 |
| DO (mg/L) Daily Minimum | 5.5 | 5.6 | 5.9 | 6.7 | 6.2 | 8.0 | 6.9 | 6.5 | 5.6 | 5.3 | 5.1 | 5.1 |
| CBOD5 (lbs/day) Average Monthly | < 3.3 | < 3.8 | < 11.5 | 4.5 | < 2.6 | < 3.7 | < 2.0 | < 2.3 | < 3.7 | < 3.3 | < 2.0 | < 1.9 |
| CBOD5 (lbs/day) Weekly Average | < 4.2 | < 5.9 | 32.0 | 7.8 | < 5.4 | < 8.9 | < 2.7 | < 2.9 | < 5.5 | < 5.3 | < 2.3 | < 2.0 |
| CBOD5 (mg/L) Average Monthly | < 4.0 | < 4.0 | < 8.5 | 9.6 | < 4.0 | < 4.0 | < 3.0 | < 3.8 | < 4.0 | < 4.0 | < 3.2 | < 3.0 |
| CBOD5 (mg/L) Weekly Average | < 4.0 | < 4.0 | 20.0 | 13.9 | < 4.0 | < 4.0 | < 4.0 | < 4.0 | < 4.0 | < 4.0 | 3.7 | < 3.0 |
| BOD5 (lbs/day) Raw Sewage Influent Average Monthly | 479 | 367 | 288 | 90 | 90 | 175 | 186 | 105 | 449 | 260 | 616 | 593 |
| BOD5 (lbs/day) Raw Sewage Influent Daily Maximum | 858 | 825 | 420 | 100 | 97 | 672 | 357 | 184 | 1240 | 502 | 951 | 920 |
| BOD5 (mg/L) Raw Sewage Influent Average Monthly | 622 | 417 | 282 | 198 | 212 | 261 | 279 | 174 | 497 | 299 | 925 | 955 |
| TSS (lbs/day) Average Monthly | 3.5 | 4.6 | 16.6 | 9.9 | 6.4 | 13.7 | 6.3 | 4.5 | < 7.9 | < 4.3 | < 4.1 | < 3.1 |
| TSS (lbs/day) Raw Sewage Influent Average Monthly | 547 | 550 | 323 | 114 | 60 | 153 | 85 | 77 | 312 | 465 | 1226 | 1615 |
| TSS (lbs/day) Raw Sewage Influent Daily Maximum | 1232 | 676 | 594 | 173 | 80 | 506 | 132 | 202 | 761 | 1509 | 2104 | 6590 |
| TSS (lbs/day) Weekly Average | 4.7 | 7.1 | 54.3 | 13.9 | 10.0 | 28.9 | 7.2 | 7.3 | 17.8 | 7.3 | 4.8 | < 3.4 |

**NPDES Permit Fact Sheet
South Patrol Road STP**

NPDES Permit No. PA0030597

| Parameter | MAY-21 | APR-21 | MAR-21 | FEB-21 | JAN-21 | DEC-20 | NOV-20 | OCT-20 | SEP-20 | AUG-20 | JUL-20 | JUN-20 |
|--|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|
| TSS (mg/L) Average Monthly | 4.5 | 5.5 | 10.5 | 20.8 | 10.3 | 16.1 | 9.6 | 7.3 | < 8.2 | < 5.1 | < 6.4 | < 5.0 |
| TSS (mg/L) Raw Sewage Influent Average Monthly | 644 | 663 | 357 | 239 | 114 | 222 | 128 | 120 | 329 | 416 | 1825 | 2680 |
| TSS (mg/L) Weekly Average | 6.4 | 9.8 | 18.0 | 28.0 | 12.8 | 21.0 | 10.8 | 10.0 | 15.0 | 5.5 | 8.0 | < 5.0 |
| Fecal Coliform (No./100 ml) Geometric Mean | < 2 | < 2 | < 5 | < 3 | < 1 | < 1 | < 2 | < 2 | < 4 | < 4 | < 4 | < 4 |
| Fecal Coliform (No./100 ml) Instantaneous Maximum | 3 | 17 | 222 | 16 | < 1 | 1 | 11 | 7 | 206 | 352 | 22 | 35 |
| UV Intensity (mW/cm ²) Daily Minimum | 7.8 | 6.55 | 2.25 | 1.45 | 1.9 | 2.75 | 6.0 | 4.65 | 2.75 | 9.25 | 9.55 | 7.7 |
| Nitrate-Nitrite (mg/L) Average Monthly | < 7.13 | < 12.69 | < 12.82 | 21 | < 22.43 | < 24.064 | < 28.82 | 27.88 | < 21.688 | 16.96 | < 9.266 | 9.184 |
| Nitrate-Nitrite (lbs) Total Monthly | < 195 | < 323 | < 442 | 332 | < 323 | < 483 | < 592 | 600 | < 546 | 362 | < 174 | 191 |
| Total Nitrogen (mg/L) Average Monthly | < 9.8 | < 14.3 | < 15.01 | 27.44 | < 25.08 | < 25.719 | < 29.84 | < 29.29 | < 23.164 | < 18.21 | < 10.781 | < 10.494 |
| Total Nitrogen (lbs) Effluent Net Total Monthly | < 260 | < 364 | < 516 | 451 | < 354 | < 520 | < 613 | < 632 | < 581 | < 390 | < 202 | < 218 |
| Total Nitrogen (lbs) Total Monthly | < 260 | < 364 | < 516 | 451 | < 354 | < 520 | < 613 | < 632 | < 581 | < 390 | < 202 | < 218 |
| Total Nitrogen (lbs) Effluent Net Total Annual | | | | | | | | | < 5088.0 | | | |
| Total Nitrogen (lbs) Total Annual | | | | | | | | | < 5088 | | | |
| Ammonia (lbs/day) Average Monthly | < 1.3 | < 0.6 | < 1.0 | 3.0 | < 0.6 | < 0.6 | < 0.3 | < 0.5 | < 0.3 | < 0.3 | < 0.4 | < 0.3 |
| Ammonia (mg/L) Average Monthly | < 1.62 | < 0.77 | < 1.42 | 5.17 | < 2.02 | < 0.83 | < 0.43 | < 0.88 | < 0.47 | < 0.38 | < 0.61 | < 0.44 |
| Ammonia (lbs) Total Monthly | < 41 | < 18 | < 43 | 97 | < 18.0 | < 17 | < 10 | < 17 | < 10 | < 8 | < 11 | < 9 |
| Ammonia (lbs) Total Annual | | | | | | | | | < 310 | | | |
| TKN (mg/L) Average Monthly | < 2.67 | < 1.61 | < 2.19 | 6.44 | < 2.65 | < 1.66 | < 1.03 | < 1.41 | < 1.48 | < 1.25 | < 1.52 | < 1.31 |
| TKN (lbs) Total Monthly | < 65 | < 40 | < 75 | 119 | < 31 | < 37 | < 21 | < 32 | < 36 | < 28 | < 28 | < 27 |

NPDES Permit Fact Sheet
South Patrol Road STP

NPDES Permit No. PA0030597

| Parameter | MAY-21 | APR-21 | MAR-21 | FEB-21 | JAN-21 | DEC-20 | NOV-20 | OCT-20 | SEP-20 | AUG-20 | JUL-20 | JUN-20 |
|---|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|
| Total Phosphorus (lbs/day) Average Monthly | 0.1 | 0.1 | 0.4 | 0.4 | 0.2 | 0.3 | 0.1 | 0.1 | 0.2 | 0.08 | 0.08 | 0.05 |
| Total Phosphorus (mg/L) Average Monthly | 0.14 | 0.13 | 0.27 | 0.75 | 0.36 | 0.39 | 0.19 | 0.17 | 0.25 | 0.102 | 0.136 | 0.07 |
| Total Phosphorus (lbs) Effluent Net Total Monthly | 4 | 3 | 11 | 11 | 6 | 9 | 4 | 4 | 7 | 2 | 2 | 1 |
| Total Phosphorus (lbs) Total Monthly | 4 | 3 | 11 | 11 | 6 | 9 | 4 | 4 | 7 | 2 | 2 | 1 |
| Total Phosphorus (lbs) Effluent Net Total Annual | | | | | | | | | < 56.0 | | | |
| Total Phosphorus (lbs) Total Annual | | | | | | | | | < 56 | | | |

Existing Effluent Limits and Monitoring Requirements

Tables below summarize effluent limits and monitoring requirements specified in the current NPDES permit renewal.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|----------------------|------------------|-----------------------|-----------------|----------------|------------------|-------------------------------|----------------------|
| | Mass Units (lbs/day) | | Concentrations (mg/L) | | | | Minimum Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | 9.0 Max | XXX | 1/day | Grab |
| Dissolved Oxygen | XXX | XXX | 5.0 | XXX | XXX | XXX | 1/day | Grab |
| CBOD5 | 52.0 | 83.0 | XXX | 25.0 | 40.0 | 50 | 1/week | 24-Hr Composite |
| BOD5 Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| Total Suspended Solids Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| Total Suspended Solids | 62.0 | 93.0 | XXX | 30.0 | 45.0 | 60 | 1/week | 24-Hr Composite |
| Fecal Coliform (No/100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | 10000 | 1/week | Grab |
| Fecal Coliform (No/100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 1/week | Grab |
| Ultraviolet light intensity (mW/cm ²) | XXX | XXX | Report | XXX | XXX | XXX | 1/day | Recorded |
| Ammonia-Nitrogen Nov 1 - Apr 30 | 18.0 | XXX | XXX | 9.0 | XXX | 18 | 2/week | 24-Hr Composite |
| Ammonia-Nitrogen May 1 - Oct 31 | 6.0 | XXX | XXX | 3.0 | XXX | 6 | 2/week | 24-Hr Composite |
| Total Phosphorus | 4.0 | XXX | XXX | 2.0 | XXX | 4 | 2/week | 24-Hr Composite |

Existing Effluent Limits and Monitoring Requirements (continued)

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|----------------------|---------------------------------|--------|-----------------------|-----------------|---------|------------------|--|----------------------|
| | Mass Units (lbs) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Monthly | Annual | Monthly | Monthly Average | Maximum | Instant. Maximum | | |
| Ammonia--N | Report | Report | XXX | Report | XXX | XXX | 2/week | 24-Hr Composite |
| Kjeldahl--N | Report | XXX | XXX | Report | XXX | XXX | 2/week | 24-Hr Composite |
| Nitrate-Nitrite as N | Report | XXX | XXX | Report | XXX | XXX | 2/week | 24-Hr Composite |
| Total Nitrogen | Report | Report | XXX | Report | XXX | XXX | 1/month | Calculation |
| Total Phosphorus | Report | Report | XXX | Report | XXX | XXX | 2/week | 24-Hr Composite |
| Net Total Nitrogen | Report | 9132.0 | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Net Total Phosphorus | Report | 1218.0 | XXX | XXX | XXX | XXX | 1/month | Calculation |

Development of Effluent Limitations and Monitoring Requirements

| | |
|---|---|
| Outfall No. <u>001</u> | Design Flow (MGD) <u>.25</u> |
| Latitude <u>39° 58' 58.52"</u> | Longitude <u>-77° 41' 17.90"</u> |
| Wastewater Description: <u>Sewage Effluent</u> | |

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |

Comments: UV disinfection is utilized; therefore, TRC effluent standards are not applicable.

Water Quality-Based Limitations

CBOD₅, NH₃-N and Dissolved Oxygen (DO)

WQM 7.0 is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD₅, NH₃-N and DO. DEP's guidance no. 391-2000-007 provides the technical methods contained in WQM 7.0 for conducting wasteload allocation and for determining recommended NPDES effluent limits for point source discharges. DEP recently updated this model (ver. 1.1) to include new ammonia criteria that has been approved by US EPA as part of the 2017 Triennial Review. The model output indicates that all existing effluent limits for these pollutants are still appropriate. No changes are therefore recommended.

Toxic Pollutants

This is a minor sewage facility with a design flow less than 1.0 MGD; therefore, only certain metals were required to be sampled as part of the application. The application reported non-detect results of Total Copper and Total Lead. Total Zinc was 0.043 mg/L which is lower than the current DEP water quality criteria (0.12 mg/L). No reasonable potential has been determined for these toxic pollutants.

Best Professional Judgment (BPJ) Limitations

Dissolved Oxygen

The existing minimum DO effluent limit is the current trout stocking fishery water quality criterion for DO listed in 25 Pa Code §93.7(a). It is recommended that this limit be maintained in the permit to ensure the protection of water quality standards. This approach is consistent with DEP's current Standard Operating Procedure (SOP) no. BPNPSM-PMT-033 and has been applied to other point source dischargers throughout the state.

Total Phosphorus

The existing permit contains average monthly and instantaneous maximum (IMAX) effluent limits of 2.0 mg/L and 4.0 mg/L, respectively. Historically a TP effluent limit of 2.0 mg/L was established in the permit when DEP generally determines that

the facility is expected to contribute 0.25% or more of the total point source phosphorus loading at the point of impact (page 17 of DEP's technical guidance no. 391-2000-018). DEP previously documented that the discharge contributes more than 0.25% and phosphorus controls were therefore needed. There is no reason to relax or remove these effluent limits; therefore, continuation of existing effluent limits is still appropriate in accordance with 40 CFR §122.44(l)(1).

Additional Considerations

Flow Monitoring Requirement

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

Influent BOD & TSS Monitoring Requirement

As a result of negotiation with EPA, the existing influent monitoring reporting requirement for TSS and BOD5 will be maintained in the draft permit. This requirement has been consistently assigned to all municipal wastewater treatment facilities.

E. Coli Monitoring Requirement

As recommended by DEP's SOP no. BPNPSM-PMT-033, a routine monitoring for E. Coli will be included in the permit under 25 Pa Code §92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/quarter will be included permit to be consistent with the recommendation from this SOP.

UV Monitoring Requirement

The existing UV monitoring requirement will remain unchanged in the permit. This requirement is recommended by DEP's SOP no. BPNPSM-PMT-033 and has been applied to all sewage facilities greater than 0.002 MGD that are equipped with the UV system.

Total Dissolved Solids (TDS)

TDS and its associated solids including Bromide, Chloride, and Sulfate have become statewide pollutants of concern. The requirement to monitor these pollutants must be considered under the criteria specified in 25 Pa. Code § 95.10 and the following January 23, 2014 DEP Central Office Directive:

For point source discharges and upon issuance or reissuance of an individual NPDES permit:

-Where the concentration of TDS in the discharge exceeds 1,000 mg/L, or the net TDS load from a discharge exceeds 20,000 lbs/day, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for TDS, sulfate, chloride, and bromide. Discharges of 0.1 MGD or less should monitor and report for TDS, sulfate, chloride, and bromide if the concentration of TDS in the discharge exceeds 5,000 mg/L.

-Where the concentration of bromide in a discharge exceeds 1 mg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for bromide. Discharges of 0.1 MGD or less should monitor and report for bromide if the concentration of bromide in the discharge exceeds 10 mg/L.

The permittee reported maximum concentrations of 513 mg/L for TDS and 0 mg/L for bromide. Accordingly, the requirement to monitor for these pollutants is not necessary.

Mass Loading Limitations

All effluent mass loading limits will be based on the formula: design flow x concentration limit x conversion factor of 8.34.

Chesapeake Bay TMDL

On March 30, 2012, DEP finalized Pennsylvania's Chesapeake Watershed Implementation Plan Phase 2 (i.e., Phase 2 WIP) to address U.S EPA's expectations for the Chesapeake Bay TMDL. The Chesapeake Bay TMDL identifies the necessary pollution reductions from major sources of nitrogen, phosphorus and sediment across the Bay jurisdictions and sets pollution limits necessary to meet water quality standards. The Phase 2 WIP is an update to the Pennsylvania's Chesapeake Bay TMDL Strategy (2004) and the Chesapeake WIP Phase I (2011). In August 2019, DEP finalized Phase 3 Chesapeake Bay Watershed Implementation Plan to provide the plans in place by 2025 to further achieve the nutrient and sediment reduction targets. The more details on the TMDL are available at www.dep.pa.gov.

**NPDES Permit Fact Sheet
South Patrol Road STP**

NPDES Permit No. PA0030597

As part of the Phase 3 WIP process, a Supplement to the Phase 3 WIP was developed, providing an update on TMDL implementation for point sources and a discussion of adjustments to the permitting strategy as a result of implementation experience. According to this document, Silver Spring Township WWTP is a Phase 3 significant discharger located within the Chesapeake Bay watershed. The following Cap Loads specified in the current Supplement to the Phase 3 WIP will be included in the draft permit:

| NPDES Permit No. | Phase | Facility | Latest Permit Issuance Date | Permit Expiration Date | Cap Load Compliance Start Date | TN Cap Load (lbs/yr) | TN Offsets Included in Cap Load (lbs/yr) | TP Cap Load (lbs/yr) | TN Delivery Ratio | TP Delivery Ratio |
|------------------|-------|-----------------------------------|-----------------------------|------------------------|--------------------------------|----------------------|--|----------------------|-------------------|-------------------|
| PA0030597 | 3 | Franklin County General Authority | 12/27/2016 | 12/31/2021 | 10/1/2012 | 9,132 | - | 1,218 | 0.683 | 0.67 |

Class A Wild Trout Fishery

A Class A Wild Trout stream is not impacted by this discharge.

Anti-backsliding Requirements

Unless stated otherwise in this fact sheet, all permit requirements proposed in this fact sheet are at least as stringent as those specified in the existing permit.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|-------------------------------------|-------------------------------------|------------------------|-----------------------|-----------------|---------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Monthly | Annual | Monthly | Monthly Average | Maximum | Instant. Maximum | | |
| Total Nitrogen (lbs) Effluent Net | XXX | 9132.0 Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |
| Total Nitrogen (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |
| Ammonia (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |
| Total Phosphorus (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |
| Total Phosphorus (lbs) Effluent Net | XXX | 1218.0 Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|------------------|-----------------------|------------------|----------------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Instant. Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/day | Grab |
| DO | XXX | XXX | 5.0 Daily Min | XXX | XXX | XXX | 1/day | Grab |
| CBOD5 | 52.0 | 83.0 | XXX | 25.0 | 40.0 | 50 | 1/week | 24-Hr Composite |
| BOD5 Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| TSS | 62.0 | 93.0 | XXX | 30.0 | 45.0 | 60 | 1/week | 24-Hr Composite |
| TSS Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | 10000 | 1/week | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 1/week | Grab |
| UV Intensity (mW/cm ²) | XXX | XXX | Report | XXX | XXX | XXX | 1/day | Recorded |
| Nitrate-Nitrite | XXX | XXX | XXX | Report | XXX | XXX | 2/week | 24-Hr Composite |
| Nitrate-Nitrite (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Total Nitrogen | XXX | XXX | XXX | Report | XXX | XXX | 1/month | Calculation |
| Total Nitrogen (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---------------------------|-------------------------------------|-------------------|-----------------------|--------------------|-------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Instant. Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Ammonia Nov 1 - Apr 30 | 18.0 | XXX | XXX | 9.0 | XXX | 18 | 2/week | 24-Hr Composite |
| Ammonia May 1 - Oct 31 | 6.0 | XXX | XXX | 3.0 | XXX | 6 | 2/week | 24-Hr Composite |
| Ammonia (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| TKN | XXX | XXX | XXX | Report | XXX | XXX | 2/week | 24-Hr Composite |
| TKN (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Total Phosphorus | 4.0 | XXX | XXX | 2.0 | XXX | 4 | 2/week | 24-Hr Composite |
| Total Phosphorus (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| E. Coli (No. / 100 mL) | XXX | XXX | Report Daily Min | XXX | XXX | XXX | 1/quarter | Grab |

Attachments


1. StreamStats

7/30/2021

StreamStats

StreamStats Report

Region ID: PA
 Workspace ID: PA20210730121828394000
 Clicked Point (Latitude, Longitude): 39.98284, -77.68834
 Time: 2021-07-30 08:18:44 -0400



| Basin Characteristics | | | |
|-----------------------|--|-------|-----------------------|
| Parameter Code | Parameter Description | Value | Unit |
| DRNAREA | Area that drains to a point on a stream | 3.32 | square miles |
| PRECIP | Mean Annual Precipitation | 39 | inches |
| STRDEN | Stream Density -- total length of streams divided by drainage area | 2.83 | miles per square mile |
| ROCKDEP | Depth to rock | 3 | feet |
| CARBON | Percentage of area of carbonate rock | 36.78 | percent |

<https://streamstats.usgs.gov/>

1/3

7/30/2021

StreamStats

Low-Flow Statistics Parameters [Low Flow Region 2]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|---------------------------|-------|-----------------------|-----------|-----------|
| DRNAREA | Drainage Area | 3.32 | square miles | 4.93 | 1280 |
| PRECIP | Mean Annual Precipitation | 39 | inches | 35 | 50.4 |
| STRDEN | Stream Density | 2.83 | miles per square mile | 0.51 | 3.1 |
| ROCKDEP | Depth to Rock | 3 | feet | 3.32 | 5.65 |
| CARBON | Percent Carbonate | 36.78 | percent | 0 | 99 |

Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report [Low Flow Region 2]

| Statistic | Value | Unit |
|-------------------------|--------|--------------------|
| 7 Day 2 Year Low Flow | 0.121 | ft ³ /s |
| 30 Day 2 Year Low Flow | 0.192 | ft ³ /s |
| 7 Day 10 Year Low Flow | 0.0323 | ft ³ /s |
| 30 Day 10 Year Low Flow | 0.0564 | ft ³ /s |
| 90 Day 10 Year Low Flow | 0.109 | ft ³ /s |

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

2. WQM 7.0 ver. 1.1

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|---------------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 13C | 60038 | ROCKY SPRING BRANCH | 2.780 | 583.00 | 3.35 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY (cfs) | Trib Flow (cfs) | Stream Flow (cfs) | Rich Trav Time (days) | Rich Velocity (fps) | WD Ratio | Rich Width (ft) | Rich Depth (ft) | Tributary | | Stream | |
|--------------|-----------|-----------------|-------------------|-----------------------|---------------------|----------|-----------------|-----------------|-----------|------|-----------|------|
| | | | | | | | | | Temp (°C) | pH | Temp (°C) | pH |
| Q7-10 | 0.111 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q90-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|-----------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| SouthPatrol STP | PA0030597 | 0.2500 | 0.2500 | 0.2500 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBCO5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 5.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 3.00 | 0.00 | 0.00 | 0.70 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|---------------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 13C | 60038 | ROCKY SPRING BRANCH | 2,570 | 574.00 | 3.48 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY (cfs) | Trib Flow (cfs) | Stream Flow (cfs) | Rich Trav Time (days) | Rich Velocity (fps) | WD Ratio | Rich Width (ft) | Rich Depth (ft) | Inletary | | Stream | |
|--------------|-----------|-----------------|-------------------|-----------------------|---------------------|----------|-----------------|-----------------|-----------|------|-----------|------|
| | | | | | | | | | Temp (°C) | pH | Temp (°C) | pH |
| Q7-10 | 0.111 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q90-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

| Discharge Data | | | | | | | |
|----------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 |

| Parameter Data | | | | |
|------------------|------------------|------------------|--------------------|--------------------|
| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | | <u>Stream Name</u> | | | | | | | |
|--------------------|-------------------|--------------------|-----------------------|--------------------------|---------------------|------------|------------|-----------|----------------|------------------------|--------------------|-------------|
| 13C | | 60088 | | | ROCKY SPRING BRANCH | | | | | | | |
| RM | Stream Flow (cfs) | PWS With (cfs) | Net Stream Flow (cfs) | Disc Analysis Flow (cfs) | Reach Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Reach Trav Time (days) | Analysis Temp (°C) | Analysis pH |
| Q7-10 Flow | | | | | | | | | | | | |
| 2.780 | 0.37 | 0.00 | 0.37 | 3868 | 0.00812 | 48 | 11 | 22.91 | 0.14 | 0.089 | 22.55 | 7.00 |
| Q1-10 Flow | | | | | | | | | | | | |
| 2.780 | 0.32 | 0.00 | 0.32 | 3868 | 0.00812 | NA | NA | NA | 0.14 | 0.093 | 22.72 | 7.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 2.780 | 0.44 | 0.00 | 0.44 | 3868 | 0.00812 | NA | NA | NA | 0.15 | 0.085 | 22.34 | 7.00 |

WQM 7.0 D.O. Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | |
|---------------------------------|-----------------------------------|----------------------------------|---------------------|-----------------------------|
| 13C | 60038 | ROCKY SPRING BRANCH | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | | <u>Analysis pH</u> |
| 2.760 | 0.250 | 22.549 | | 7.000 |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | | <u>Reach Velocity (fps)</u> |
| 11.001 | 0.480 | 22.912 | | 0.144 |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | | <u>Reach Kn (1/days)</u> |
| 13.73 | 1.385 | 1.53 | | 0.852 |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | | <u>Reach DO Goal (mg/L)</u> |
| 6.590 | 24.404 | Owens | | 5 |
| <u>Reach Travel Time (days)</u> | <u>Subreach Results</u> | | | |
| 0.089 | <u>TravTime (days)</u> | <u>CBOD5 (mg/L)</u> | <u>NH3-N (mg/L)</u> | <u>D.O. (mg/L)</u> |
| | 0.009 | 13.54 | 1.52 | 6.71 |
| | 0.018 | 13.35 | 1.51 | 6.81 |
| | 0.027 | 13.16 | 1.49 | 6.89 |
| | 0.036 | 12.98 | 1.48 | 6.96 |
| | 0.045 | 12.80 | 1.47 | 7.02 |
| | 0.054 | 12.63 | 1.46 | 7.08 |
| | 0.063 | 12.45 | 1.45 | 7.12 |
| | 0.071 | 12.28 | 1.44 | 7.16 |
| | 0.080 | 12.11 | 1.43 | 7.20 |
| | 0.089 | 11.94 | 1.42 | 7.23 |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.87 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.187 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 5 | | |

Monday, .

WQM 7.0 Wasteload Allocations

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |
|------------------|--------------------|---------------------|
| 13C | 60038 | ROCKY SPRING BRANCH |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|-----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 2.780 | SouthPatrol STP | 13.37 | 6 | 13.37 | 6 | 0 | 0 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|-----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 2.780 | SouthPatrol STP | 1.62 | 3 | 1.62 | 3 | 0 | 0 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | <u>CRD05</u> | | <u>NH3-N</u> | | <u>Dissolved Oxygen</u> | | Critical Reach | Percent Reduction |
|------|-----------------|-----------------|-----------------|-----------------|-----------------|-------------------------|-----------------|----------------|-------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 2.78 | SouthPatrol STP | 25 | 25 | 3 | 3 | 5 | 5 | 0 | 0 |

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | | <u>Stream Code</u> | | <u>Stream Name</u> | | | |
|------------------|-----------------|--------------------|-----------------|---------------------|-------------------------------|---------------------------|---------------------------|
| 19C | | 60038 | | ROCKY SPRING BRANCH | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Eff. Limit 30-day Ave. (mg/L) | Eff. Limit Maximum (mg/L) | Eff. Limit Minimum (mg/L) |
| 2.780 | SouthPatrol STP | PA0030597 | 0.250 | CBOD5 | 25 | | |
| | | | | NH3-N | 3 | 6 | |
| | | | | Dissolved Oxygen | | | 5 |

| Tools and References Used to Develop Permit | |
|---|--|
| <input type="checkbox"/> | WQM for Windows Model (see Attachment [redacted]) |
| <input type="checkbox"/> | Toxics Management Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | TRC Model Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 385-2000-011, 9/08. |
| <input type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97. |
| <input type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 391-2000-006, 9/97. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008. |
| <input type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999. |
| <input type="checkbox"/> | Design Stream Flows, 391-2000-023, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97. |
| <input type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input type="checkbox"/> | SOP: [redacted] |
| <input type="checkbox"/> | Other: [redacted] |