

Application Type	Renewal	
	Non-	
Facility Type	Municipal	
Major / Minor	Minor	

NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

Application No.	PA0035009
APS ID	528771
Authorization ID	1335470

Applicant and Facility Information

Applicant Name	Lake Lehman School District	Facility Name	Lake Lehman High School
Applicant Address	P.O. Box 38, 1237 Market Street	Facility Address	Old Route 115
	Lehman, PA 18627-0038		Lehman, PA 18627-0038
Applicant Contact	James McGovern, Superintendent	Facility Contact	Dave Madajewski, Director of Buildings and Grounds
Applicant Phone	(570) 675-2165	Facility Phone	(570) 255-2708
Client ID	28298	Site ID	_ 245767
Ch 94 Load Status	Not Overloaded	Municipality	Lehman Township
Connection Status		County	Luzerne
Date Application Receiv	vedDecember 2, 2020	EPA Waived?	Yes
Date Application Accep	ted December 15, 2020	If No, Reason	
Purpose of Application	Renewal of NPDES permit for disch	parge of treated sewage.	
·			

Summary of Review

The applicant is requesting the renewal of an NPDES permit to discharge up to 0.018 MGD of treated sewage into an Unnamed Tributary to East Fork Harveys Creek, a Cold-Water Fishery, Migratory Fish (CWF, MF) receiving stream in State Water Plan Basin 5-B (Wapwallopen Creek). As per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than its designated use. This stream segment is not designated as a naturally reproducing trout stream as per PA Fish & Boat Commission. This discharge is not expected to affect public water supplies.

Limitations for pH, CBOD₅, Total Suspended Solids (TSS), Fecal Coliform, and Dissolved Oxygen (DO) are technologybased and carried over from the previous permit.

Limitations for Ammonia-Nitrogen and Total Residual Chlorine (TRC) are water quality-based and carried over from the previous permit.

WQM 7.0 modeling and the TRC Calculation Spreadsheet did not recommend stricter limits.

Sewage discharges now require monitoring and reporting for E. Coli. A monitoring frequency of 1/month for design flows >= 1 MGD, 1/quarter for design flows >= 0.05 and < 1 MGD, 1/year for design flows of 0.002 – 0.05 MGD will be utilized.

The monthly monitoring and reporting for Total Nitrogen, Total Phosphorous, Total Kjeldahl Nitrogen, and Nitrate-Nitrite as N has been maintained in this permit.

Approve	Deny	Signatures	Date
х		/s/ Allison Seyfried / Environmental Engineering Specialist	December 8, 2021
х		/s/ Amy M. Bellanca, P.E. / Environmental Engineer Manager	12-17-21

Summary of Review

Monitoring frequencies for all parameters with limitations have been updated to the recommended frequencies found in Table 6-3 of DEP's Technical Guidance for the Development and Specification of Effluent Limitations (Document No. 362-0400-001).

The water quality-based limits were developed by modeling performed/revised in 1988. In that modeling, it was determined that the point of first use is at the confluence of the Unnamed Tributary to East Fork Harvey Creek with East Fork Harvey Creek. That modeling used Stream gage 0153700 (Toby Creek at Luzerne, PA) to calculate the effluent limits. The data from that stream gage is now outdated because the last year that flow data was obtained from the stream gage was in 1993.

The drainage area at Outfall 001 is too small for USGS StreamStats to estimate accurate low flow values. Therefore, the default Low Flow Yield (LFY) of 0.1 cfs/mi² was used to model the discharge and the same point of first use was used. For modeling inputs, RMI values were obtained using the "PA Historic Streams" feature of eMapPA, drainage areas were delineated using USGS's StreamStats Interactive Map, and elevations were obtained using the elevation profile feature of StreamStats.

The existing permit expired on May 31, 2021 and the application for renewal was received on time.

A Water Management System Inspection query indicated that on October 6, 2020 a Compliance Evaluation was performed.

There are currently 16 open violations, including one in the Clean Water Program, for this client that may need to be resolved before issuance of the final permit. The violation for Clean Water is:

1. 10/06/2020 - Violation ID 896235 – Violation Code 92A.41(A)10B – NPDES-Failure to utilize approved analytical methods. (Program Specific ID: PA0035009).

Sludge use and disposal description and location(s): As per the NPDES permit renewal application, sludge is hauled to the Wyoming Valley Sanitary Authority in Hanover, PA by Rural Wastewater.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No. 001		Design Flow (MGD)	0.018
Latitude 41º 18' 14.58"		Longitude	-76º 1' 11.08"
Quad NameHarveys Lake		Quad Code	0837
Wastewater Description: Se	ewage Effluent		
	d Tributary to East Fork		
Receiving Waters Harveys	Creek (CWF, MF)	Stream Code	28320
NHD Com ID65633015	5	RMI	1.24
Drainage Area 0.21 mi ²		Yield (cfs/mi ²)	0.1
Q ₇₋₁₀ Flow (cfs) 0.223		Q7-10 Basis	State-wide default
Elevation (ft) <u>1,236.50</u>		Slope (ft/ft)	
Watershed No. 5-B		Chapter 93 Class.	CWF, MF
Existing Use -		Existing Use Qualifier	-
Exceptions to Use -		Exceptions to Criteria	-
Assessment Status At	ttaining Use(s)		
Cause(s) of Impairment -			
Source(s) of Impairment -			
TMDL Status -		Name -	
Nearest Downstream Public W	/ater Supply Intake	Danville Borough Municipal Au	uthority
PWS Waters Susquehan	na River	Flow at Intake (cfs)	
PWS RMI <u>122.5</u>		Distance from Outfall (mi)	~ 50

	Trea	atment Facility Summa	ary	
reatment Facility Nar	ne: Lake Lehman School Di	istrict		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Aeration	Chlorination	0.00967 (2017-2019)
Hydraulic Capacity (MGD)	Organic Capacity (Ibs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposa
0.018	120	Not Overloaded	Settled	Hauled

Development of Effluent Limitations

Outfall No.	001		Design Flow (MGD)	0.018
Latitude	41º 18' 24.90	n	Longitude	-76º 1' 12.50"
Wastewater De	escription:	Sewage Effluent		

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25.0	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
CBOD5	50.0	IMAX	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended	30.0	Average Monthly	133.102(b)(1)	92a.47(a)(1)
Solids	60.0	IMAX	133.102(b)(2)	92a.47(a)(2)
pН	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
Dissolved Oxygen	5.0	Minimum	-	BPJ
E. Coli	Report	IMAX	-	92a.61

Water Quality-Based Limitations

The following limitations were determined through water quality modeling:

Parameter	Limit (mg/l)	SBC	Model
Total Residual Chlorine	1.1	IMAX	
Ammonia-Nitrogen	2.5	Average Monthly	
May 1 - Oct 31	5.0	IMAX	1989 Revised Modeling
Ammonia-Nitrogen	7.5	Average Monthly	
Nov 1 - Apr 30	15.0	IMAX	

Anti-Backsliding

No limitations were made less stringent.

Modeling with State-Wide default LFY at Point of First Use

$$\frac{0.1 \, ft^3/sec}{mi^2} \times 2.23 \, mi^2 = \frac{0.223 \, ft^3}{sec}$$

Modeling Using StreamStats

At Outfall 001 to Unnamed Tributary to East Harveys Creek (28320):

RMI	Elevation (ft)	Drainage Area (mi ²)	Q ₇₋₁₀ Flow (cfs)
1.24	1,236.50	0.21	-

StreamStats Report



Code	Parameter Description	Valu	e Unit
DRNAREA	Area that drains to a point on a stream	0.21	square miles
Statistic		Value	Unit
7 Day 2 Year Lo	ow Flow	0.193	ft^3/s
30 Day 2 Year L	ow Flow	0.273	ft^3/s
7 Day 10 Year L	ow Flow	0.0787	ft^3/s

At confluence with Drakes Creek:

RMI	Elevation (ft)	Drainage Area (mi ²)
0.65	864.5	7.13

StreamStats Report

Workspace ID: Clicked Point (Latitude, Longitude): Time: 2021-12-08 07:55:46 -0500 + - - - - - - - - - - - - -	Region ID:	PA
Time: 2021-12-08 07:55:46 -0500	Workspace ID:	PA20211208125511133000
t t t t t t t t t t t t t t	Clicked Point (Latitude, Longitude):	41.25630, -75.99543
Leiman Leiman Huke Swoyersvi Luzerne Edwardsville Kingston Dymouth	Time:	2021-12-08 07:55:46 -0500
Plymouth Wilkes-Barre	+	Concerned P
Plymouth		Wilkes Pare
		Plymouth.
And	Contraction of P	Leaflet Esri


Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	7.13	square miles

At confluence with East Fork Harveys Creek (point of first use) (28318):

RMI	Elevation (ft)	Drainage Area (mi ²)	Q ₇₋₁₀ Flow (cfs)
0.00	1.125	2.23	0.0787
3.69 (on East Fork Harveys Creek)	.,0	2.20	0.01.01

Low Flow Yield using StreamStats =
$$\frac{0.0787 \ ft^3/sec}{2.23 \ mi^2} = 0.0353 \ \frac{ft^3/sec}{mi^2}$$

StreamStats Report



Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	2.23	square miles

WQM 7.0 Effluent Limits

	SWP Basin Stream Code 05B 28318							
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)	
3.690	Lake Lehman SD	PA0035009	0.018	CBOD5	25			
				NH3-N	22.11	44.22		
				Dissolved Oxygen			3	

		A3:A9 and D3:D9				
0.223 = Q stream (cfs)		0.5	= CV Daily			
0.018 = Q discharge (MGD)		0.5	= CV Hourly			
30	= no. sample	s	1	= AFC_Partial N	lix Factor	
0.3	= Chlorine D	emand of Stream	1	= CFC_Partial N	lix Factor	
0	= Chlorine D	emand of Discharge	15	= AFC_Criteria	Compliance Time (min)	
0.5	= BAT/BPJ V	alue	720	= CFC_Criteria Compliance Time (min)		
0 = % Factor of Safety (FOS)			=Decay Coeffici	ent (K)		
Source	Reference	AFC Calculations		Reference	CFC Calculations	
TRC	1.3.2.iii	WLA afc = 2.574		1.3.2.iii	WLA cfc = 2.502	
PENTOXSD TRG	5.1a	LTAMULT afc = 0.373		5.1c	LTAMULT cfc = 0.581	
PENTOXSD TRG	5.1b	LTA_afc= 0.959		5.1d	LTA_cfc = 1.454	
Source		Efflue	nt Limit Calcul	lations		
PENTOXSD TRG	5.1f	AML MULT = 1.231				
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500 BAT/BPJ				
INST MAX LIMIT (mg/l) = 1.635						