

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0035637
 APS ID 860874
 Authorization ID 1412945

Applicant and Facility Information

Applicant Name	<u>PennDOT Bureau of Operations</u>	Facility Name	<u>Roadside Rest North Bound 55</u>
Applicant Address	<u>400 North Street, 6th Floor</u> <u>Harrisburg, PA 17105-3060</u>	Facility Address	<u>Rest Area No 55</u> <u>Greenfield Twp, PA 18411</u>
Applicant Contact	<u>Mark Bowen</u>	Facility Contact	<u>Sean Skeath</u>
Applicant Phone	<u>215-397-4055</u>	Facility Phone	<u>570-449-4538</u>
Client ID	<u>62162</u>	Site ID	<u>246168</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Greenfield Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Lackawanna</u>
Date Application Received	<u>October 6, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>October 6, 2022</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of existing NPDES permit to discharge treated sewage.</u>		

Summary of Review

This permit renewal has been through two 30-day public comment periods, from 5/24/2025 to 6/24/2025 and 7/12/2025 to 8/11/2025. Two comments were received from the permittee regarding the address used on the permit and the ammonia nitrogen (NH₃-N) daily maximum limits. The comments and responses are summarized on the next page of this fact sheet.

The applicant is requesting renewal of an individual NPDES permit to discharge 0.0098 MGD of treated sewage to Tributary 28884 of South Branch Tunkhannock Creek, a designated Cold-Water Fishes, Migratory Fishes (CWF-MF) receiving stream in state water plan basin 04-F (Tunkhannock Creek). This stream drains to Lackawanna Lake and eventually the Susquehanna River. The applicant's average reported discharge flow over the past 5 years has been 0.0023 MGD. As per the Departments Existing Use list, the receiving stream does not have a more protective existing use than the designated use. There is no TMDL for the receiving stream and it is currently attaining its designated use.

Both the WQM 7.0 and TRC Spreadsheet water quality modeling tools were used to evaluate the discharge. Stream gage 01533950 – South Branch Tunkhannock Creek near Montdale, PA, has flow history from 1962 – 1978 and was not used due to its age. Previous modeling utilized the DEP default LFY of 0.1 cfs/mi², however, USGS's StreamStats was able to calculate an LFY for the stream accurately, with a Q_{7/10} of 0.01 MGD and LFY of 0.027 MGD at the point of discharge. This new Q_{7/10} and LFY affected WQM 7.0 modeling results, creating a more stringent Ammonia-Nitrogen monthly average limit from 5 mg/L to 3.58 mg/L and an IMAX limit from 10 mg/L to 7.16 mg/L during the May to October period of the year. The winter months have been adjusted accordingly to match this change. The facility should still be able to maintain this requirement after review of past eDMR data. WQM 7.0 modeling did not result in more stringent limits for CBOD₅ or Dissolved Oxygen, so previous permit limits will be reused. The TRC Spreadsheet modeling did not result in more stringent limits for Total Residual Chlorine.

Total Phosphorus limits are water-quality based and carried over from the previous permit.

Approve	Deny	Signatures	Date
X		<i>Luca Jordache</i> Luca Jordache / Environmental Engineer Trainee	8/18/2025
X		<i>Edward Dudick</i> Edward Dudick, P.E. / Environmental Engineer Manager	August 18, 2025

Summary of Review

CBOD₅, TSS, pH, and Fecal Coliform limits are technology-based and carried over from the previous permit. A new technology-based limit was established for E. Coli that requires a sample to be reported at least once per year. All dischargers of sewage are now required to provide E. Coli reporting according to PA 25 Code §92a.61⁽¹¹⁾⁽¹²⁾.

Requirements for Nitrate+Nitrite-N and Total Kjeldahl Nitrogen are carried over from the previous permit to calculate the Total Nitrogen.

For this permit renewal, all monitoring frequencies are consistent with the DEP's *Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits* (Document no. 386-0400-001). Table 6-3 of this document contains the effluent self-monitoring frequency requirements for sewage discharges.

The previously issued permit for this operation expired on March 31, 2023, and the application for renewal was received on time. There are no currently open violations for the client that would warrant withholding the issuance of this permit. The EPA waiver is in effect.

The following attachments were used to aid in the determination of limits in this permit:



TRC
Calculations.pdf



Watershed
Information.pdf



WQM 7.0 Model
PA0035637.pdf



TRC Calc
Comparison.pdf

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Comments from Permittee: (Reply in Bold)

1. Please note that the contact information contained in this draft NPDES permit should be updated as follows: PennDOT Bureau of Operations, 400 North Street, 6th floor, Harrisburg, PA, 17120.

The address has been updated on all permit documents.

2. It is not appropriate to implement the peak instantaneous discharge limit as maximum day limit. The PADEP's WQM 7.0 Water Quality Model used to develop ammonia discharge limits only establishes monthly average and peak instantaneous limits. There does not appear to be any regulatory rationale for setting a maximum day discharge limit. We request that the proposed winter-time ammonia nitrogen maximum day limit of 18.0 mg/L be removed from the final NPDES Permit.

The daily maximum winter-time ammonia nitrogen limit was added to this permit to account for the inability of an 8-hr composite sample to be instantaneous and accurate in capturing the characteristics of discharge over the course of 24 hours. If the permittee requests to only have an IMAX limit without a daily max limit, the sample type must be changed to 24-hr composite. As per request of the permittee, the sample type for ammonia nitrogen will be changed to 24-hr composite and the daily maximum limit will be removed from the redrafted permit.

Discharge Information			
Outfall No.:	001	Design Flow (MGD):	0.0098
Latitude:	41° 36' 0.56"	Longitude:	-75° 38' 57.10"
Quad Name:	Dalton	Quad Code:	0640
Wastewater Description: Sewage Effluent			
Receiving Waters Information			
Receiving Waters:	Unnamed Tributary of South Branch Tunkhannock Creek (CWF, MF)	Stream Code:	28884
NHD Com ID:	66402579	RMI:	4.54 (DP to Lackawanna Lake)
Drainage Area:	0.54	Yield (cfs/mi ²):	0.027
Q ₇₋₁₀ Flow (cfs):	0.01	Q ₇₋₁₀ Basis:	StreamStats Calculation
Elevation (ft):	1183	Slope (ft/ft):	0.049
Watershed No.:	04-F	Chapter 93 Class.:	CWF, MF
Existing Use:	-	Existing Use Qualifier:	-
Exceptions to Use:	-	Exceptions to Criteria:	-
Assessment Status:	Attaining Use(s)		
Cause(s) of Impairment:	-		
Source(s) of Impairment:	-		
TMDL Status:	-	Name:	-
Water Supply Information			
Nearest Downstream Public Water Supply Intake:	Danville Municipal Water Authority		
PWS Waters:	Susquehanna River	Flow at Intake (cfs):	1160 (Q _{30/10})
PWS RMI:	107.05	Distance from Outfall (mi):	67.04

Treatment Facility Summary				
Treatment Facility Name: PA DOT - Rest Area 55				
WQM Permit No.	Issuance Date			
3590404	6/15/1990			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Gas Chlorine	0.0023 (2020-2025)
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0098	20.5	Not Overloaded	Aerated Sludge Holding	Hauled

Compliance History

DMR Data for Outfall 001 (from April 1, 2024 to March 31, 2025)

Parameter	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24
Flow (MGD) Average Monthly	0.0037	0.0037	0.0035	0.0039	0.0034	0.0055	0.0043	0.0025	0.0026	0.0018	0.0019	0.0019
Flow (MGD) Daily Maximum	0.0088	0.0148	0.0118	0.0092	0.009	0.0133	0.0077	0.0092	0.0047	0.0036	0.006	0.006
pH (S.U.) Minimum	6.9	7.0	7.0	6.8	7.4	7.5	6.8	6.1	7.1	6.9	6.6	6.6
pH (S.U.) Instantaneous Maximum	8.5	7.7	8.1	8.7	8.2	8.2	7.9	8.7	8.1	7.8	7.7	7.7
DO (mg/L) Minimum	7.3	9.5	9.7	6.0	6.6	6.1	4.5	5.0	5.3	6.0	6.2	6.2
TRC (mg/L) Average Monthly	< 0.1	0.2	0.1	0.3	0.2	0.2	0.2	0.1	0.2	0.2	0.2	0.2
TRC (mg/L) Instantaneous Maximum	0.4	0.63	0.6	0.9	0.5	0.6	0.6	0.6	0.6	0.8	1.0	1.0
CBOD5 (mg/L) Average Monthly	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0	< 6.0
TSS (mg/L) Average Monthly	< 6.9	6.7	< 5.0	15.4	< 5.9	5.4	9.2	20.0	< 8.7	14.2	< 6.6	< 6.6
Fecal Coliform (No./100 ml) Geometric Mean	< 5	< 1	33	< 1	< 1	< 1	1	< 3	< 6	< 1	< 1	< 1
Fecal Coliform (No./100 ml) Instantaneous Maximum	21.6	< 1	1120	< 1	< 1	< 1	1	6.3	32.7	< 1	< 1	< 1
Nitrate-Nitrite (mg/L) Average Monthly	< 77.4	< 53.4	< 64.6	< 103.5	< 139.1	< 138.6	< 96.5	< 115.79	< 95.4	< 108.72	< 108.3	< 108.3
Total Nitrogen (mg/L) Average Monthly	< 78.4	< 54.4	< 65.6	< 104.5	< 142.1	< 139.6	< 97.5	< 116.79	< 97.32	< 109.72	< 109.3	< 109.3
Ammonia (mg/L) Average Monthly	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	0.6	< 0.6	< 1.0	< 0.6	1.0	1.0
TKN (mg/L) Average Monthly	< 1.0	< 1	< 1	< 1	< 3.0	< 1	< 1	< 1	< 1.92	< 1	< 1	< 1
Total Phosphorus (mg/L) Average Monthly	0.5	0.2	0.1	0.3	0.2	0.3	0.3	0.4	0.9	0.6	0.8	0.8

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.0098</u>
Latitude <u>41° 36' 1.00"</u>	Longitude <u>-75° 38' 53.00"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	50	IMAX	-	-
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	60	IMAX	-	-
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
	1,000 / 100 ml	IMAX	-	-
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
	10,000 / 100 ml	IMAX	-	-
E. Coli	Report	IMAX	-	92a.61

Comments: E. Coli is a recently added contaminant to the TBEL list that is now required for all dischargers of treated sewage to report at least once per year.

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Dissolved Oxygen	4.0	Minimum	WQM 7.0
Ammonia-Nitrogen (5/1 – 10/31)	3.58	Average Monthly	WQM 7.0
	7.16	IMAX	
Ammonia-Nitrogen (11/1 – 4/30)	10.74	Average Monthly	WQM 7.0
	21.48	IMAX	
Total Residual Chlorine (TRC)	0.4	Average Monthly	TRC Spreadsheet
	1.0	IMAX	
Total Phosphorus	2.0	Average Monthly	Previous Modeling
	4.0	IMAX	

Comments: The limits for Ammonia-Nitrogen have been adjusted after re-modeling the discharge and stream via WQM 7.0. The new limits should still be attainable for this facility after reviewing eDMR data over the past 5 years for Ammonia-Nitrogen levels. See attached WQM 7.0 results for more information.

Anti-Backsliding

Most limits remained unchanged from the previous permit, with TRC getting slightly more restrictive. Due to anti-backsliding policy, limits may not be loosened without a strong argument and evidence for doing so.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.4	XXX	1.0	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	50 (Daily Max)	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	60 (Daily Max)	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	Calculation
Ammonia Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	10.74	XXX	21.48	2/month	24-Hr Composite
Ammonia Nitrogen May 1 - Oct 31	XXX	XXX	XXX	3.58	XXX	7.16	2/month	24-Hr Composite

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
TKN	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	2.0	4 (Daily Max)	4	2/month	8-Hr Composite

Compliance Sampling Location: Samples must be taken at the point of contact between discharge and the receiving waters (Unnamed Tributary of South Branch Tunkhannock Creek).

Tools and References Used to Develop Permit	
<input type="checkbox"/>	 WQM 7.0 Model PA0035637.pdf) WQM for Windows Model (see Attachment
<input type="checkbox"/>	 TRC Calculations.pdf) TRC Model Spreadsheet (see Attachment
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	   TECHNICAL_GUIDA NCE_FOR_THE_DEVE SOP: Individual Sewage SOP - Effluent Limits Individual NPDES SOP - Sewage (Versi
<input type="checkbox"/>	  Watershed Information.pdf TRC Calc Comparison.pdf Other: