

Application Type Renewal
 Facility Type Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0038130
 APS ID 1140520
 Authorization ID 1532491

Applicant and Facility Information

Applicant Name	<u>Mont Alto Municipal Authority</u>	Facility Name	<u>Mont Alto STP</u>
Applicant Address	<u>3 North Main Street</u> <u>Mont Alto, PA 17237</u>	Facility Address	<u>6341 Anthony Highway</u> <u>Mont Alto, PA 17237</u>
Applicant Contact	<u>Curtis Finney</u>	Facility Contact	<u>Mason Fogelsonger</u>
Applicant Phone	<u>(717) 749-5808</u>	Facility Phone	<u>(717) 749-5808</u>
Client ID	<u>146517</u>	Site ID	<u>446000</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Quincy Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Franklin</u>
Date Application Received	<u>June 25, 2025</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>July 1, 2025</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES Renewal.</u>		

Summary of Review

Mont Alto Municipal Authority (MAMA) has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on April 19, 2021 and became effective on May 1, 2021. The permit will expire on April 30, 2026.

Based on the review, it is recommended that the permit be drafted.

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Jinsu Kim</i> Jinsu Kim / Environmental Engineering Specialist	December 8, 2025
X		<i>Daniel W. Martin</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	January 14, 2026

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.30</u>
Latitude	<u>39° 50' 4.55"</u>	Longitude	<u>77° 34' 10.27"</u>
Quad Name	<u>Waynesboro</u>	Quad Code	<u>2025</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>West Branch Antietam Creek</u>	Stream Code	<u>59258</u>
NHD Com ID	<u>49486714</u>	RMI	<u>10.17</u>
Drainage Area	<u>7.87 sq. mi.</u>	Yield (cfs/mi ²)	<u>0.196</u>
Q7-10 Flow (cfs)	<u>1.54</u>	Q7-10 Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u>788</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>13-C</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>See comments below</u>		
Cause(s) of Impairment	<u>See comments below</u>		
Source(s) of Impairment	<u>See comments below</u>		
TMDL Status	<u>Final</u>	Name	<u>West Branch Antietam Creek TMDL</u>
Nearest Downstream Public Water Supply Intake	<u>City of Brunswick</u>		
PWS Waters	<u></u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u></u>	Distance from Outfall (mi)	<u>>50</u>

Drainage Area

The discharge is to West Branch Antietam Creek at RM 10.17. A drainage area upstream of the point of discharge is estimated to be 7.87 sq.mi using USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

Streamflow

USGS StreamStats produced a Q7-10 flow of 1.54 cfs at the point of discharge.

West Branch Antietam Creek

Under 25 PA Code §93.9z, West Branch Antietam Creek from SR 997 Bridge to Confluence with East Branch Antietam Creek is designated as cold water fishes. No special protection water is therefore impacted by this discharge. DEP's latest integrated water quality report shows that just downstream of the point of discharge, the stream is impaired for siltation and nutrients as a result of agricultural activities and water/flow variability as a result of small residential runoff. The permit will be developed to ensure that the discharge does not cause or contribute to these impairments. West Branch Antietam Creek is mainly impaired for sediment and nutrients particularly Total Phosphorus. As a result, DEP developed a Total Maximum Daily Load (TMDL) in December 2010 to address this impairment listings. This TMDL has a wasteload allocation (WLA) for this facility. More details on this TMDL WLA will be discussed later in this fact sheet.

Public Water Supply Intake

The fact sheet developed for the last permit renewal indicates that the nearest downstream water supply intake is for the City of Brunswick on the Potomac River. The distance downstream from the outfall to the intake is over 50 miles. Due to the distance and dilution, the discharge is not expected to impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Mont Alto STP				
WQM Permit No.	Issuance Date			
2810402	09/13/2010			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	SBR	Ultraviolet (UV)	0.30
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.450	688	Not Overloaded	Aerobic Digestion	Land Application

MAMA owns and operates a municipal wastewater treatment plant serving the Mont Alto Borough (95%) and Quincy Township (5%). All sewer systems are 100% separated. The treatment plant utilizes a sequencing batch reactor activated sludge treatment process consisting of fine screen, SBRs (2), UV disinfection and an outfall structure. The facility is rated for 0.30 MGD as annual average design flow and 0.45 MGD as hydraulic design capacity.

Alum is used for phosphorous removal. Sludge is processed via an on-site aerobic digester and then is land applied as Class B material to agricultural land under NPDES PAG083590. According to the application, the facility receives about 5 GPD of wastewater from an industrial user known as Blue Ridge Mountain Cookery (metal fabrication company). The facility does not have an EPA-approved pretreatment program at this time.

Compliance History																																																																																																																	
Summary of DMRs:	A summary of past 12-month DMR data is presented on the next page.																																																																																																																
Summary of Inspections:	04/20/2022: DEP conducted a routine inspection. No significant violation was identified at the time of inspection.																																																																																																																
Other Comments:	<p>Since the last permit reissuance, this facility had a number of permit violations mostly associated with effluent limit violations. These violations are listed below.</p> <table border="1"> <thead> <tr> <th>Date</th> <th>Description</th> <th>Parameter</th> <th>Results</th> <th>Limits</th> <th>Units</th> <th>SBC</th> </tr> </thead> <tbody> <tr> <td>5/1/2021</td> <td>Violation of permit schedule</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>5/1/2021</td> <td>Violation of permit condition</td> <td>Ammonia-Nitrogen</td> <td>20</td> <td>16.3</td> <td>lbs/day</td> <td>Average Monthly</td> </tr> <tr> <td>5/1/2021</td> <td>Violation of permit condition</td> <td>Ammonia-Nitrogen</td> <td>25</td> <td>6.5</td> <td>mg/L</td> <td>Average Monthly</td> </tr> <tr> <td>6/1/2021</td> <td>Violation of permit condition</td> <td>Ammonia-Nitrogen</td> <td>11</td> <td>6.5</td> <td>mg/L</td> <td>Average Monthly</td> </tr> <tr> <td>6/1/2023</td> <td>Violation of permit condition</td> <td>Total Phosphorus</td> <td>2.5</td> <td>2</td> <td>mg/L</td> <td>Average Monthly</td> </tr> <tr> <td>7/1/2023</td> <td>Violation of permit condition</td> <td>Fecal Coliform</td> <td>2420</td> <td>1000</td> <td>No./100 ml</td> <td>Instantaneous Maximum</td> </tr> <tr> <td>7/1/2023</td> <td>Violation of permit condition</td> <td>Total Phosphorus</td> <td>2.1</td> <td>2</td> <td>mg/L</td> <td>Average Monthly</td> </tr> <tr> <td>11/1/2023</td> <td>Violation of permit condition</td> <td>Total Phosphorus</td> <td>2.48</td> <td>2</td> <td>mg/L</td> <td>Average Monthly</td> </tr> <tr> <td>5/1/2024</td> <td>Violation of permit condition</td> <td>Ammonia-Nitrogen</td> <td>10.1</td> <td>6.5</td> <td>mg/L</td> <td>Average Monthly</td> </tr> <tr> <td>11/1/2024</td> <td>Violation of permit condition</td> <td>Total Phosphorus</td> <td>3.3</td> <td>2</td> <td>mg/L</td> <td>Average Monthly</td> </tr> <tr> <td>12/1/2024</td> <td>Violation of permit condition</td> <td>Total Phosphorus</td> <td>2.7</td> <td>2</td> <td>mg/L</td> <td>Average Monthly</td> </tr> <tr> <td>1/1/2025</td> <td>Violation of permit condition</td> <td>Total Phosphorus</td> <td>2.9</td> <td>2</td> <td>mg/L</td> <td>Average Monthly</td> </tr> <tr> <td>2/1/2025</td> <td>Violation of permit condition</td> <td>Total Phosphorus</td> <td>2.4</td> <td>2</td> <td>mg/L</td> <td>Average Monthly</td> </tr> <tr> <td>7/1/2025</td> <td>Violation of permit condition</td> <td>Total Phosphorus</td> <td>2.1</td> <td>2</td> <td>mg/L</td> <td>Average Monthly</td> </tr> <tr> <td>10/1/2025</td> <td>Violation of permit condition</td> <td>Total Phosphorus</td> <td>2.2</td> <td>2</td> <td>mg/L</td> <td>Average Monthly</td> </tr> </tbody> </table> <p>DEP's database shows there is no open violation associated with this facility or permittee.</p>	Date	Description	Parameter	Results	Limits	Units	SBC	5/1/2021	Violation of permit schedule						5/1/2021	Violation of permit condition	Ammonia-Nitrogen	20	16.3	lbs/day	Average Monthly	5/1/2021	Violation of permit condition	Ammonia-Nitrogen	25	6.5	mg/L	Average Monthly	6/1/2021	Violation of permit condition	Ammonia-Nitrogen	11	6.5	mg/L	Average Monthly	6/1/2023	Violation of permit condition	Total Phosphorus	2.5	2	mg/L	Average Monthly	7/1/2023	Violation of permit condition	Fecal Coliform	2420	1000	No./100 ml	Instantaneous Maximum	7/1/2023	Violation of permit condition	Total Phosphorus	2.1	2	mg/L	Average Monthly	11/1/2023	Violation of permit condition	Total Phosphorus	2.48	2	mg/L	Average Monthly	5/1/2024	Violation of permit condition	Ammonia-Nitrogen	10.1	6.5	mg/L	Average Monthly	11/1/2024	Violation of permit condition	Total Phosphorus	3.3	2	mg/L	Average Monthly	12/1/2024	Violation of permit condition	Total Phosphorus	2.7	2	mg/L	Average Monthly	1/1/2025	Violation of permit condition	Total Phosphorus	2.9	2	mg/L	Average Monthly	2/1/2025	Violation of permit condition	Total Phosphorus	2.4	2	mg/L	Average Monthly	7/1/2025	Violation of permit condition	Total Phosphorus	2.1	2	mg/L	Average Monthly	10/1/2025	Violation of permit condition	Total Phosphorus	2.2	2	mg/L	Average Monthly
Date	Description	Parameter	Results	Limits	Units	SBC																																																																																																											
5/1/2021	Violation of permit schedule																																																																																																																
5/1/2021	Violation of permit condition	Ammonia-Nitrogen	20	16.3	lbs/day	Average Monthly																																																																																																											
5/1/2021	Violation of permit condition	Ammonia-Nitrogen	25	6.5	mg/L	Average Monthly																																																																																																											
6/1/2021	Violation of permit condition	Ammonia-Nitrogen	11	6.5	mg/L	Average Monthly																																																																																																											
6/1/2023	Violation of permit condition	Total Phosphorus	2.5	2	mg/L	Average Monthly																																																																																																											
7/1/2023	Violation of permit condition	Fecal Coliform	2420	1000	No./100 ml	Instantaneous Maximum																																																																																																											
7/1/2023	Violation of permit condition	Total Phosphorus	2.1	2	mg/L	Average Monthly																																																																																																											
11/1/2023	Violation of permit condition	Total Phosphorus	2.48	2	mg/L	Average Monthly																																																																																																											
5/1/2024	Violation of permit condition	Ammonia-Nitrogen	10.1	6.5	mg/L	Average Monthly																																																																																																											
11/1/2024	Violation of permit condition	Total Phosphorus	3.3	2	mg/L	Average Monthly																																																																																																											
12/1/2024	Violation of permit condition	Total Phosphorus	2.7	2	mg/L	Average Monthly																																																																																																											
1/1/2025	Violation of permit condition	Total Phosphorus	2.9	2	mg/L	Average Monthly																																																																																																											
2/1/2025	Violation of permit condition	Total Phosphorus	2.4	2	mg/L	Average Monthly																																																																																																											
7/1/2025	Violation of permit condition	Total Phosphorus	2.1	2	mg/L	Average Monthly																																																																																																											
10/1/2025	Violation of permit condition	Total Phosphorus	2.2	2	mg/L	Average Monthly																																																																																																											

Effluent Data

DMR Data for Outfall 001 (from November 1, 2024 to October 31, 2025)

Parameter	OCT-25	SEP-25	AUG-25	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24
Flow (MGD) Average Monthly	0.0777	0.0725	0.0780	0.0825	0.1051	0.1522	0.0874	0.0806	0.0929	0.0777	0.0879	0.0845
Flow (MGD) Daily Maximum	0.1555	0.0891	0.1605	0.1736	0.2625	0.4451	0.1592	0.14	0.1697	0.0951	0.176	0.1495
pH (S.U.) Instantaneous Minimum	6.59	6.79	6.68	6.67	6.86	6.84	6.58	6.55	6.25	6.74	6.89	6.75
pH (S.U.) Instantaneous Maximum	7.16	7.35	7.40	7.38	7.65	7.39	7.05	7.1	7.15	7.68	7.44	7.37
DO (mg/L) Daily Minimum	5.21	6.30	5.27	5.08	5.17	5.46	5.09	5.05	5.06	5.05	5.06	5.08
CBOD5 (lbs/day) Average Monthly	2	3	2	2	5	5	2	2	2	1	2	2
CBOD5 (lbs/day) Weekly Average	3	3	2	3	6	5	2	2	2	1	2	2
CBOD5 (mg/L) Average Monthly	4.0	5.0	3.0	4.0	3.0	3.0	3.0	3.0	2.0	2.0	3.0	3.0
CBOD5 (mg/L) Weekly Average	5.0	5.0	4.0	5.0	3.0	3.0	3.0	4.0	2.0	3.0	3.0	3.0
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	292	692	351	144	227	482	363	299	290	296	248	276
BOD5 (mg/L) Raw Sewage Influent Average Monthly	478	1125	615	230	149	296	499	505	430	517	370	419
TSS (lbs/day) Average Monthly	4	0.9	1	2	3	6	3	0.9	2	0.6	2	2
TSS (lbs/day) Raw Sewage Influent Average Monthly	402	431	548	141	271	667	335	376	390	199	197	459
TSS (lbs/day) Weekly Average	4	1	1	2	5	9	5	1	2	0.6	3	2
TSS (mg/L) Average Monthly	7.0	2.0	2.0	3.0	2.0	4.0	5.0	2.0	3.0	1.0	3.0	3.0
TSS (mg/L) Raw Sewage Influent Average Monthly	656	700	965	224	170	406	470	626	580	344	294	678

**NPDES Permit Fact Sheet
Mont Alto STP**

NPDES Permit No. PA0038130

Parameter	OCT-25	SEP-25	AUG-25	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24
TSS (mg/L) Weekly Average	7.0	2.0	2.0	4.0	3.0	5.0	7.0	2.0	3.0	1.0	4.0	4.0
Fecal Coliform (No./100 ml) Geometric Mean	12	3	1	1	3	20	4	1	1	1	1	21
Fecal Coliform (No./100 ml) Instantaneous Maximum	28	11	1	2	9	65	5	1	1	1	1	23
Nitrate-Nitrite (lbs/day) Average Monthly	4	2	1	2	6	6	2	2.0	3	4	8	13
Nitrate-Nitrite (mg/L) Average Monthly	6.36	2.5	2.4	2.6	4.2	4	2.6	2.6	4.7	6.2	11.4	20.4
Total Nitrogen (lbs/day) Average Monthly	5	2	2	2	7	8	3	2.0	4	4	8	14
Total Nitrogen (mg/L) Average Monthly	7.95	3.06	2.9	3.42	4.7	5.2	4.1	4.0	5.9	7.77	12.3	21.6
Ammonia (lbs/day) Average Monthly	0.06	0.06	0.06	0.06	0.2	0.2	0.07	0.06	0.07	0.06	0.07	0.07
Ammonia (mg/L) Average Monthly	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
TKN (lbs/day) Average Monthly	1	0.3	0.3	0.5	0.8	2	1	0.8	0.8	0.9	0.6	0.8
TKN (mg/L) Average Monthly	1.6	0.56	0.5	0.82	0.5	1.2	1.6	1.4	1.2	1.62	0.9	1.2
Total Phosphorus (lbs/day) Average Monthly	1.0	1.0	0.7	1.0	2.0	2.0	1.0	0.7	2.0	2.0	2.0	2.0
Total Phosphorus (mg/L) Average Monthly	2.2	2.0	1.3	2.1	1.21	1.3	1.6	1.2	2.4	2.9	2.7	3.3
UV Dosage (mWsec/cm ²) Daily Minimum	25.2	25.2	25.2	25.2	25.2	25.2	25.2	25.2	25.2	25.2	25.2	25.2

Existing Effluent Limits and Monitoring Requirements

The table below summarizes effluent limitations and monitoring requirements implemented in the existing NPDES permit.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Daily Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	63	100	XXX	25.0	40.0	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Suspended Solids	75	113	XXX	30.0	45.0	60	2/month	8-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Ammonia-Nitrogen Nov 1 - Apr 30	48.9	XXX	XXX	19.5	XXX	39	2/month	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	16.3	XXX	XXX	6.5	XXX	13	2/month	8-Hr Composite
Total Kjeldahl Nitrogen	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus	5.0	XXX	XXX	2.0	XXX	4	2/month	8-Hr Composite
Ultraviolet light dosage (mWsec/cm ²)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Recorded

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>.3</u>
Latitude <u>39° 50' 4.56"</u>	Longitude <u>-77° 34' 10.28"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: Since the facility utilizes UV disinfection, the total residual chlorine standard is not applicable.

Water Quality-Based Limitations

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD₅, NH₃-N and DO. DEP's technical guidance no. 391-2000-007 describes the technical methods contained in the model for conducting wasteload allocation analyses and for determining recommended limits for point source discharges. The model was utilized and the output indicates that existing effluent limits for these parameters are still adequate. No change is therefore recommended.

Toxics

DEP's minor sewage facility permit application requires facilities greater than 0.1 MGD to collect effluent and analyze for Total Copper, Total Lead, and Total Zinc. DEP's Toxics Management Spreadsheet (TMS) shows no WQBELs are needed for these pollutants.

Best Professional Judgment (BPJ) Limitations

Dissolved Oxygen

A minimum of 5.0 mg/L for DO is an existing effluent limit and is a current state water quality criterion found in 25 Pa. Code § 93.7(a). This effluent limit will remain unchanged for the upcoming permit renewal to ensure the protection of water quality standards. This approach is also consistent with DEP's SOP no. BPNPSM-PMT-033. This requirement has also been assigned to other facilities throughout the state.

Total Phosphorus

The permit currently contains Total Phosphorus effluent limits of average monthly and instantaneous maximum (IMAX) limits of 2.0 mg/L and 4.0 mg/L, respectively. These effluent limits will remain unchanged as the West Branch Antietam Creek Watershed is impaired for not only suspended solids but also nutrients including phosphorus.

Additional Considerations

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

E. Coli Monitoring Requirement

DEP's SOP no. BPNPSM-PMT-033 recommends a quarterly routine monitoring of E. Coli for all sewage facilities that have design flow less than 1.0 MGD but greater than 0.05 MGD. A quarterly monitoring for E. Coli will therefore be included in the permit.

Influent BOD & TSS Monitoring

As a result of negotiation with EPA, the existing influent monitoring reporting requirement for TSS and BOD5 will be maintained in the draft permit. This requirement has been consistently assigned to all municipal wastewater treatment facilities.

Ultraviolet (UV) Monitoring

DEP's Standard Operating Procedure (SOP no. BPNPSM-PMT-033) recommends a routine monitoring of Ultraviolet (UV) transmittance or intensity when the facility is utilizing an UV disinfection system in lieu of chlorination. This is a reasonable approach and has been assigned to other facilities equipped with similar technology. Accordingly, existing UV monitoring requirement will remain in the permit.

Local TMDL Requirements

As mentioned previously, the discharge is to West Branch Antietam Creek. DEP developed a TMDL in December 2010 to address nutrient and suspended solids impairments identified within the West Branch Antietam Creek Watershed. For this facility, this TMDL specifies the Total Suspended Solids waste load allocation (WLA) of 27,397 lbs/year or 75 lbs/day based on 30 mg/L average monthly concentration with the design flow of 0.30 MGD. As the existing permit already contains the average monthly mass load limit of 75 lbs/day, no change is recommended. The TMDL does not specify a Total Phosphorus WLA at this time.

Chesapeake Bay TMDL & TN/TP SOP Monitoring Requirement

The discharge is located within the Chesapeake Bay watershed and is considered under the Supplement to Phase III Watershed Implementation Plan (WIP) a Phase 4 facility designed to treat between 0.2 MGD and 0.4 MGD. The existing monitoring requirement will continue to be included in the upcoming permit renewal. This approach is consistent with The WIP and SOP as it is important to collect ample and up-to-date datasets for DEP to understand impacts of all point source discharges to the Chesapeake Bay watershed.

Monitoring Frequency and Sample Type

Unless stated otherwise in this fact sheet, all existing monitoring frequencies and sample types will remain unchanged in the permit and are consistent with recommended requirements specified in DEP's technical guidance no. 362-0400-001.

Mass Loading Limitations

All effluent mass loading limits will be based on the formula: design flow x concentration limit x conversion factor of 8.34.

Class A Wild Trout Fishery

A Class A Wild Trout Fishery is not impacted by this discharge.

Anti-Degradation Requirements

Unless stated otherwise in this fact sheet, all permit requirements proposed in this fact sheet are at least as stringent as permit requirements specified in the existing permit renewal in accordance with 40 CFR §122.44(l)(1).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Daily Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
CBOD5	63	100	XXX	25.0	40.0	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	75	113	XXX	30.0	45.0	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Nitrate-Nitrite	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Ammonia Nov 1 - Apr 30	48.9	XXX	XXX	19.5	XXX	39	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	16.3	XXX	XXX	6.5	XXX	13	2/month	8-Hr Composite
TKN	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite


Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Daily Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	5.0	XXX	XXX	2.0	XXX	4	2/month	8-Hr Composite
UV Dosage (mWsec/cm ²)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Recorded
E. Coli (No. / 100 mL)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]

StreamStats Report

Region ID: PA
 Workspace ID: PA20200422003325407000
 Clicked Point (Latitude, Longitude): 39.83438, -77.56953
 Time: 2020-04-21 20:33:42 -0400



Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	7.87	square miles
PRECIP	Mean Annual Precipitation	43	inches
STRDEN	Stream Density -- total length of streams divided by drainage area	1.36	miles per square mile
ROCKDEP	Depth to rock	5.2	feet
CARBON	Percentage of area of carbonate rock	38	percent

Low-Flow Statistics Parameters^[Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	7.87	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	43	inches	35	50.4
STRDEN	Stream Density	1.36	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	5.2	feet	3.32	5.65
CARBON	Percent Carbonate	38	percent	0	99

Low-Flow Statistics Flow Report^[Low Flow Region 2]

PIl: Prediction Interval-Lower, PIu: Prediction Interval-Upper, SEp: Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	SEp
7 Day 2 Year Low Flow	2.49	ft ³ /s	38	38
30 Day 2 Year Low Flow	2.91	ft ³ /s	33	33
7 Day 10 Year Low Flow	1.54	ft ³ /s	51	51
30 Day 10 Year Low Flow	1.76	ft ³ /s	46	46
90 Day 10 Year Low Flow	2.16	ft ³ /s	36	36

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)


USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the

Node 2

StreamStats Report

Region ID: PA
 Workspace ID: PA20200424133204345000
 Clicked Point (Latitude, Longitude): 39.82512, -77.57294
 Time: 2020-04-24 09:32:21 -0400



Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	9.37	square miles
PRECIP	Mean Annual Precipitation	43	inches
STRDEN	Stream Density -- total length of streams divided by drainage area	1.44	miles per square mile
ROCKDEP	Depth to rock	5.2	feet
CARBON	Percentage of area of carbonate rock	42	percent

Low-Flow Statistics Parameters^[Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	9.37	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	43	inches	35	50.4
STRDEN	Stream Density	1.44	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	5.2	feet	3.32	5.65
CARBON	Percent Carbonate	42	percent	0	99

Low-Flow Statistics Flow Report^[Low Flow Region 2]

PIl: Prediction Interval-Lower, PIu: Prediction Interval-Upper, SEp: Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	SEp
7 Day 2 Year Low Flow	2.98	ft ³ /s	38	38
30 Day 2 Year Low Flow	3.46	ft ³ /s	33	33
7 Day 10 Year Low Flow	1.87	ft ³ /s	51	51
30 Day 10 Year Low Flow	2.13	ft ³ /s	46	46
90 Day 10 Year Low Flow	2.56	ft ³ /s	36	36

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
13C	59258	WEST BRANCH ANTIETAM CREEK	10.170	788.00	7.87	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	1.54	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Mont Alto WWTP	PA0038130	0.3000	0.3000	0.3000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	6.50	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
13C	59258	WEST BRANCH ANTIETAM CREEK	9.500	758.00	9.37	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	1.87	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

■



Toxics Management Spreadsheet
Version 1.4, May 2025

Discharge Information

Instructions Discharge Stream

Facility: Mont Alto STP NPDES Permit No.: PA0038130 Outfall No.: 001

Evaluation Type: Custom / Additives Wastewater Description: Sewage

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _n
0.3	131	7						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod
Total Copper	µg/L	0.011								
Total Lead	µg/L	0.001								
Total Zinc	µg/L	0.042								



Stream / Surface Water Information

Mont Alto STP, NPDES Permit No. PA0038130, Outfall 001

Instructions Discharge Stream

Receiving Surface Water Name: **West Branch Antietam Creek** No. Reaches to Model: **1**

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code *	RMI *	Elevation (ft) *	DA (mi ²) *	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria *
Point of Discharge	059258	10.17	788	7.87			Yes
End of Reach 1	059258	9.5	758	9.37			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²) *	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness *	pH		
Point of Discharge	10.17	0.1	1.54										151	7	
End of Reach 1	9.5	0.1	1.87												

Q_h

Location	RMI	LFY (cfs/mi ²) *	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis
			Stream	Tributary						Hardness	pH	Hardness	pH	
Point of Discharge	10.17													
End of Reach 1	9.5													



Model Results Mont Alto STP, NPDES Permit No. PA0038130, Outfall 001

All
 Inputs
 Results
 Limits

- Hydrodynamics
- Wasteload Allocations

AFC
 CCT (min):
 PMF:
 Analysis Hardness (mg/l):
 Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	19.242	20.0	86.6	Chem Translator of 0.96 applied
Total Lead	0	0		0	97.526	133	573	Chem Translator of 0.735 applied
Total Zinc	0	0		0	161.823	165	715	Chem Translator of 0.978 applied

CFC
 CCT (min):
 PMF:
 Analysis Hardness (mg/l):
 Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	12.402	12.9	55.8	Chem Translator of 0.96 applied
Total Lead	0	0		0	3.800	5.17	22.3	Chem Translator of 0.735 applied
Total Zinc	0	0		0	163.146	165	715	Chem Translator of 0.986 applied

THH
 CCT (min):
 PMF:
 Analysis Hardness (mg/l):
 Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

CRL
 CCT (min):
 PMF:
 Analysis Hardness (mg/l):
 Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	

**West Branch Antietam Creek Watershed
TMDL
Franklin County, Pennsylvania**

Prepared by:



December, 2010

Subshed	Pollutant	Loading Rate in Reference (lb/ac-yr)	Total Area in West Branch Antietam Creek Subshed (ac)	Target TMDL Value (lb/yr)	Target TMDL Value (lb/day)
UNT 59260	Sediment	171	1,090	186,740*	512
UNT 59260	Nutrients	0.3	1,090	360*	1
UNT 59264	Sediment	171	1,724	295,464*	809
UNT 59264	Nutrients	0.3	1,724	569*	2
UNT 59267	Sediment	338	9,692	3,278,107*	8,981
UNT 59267	Nutrients	0.2	9,692	1,855*	5
UNT 59281	Sediment	176	6,207	1,254,754*	3,438

* takes into account rounding in previous calculations

The target TMDL values were then used as the basis for load allocations and reductions in the West Branch Antietam Creek Subsheds, using the following two equations:

1. $TMDL = WLA + LA + MOS$
2. $LA = ALA + LNR$

where:

TMDL = Total Maximum Daily Load
 WLA = Waste Load Allocation (Point Sources)
 LA = Load Allocation (Nonpoint Sources)
 MOS = Margin of Safety
 ALA = Adjusted Load Allocation
 LNR = Loads Not Reduced

Waste Load Allocation

The waste load allocation (WLA) portion of the TMDL equation is the total loading of a pollutant that is assigned to point sources. There is one permitted discharge in the West Branch Antietam Creek Watershed, found in the UNT 59281 Subshed, that has effluent limits. The permit limit for the Mont Alto Sewage Treatment Plant, NPDES permit number PA0038130, for total suspended solids (TSS) is derived from a concentration of 30 mg/L (monthly average) with a design flow of 0.30 million gallons per day (mgd) and equals 27,397 pounds per year, 75 lbs/day.

$WLA = 0.30 \text{ mgd Flow} * 30 \text{ mg/L monthly average concentration} * 8.34 * 365 = 27,397 \text{ TSS lbs./yr}$
 75 TSS lbs/day.

Margin of Safety

The margin of safety (MOS) is that portion of the pollutant loading that is reserved to account for any uncertainty in the data and computational methodology used for the analysis. For this analysis, the MOS is explicit. Ten percent of the targeted TMDL for sediment was reserved as the MOS. Using 10% of the TMDL load is based on professional judgment and will provide an additional level of protection to the designated uses of West Branch Antietam Creek. An example of the MOS