

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

Application No. PA0038814
APS ID 1009297
Authorization ID 1301665

Applicant and Facility Information

| | |
|--|--|
| Applicant Name <u>Ellport Borough Sewer Authority</u> | Facility Name <u>Ellport Borough STP</u> |
| Applicant Address <u>313 Burns Avenue</u> <u>Ellwood City, PA 16117-3910</u> | Facility Address <u>313 Burns Avenue</u> <u>Ellwood City, PA 16117-3910</u> |
| Applicant Contact <u>David Steffler</u> | Facility Contact <u>Michael Milnes (Operator)</u> |
| Applicant Phone <u>(724) 752-1422</u> | Facility Phone <u>(724) 752-1422</u> |
| Client ID <u>62947</u> | Site ID <u>261253</u> |
| Ch 94 Load Status <u>Not Overloaded</u> | Municipality <u>Ellport Borough</u> |
| Connection Status <u>No Limitations</u> | County <u>Lawrence</u> |
| Date Application Received <u>January 2, 2020</u> | EPA Waived? <u>Yes</u> |
| Date Application Accepted <u>January 21, 2020</u> | If No, Reason _____ |
| Purpose of Application <u>Renewal of a NPDES Permit for an existing discharge of treated sewage from a POTW.</u> | |

Summary of Review

This is a Publicly Owned Treatment Works (POTW) serving the municipalities of Ellport Borough, Perry Township and Franklin Township in Lawrence County.

There are no proposed changes to discharge quality or quantity as part of this permit renewal.

There are currently no open violations listed in EFACTS for this permittee (3/29/2022).

Sludge use and disposal description and location(s): Sludge is hauled offsite and disposed of at municipal waste landfill operated by Joseph J. Brunner Inc. and located in New Sewickley Township, Beaver County.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Approve | Deny | Signatures | Date |
|---------|------|---|----------------|
| X | | Adam J. Pesek Adam J. Pesek, E.I.T. / Environmental Engineer | March 29, 2022 |
| X | | Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager | April 11, 2022 |

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|--|------------------------------|----------------------|
| Outfall No. | 001 | Design Flow (MGD) | 0.72 |
| Latitude | 40° 51' 58" | Longitude | -80° 15' 29" |
| Quad Name | Beaver Falls | Quad Code | 1203 |
| Wastewater Description: Sewage Effluent | | | |
| Receiving Waters | Slippery Rock Creek | Stream Code | 34025 |
| NHD Com ID | 126216417 | RMI | 4.96 |
| Drainage Area | 827 | Yield (cfs/mi ²) | 0.08 |
| Q ₇₋₁₀ Flow (cfs) | 66.04 | Q ₇₋₁₀ Basis | New Castle TDS Study |
| Elevation (ft) | 800 | Slope (ft/ft) | 0.0027 |
| Watershed No. | 20-C | Chapter 93 Class. | WWF |
| Existing Use | | Existing Use Qualifier | |
| Exceptions to Use | | Exceptions to Criteria | |
| Assessment Status | Impaired | | |
| Cause(s) of Impairment | PATHOGENS | | |
| Source(s) of Impairment | SOURCE UNKNOWN | | |
| TMDL Status | | Name | |
| Background/Ambient Data | | Data Source | |
| pH (SU) | 7.0 | Default | |
| Temperature (°C) | 25 | Default (WWF) | |
| Hardness (mg/L) | | | |
| Other: NH ₃ -N | 0.1 | Default | 66.04 |
| Nearest Downstream Public Water Supply Intake | PA American Water Company – Ellwood District | | |
| PWS Waters | Connoquenessing Creek | Flow at Intake (cfs) | 67 |
| PWS RMI | 0.25 | Distance from Outfall (mi) | 4.7 |

Changes Since Last Permit Issuance:

Other Comments: There are three unauthorized sanitary sewer overflows in the sanitary sewer system.

Outfall 002 – Overflow at Pump Station No. 1 for flows exceeding 550 gpm.

Outfall 003 – Overflow at Pump Station No. 2.

Outfall 004 – Historical bypass of the treatment plant which is normally closed (can be opened by a valve). The bypass is believed to have been removed during the last treatment plant upgrade.

| Treatment Facility Summary | | | | |
|--|----------------------------|-------------------|---------------------|------------------------|
| Treatment Facility Name: Ellport Borough STP | | | | |
| WQM Permit No. | | Issuance Date | | |
| 3777402 | | 9/22/1977 | | |
| 3705401 | | 3/24/2005 | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Secondary | Extended Aeration | Gas Chlorine | 0.72 |
| | | | | |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.72 | 1000 | Not Overloaded | Aerobic Digestion | Landfill |

Changes Since Last Permit Issuance: The 8/22/2019 Inspection Report indicated the permittee should submit a WQM Permit Amendment application for dechlorination equipment that is already installed and removal of comminutor/grinder unit if the permittee is not planning to install them as permitted. No WQM Permit amendment application has been submitted to date.

Other Comments:

| Compliance History | |
|-------------------------|--|
| Summary of DMRs: | Only one effluent violation reported for D.O. since the beginning of 2017 |
| Summary of Inspections: | <p>CAP approved on July 27, 2020 to address hydraulic overload conditions at Lift Stations #1 and #2 that occurred during wet weather events.</p> <p>The last site inspection occurred on January 21, 2020. The inspection report indicated it was a follow up inspection to the one done in 2019. No major issues reported.</p> <p>A site inspection was conducted on August 22, 2019. The inspection report noted violations noted below:</p> <ol style="list-style-type: none">1. Failure to comply with terms and conditions of a WQM Permit (P. L. 1987, No. 394, Sec 611). Water Quality Management (WQM) Permit 3705401 dated March 24, 2015 approved the construction/modification/operation of 'New Wastewater Treatment Units' which includes a comminutor/grinder sized for a flow rate of 2000-gpm (2.9-MGD). A comminutor/grinder is not installed at the headworks. A Muffin Monster control panel and manual, coarse bar screen are installed at the headworks.2. Failure to apply for and/or obtain a WQM Permit for the construction of sewage or industrial waste facilities. A chemical feed system has been installed to apply sodium bisulfite to treatment plant effluent, for the purpose of de-chlorination, without applying for a WQM Permit amendment. |

Other Comments: **The Department will request a WQM Permit application be submitted when the draft permit is sent out.**

Compliance History

DMR Data for Outfall 001 (from February 1, 2021 to January 31, 2022)

| Parameter | JAN-22 | DEC-21 | NOV-21 | OCT-21 | SEP-21 | AUG-21 | JUL-21 | JUN-21 | MAY-21 | APR-21 | MAR-21 | FEB-21 |
|---|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.438 | 0.477 | 0.350 | 0.378 | 0.308 | 0.347 | 0.396 | 0.295 | 0.496 | 0.353 | 0.610 | 0.411 |
| Flow (MGD) Weekly Average | 0.886 | 0.855 | 0.554 | 1.312 | 0.467 | 1.168 | 0.998 | 0.399 | 1.715 | 0.488 | 2.268 | 0.585 |
| pH (S.U.) Minimum | 6.94 | 6.96 | 7.00 | 7.00 | 7.15 | 7.11 | 7.04 | 7.06 | 6.97 | 6.98 | 6.86 | 6.98 |
| pH (S.U.) Maximum | 7.36 | 7.66 | 7.59 | 7.67 | 7.43 | 7.34 | 7.38 | 7.37 | 7.46 | 7.41 | 7.85 | 7.23 |
| DO (mg/L) Minimum | 5.94 | 5.52 | 5.64 | 5.70 | 5.50 | 5.12 | 5.07 | 5.28 | 6.47 | 6.16 | 6.73 | 7.73 |
| TRC (mg/L) Average Monthly | 0.36 | 0.38 | 0.38 | 0.38 | 0.10 | 0.15 | 0.11 | 0.18 | 0.46 | 0.45 | 0.40 | 0.46 |
| TRC (mg/L) Instantaneous Maximum | 0.50 | 0.50 | 0.50 | 0.50 | 0.20 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| CBOD5 (lbs/day) Average Monthly | 20.1 | 27.6 | 18.6 | 34.8 | 25.8 | 21.4 | 28.2 | 19.9 | 22.9 | 23.9 | 34.1 | 21.5 |
| CBOD5 (lbs/day) Weekly Average | 25.5 | 35.0 | 22.4 | 44.4 | 33.1 | 24.3 | 33.3 | 21.6 | 27.7 | 31.2 | 46.2 | 32.8 |
| CBOD5 (mg/L) Average Monthly | 5.52 | 6.94 | 6.40 | 11.05 | 10.06 | 7.425 | 8.55 | 8.12 | 5.55 | 8.125 | 6.72 | 6.30 |
| CBOD5 (mg/L) Weekly Average | 7.0 | 8.80 | 7.70 | 14.1 | 12.9 | 8.40 | 10.1 | 8.80 | 6.70 | 10.6 | 9.10 | 7.90 |
| BOD5 (lbs/day) Influent Average Monthly | 773.5 | 1004.8 | 829.7 | 1244.2 | 857.4 | 894.6 | 936.2 | 611.6 | 967.9 | 853.7 | 1434.4 | 770.3 |
| BOD5 (lbs/day) Influent Weekly Average | 1099.5 | 1551.4 | 1164.6 | 1626.7 | 1068.5 | 1198.1 | 1079.9 | 819.2 | 1154.1 | 912.6 | 1638.1 | 884.3 |
| BOD5 (mg/L) Influent Average Monthly | 211.75 | 252.6 | 284.25 | 394.7 | 333.8 | 309.25 | 283.5 | 248.6 | 234.0 | 290.0 | 282.0 | 224.75 |
| TSS (lbs/day) Average Monthly | 3.65 | 15.9 | 9.48 | 29.9 | 17.4 | 13.0 | 28.8 | 16.7 | 11.3 | 8.83 | 7.12 | 7.53 |
| TSS (lbs/day) Influent Average Monthly | 633.7 | 805.1 | 932.6 | 1149.8 | 927.3 | 828.4 | 828.9 | 588.5 | 785.9 | 720.5 | 1188.4 | 690.6 |

**NPDES Permit Fact Sheet
Ellport Borough STP**

NPDES Permit No. PA0038814

| | | | | | | | | | | | | |
|--|--------|--------|--------|--------|--------|--------|-------|-------|-------|--------|--------|-------|
| TSS (lbs/day) Influent Daily Maximum | 1044.7 | 1615.4 | 1205.5 | 1292.5 | 1299.7 | 1099.7 | 990.7 | 770.0 | 864.5 | 1000.9 | 1592.3 | 867.2 |
| TSS (lbs/day) Weekly Average | 3.65 | 31.8 | 20.4 | 34.6 | 28.2 | 26.0 | 42.9 | 24.6 | 16.5 | 23.5 | 10.1 | 7.53 |
| TSS (mg/L) Average Monthly | 1.0 | 4.0 | 3.25 | 9.50 | 6.80 | 4.50 | 8.75 | 6.80 | 2.75 | 3.0 | 1.40 | 1.0 |
| TSS (mg/L) Influent Average Monthly | 173.5 | 202.4 | 319.5 | 364.7 | 361.0 | 286.25 | 251.0 | 239.2 | 190.0 | 277.75 | 233.6 | 201.5 |
| TSS (mg/L) Weekly Average | 1.0 | 8.0 | 7.0 | 11.0 | 11.0 | 9.00 | 13.0 | 10.0 | 4.0 | 8.0 | 2.0 | 1.0 |
| Fecal Coliform (CFU/100 ml) Geometric Mean | 2.39 | 1.24 | 5.02 | 6.47 | 9.12 | 13.6 | 11.0 | 15.7 | 2.21 | 7.135 | 2.93 | 3.08 |
| Fecal Coliform (CFU/100 ml) Instantaneous Maximum | 11.0 | 3.0 | 10.0 | 16.0 | 36.0 | 22.0 | 62.5 | 39.0 | 12.0 | 24.0 | 9.0 | 10.0 |
| Total Nitrogen (lbs/day) Average Quarterly | | 29.7 | | | 48.0 | | | 28.2 | | | 51.3 | |
| Total Nitrogen (mg/L) Average Quarterly | | 7.27 | | | 16.6 | | | 11.5 | | | 10.1 | |
| Ammonia (lbs/day) Average Monthly | 8.80 | 32.8 | 35.7 | 25.6 | 33.0 | 35.4 | 34.2 | 28.7 | 8.76 | 4.41 | 1.78 | 1.66 |
| Ammonia (mg/L) Average Monthly | 2.41 | 8.27 | 12.2 | 8.15 | 12.8 | 12.2 | 10.38 | 11.6 | 2.12 | 1.50 | 0.35 | 0.485 |
| Total Phosphorus (lbs/day) Average Quarterly | | 8.23 | | | 11.3 | | | 16.2 | | | 7.58 | |
| Total Phosphorus (mg/L) Average Quarterly | | 2.07 | | | 3.93 | | | 6.61 | | | 1.49 | |

Development of Effluent Limitations

| | | | |
|--------------------------------|-----------------|--------------------------|-----------------|
| Outfall No. | 001 | Design Flow (MGD) | 0.72 |
| Latitude | 40° 51' 58.00" | Longitude | -80° 15' 29.00" |
| Wastewater Description: | Sewage Effluent | | |

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|---------------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |
| E. Coli | Report (No./100 ml) | IMAX | - | 92a.61 |

Comments: Monitoring for E. coli will be placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

| Parameter | Limit (mg/l) | SBC | Model |
|------------------|--------------|-----------------|--|
| Ammonia Nitrogen | 21 | Average Monthly | WQM 7.0 Version 1.0b (Previous Modeling) |

Comments: Monitoring for ammonia nitrogen will be placed in the permit during the wintertime period because the standard season multiplier of "3" is well above the threshold value of 25 mg/l discussed in the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Best Professional Judgment (BPJ) Limitations

Comments: A dissolved oxygen daily minimum limit of 4.0 mg/l and a TRC IMAX limit of 1.6 is placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Other Considerations

Comments: Monitoring for influent BOD₅ and influent TSS is placed in the permit in accordance with the Department's SOP entitled "New and Reissuance Individual Sewage NPDES Permit Applications."

Monitoring for total nitrogen and total phosphorus is placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Anti-Backsliding

N/A

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|---------------------|-----------------------|---------------------|-------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 Daily Min | XXX | 9.0 Daily Max | XXX | 1/day | Grab |
| DO | XXX | XXX | 5.0 Daily Min | XXX | XXX | XXX | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 1/day | Grab |
| CBOD5 | 150 | 240 | XXX | 25 | 40 | 50 | 1/week | 8-Hr Composite |
| BOD5 Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 8-Hr Composite |
| TSS Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 8-Hr Composite |
| TSS | 180 | 270 | XXX | 30 | 45 | 60 | 1/week | 8-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | 10000 | 1/week | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 1/week | Grab |
| E. Coli (No./100 ml) | XXX | XXX | XXX | XXX | XXX | Report | 1/quarter | Grab |
| Total Nitrogen | Report Avg Qrtly | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 8-Hr Composite |
| Ammonia Nov 1 - Apr 30 | Report | XXX | XXX | Report | XXX | XXX | 1/month | 8-Hr Composite |
| Ammonia May 1 - Oct 31 | 126 | XXX | XXX | 21 | XXX | 42 | 1/week | 8-Hr Composite |
| Total Phosphorus | Report Avg Qrtly | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 8-Hr Composite |

Compliance Sampling Location: Outfall 001 (after disinfection)

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|--------------|----------------|-----------------------|-------|-------------------|-----------------------------|------------------|----------------------------|-------------------------------------|
| 20C | 34025 | CONNOQUENESSING CREEK | 4.960 | 800.00 | 827.00 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary | | Stream | |
|-----------------|--------|--------------|----------------|-------------------------------|--------------------------|-------------|----------------------|----------------------|--------------|------|--------------|------|
| | (cfsm) | (cfs) | (cfs) | | | | | | Temp (°C) | pH | Temp (°C) | pH |
| Q7-10 | 0.080 | 66.04 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 25.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|-----------------|---------------|-----------------------------------|------------------------------------|---------------------------------|-------------------|----------------------|------------|
| Ellport Boro SA | PA0038814 | 0.7200 | 0.0000 | 0.0000 | 0.000 | 20.00 | 7.20 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------------|------------------------|--------------------------|--------------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 4.00 | 7.54 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.10 | 0.00 | 0.70 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|--------------|----------------|-----------------------|-------|-------------------|-----------------------------|------------------|----------------------------|-------------------------------------|
| 20C | 34025 | CONNOQUENESSING CREEK | 1.640 | 770.00 | 836.00 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | <u>Tributary</u> Temp | <u>Stream</u> pH | Temp | pH |
|-----------------|--------|--------------|----------------|-------------------------------|--------------------------|-------------|----------------------|----------------------|--------------------------|---------------------|------|------|
| | (cfsm) | (cfs) | (cfs) | | | | | | (°C) | | (°C) | |
| Q7-10 | 0.080 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 25.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|--------------|---------------|-----------------------------------|------------------------------------|---------------------------------|-------------------|----------------------|------------|
| Ellwood City | PA0026832 | 3.3000 | 0.0000 | 0.0000 | 0.000 | 20.00 | 6.70 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------------|------------------------|--------------------------|--------------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 4.00 | 7.54 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.10 | 0.00 | 0.70 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|--------------|----------------|-----------------------|-------|-------------------|-----------------------------|------------------|----------------------------|-------------------------------------|
| 20C | 34025 | CONNOQUENESSING CREEK | 0.010 | 745.00 | 838.00 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary | | Stream | |
|-----------------|--------|--------------|----------------|-------------------------------|--------------------------|-------------|----------------------|----------------------|--------------|------|--------------|------|
| | (cfsm) | (cfs) | (cfs) | | | | | | Temp (°C) | pH | Temp (°C) | pH |
| Q7-10 | 0.080 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 25.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|------|---------------|-----------------------------------|------------------------------------|---------------------------------|-------------------|----------------------|------------|
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 0.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------------|------------------------|--------------------------|--------------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | <u>Stream Name</u> | | | | | | | | |
|--------------------|-------------|--------------------|-----------------|-----------------------|-------------|-------|--------|-----------|----------|-----------------|---------------|-------------|
| 20C | | 34025 | | CONNOQUENESSING CREEK | | | | | | | | |
| RMI | Stream Flow | PWS With | Net Stream Flow | Disc Analysis Flow | Reach Slope | Depth | Width | W/D Ratio | Velocity | Reach Trav Time | Analysis Temp | Analysis pH |
| | (cfs) | (cfs) | (cfs) | (cfs) | (ft/ft) | (ft) | (ft) | | (fps) | (days) | (°C) | |
| Q7-10 Flow | | | | | | | | | | | | |
| 4.960 | 66.04 | 0.00 | 66.04 | 1.1138 | 0.00171 | 1.087 | 141.86 | 130.54 | 0.44 | 0.466 | 24.92 | 7.00 |
| 1.640 | 66.76 | 0.00 | 66.76 | 6.2189 | 0.00290 | 1.095 | 142.05 | 129.69 | 0.47 | 0.212 | 24.57 | 6.97 |
| Q1-10 Flow | | | | | | | | | | | | |
| 4.960 | 42.27 | 0.00 | 42.27 | 1.1138 | 0.00171 | NA | NA | NA | 0.34 | 0.595 | 24.87 | 7.00 |
| 1.640 | 42.73 | 0.00 | 42.73 | 6.2189 | 0.00290 | NA | NA | NA | 0.38 | 0.266 | 24.36 | 6.96 |
| Q30-10 Flow | | | | | | | | | | | | |
| 4.960 | 89.81 | 0.00 | 89.81 | 1.1138 | 0.00171 | NA | NA | NA | 0.52 | 0.393 | 24.94 | 7.00 |
| 1.640 | 90.79 | 0.00 | 90.79 | 6.2189 | 0.00290 | NA | NA | NA | 0.55 | 0.181 | 24.68 | 6.98 |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 5 | | |

WQM 7.0 Wasteload Allocations

| <u>SWP Basin</u> | | <u>Stream Code</u> | <u>Stream Name</u> | | | | | |
|------------------|--|--------------------|-----------------------|--|--|--|--|--|
| 20C | | 34025 | CONNOQUENESSING CREEK | | | | | |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|-----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 4.960 | Ellport Boro SA | 11.15 | 50 | 11.15 | 50 | 0 | 0 |
| 1.640 | Ellwood City | 12.01 | 50 | 12.07 | 50 | 0 | 0 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|-----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 4.960 | Ellport Boro SA | 1.37 | 25 | 1.37 | 22.1 | 2 | 12 |
| 1.640 | Ellwood City | 1.4 | 24.56 | 1.41 | 21.72 | 2 | 12 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | <u>CBOD5</u> | | <u>NH3-N</u> | | <u>Dissolved Oxygen</u> | | Critical Reach | Percent Reduction |
|------|-----------------|--------------------|--------------------|--------------------|--------------------|-------------------------|--------------------|-------------------|----------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 4.96 | Ellport Boro SA | 25 | 25 | 22.1 | 22.1 | 4 | 4 | 0 | 0 |
| 1.64 | Ellwood City | 25 | 25 | 21.72 | 21.72 | 4 | 4 | 0 | 0 |

| <u>SWP Basin</u> | | <u>Stream Code</u> | <u>Stream Name</u> | |
|---------------------------------|-----------------------------------|----------------------------------|-----------------------|-----------------------------|
| 20C | | 34025 | CONNOQUENESSING CREEK | |
| <u>RM1</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | | <u>Analysis pH</u> |
| 4.960 | 0.720 | 24.917 | | 7.003 |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | | <u>Reach Velocity (fps)</u> |
| 141.862 | 1.087 | 130.539 | | 0.436 |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | | <u>Reach Kn (1/days)</u> |
| 2.38 | 0.183 | 0.46 | | 1.022 |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | | <u>Reach DO Goal (mg/L)</u> |
| 7.481 | 3.907 | Tsivoglou | | 5 |
| <u>Reach Travel Time (days)</u> | | | | |
| 0.466 | | | | |
| Subreach Results | | | | |
| TravTime (days) | CBOD5 (mg/L) | NH3-N (mg/L) | D.O. (mg/L) | |
| 0.047 | 2.36 | 0.44 | 7.51 | |
| 0.093 | 2.33 | 0.42 | 7.53 | |
| 0.140 | 2.31 | 0.40 | 7.54 | |
| 0.186 | 2.28 | 0.38 | 7.54 | |
| 0.233 | 2.26 | 0.37 | 7.54 | |
| 0.279 | 2.23 | 0.35 | 7.54 | |
| 0.326 | 2.21 | 0.33 | 7.54 | |
| 0.373 | 2.19 | 0.32 | 7.54 | |
| 0.419 | 2.16 | 0.30 | 7.54 | |
| 0.466 | 2.14 | 0.29 | 7.54 | |

| <u>SWP Basin</u> | | <u>Stream Code</u> | <u>Stream Name</u> | |
|---------------------------------|-----------------------------------|----------------------------------|-----------------------|-----------------------------|
| 20C | | 34025 | CONNOQUENESSING CREEK | |
| <u>RM1</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | | <u>Analysis pH</u> |
| 1.640 | 4.020 | 24.574 | | 6.973 |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | | <u>Reach Velocity (fps)</u> |
| 142.048 | 1.095 | 129.693 | | 0.469 |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | | <u>Reach Kn (1/days)</u> |
| 3.74 | 0.692 | 1.79 | | 0.995 |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | | <u>Reach DO Goal (mg/L)</u> |
| 7.292 | 7.084 | Tsivoglou | | 5 |
| <u>Reach Travel Time (days)</u> | | | | |
| 0.212 | | | | |
| Subreach Results | | | | |
| TravTime (days) | CBOD5 (mg/L) | NH3-N (mg/L) | D.O. (mg/L) | |
| 0.021 | 3.67 | 1.75 | 7.20 | |
| 0.042 | 3.60 | 1.71 | 7.13 | |
| 0.064 | 3.54 | 1.68 | 7.07 | |
| 0.085 | 3.48 | 1.64 | 7.02 | |
| 0.106 | 3.41 | 1.61 | 6.99 | |
| 0.127 | 3.35 | 1.57 | 6.96 | |
| 0.149 | 3.29 | 1.54 | 6.94 | |
| 0.170 | 3.23 | 1.51 | 6.93 | |
| 0.191 | 3.17 | 1.48 | 6.93 | |
| 0.212 | 3.12 | 1.45 | 6.93 | |

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | | | |
|------------------|--------------------|-----------------------|-----------------|------------------|--------------------------------|----------------------------|----------------------------|
| 20C | 34025 | CONNOQUENESSING CREEK | | | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 4.960 | Ellport Boro SA | PA0038814 | 0.720 | CBOD5 | 25 | | |
| | | | | NH3-N | 22.1 | 44.2 | |
| | | | | Dissolved Oxygen | | | 4 |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 1.640 | Ellwood City | PA0026832 | 3.300 | CBOD5 | 25 | | |
| | | | | NH3-N | 21.72 | 43.44 | |
| | | | | Dissolved Oxygen | | | 4 |



Discharge Information

Instructions Discharge Stream

Facility: **Elport Boro STP** NPDES Permit No.: **PA0038814** Outfall No.: **001**

Evaluation Type: **Major Sewage / Industrial Waste** Wastewater Description: **Treated Domestic Sewage**

| Discharge Characteristics | | | | | | | | |
|---------------------------|------------------|----------|----------------------------|-----|-----|-----|--------------------------|----------------|
| Design Flow (MGD)* | Hardness (mg/l)* | pH (SU)* | Partial Mix Factors (PMFs) | | | | Complete Mix Times (min) | |
| | | | AFC | CFC | THH | CRL | Q ₇₋₁₀ | Q _h |
| 0.72 | 100 | 7.2 | | | | | | |

| | | | | 0 if left blank | | 0.5 if left blank | | 0 if left blank | | | 1 if left blank | | | | |
|---------------------|---------------------------------|------|---|-----------------|--------------------|-------------------|-------------|-----------------|-----------|-----------|-----------------|-----|--------------|-------------|--|
| Discharge Pollutant | | | | Units | Max Discharge Conc | Trib Conc | Stream Conc | Daily CV | Hourly CV | Stream CV | Fate Coeff | FOS | Criteria Mod | Chem Transl | |
| Group 1 | Total Dissolved Solids (PWS) | mg/L | | 520 | | | | | | | | | | | |
| | Chloride (PWS) | mg/L | | 190 | | | | | | | | | | | |
| | Bromide | mg/L | < | 0.5 | | | | | | | | | | | |
| | Sulfate (PWS) | mg/L | | 61 | | | | | | | | | | | |
| | Fluoride (PWS) | mg/L | | | | | | | | | | | | | |
| Group 2 | Total Aluminum | µg/L | | | | | | | | | | | | | |
| | Total Antimony | µg/L | | | | | | | | | | | | | |
| | Total Arsenic | µg/L | | | | | | | | | | | | | |
| | Total Barium | µg/L | | | | | | | | | | | | | |
| | Total Beryllium | µg/L | | | | | | | | | | | | | |
| | Total Boron | µg/L | | | | | | | | | | | | | |
| | Total Cadmium | µg/L | | | | | | | | | | | | | |
| | Total Chromium (III) | µg/L | | | | | | | | | | | | | |
| | Hexavalent Chromium | µg/L | | | | | | | | | | | | | |
| | Total Cobalt | µg/L | | | | | | | | | | | | | |
| | Total Copper | µg/L | | | | | | | | | | | | | |
| | Free Cyanide | µg/L | | | | | | | | | | | | | |
| | Total Cyanide | µg/L | | | | | | | | | | | | | |
| | Dissolved Iron | µg/L | | | | | | | | | | | | | |
| | Total Iron | µg/L | | | | | | | | | | | | | |
| | Total Lead | µg/L | | | | | | | | | | | | | |
| | Total Manganese | µg/L | | | | | | | | | | | | | |
| | Total Mercury | µg/L | | | | | | | | | | | | | |
| | Total Nickel | µg/L | | | | | | | | | | | | | |
| | Total Phenols (Phenolics) (PWS) | µg/L | | | | | | | | | | | | | |
| | Total Selenium | µg/L | | | | | | | | | | | | | |
| | Total Silver | µg/L | | | | | | | | | | | | | |
| | Total Thallium | µg/L | | | | | | | | | | | | | |
| | Total Zinc | µg/L | | | | | | | | | | | | | |
| | Total Molybdenum | µg/L | | | | | | | | | | | | | |
| | Acrolein | µg/L | < | | | | | | | | | | | | |
| | Acrylamide | µg/L | < | | | | | | | | | | | | |
| | Acrylonitrile | µg/L | < | | | | | | | | | | | | |
| | Benzene | µg/L | < | | | | | | | | | | | | |
| | Bromoform | µg/L | < | | | | | | | | | | | | |

| | | | | | | | | | | | | | | | | | | | | |
|---------|-----------------------------|------|---|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
| Group 3 | Carbon Tetrachloride | µg/L | < | | | | | | | | | | | | | | | | | |
| | Chlorobenzene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Chlorodibromomethane | µg/L | < | | | | | | | | | | | | | | | | | |
| | Chloroethane | µg/L | < | | | | | | | | | | | | | | | | | |
| | 2-Chloroethyl Vinyl Ether | µg/L | < | | | | | | | | | | | | | | | | | |
| | Chloroform | µg/L | < | | | | | | | | | | | | | | | | | |
| | Dichlorobromomethane | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,1-Dichloroethane | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,2-Dichloroethane | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,1-Dichloroethylene | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,2-Dichloropropane | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,3-Dichloropropylene | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,4-Dioxane | µg/L | < | | | | | | | | | | | | | | | | | |
| | Ethylbenzene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Methyl Bromide | µg/L | < | | | | | | | | | | | | | | | | | |
| | Methyl Chloride | µg/L | < | | | | | | | | | | | | | | | | | |
| | Methylene Chloride | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,1,2,2-Tetrachloroethane | µg/L | < | | | | | | | | | | | | | | | | | |
| | Tetrachloroethylene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Toluene | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,2-trans-Dichloroethylene | µg/L | < | | | | | | | | | | | | | | | | | |
| Group 4 | 1,1,1-Trichloroethane | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,1,2-Trichloroethane | µg/L | < | | | | | | | | | | | | | | | | | |
| | Trichloroethylene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Vinyl Chloride | µg/L | < | | | | | | | | | | | | | | | | | |
| | 2-Chlorophenol | µg/L | < | | | | | | | | | | | | | | | | | |
| | 2,4-Dichlorophenol | µg/L | < | | | | | | | | | | | | | | | | | |
| | 2,4-Dimethylphenol | µg/L | < | | | | | | | | | | | | | | | | | |
| | 4,6-Dinitro-o-Cresol | µg/L | < | | | | | | | | | | | | | | | | | |
| | 2,4-Dinitrophenol | µg/L | < | | | | | | | | | | | | | | | | | |
| | 2-Nitrophenol | µg/L | < | | | | | | | | | | | | | | | | | |
| | 4-Nitrophenol | µg/L | < | | | | | | | | | | | | | | | | | |
| Group 5 | p-Chloro-m-Cresol | µg/L | < | | | | | | | | | | | | | | | | | |
| | Pentachlorophenol | µg/L | < | | | | | | | | | | | | | | | | | |
| | Phenol | µg/L | < | | | | | | | | | | | | | | | | | |
| | 2,4,6-Trichlorophenol | µg/L | < | | | | | | | | | | | | | | | | | |
| | Acenaphthene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Acenaphthylene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Anthracene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Benidine | µg/L | < | | | | | | | | | | | | | | | | | |
| | Benzo(a)Anthracene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Benzo(a)Pyrene | µg/L | < | | | | | | | | | | | | | | | | | |
| | 3,4-Benzofluoranthene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Benzo(ghi)Perylene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Benzo(k)Fluoranthene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Bis(2-Chloroethoxy)Methane | µg/L | < | | | | | | | | | | | | | | | | | |
| | Bis(2-Chloroethyl)Ether | µg/L | < | | | | | | | | | | | | | | | | | |
| | Bis(2-Chloroisopropyl)Ether | µg/L | < | | | | | | | | | | | | | | | | | |
| | Bis(2-Ethylhexyl)Phthalate | µg/L | < | | | | | | | | | | | | | | | | | |
| | 4-Bromophenyl Phenyl Ether | µg/L | < | | | | | | | | | | | | | | | | | |
| | Butyl Benzyl Phthalate | µg/L | < | | | | | | | | | | | | | | | | | |
| | 2-Chloronaphthalene | µg/L | < | | | | | | | | | | | | | | | | | |
| | 4-Chlorophenyl Phenyl Ether | µg/L | < | | | | | | | | | | | | | | | | | |
| | Chrysene | µg/L | < | | | | | | | | | | | | | | | | | |
| | Dibenzo(a,h)Anthracene | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,2-Dichlorobenzene | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,3-Dichlorobenzene | µg/L | < | | | | | | | | | | | | | | | | | |
| | 1,4-Dichlorobenzene | µg/L | < | | | | | | | | | | | | | | | | | |
| | 3,3-Dichlorobenzidine | µg/L | < | | | | | | | | | | | | | | | | | |
| | Diethyl Phthalate | µg/L | < | | | | | | | | | | | | | | | | | |
| | Dimethyl Phthalate | µg/L | < | | | | | | | | | | | | | | | | | |
| | Di-n-Butyl Phthalate | µg/L | < | | | | | | | | | | | | | | | | | |
| | 2,4-Dinitrotoluene | µg/L | < | | | | | | | | | | | | | | | | | |



Stream / Surface Water Information

Ellport Boro STP, NPDES Permit No. PA0038814, Outfall 001

Instructions Discharge **Stream**

Receiving Surface Water Name: **Connoquenessing Creek**

No. Reaches to Model: **1**

- ☒ Statewide Criteria
☐ Great Lakes Criteria
☐ ORSANCO Criteria

| Location | Stream Code* | RMI* | Elevation (ft)* | DA (mi ²)* | Slope (ft/ft) | PWS Withdrawal (MGD) | Apply Fish Criteria* |
|--------------------|--------------|------|-----------------|------------------------|---------------|----------------------|----------------------|
| Point of Discharge | 034025 | 4.96 | 800 | 827 | | | Yes |
| End of Reach 1 | 034025 | 0.25 | 735 | 839 | | 1 | Yes |

Q₇₋₁₀

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|-----------|-----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 4.96 | 0.1 | 66.04 | | | | | | | | | 100 | 7 | | |
| End of Reach 1 | 0.25 | 0.1 | 67 | | | | | | | | | 100 | 7 | | |

Q_h

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|-----------|-----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 4.96 | | | | | | | | | | | | | | |
| End of Reach 1 | 0.25 | | | | | | | | | | | | | | |

Toxics Management Spreadsheet
Version 1.3, March 2021

Model Results

Ellport Boro STP, NPDES Permit No. PA0038814, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

☒ All☐ Inputs☐ Results☐ Limits☒ HydrodynamicsQ₇₋₁₀

| RMI | Stream Flow (cfs) | PWS Withdrawal (cfs) | Net Stream Flow (cfs) | Discharge Analysis Flow (cfs) | Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Travel Time (days) | Complete Mix Time (min) |
|------|-------------------|----------------------|-----------------------|-------------------------------|---------------|------------|------------|-----------|----------------|--------------------|-------------------------|
| 4.96 | 66.04 | | 66.04 | 1.114 | 0.003 | 1.088 | 138.387 | 127.149 | 0.446 | 0.646 | 437.31 |
| 0.25 | 67.00 | 1.547 | 65.453 | | | | | | | | |

Q_h

| RMI | Stream Flow (cfs) | PWS Withdrawal (cfs) | Net Stream Flow (cfs) | Discharge Analysis Flow (cfs) | Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Travel Time (days) | Complete Mix Time (min) |
|------|-------------------|----------------------|-----------------------|-------------------------------|---------------|------------|------------|-----------|----------------|--------------------|-------------------------|
| 4.96 | 289.40 | | 289.40 | 1.114 | 0.003 | 2.073 | 138.387 | 66.747 | 1.013 | 0.284 | 170.669 |
| 0.25 | 293.075 | 1.547 | 291.53 | | | | | | | | |

☒ Wasteload Allocations☒ AFC

CCT (min): 15

PMF: 0.185

Analysis Hardness (mg/l): 100

Analysis pH: 7.01

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |

☒ CFC

CCT (min): #####

PMF: 1

Analysis Hardness (mg/l): 100

Analysis pH: 7.00

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |

☒ THH

CCT (min): #####

THH PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

PWS PMF: 1

Model Results

3/28/2022

Page 5

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|---|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | 500,000 | 500,000 | 30,576,133 | WQC applied at RMI 0.25 with a design stream flow of 67 cfs |
| Chloride (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | 15,288,067 | WQC applied at RMI 0.25 with a design stream flow of 67 cfs |
| Sulfate (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | 15,288,067 | WQC applied at RMI 0.25 with a design stream flow of 67 cfs |

☒ **CRL** CCT (min): ##### PMF: 1 Analysis Hardness (mg/l): N/A Analysis pH: N/A

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |

☒ **Recommended WQBELs & Monitoring Requirements**

No. Samples/Month: 4

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|------------|---------------|---------------|----------------------|-----|------|-------|-----------------|-------------|----------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| | | | | | | | | | |

☒ **Other Pollutants without Limits or Monitoring**

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

| Pollutants | Governing WQBEL | Units | Comments |
|------------------------------|-----------------|-------|----------------------------|
| Total Dissolved Solids (PWS) | 30,576 | mg/L | Discharge Conc ≤ 10% WQBEL |
| Chloride (PWS) | 15,288 | mg/L | Discharge Conc ≤ 10% WQBEL |
| Bromide | N/A | N/A | No WQS |
| Sulfate (PWS) | 15,288 | mg/L | Discharge Conc ≤ 10% WQBEL |

TRC_CALC (1)

| TRC EVALUATION | | | | |
|---|---|-------------------------------|--------------------------------------|----------------------------|
| Input appropriate values in A3:A9 and D3:D9 | | | | |
| 66.04 | = Q stream (cfs) | 0.5 | = CV Daily | |
| 0.72 | = Q discharge (MGD) | 0.5 | = CV Hourly | |
| 30 | = no. samples | 0.185 | = AFC_Partial Mix Factor | |
| 0.3 | = Chlorine Demand of Stream | 1 | = CFC_Partial Mix Factor | |
| 0 | = Chlorine Demand of Discharge | 15 | = AFC_Criteria Compliance Time (min) | |
| 0.5 | = BAT/BPJ Value | 720 | = CFC_Criteria Compliance Time (min) | |
| 0 | = % Factor of Safety (FOS) | | = Decay Coefficient (K) | |
| Source | Reference | AFC Calculations | | Reference CFC Calculations |
| TRC | 1.3.2.iii | WLA afc = 3.518 | | 1.3.2.iii WLA cfc = 18.450 |
| PENTOXSD TRG | 5.1a | LTAMULT afc = 0.373 | | 5.1c LTAMULT cfc = 0.581 |
| PENTOXSD TRG | 5.1b | LTA_afc = 1.311 | | 5.1d LTA_cfc = 10.726 |
| Source | Effluent Limit Calculations | | | |
| PENTOXSD TRG | 5.1f | AML MULT = 1.231 | | |
| PENTOXSD TRG | 5.1g | AVG MON LIMIT (mg/l) = 0.500 | | BAT/BPJ |
| | | INST MAX LIMIT (mg/l) = 1.635 | | |
| WLA afc | $(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... \\ ...+Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$ | | | |
| LTAMULT afc | $EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$ | | | |
| LTA_afc | wla_afc*LTAMULT_afc | | | |
| WLA_cfc | $(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... \\ ...+Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$ | | | |
| LTAMULT_cfc | $EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$ | | | |
| LTA_cfc | wla_cfc*LTAMULT_cfc | | | |
| AML MULT | $EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$ | | | |
| AVG MON LIMIT | MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT) | | | |
| INST MAX LIMIT | 1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc) | | | |

Ellport Borough STP
Ellport Borough, Lawrence County
NPDES# PA0038814

| Date | pH min | pH max | Ave (10^pH min | | | |
|---------|--------|--------|----------------|------------|-----------|---------------|
| | | | 10^-pH min | 10^-pH max | & pH max) | -Log (Ave pH) |
| Jul-19 | 6.90 | 7.20 | 1.26E-07 | 6.31E-08 | 9.45E-08 | 7.0 |
| Aug-19 | 6.98 | 7.18 | 1.05E-07 | 6.61E-08 | 8.54E-08 | 7.1 |
| Sep-19 | 6.98 | 7.23 | 1.05E-07 | 5.89E-08 | 8.18E-08 | 7.1 |
| Jul-20 | 7.06 | 7.69 | 8.71E-08 | 2.04E-08 | 5.38E-08 | 7.3 |
| Aug-20 | 6.97 | 7.64 | 1.07E-07 | 2.29E-08 | 6.5E-08 | 7.2 |
| Sep-20 | 6.99 | 7.50 | 1.02E-07 | 3.16E-08 | 6.7E-08 | 7.2 |
| Jul-21 | 7.04 | 7.38 | 9.12E-08 | 4.17E-08 | 6.64E-08 | 7.2 |
| Aug-20 | 7.11 | 7.34 | 1.07E-07 | 2.29E-08 | 6.5E-08 | 7.2 |
| Sep-20 | 7.15 | 7.43 | 1.02E-07 | 3.16E-08 | 6.7E-08 | 7.2 |
| Median: | | | | | | 7.2 |