

Application Type Renewal  
 Facility Type Sewage  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
ADDENDUM**

Application No. PA0061204  
 APS ID 797238  
 Authorization ID 1446840

**Applicant and Facility Information**

Applicant Name	<u>Aqua Pennsylvania Wastewater, Inc.</u>	Facility Name	<u>Lake Harmony WWTP</u>
Applicant Address	<u>762 W. Lancaster Avenue</u> <u>Bryn Mawr, PA 19010</u>	Facility Address	<u>123 Cross Hill Road</u> <u>Lake Harmony, PA 18624</u>
Applicant Contact	<u>Todd Duerr</u>	Facility Contact	<u>Robert Soltis</u>
Applicant Phone	<u>(610) 645-1122</u>	Facility Phone	<u>(570) 443-7099</u>
Client ID	<u>62614</u>	Site ID	<u>1801</u>
SIC Code	<u>4952</u>	Municipality	<u>Kidder Township</u>
SIC Description	<u>Trans. &amp; Utilities - Sewerage Systems</u>	County	<u>Carbon</u>
Date Published in PA Bulletin	<u>November 16, 2024</u>	EPA Waived?	<u>Yes</u>
Comment Period End Date	<u>December 16, 2024</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of NPDES permit.</u>		

**Internal Review and Recommendations**

Public notification of draft permit issuance was published in the PA Bulletin on November 16, 2024. A comment was received from the permittee's consultant in a letter dated December 16, 2024. The comment and DEP's response are below. Due to changes made to the permit, another draft permit will be issued with a new public comment period.

**Comment:**

"While Aqua currently demonstrates the ability to meet the new Total Zinc limitations, Aqua is requesting that the effective date of the Zinc limitations become effective 4 years after the Permit Effective Date."

**DEP Response:**

It appears the permittee can meet the limitations upon permit issuance, however, the request to delay the effective date of the limitations to four years after the permit effective date is granted. The permittee may need to adjust certain processes to meet the new Total Copper limitations (new for this renewal) and the four-year timeline for the Total Zinc limitations will now coincide with the timeline to meet the new Total Copper limitations. Milestones for meeting the Total Zinc final limitations are included in Part C.IV.

Approve	Return	Deny	Signatures	Date
X			 Brian Burden, E.I.T. / Project Manager	March 3, 2025
X			Amy M. Bellanca (signed) Amy M. Bellanca, P.E. / Program Manager	3-10-25