

## NORTHEAST REGIONAL OFFICE CLEAN WATER PROGRAM

Application Type

Facility Type

Major / Minor

Renewal

Sewage

Minor

## NPDES PERMIT FACT SHEET ADDENDUM

Application No. PA0062103

APS ID 617611

Authorization ID 1255613

Applicant Name Spi		brook Township Sewer rity	_ Facility Name	Springbrook Township Sewer Authority WWTP	
Applicant Address	P.O. B	ox 1100	Facility Address	Green Run Road	
	Moscow, PA 18444		_	Roaring Brook Twp., PA 18444	
Applicant Contact	James	Powell	Facility Contact	James Powell	
Applicant Phone	(570) 8	342-1485	Facility Phone	(570) 842-1485	
Client ID	44196		Site ID	257241	
SIC Code	4952		Municipality	Roaring Brook Township	
SIC Description	Trans.	& Utilities - Sewerage Systems	County	Lackawanna	
Date Published in PA Bulletin		September 21, 2019	EPA Waived?	Yes	
Comment Period End Date		October 21, 2019	If No, Reason	-	

## **Internal Review and Recommendations**

Public notice was published in the PA Bulletin on September 21, 2019. No comments were received during the 30-day comment period.

One typographical error was discovered during final permit preparation: The minimum measurement frequency for Dissolved Oxygen has been updated from "1/week" to "1/day" in accordance with Table 6-3 of DEP's Technical Guidance for the Development and Specification of Effluent Limitations (doc. no. 362-0400-001). This requirement was cited in the draft permit fact sheet.

The Total Residual Chlorine IMAX limitation described in the original draft permit fact sheet, dated September 5, 2019, was mistakenly left out of the draft permit document. A second draft permit is being issued with another comment period based on the addition of the TRC limitation to the permit documents. The same open violations noted in the original draft permit fact sheet are still open.

Approve	Return	Deny	Signatures	Date
Х			/s/ Brian Burden, E.I.T. / Project Manager	October 22, 2019
Х			/s/ Amy M. Bellanca, P.E. / Environmental Engineer Manager	October 22, 2019