

Application Type Renewal  
 Facility Type Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0084077  
 APS ID 278106  
 Authorization ID 1473078

**Applicant and Facility Information**

Applicant Name	<u>Snake Spring Township Municipal Authority Bedford County</u>	Facility Name	<u>Snake Spring Township STP</u>
Applicant Address	<u>624 Pennknoll Road</u> <u>Everett, PA 15537-6945</u>	Facility Address	<u>624 Pennknoll Road</u> <u>Everett, PA 15537-6945</u>
Applicant Contact	<u>Kristen Statler</u>	Facility Contact	<u>Kristen Statler</u>
Applicant Phone	<u>(814) 623-2627</u>	Facility Phone	<u>(814) 623-2627</u>
Client ID	<u>93166</u>	Site ID	<u>461708</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Snake Spring Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Bedford</u>
Date Application Received	<u>February 13, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>April 6, 2024</u>	If No, Reason	<u></u>
Purpose of Application	<u>This is an application request for NPDES renewal.</u>		

Approve	Deny	Signatures	Date
X		Nicholas Hong, P.E. / Environmental Engineer Nick Hong (via electronic signature)	May 8, 2024
X		Daniel W. Martin, P.E. / Environmental Engineer Manager Maria D. Bebenek for	May 21, 2024
X		Maria D. Bebenek, P.E. / Environmental Program Manager Maria D. Bebenek	May 21, 2024

### Summary of Review

The application submitted by the applicant requests a NPDES renewal permit for the Snake Spring Township STP located at 624 Pennknoll Road, Everett, PA 15537 in Bedford County, municipality of Snake Spring Township. The existing permit became effective on September 1, 2019 and expires(d) on August 31, 2024. The application for renewal was received by DEP Southcentral Regional Office (SCRO) on February 13, 2024.

The purpose of this Fact Sheet is to present the basis of information used for establishing the proposed NPDES permit effluent limitations. The Fact Sheet includes a description of the facility, a description of the facility's receiving waters, a description of the facility's receiving waters attainment/non-attainment assessment status, and a description of any changes to the proposed monitoring/sampling frequency. Section 6 provides the justification for the proposed NPDES effluent limits derived from technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), total maximum daily loading (TMDL), antidegradation, anti-backsliding, and/or whole effluent toxicity (WET). A brief summary of the outlined descriptions has been included in the Summary of Review section.

The subject facility is a 0.19 MGD annual average design flow treatment facility. The hydraulic design flow rate for the facility is 0.28 MGD. The applicant does not anticipate any proposed upgrades to the treatment facility in the next five years. The NPDES application has been processed as a Minor Sewage Facility (Level 2) due to the type of sewage and the design flow rate for the facility. The applicant disclosed the Act 14 requirement to Bedford County Commissioners and Snake Spring Township Municipal Authority and the notice was received by the parties on July 14, 2023. A planning approval letter was not necessary as the facility is neither new or expanding.

Utilizing the DEP's web-based Emap-PA information system, the receiving waters has been determined to be the Raystown Juniata Branch River. The sequence of receiving streams that the Raystown Juniata Branch River discharges into is the Juniata River which eventually drains into the Chesapeake Bay. The subject site is subject to the Chesapeake Bay implementation requirements. The receiving water has protected water usage for trout stocking fish (TSF) and migratory fishes (MF). No Class A Wild Trout fisheries are impacted by this discharge. The absence of high quality and/or exceptional value surface waters removes the need for an additional evaluation of anti-degradation requirements.

The Raystown Juniata Branch River is a Category 2 stream listed in the 2024 Integrated List of All Waters (formerly 303d Listed Streams). This stream is an attaining stream that supports aquatic life. The receiving waters is not subject to a local total maximum daily load (TMDL) plan to improve water quality in the subject facility's watershed.

The existing permit and proposed permit differ as follows:

- **Monitoring shall be required for lead on a quarterly basis**
- **Due to the EPA triennial review, monitoring shall be required on a quarterly basis for E. Coli.**
- **Monitoring frequency for ammonia-nitrogen shall be at least 1x/week**

Sludge use and disposal description and location(s): Biosolids/sewage sludge disposed at (a) Sandy Run Landfill, Hopewell Township, Bedford County. Disposed in landfill (b) Carl Egolf Farm, Napier Township in Bedford County as agricultural utilization

The proposed permit will expire five (5) years from the effective date.

Based on the review in this report, it is recommended that the permit be drafted. DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Any additional information or public review of documents associated with the discharge or facility may be available at PA DEP Southcentral Regional Office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file review, contact the SCRO File Review Coordinator at 717.705.4700.

## **1.0 Applicant**

### **1.1 General Information**

This fact sheet summarizes PA Department of Environmental Protection's review for the NPDES renewal for the following subject facility.

Facility Name: Snake Spring Township Municipal Authority WWTP

NPDES Permit # PA0084077

Physical Address: 624 Pennknoll Road  
Everett, PA 15537

Mailing Address: 624 Pennknoll Road  
Everett, PA 15537

Contact: Kristen Statler  
Office Secretary  
(814) 623-2627  
Sstma15537@outlook.com

Consultant: Amy Sipes  
Environmental Scientist  
Stiffler, McGraw and Associates, Inc.  
1731 North Juniata Street  
Hollidaysburg, PA 16648  
asipes@stiffler-mcgraw.com

### **1.2 Permit History**

Permit submittal included the following information.

- NPDES Application
- Flow Diagrams
- Effluent Sample Data

## **2.0 Treatment Facility Summary**

### **2.1.1 Site location**

The physical address for the facility is 624 Pennknoll Road, Everett, PA 15537. A topographical and an aerial photograph of the facility are depicted as Figure 1 and Figure 2.

Figure 1: Topographical map of the subject facility





Figure 2: Aerial Photograph of the subject facility



**2.1.2 Sources of Wastewater/Stormwater**

The wastewater treatment plant receives 100% of their wastewater contributions from Snake Spring Township.

The facility receives industrial/commercial wastewater contributions. The facility reported 81 commercial/industrial users. See attachment for list of users.

The facility did not receive hauled in wastes in the last three years. The facility does not anticipate receiving hauled in wastes in the next five years.


**2.2 Description of Wastewater Treatment Process**

The subject facility is a 0.19 MGD average annual design flow facility. The subject facility treats wastewater using an equalization tank, an aeration tank(s), two (2) ClarAstor clarifier unit(s), a chlorine contact tank, a sludge digester(s), and a sludge drying bed(s). The facility is being evaluated for flow, pH, dissolved oxygen, TRC, CBOD, TSS, TRC, fecal coliform, nitrogen species, and phosphorus. The existing permits limits for the facility is summarized in Section 2.4.

The treatment process is summarized in the table.

<b>Treatment Facility Summary</b>				
<b>Treatment Facility Name:</b> Snake Spring Township STP				
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Activated Sludge	Gas Chlorine	0.19
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.28	820	Not Overloaded	Combination	Land Application

The treatment process is depicted in the figure.



**2.3 Facility Outfall Information**

The facility has the following outfall information for wastewater.

<b>Outfall No.</b>	<u>001</u>	<b>Design Flow (MGD)</b>	<u>.19</u>
<b>Latitude</b>	<u>40° 1' 1.00"</u>	<b>Longitude</b>	<u>-78° 26' 54.00"</u>
<b>Wastewater Description:</b>	<u>Sewage Effluent</u>		

**2.3.1 Operational Considerations- Chemical Additives**

Chemical additives are chemical products introduced into a waste stream that is used for cleaning, disinfecting, or maintenance and which may be detected in effluent discharged to waters of the Commonwealth. Chemicals excluded are those used for neutralization of waste streams, the production of goods, and treatment of wastewater.

The subject facility utilizes the following chemicals as part of their treatment process.

- Ferrous sulfate

**2.4 Existing NPDES Permits Limits**

The existing NPDES permit limits are summarized in the table.

**PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS**

I. A. For Outfall 001, Latitude 40° 1' 1.00", Longitude 78° 26' 54.00", River Mile Index 86, Stream Code 13349

Receiving Waters: Raystown Branch Juniata River (TSF, MF)

Type of Effluent: Sewage Effluent

1. The permittee is authorized to discharge during the period from **September 1, 2019** through **August 31, 2024**.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	39	63	XXX	25	40	50	1/week	24-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Suspended Solids	47	71	XXX	30	45	60	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab

Outfall001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly Report Annl Avg	Weekly Average	Instant. Maximum		
Nitrate-Nitrite as N	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	2/year	24-Hr Composite
Nitrate-Nitrite as N (Total Load, lbs)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	2/year	Calculation
Total Nitrogen	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	2/year	Calculation
Total Nitrogen (Total Load, lbs)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	2/year	Calculation
Ammonia-Nitrogen (Total Load, lbs)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	2/year	Calculation
Total Kjeldahl Nitrogen	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	2/year	24-Hr Composite
Total Kjeldahl Nitrogen (Total Load, lbs)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	2/year	Calculation
Total Phosphorus	3.17	XXX	XXX	2.0	XXX	4	1/week	24-Hr Composite
Total Phosphorus (Total Load, lbs)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	2/year	Calculation

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

### **3.0 Facility NPDES Compliance History**

#### **3.1 Summary of Inspections**

A summary of the most recent inspections during the existing permit review cycle is as follows.

The DEP inspector noted the following during the inspection.

06/25/2020:

- A review of the facility's discharge monitoring reports (DMRs) showed that a No Data Indicator (NODI) code was used in place of a value on the 2019 Annual DMR. Specifically, the NODI code "E" was used to report the average annual loading for ammonia. DEP advised the operator to use the code since the recently renewed NPDES permit did not have a sampling requirement for ammonia concentration. The permit asks for a calculation of the average annual loading for ammonia only. The Department's permitting engineer for this facility was made aware of the issue and recently updated part A of the NPDES permit to include twice yearly sampling and reporting of the ammonia concentration, as well as the loading. A copy of the updated permit will be sent to the township. The electronic DMR should also reflect these changes.

03/10/2021:

- On March 9, 2021 Josh Baker, operator at the Snake Spring Township STP, contacted DEP and said that a property owner informed the township of a possible sewer line leak on his property. The property is the Hartley RV campground at 924 Hartley Road, Bedford PA. Josh said he investigated and found a small area of black slimy mud in the grass close to a township sewage pump station. The operator said that the wet well near the leak was pumped down to prevent any further discharge. The location of the leak was between the pump station and the Raystown Branch. The area is also across the river from the township's wastewater treatment plant. There did not appear to be any other breakouts of sewage in the area. Lang septic was onsite earlier in the day and had pumped down the wet well again.

01/12/2022:

- Since last inspection one blower was replaced and a valve in the digester tank was replaced. The operator was looking into a problem with one of the chlorine feed pumps and may replace the unit. The Authority had arranged to replace the back-up generator. The current unit is old, but still operable. It no longer switches on automatically for routine exercising.

- On June 7, 2019 the Authority reported a sanitary sewer overflow in a field at a nearby campground. The overflow was due to a broken pipe. No sewage entered a waterway and the pipe was repaired. A review of paperwork shows the operator is submitting an older version of the Chesapeake Bay Annual Spreadsheet.

02/17/2023:

- There was nothing significant to report.

03/01/2024:

- Since last inspection one valve actuator was replaced, one sludge wasting pump was replaced, and one EQ pump was replaced.
- Both pumps at the Hartley pump station were rebuilt.
- The authority recently switched to CSM Environmental for their wastewater testing. Sludge was last removed from the plant in January 2024

03/28/2024:

- There was nothing significant to report.

### **3.2 Summary of DMR Data**

A review of approximately 1-year of DMR data shows that the monthly average flow data for the facility below the design capacity of the treatment system. The maximum average flow data for the DMR reviewed was 0.068 MGD in January 2024. The design capacity of the treatment system is 0.28 MGD.

The off-site laboratory used for the analysis of the parameters was Pace Analytical located at 2019 9<sup>th</sup> Avenue, Altoona, PA 16602.

DMR Data for Outfall 001 (from April 1, 2023 to March 31, 2024)

Parameter	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23
Flow (MGD) Average Monthly	0.066	0.062	0.068	0.052	0.051	0.048	0.050	0.053	0.061	0.052	0.059	0.053
Flow (MGD) Daily Maximum	0.127	0.097	0.190	0.099	0.125	0.068	0.090	0.090	0.108	0.085	0.113	0.098
pH (S.U.) Instantaneous Minimum	7.08	6.95	6.71	7.1	7.06	7.10	7.00	6.99	7.01	7.05	6.89	6.99
pH (S.U.) Instantaneous Maximum	7.53	8.26	7.65	7.76	7.6	7.54	7.50	7.38	7.53	7.39	7.34	7.24
DO (mg/L) Instantaneous Minimum	7.01	6.35	6.81	6.71	5.98	5.55	5.11	5.85	5.00	5.02	5.22	5.91
TRC (mg/L) Average Monthly	0.37	0.36	0.35	0.37	0.36	0.31	0.23	0.33	0.28	0.35	0.27	0.36
TRC (mg/L) Instantaneous Maximum	0.68	0.70	0.65	0.65	0.51	0.57	0.52	0.60	0.51	0.59	0.45	0.61
CBOD5 (lbs/day) Average Monthly	< 2	< 2	< 2	< 2	< 2	< 1	< 3	< 1	< 2	< 1	< 2	< 2
CBOD5 (lbs/day) Weekly Average	< 2	< 2	< 5	< 2	< 3	< 1	< 3	< 2	< 2	< 2	< 2	< 2
CBOD5 (mg/L) Average Monthly	< 3	< 3	< 3	< 3	< 3	< 3	< 1	< 3	< 3	< 3	< 3	< 3
CBOD5 (mg/L) Weekly Average	< 3	3	3	< 3	< 3	< 3	< 2	< 3	< 3	< 3	3	< 3
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	103	106	129	159	136	122	132	110	166	115	124	133
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	110	137	254	194	209	126	179	127	323	131	154	161
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	189	202	180	297	240	269	278	231	291	247	244	253
TSS (lbs/day) Average Monthly	< 2	< 2	< 2	< 1	< 1	< 5	< 4	< 1	< 0.9	< 1	< 1	< 2

**NPDES Permit Fact Sheet  
Snake Spring Township STP**

**NPDES Permit No. PA0084077**

TSS (lbs/day) Raw Sewage Influent   Average Monthly	34	37	63	39	27	29	29	24	53	22	39	34
TSS (lbs/day) Raw Sewage Influent   Daily Maximum	39	49	174	44	40	60	35	34	158	36	125	53
TSS (lbs/day) Weekly Average	< 2	< 2	< 5	2	3	18	6	2	< 1	2	2	3
TSS (mg/L) Average Monthly	< 3	< 3	< 3	< 3	< 2	< 11	< 2	2	< 2	< 2	< 3	< 4
TSS (mg/L) Raw Sewage Influent   Average Monthly	64	70	76	74	48	64	61	49	90	49	64	64
TSS (mg/L) Weekly Average	< 3	< 3	4	4	3	37	2	3	< 2	4	3	6
Fecal Coliform (No./100 ml) Geometric Mean	2	< 1	< 4	< 1	< 4	< 3	< 3	< 2	< 6	< 1	2	5
Fecal Coliform (No./100 ml) Instantaneous Maximum	10	1	48	2	167	17.3	10.9	4.1	35.9	1	7.4	10.9
Nitrate-Nitrite (mg/L) Annual Average				< 20.215								
Nitrate-Nitrite (lbs) Annual Average				< 10.9								
Total Nitrogen (mg/L) Annual Average				< 21.053								
Total Nitrogen (lbs) Annual Average				< 11.5								
Ammonia (mg/L) Annual Average				< 0.276								
Ammonia (lbs) Annual Average				< 0.200								
TKN (mg/L) Annual Average				< 0.84								
TKN (lbs) Annual Average				< 0.5								
Total Phosphorus (lbs/day) Average Monthly	0.200	0.300	0.300	0.200	0.200	0.200	0.300	0.500	0.300	0.400	0.627	0.300

**NPDES Permit Fact Sheet  
Snake Spring Township STP**

**NPDES Permit No. PA0084077**

Total Phosphorus (mg/L) Average Monthly	0.380	0.490	0.340	0.413	0.401	0.514	0.582	1.005	0.618	0.876	0.300	0.573
Total Phosphorus (lbs) Annual Average				0.300								

**3.3 Non-Compliance**

**3.3.1 Non-Compliance- NPDES Effluent**

A summary of the non-compliance to the permit limits for the existing permit cycle is as follows.

From the DMR data beginning in September 1, 2019 to May 6, 2024, the following were observed effluent non-compliances.

Summary of Non-Compliance w/ NPDES Permit Limits Beginning September 1, 2019 and Ending May 6, 2024								
NON_COMPL_CATEGORY_DESC	PARAMETER	SAMPLE_VALUE	VIOLATION_CONDITION	PERMIT_VALUE	UNIT_OF_MEASURE	STAT_BASE_CODE	DISCHARGE_COMMENTS	FACILITY_COMMENTS
Effluent	Total Suspended Solids	46	>	45	mg/L	Weekly Average		
Effluent	Fecal Coliform	2419.8	>	1000	No./100 ml	Instantaneous Maximum		Flows were extremely elevated during Hurricane Ida. We have never had issue with fecal counts otherwise. Flows returned to normal as well as the sample results.
Effluent	Fecal Coliform	11199	>	10000	No./100 ml	Instantaneous Maximum		
Unauthorized Discharges							Bedford County VoTech school notified Josh Baker there was sewage on the ground. After inspection it was determined that the property had a broken/seperated pipe connected to an outbuildings grinder pump resulting in an approx 8ft area of spilled sewage. Josh advised discontinued use of outbuilding sewer system. Josh then returned to the property and applied lime to the affected area.	

**3.3.2 Non-Compliance- Enforcement Actions**

A summary of the non-compliance enforcement actions for the current permit cycle is as follows:

Beginning in September 1, 2018 and Ending May 6, 2024, the following were observed enforcement actions.

**Summary of Enforcement Actions  
Beginning September 1, 2018 and Ending May 6, 2024**

ENF ID	ENF TYPE	ENF TYPE DESC	ENF CREATION DATE	EXECUTED DATE	VIOLATIONS	ENF FINALSTATUS	ENF CLOSED DATE
<a href="#">389899</a>	NOV	Notice of Violation	11/06/2020	11/03/2020	92A.62	Comply/Closed	11/30/2020
379477	NOV	Notice of Violation	10/08/2019	10/08/2019	302.202		

**3.4 Summary of Biosolids Disposal**

A summary of the biosolids disposed of from the facility is as follows.

2023						
Sewage Sludge / Biosolids Production Information						
Hauled Off-Site						
Liquid Sewage Sludge/Biosolids				Dewatered Sewage Sludge/Biosolids		
Date (YEAR)	Gallons	% Solids	Dry Tons	Tons Dewatered	% Solids	Dry Tons
January						
February						
March						
April	144,000	1.66	9.725			
May						
June				2.46	88.4	2.17
July						
August				3.06	84.6	2.59
September						
October				4.37	70.8	3.09
November						
December						
Notes:						
Biosolids/sewage sludge disposed at (a) Sandy Run Landfill, Hopewell Township, Bedford County. Disposed in landfill (b) Carl Egolf Farm, Napier Township in Bedford County as agricultural utilization						

**3.5 Open Violations**

No open violations existed as of May 2024.

**4.0 Receiving Waters and Water Supply Information Detail Summary**

**4.1 Receiving Waters**

The receiving waters has been determined to be the Raystown Juniata Branch River. The sequence of receiving streams that the Raystown Juniata Branch River discharges into is the Juniata River which eventually drains into the Chesapeake Bay.

**4.2 Public Water Supply (PWS) Intake**

The closest PWS to the subject facility is Saxton Municipal Water Authority (PWS ID # 4050021) located approximately 47 miles downstream of the subject facility on the Juniata River. Based upon the distance and the flow rate of the facility, the PWS should not be impacted.

**4.3 Class A Wild Trout Streams**

Class A Wild Trout Streams are waters that support a population of naturally produced trout of sufficient size and abundance to support long-term and rewarding sport fishery. DEP classifies these waters as high-quality coldwater fisheries.

The information obtained from EMAP suggests that no Class A Wild Trout Fishery will be impacted by this discharge.

#### **4.4 2024 Integrated List of All Waters (303d Listed Streams)**

Section 303(d) of the Clean Water Act requires States to list all impaired surface waters not supporting uses even after appropriate and required water pollution control technologies have been applied. The 303(d) list includes the reason for impairment which may be one or more point sources (i.e. industrial or sewage discharges) or non-point sources (i.e. abandoned mine lands or agricultural runoff and the pollutant causing the impairment such as metals, pH, mercury or siltation).

States or the U.S. Environmental Protection Agency (EPA) must determine the conditions that would return the water to a condition that meets water quality standards. As a follow-up to listing, the state or EPA must develop a Total Maximum Daily Load (TMDL) for each waterbody on the list. A TMDL identifies allowable pollutant loads to a waterbody from both point and non-point sources that will prevent a violation of water quality standards. A TMDL also includes a margin of safety to ensure protection of the water.

The water quality status of Pennsylvania's waters uses a five-part categorization (lists) of waters per their attainment use status. The categories represent varying levels of attainment, ranging from Category 1, where all designated water uses are met to Category 5 where impairment by pollutants requires a TMDL for water quality protection.

**The receiving waters is listed in the 2024 Pennsylvania Integrated Water Quality Monitoring and Assessment Report as a Category 2 waterbody. The surface waters is an attaining stream that supports aquatic life. The designated use has been classified as protected waters for trout stocking fishes (TSF) and migratory fishes (MF).**

#### **4.5 Low Flow Stream Conditions**

Water quality modeling estimates are based upon conservative data inputs. The data are typically estimated using either a stream gauge or through USGS web based StreamStats program. The NPDES effluent limits are based upon the combined flows from both the stream and the facility discharge.

A conservative approach to estimate the impact of the facility discharge using values which minimize the total combined volume of the stream and the facility discharge. The volumetric flow rate for the stream is based upon the seven-day, 10-year low flow (Q710) which is the lowest estimated flow rate of the stream during a 7 consecutive day period that occurs once in 10 -year time period. The facility discharge is based upon a known design capacity of the subject facility.

The closest WQN station to the subject facility is the Raystown Branch Juniata (WQN223). This WQN station is located approximately 48 miles downstream of the subject facility.

The closest gauge station to the subject facility is the Raystown Branch Juniata River at Saxton, PA (USGS station number 1562000). This gauge station is located approximately 48 miles downstream of the subject facility.

For WQM modeling, pH and stream water temperature data from the water quality network station was used. pH was estimated to be 8.0 and the stream water temperature was estimated to be 23.3 C.

The hardness of the stream was estimated from the water quality network to be 96 mg/l CaCO<sub>3</sub>.

The low flow yield and the Q710 for the subject facility was estimated as shown below.

Gauge Station Data		
USGS Station Number	1562000	
Station Name	Raystown Branch Juniata River at Saxton, PA	
Q710	67.1	ft <sup>3</sup> /sec
Drainage Area (DA)	756	mi <sup>2</sup>
<b>Calculations</b>		
The low flow yield of the gauge station is:		
Low Flow Yield (LFY) = Q710 / DA		
LFY = ( 67.1 ft <sup>3</sup> /sec / 756 mi <sup>2</sup> )		
LFY =	0.0888	ft <sup>3</sup> /sec/mi <sup>2</sup>
The low flow at the subject site is based upon the DA of		
	366	mi <sup>2</sup>
Q710 = (LFY@gauge station)(DA@Subject Site)		
Q710 = (0.0888 ft <sup>3</sup> /sec/mi <sup>2</sup> )(366 mi <sup>2</sup> )		
Q710 =	32.485	ft <sup>3</sup> /sec

**4.6 Summary of Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.19</u>
Latitude	<u>40° 1' 1.97"</u>	Longitude	<u>-78° 26' 52.01"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Raystown Branch Juniata River (TSF, MF)</u>	Stream Code	<u>13349</u>
NHD Com ID	<u>65847495</u>	RMI	<u>88.6</u>
Drainage Area	<u>366</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.0888</u>
Q <sub>7-10</sub> Flow (cfs)	<u>32.485</u>	Q <sub>7-10</sub> Basis	<u>Streamstats/streamgauge</u>
Elevation (ft)	<u>312</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>11-C</u>	Chapter 93 Class.	<u>TSF, MF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining Use(s) supports aquatic life</u>		
Cause(s) of Impairment	<u>Not appl.</u>		
Source(s) of Impairment	<u>Not appl.</u>		
TMDL Status	<u>Not appl.</u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u>8.00</u>	<u>WQN223; Median July to Oct</u>	
Temperature (°C)	<u>23.3</u>	<u>WQN223; Median July to Oct</u>	
Hardness (mg/L)	<u>96</u>	<u>WQN; historical median</u>	
Other:	<u></u>	<u></u>	
Nearest Downstream Public Water Supply Intake		<u>Saxton Municipal Water Authority</u>	
PWS Waters	<u>Juniata River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u>41</u>	Distance from Outfall (mi)	<u>48</u>

**5.0: Overview of Presiding Water Quality Standards**

**5.1 General**

There are at least six (6) different policies which determines the effluent performance limits for the NPDES permit. The policies are technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), antidegradation, total maximum daily loading (TMDL), anti-backsliding, and whole effluent toxicity (WET) The effluent performance limitations enforced are the selected permit limits that is most protective to the designated use of the receiving waters. An overview of each of the policies that are applicable to the subject facility has been presented in Section 6.

**5.2.1 Technology-Based Limitations**

TBEL treatment requirements under section 301(b) of the Act represent the minimum level of control that must be imposed in a permit issued under section 402 of the Act (40 CFR 125.3). Available TBEL requirements for the state of Pennsylvania are itemized in PA Code 25, Chapter 92a.47.

The presiding sources for the basis for the effluent limitations are governed by either federal or state regulation. The reference sources for each of the parameters is itemized in the tables. The following technology-based limitations apply, subject to water quality analysis and best professional judgement (BPJ) where applicable:

Parameter	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**5.2.2 Mass Based Limits**

For publicly owned treatment works (POTW), mass loadings are calculated based upon design flow rate of the facility and the permit limit concentration. The generalized calculation for mass loadings is shown below:

$$Quantity \left( \frac{lb}{day} \right) = (MGD)(Concentration)(8.34)$$

**5.3 Water Quality-Based Limitations**

WQBEL are based on the need to attain or maintain the water quality criteria and to assure protection of designated and existing uses (PA Code 25, Chapter 92a.2). The subject facility that is typically enforced is the more stringent limit of either the TBEL or the WQBEL.

Determination of WQBEL is calculated by spreadsheet analysis or by a computer modeling program developed by DEP. DEP permit engineers utilize the following computing programs for WQBEL permit limitations: (1) MS Excel worksheet for Total Residual Chlorine (TRC); (2) WQM 7.0 for Windows Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen Version 1.1 (WQM Model) and (3) Toxics using DEP Toxics Management Spreadsheet for Toxics pollutants.

The modeling point nodes utilized for this facility are summarized below.

<b>General Data 1</b>	<b>(Modeling Point #1)</b>	<b>(Modeling Point #2)</b>	<b>Units</b>
Stream Code	13349	13349	
River Mile Index	88.6	86.68	miles
Elevation	312	309	feet
Latitude	40.017778	40.014656	
Longitude	-78.446944	-78.425594	
Drainage Area	366	367	sq miles
Low Flow Yield	0.0888	0.0888	cfs/sq mile

### **5.3.1 Water Quality Modeling 7.0**

The WQM Model is a computer model that is used to determine NPDES discharge effluent limitations for Carbonaceous BOD (CBOD5), Ammonia Nitrogen (NH3-N), and Dissolved Oxygen (DO) for single and multiple point source discharges scenarios. WQM Model is a complete-mix model which means that the discharge flow and the stream flow are assumed to instantly and completely mixed at the discharge node.

WQM recommends effluent limits for DO, CBOD5, and NH3-N in mg/l for the discharge(s) in the simulation.

Four types of limits may be recommended. The limits are

- (a) a minimum concentration for DO in the discharge as 30-day average;
- (b) a 30-day average concentration for CBOD5 in the discharge;
- (c) a 30-day average concentration for the NH3-N in the discharge;
- (d) 24-hour average concentration for NH3-N in the discharge.

The WQM Model requires several input values for calculating output values. The source of data originates from either EMAP, the National Map, or Stream Stats. Data for stream gauge information, if any, was abstracted from USGS Low-Flow, Base-Flow, and Mean-Flow Regression Equations for Pennsylvania Streams authored by Marla H. Stuckey (Scientific Investigations Report 2006-5130).

**The applicable WQM Effluent Limit Type are discussed in Section 6 under the corresponding parameter which is either DO, CBOD, or ammonia-nitrogen.**

### **5.3.2 Toxics Modeling**

The Toxics Management Spreadsheet model is a computer model that is used to determine effluent limitations for toxics (and other substances) for single discharge wasteload allocations. This computer model uses a mass-balance water quality analysis that includes consideration for mixing, first-order decay, and other factors used to determine recommended water quality-based effluent limits. Toxics Management Spreadsheet does not assume that all discharges completely mix with the stream. The point of compliance with water quality criteria are established using criteria compliance times (CCTs). The available CCTs are either acute fish criterion (AFC), chronic fish criterion (CFC), or human health criteria (THH & CRL).

**Acute Fish Criterion (AFC)** measures the criteria compliance time as either the maximum criteria compliance time (i.e. 15 minutes travel time downstream of the current discharge) or the complete mix time whichever comes first. AFC is evaluated at Q710 conditions.

**Chronic Fish Criterion (CFC)** measures the criteria compliance time as either the maximum criteria compliance time (i.e. 12 hours travel time downstream of the current discharge) or the complete mix time whichever comes first. CFC is evaluated at Q710 conditions.

**Threshold Human Health (THH)** measures the criteria compliance time as either the maximum criteria compliance time (i.e. 12 hours travel time downstream of the current discharge) or the estimated travel time downstream to the nearest potable water supply intake whichever comes first. THH is evaluated at Q710 conditions.

**Cancer Risk Level (CRL)** measures the criteria compliance time as either the maximum criteria compliance time (i.e. 12 hours travel time downstream of the current discharge) or the complete mix time whichever comes first. CRL is evaluated at Qh (harmonic mean or normal flow) conditions.

The Toxics Model requires several input values for calculating output values. The source of data originates from either EMAP, the National Map, or Stream Stats. Data for stream gauge information, if any, was abstracted from USGS Low-Flow, Base-Flow, and Mean-Flow Regression Equations for Pennsylvania Streams authored by Marla H. Stuckey (Scientific Investigations Report 2006-5130).

#### **5.3.2.1 Determining if NPDES Permit Will Require Monitoring/Limits in the Proposed Permit for Toxic Pollutants**

To determine if Toxics modeling is necessary, DEP has developed a Toxics Management Spreadsheet to identify toxics of concern. Toxic pollutants whose maximum concentrations as reported in the permit application or on DMRs are greater than the most stringent applicable water quality criterion are pollutants of concern. A Reasonable Potential Analysis was utilized to determine (a) if the toxic parameters modeled would require monitoring or (b) if permit limitations would be required for the parameters. The toxics reviewed for reasonable potential were the pollutants in TDS, chloride, bromide, sulfate, total copper, total lead, and total zinc.

Based upon the SOP- Establishing Water Quality-Based Effluent Limitations (WQBELs) and Permit Conditions for Toxic Pollutants (Revised January 10, 2019), monitoring and/or limits will be established as follows.

- (a) When reasonable potential is demonstrated, establish limits where the maximum reported concentration equals or exceeds 50% of the WQBEL.
- (b) For non-conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 25% - 50% of the WQBEL.
- (c) For conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 10% - 50% of the WQBEL.

**Applicable monitoring or permit limits for toxics are summarized in Section 6.**

**The Toxics Management Spreadsheet output has been included in Attachment B.**

#### **5.3.3 Whole Effluent Toxicity (WET)**

The facility is not subject to WET.

#### **5.4 Total Maximum Daily Loading (TMDL)**

##### **5.4.1 TMDL**

The goal of the Clean Water Act (CWA), which governs water pollution, is to ensure that all of the Nation's waters are clean and healthy enough to support aquatic life and recreation. To achieve this goal, the CWA created programs designed to regulate and reduce the amount of pollution entering United States waters. Section 303(d) of the CWA requires states to assess their waterbodies to identify those not meeting water quality standards. If a waterbody is not meeting standards, it is listed as impaired and reported to the U.S. Environmental Protection Agency. The state then develops a plan to clean up the impaired waterbody. This plan includes the development of a Total Maximum Daily Load (TMDL) for the pollutant(s) that were found to be the cause of the water quality violations. A Total Maximum Daily Load (TMDL) calculates the maximum amount of a specific pollutant that a waterbody can receive and still meet water quality standards.

A TMDL for a given pollutant and waterbody is composed of the sum of individual wasteload allocations (WLAs) for point sources and load allocations (LAs) for nonpoint sources and natural background levels. In addition, the TMDL must include an implicit or explicit margin of safety (MOS) to account for the uncertainty in the relationship between pollutant loads and the quality of the receiving waterbody. The TMDL components are illustrated using the following equation:

$$\text{TMDL} = \Sigma \text{WLAs} + \Sigma \text{LAs} + \text{MOS}$$

Pennsylvania has committed to restoring all impaired waters by developing TMDLs and TMDL alternatives for all impaired waterbodies. The TMDL serves as the starting point or planning tool for restoring water quality.

#### **5.4.1.1 Local TMDL**

The subject facility does not discharge into a local TMDL.

#### **5.4.1.2 Chesapeake Bay TMDL Requirement**

The Chesapeake Bay Watershed is a large ecosystem that encompasses approximately 64,000 square miles in Maryland, Delaware, Virginia, West Virginia, Pennsylvania, New York and the District of Columbia. An ecosystem is composed of interrelated parts that interact with each other to form a whole. All of the plants and animals in an ecosystem depend on each other in some way. Every living thing needs a healthy ecosystem to survive. Human activities affect the Chesapeake Bay ecosystem by adding pollution, using resources and changing the character of the land.

Most of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the federal Water Pollution Control Act ("Clean Water Act"), 33 U.S.C. § 1313(d). While the Chesapeake Bay is outside the boundaries of Pennsylvania, more than half of the State lies within the watershed. Two major rivers in Pennsylvania are part of the Chesapeake Bay Watershed. They are (a) the Susquehanna River and (b) the Potomac River. These two rivers total 40 percent of the entire Chesapeake Bay watershed.

The overall management approach needed for reducing nitrogen, phosphorus and sediment are provided in the Bay TMDL document and the Phase I, II, and III WIPs which is described in the Bay TMDL document and Executive Order 13508.

The Bay TMDL is a comprehensive pollution reduction effort in the Chesapeake Bay watershed identifying the necessary pollution reductions of nitrogen, phosphorus and sediment across the seven Bay watershed jurisdictions of Delaware, Maryland, New York, Pennsylvania, Virginia, West Virginia and the District of Columbia to meet applicable water quality standards in the Bay and its tidal waters.

The Watershed Implementation Plans (WIPs) provides objectives for how the jurisdictions in partnership with federal and local governments will achieve the Bay TMDL's nutrient and sediment allocations.

Phase 3 WIP provides an update on Chesapeake Bay TMDL implementation activities for point sources and DEP's current implementation strategy for wastewater. The latest revision of the supplement was September 13, 2021.

The Chesapeake Bay TMDL (Appendix Q) categorizes point sources into four sectors:

- Sector A- significant sewage dischargers;
- Sector B- significant industrial waste (IW) dischargers;
- Sector C- non-significant dischargers (both sewage and IW facilities); and
- Sector D- combined sewer overflows (CSOs).

All sectors contain a listing of individual facilities with NPDES permits that were believed to be discharging at the time the TMDL was published (2010). All sectors with the exception of the non-significant dischargers have individual wasteload allocations (WLAs) for TN and TP assigned to specific facilities. Non-significant dischargers have a bulk or aggregate allocation for TN and TP based on the facilities in that sector that were believed to be discharging at that time and their estimated nutrient loads.

Cap Loads will be established in permits as Net Annual TN and TP loads (lbs/yr) that apply during the period of October 1 – September 30. For facilities that have received Cap Loads in any other form, the Cap Loads will be modified accordingly when the permits are renewed.

Offsets have been incorporated into Cap Loads in several permits issued to date. From this point forward, permits will be issued with the WLAs as Cap Loads and will identify Offsets separately to facilitate nutrient trading activities and compliance with the TMDL.

Based upon the supplement the subject facility has been categorized as a Sector C discharger. The supplement defines Sector C as a non-significant dischargers include sewage facilities (Phase 4 facilities:  $\geq 0.2$  MGD and  $< 0.4$  MGD and Phase 5 facilities:  $> 0.002$  MGD and  $< 0.2$  MGD), small flow/single residence sewage treatment facilities ( $\leq 0.002$  MGD), and non-significant IW facilities, all of which may be covered by statewide General Permits or may have individual NPDES permits.

At this time, there are approximately 850 Phase 4 and 5 sewage facilities, approximately 715 small flow sewage treatment facilities covered by a statewide General Permit, and approximately 300 non-significant IW facilities.

For Phase 5 sewage facilities with individual permits (average annual design flow on August 29, 2005 > 0.002 MGD and < 0.2 MGD), DEP will issue individual permits with monitoring and reporting for TN and TP throughout the permit term at a frequency no less than annually, unless 1) the facility has already conducted at least two years of nutrient monitoring and 2) a summary of the monitoring results are included in the next permit's fact sheet. If, however, Phase 5 facilities choose to expand, the renewed or amended permits will contain Cap Loads based on the lesser of a) existing TN/TP concentrations at current design average annual flow or b) 7,306 lbs/yr TN and 974 lbs/yr TP.

If no data are available to determine existing concentrations for expanding Phase 4 or 5 facilities, default concentrations of 25 mg/l TN and 4 mg/l TP may be used (these are the average estimated concentrations of all non-significant sewage facilities).

DEP will not issue permits to existing Phase 4 and 5 facilities containing Cap Loads unless it is done on a broad scale or unless the facilities are expanding.

For new Phase 4 and 5 sewage discharges, in general DEP will issue new permits containing Cap Loads of "0" and new facilities will be expected to purchase credits and/or apply offsets to achieve compliance, with the exception of small flow and single residence facilities.

**Due to the Chesapeake Bay WIP, this facility is subject to Sector C monitoring requirements. Monitoring for nitrogen species and phosphorus shall be 2x/yr.**

### **5.5 Anti-Degradation Requirement**

Chapter 93.4a of the PA regulations requires that surface water of the Commonwealth of Pennsylvania may not be degraded below levels that protect the existing uses. The regulations specifically state that *Existing instream water uses and the level of water quality necessary to protect the existing uses shall be maintained and protected*. Antidegradation requirements are implemented through DEP's guidance manual entitled Water Quality Antidegradation Implementation Guidance (Document #391-0300-02).

The policy requires DEP to protect the existing uses of all surface waters and the existing quality of High Quality (HQ) and Exceptional Value (EV) Waters. Existing uses are protected when DEP makes a final decision on any permit or approval for an activity that may affect a protected use. Existing uses are protected based upon DEP's evaluation of the best available information (which satisfies DEP protocols and Quality Assurance/Quality Control (QA/QC) procedures) that indicates the protected use of the waterbody.

For a new, additional, or increased point source discharge to an HQ or EV water, the person proposing the discharge is required to utilize a nondischarge alternative that is cost-effective and environmentally sound when compared with the cost of the proposed discharge. If a nondischarge alternative is not cost-effective and environmentally sound, the person must use the best available combination of treatment, pollution prevention, and wastewater reuse technologies and assure that any discharge is nondegrading. In the case of HQ waters, DEP may find that after satisfaction of intergovernmental coordination and public participation requirements lower water quality is necessary to accommodate important economic or social development in the area in which the waters are located. In addition, DEP will assure that cost-effective and reasonable best management practices for nonpoint source control in HQ and EV waters are achieved.

**The subject facility's discharge will be to a non-special protection waters and the permit conditions are imposed to protect existing instream water quality and uses. Neither HQ waters or EV waters is impacted by this discharge.**

### **5.6 Anti-Backsliding**

Anti-backsliding is a federal regulation which prohibits a permit from being renewed, reissued, or modified containing effluent limitations which are less stringent than the comparable effluent limitations in the previous permit (40 CFR 122.I.1 and 40 CFR 122.I.2). A review of the existing permit limitations with the proposed permit limitations confirm that the facility is consistent with anti-backsliding requirements. The facility has proposed effluent limitations that are as stringent as the existing permit.

## **6.0 NPDES Parameter Details**

The basis for the proposed sampling and their monitoring frequency that will appear in the permit for each individual parameter are itemized in this Section. The final limits are the more stringent of technology based effluent treatment (TBEL) requirements, water quality based (WQBEL) limits, TMDL, antidegradation, anti-degradation, or WET.

The reader will find in this section:

- a) a justification of recommended permit monitoring requirements and limitations for each parameter in the proposed NPDES permit;
- b) a summary of changes from the existing NPDES permit to the proposed permit; and
- c) a summary of the proposed NPDES effluent limits.

## **6.1 Recommended Monitoring Requirements and Effluent Limitations**

A summary of the recommended monitoring requirements and effluent limitations are itemized in the tables. The tables are categorized by (a) Conventional Pollutants and Disinfection, (b) Nitrogen Species and Phosphorus, (c) Toxics, and (d) Non-Conventional Pollutants, and (e) Chapter 92a.61 targeted parameters

**6.1.1 Conventional Pollutants and Disinfection**

Summary of Proposed NPDES Parameter Details for Conventional Pollutants and Disinfection			
Snake Spring Township STP; PA0084077			
Parameter	Permit Limitation Required by <sup>1</sup> :	Recommendation	
pH (S.U.)	TBEL	Monitoring:	The monitoring frequency shall be daily as a grab sample (Table 6-3).
		Effluent Limit:	Effluent limits may range from pH = 6.0 to 9.0
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 95.2(1).
Dissolved Oxygen	BPJ	Monitoring:	The monitoring frequency shall be daily as a grab sample (Table 6-3).
		Effluent Limit:	Effluent limits shall be greater than 5.0 mg/l.
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by best professional judgement.
CBOD	TBEL	Monitoring:	The monitoring frequency shall be 1x/week as an 24-hr composite sample (Table 6-3).
		Effluent Limit:	Effluent limits shall not exceed 39 lbs/day and 25 mg/l as an average monthly.
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.47(a)(1). WQM modeling indicates that the TBEL is more stringent than the WQBEL. Thus, the permit limit is confined to TBEL.
TSS	TBEL	Monitoring:	The monitoring frequency shall be 1/week as a 24-hr composite sample (Table 6-3).
		Effluent Limit:	Effluent limits shall not exceed 47 lbs/day and 30 mg/l as an average monthly.
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.47(a)(1). While there is no WQM modeling for this parameter, the permit limit for TSS is generally assigned similar effluent limits as CBOD or BOD.
TRC	TBEL	Monitoring:	The monitoring frequency shall be on a daily basis as a grab sample (Table 6-3).
		Effluent Limit:	The average monthly limit should not exceed 0.5 mg/l and/or 1.6 mg/l as an instantaneous maximum.
		Rationale:	Chlorine in both combined (chloramine) and free form is extremely toxic to freshwater fish and other forms of aquatic life (Implementation Guidance Total Residual Chlorine 1). The TRC effluent limitations to be imposed on a discharger shall be the more stringent of either the WQBEL or TBEL requirements and shall be expressed in the NPDES permit as an average monthly and instantaneous maximum effluent concentration (Implementation Guidance Total Residual Chlorine 4). Based on the stream flow rate (lowest 7-day flow rate in 10 years) and the design flow rate of the subject facility calculated by the TRC Evaluation worksheet, the TBEL is more stringent than the WQBEL. The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.48(b)(2)
Fecal Coliform	TBEL	Monitoring:	The monitoring frequency shall be 1x/week as a grab sample (Table 6-3).
		Effluent Limit:	Summer effluent limits shall not exceed 200 No./100 mL as a geometric mean. Winter effluent limits shall not exceed 2000 No./100 mL as a geometric mean.
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.47(a)(4) and 92a.47(a)(5).

**Notes:**

1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other

2 Monitoring frequency based on flow rate of 0.19 MGD.

3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97

4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)

5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021

**6.1.2 Nitrogen Species and Phosphorus**

Summary of Proposed NPDES Parameter Details for Nitrogen Species and Phosphorus			
Snake Spring Township STP; PA0084077			
Parameter	Permit Limitation Required by <sup>1</sup> :	Recommendation	
Ammonia-Nitrogen	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/yr as a 24-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/yr.
Nitrate-Nitrite as N	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/yr as a 24-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/yr.
Total Nitrogen	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/yr as a calculation.
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/yr.
TKN	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/yr as a 24-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/yr.
Total Phosphorus	Anti-backsliding	Monitoring:	The monitoring frequency shall be 1x/wk as a 24-hr composite sample
		Effluent Limit:	Effluent limits shall not exceed 3.17 lbs/day and 2.0 mg/l as an average monthly.
		Rationale:	Due to anti-backsliding regulations, the current permit limit shall continue to the proposed permit. The effluent requirement originated for dischargers within 60 miles of Lake Raystown.
Notes:			
1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other			
2 Monitoring frequency based on flow rate of 0.19 MGD.			
3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97			
4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)			
5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021			

**6.1.3 Toxics**

Summary of Proposed NPDES Parameter Details for Toxics

Snake Spring Township STP; PA0084077

Parameter	Permit Limitation Required by <sup>1</sup> :	Recommendation	
Total Lead	WQBEL	Monitoring:	The monitoring frequency shall be 1x/quarter as a 24-hr composite sample (Table 6-3).
		Effluent Limit:	No monitoring requirement
		Rationale:	The NPDES application reported the parameter was sampled 3 times. The maximum result was a non-detect value of <0.0080 mg/l. The Toxics Management Spreadsheet recommends limits. However, DEP recommends collection of more samples to clearly identify if there is a concern for the pollutant. Future renewals may enforce a limit or eliminate monitoring upon the monitoring results.

Notes:

- 1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other
- 2 Monitoring frequency based on flow rate of 0.19 MGD.
- 3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97
- 4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)
- 5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021

**6.1.3.1 Implementation of Regulation- Chapter 92a.61**

Chapter 92a.61 provides provisions to DEP to monitor for pollutants that may have an impact on the quality of waters of the Commonwealth.

Based upon DEP policy directives the following pollutants shall be monitored:

- Consistent with DEP Management directives issued on March 22, 2021 and in conjunction with EPA’s 2017 Triennial Review, monitoring for E. Coli shall be required. The monitoring frequency is based upon flow rate.

Summary of Proposed NPDES Parameter Details for pollutants monitored under Chapter 92a.61

Snake Spring Township STP; PA0084077

Parameter	Permit Limitation Required by <sup>1</sup> :	Recommendation	
E. Coli	SOP; Chapter 92a.61	Monitoring:	The monitoring frequency shall be 1x/quarter as a grab sample (SOP).
		Effluent Limit:	No effluent requirements.
		Rationale:	Consistent with the SOP- Establishing Effluent Limitations for Individual Sewage Permits (Revised February 5, 2024) and under the authority of Chapter 92a.61, the facility will be required to monitor for E.Coli.

Notes:

- 1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other
- 2 Monitoring frequency based on flow rate of 0.19 MGD.
- 3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97
- 4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)
- 5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021

**6.2 Summary of Changes From Existing Permit to Proposed Permit**

A summary of how the proposed NPDES permit differs from the existing NPDES permit is summarized as follows.

- **Monitoring shall be required for lead on a quarterly basis**
- **Due to the EPA triennial review, monitoring shall be required on a quarterly basis for E. Coli**
- **Monitoring frequency for ammonia-nitrogen shall be at least 1x/week**

**6.3.1 Summary of Proposed NPDES Effluent Limits**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

The proposed NPDES effluent limitations are summarized in the table below.

**PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS**

I. A. For Outfall 001, Latitude 40° 1' 1.00", Longitude 78° 26' 54.00", River Mile Index 88.6, Stream Code 13349

Receiving Waters: Raystown Branch Juniata River (TSF, MF)

Type of Effluent: Sewage Effluent

1. The permittee is authorized to discharge during the period from **Permit Effective Date** through **Permit Expiration Date**.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)			Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type	
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average			Instant. Maximum
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	39	63	XXX	25.0	40.0	50	1/week	24-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Suspended Solids	47	71	XXX	30.0	45.0	60	1/week	24-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date )

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	Grab
Nitrate-Nitrite as N	XXX	XXX	XXX	Report SEMI AVG	XXX	XXX	1/6 months	24-Hr Composite
Nitrate-Nitrite as N (Total Load, lbs) (lbs)	Report SEMI AVG	XXX	XXX	XXX	XXX	XXX	1/6 months	Calculation
Total Nitrogen	XXX	XXX	XXX	Report SEMI AVG	XXX	XXX	1/6 months	Calculation
Total Nitrogen (Total Load, lbs) (lbs)	Report SEMI AVG	XXX	XXX	XXX	XXX	XXX	1/6 months	Calculation
Ammonia-Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Kjeldahl Nitrogen	XXX	XXX	XXX	Report SEMI AVG	XXX	XXX	1/6 months	8-Hr Composite
Total Kjeldahl Nitrogen (Total Load, lbs) (lbs)	Report SEMI AVG	XXX	XXX	XXX	XXX	XXX	1/6 months	Calculation
Total Phosphorus	3.17	XXX	XXX	2.0	XXX	XXX	1/week	24-Hr Composite
Lead, Total	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

### **6.3.2 Summary of Proposed Permit Part C Conditions**

The subject facility has the following Part C conditions.

- Chlorine Minimization
- Hauled-in Waste Restrictions
- Chesapeake Bay Nutrient Definitions
- Solids Management for Non-Lagoon Treatment Systems

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]

# Attachment A

## Stream Stats/Gauge Data

14 Selected Streamflow Statistics for Streamgauge Locations in and near Pennsylvania

Table 1. List of U.S. Geological Survey streamgauge locations in and near Pennsylvania with updated streamflow statistics.—Continued

[Latitude and Longitude in decimal degrees; mi<sup>2</sup>, square miles]

Streamgauge number	Streamgauge name	Latitude	Longitude	Drainage area (mi <sup>2</sup> )	Regulated <sup>1</sup>
01561000	Brush Creek at Gapsville, Pa.	39.956	-78.254	36.8	N
01562000	Raystown Branch Juniata River at Saxton, Pa.	40.216	-78.265	756	N
01562500	Great Trough Creek near Marklesburg, Pa.	40.350	-78.130	84.6	N
01563200	Raystown Branch Juniata River below Rays Dam nr Huntingdon, Pa.	40.429	-77.991	960	Y
01563500	Juniata River at Mapleton Depot, Pa.	40.392	-77.935	2,030	Y
01564500	Aughwick Creek near Three Springs, Pa.	40.213	-77.925	205	N
01565000	Kishacoquillas Creek at Reedsville, Pa.	40.655	-77.583	164	N
01565700	Little Lost Creek at Oakland Mills, Pa.	40.605	-77.311	6.52	N
01566000	Tuscarora Creek near Port Royal, Pa.	40.515	-77.419	214	N
01566500	Cocolamus Creek near Millerstown, Pa.	40.566	-77.118	57.2	N
01567000	Juniata River at Newport, Pa.	40.478	-77.129	3,354	Y
01567500	Bixler Run near Loysville, Pa.	40.371	-77.402	15.0	N
01568000	Sherman Creek at Shermans Dale, Pa.	40.323	-77.169	207	N
01568500	Clark Creek near Carsonville, Pa.	40.460	-76.751	22.5	LF
01569000	Stony Creek nr Dauphin, Pa.	40.380	-76.907	33.2	N
01569800	Letort Spring Run near Carlisle, Pa.	40.235	-77.139	21.6	N
01570000	Conodoguinet Creek near Hogestown, Pa.	40.252	-77.021	470	LF
01570500	Susquehanna River at Harrisburg, Pa.	40.255	-76.886	24,100	Y
01571000	Paxton Creek near Penbrook, Pa.	40.308	-76.850	11.2	N
01571500	Yellow Breeches Creek near Camp Hill, Pa.	40.225	-76.898	213	N
01572000	Lower Little Swatara Creek at Pine Grove, Pa.	40.538	-76.377	34.3	N
01572025	Swatara Creek near Pine Grove, Pa.	40.533	-76.402	116	N
01572190	Swatara Creek near Inwood, Pa.	40.479	-76.531	167	N
01573000	Swatara Creek at Harper Tavern, Pa.	40.403	-76.577	337	N
01573086	Beck Creek near Cleona, Pa.	40.323	-76.483	7.87	N
01573160	Quittapahilla Creek near Belle Grove, Pa.	40.343	-76.562	74.2	N
01573500	Manada Creek at Manada Gap, Pa.	40.397	-76.709	13.5	N
01573560	Swatara Creek near Hershey, Pa.	40.298	-76.668	483	N
01574000	West Conewago Creek near Manchester, Pa.	40.082	-76.720	510	N
01574500	Codorus Creek at Spring Grove, Pa.	39.879	-76.853	75.5	Y
01575000	South Branch Codorus Creek near York, Pa.	39.921	-76.749	117	Y
01575500	Codorus Creek near York, Pa.	39.946	-76.755	222	Y
01576000	Susquehanna River at Marietta, Pa.	40.055	-76.531	25,990	Y
01576085	Little Conestoga Creek near Churchtown, Pa.	40.145	-75.989	5.82	N
01576500	Conestoga River at Lancaster, Pa.	40.050	-76.277	324	N
01576754	Conestoga River at Conestoga, Pa.	39.946	-76.368	470	N
01578310	Susquehanna River at Conowingo, Md.	39.658	-76.174	27,100	Y
01578400	Bowery Run near Quarryville, Pa.	39.895	-76.114	5.98	N
01580000	Deer Creek at Rocks, Md.	39.630	-76.403	94.4	N
01581500	Bynum Run at Bel Air, Md.	39.541	-76.330	8.52	N
01581700	Winters Run near Benson, Md.	39.520	-76.373	34.8	N
01582000	Little Falls at Blue Mount, Md.	39.604	-76.620	52.9	N
01582500	Gunpowder Falls at Glencoe, Md.	39.550	-76.636	160	Y
01583000	Slade Run near Glyndon, Md.	39.495	-76.795	2.09	N
01583100	Piney Run at Dover, Md.	39.521	-76.767	12.3	N

26 Selected Streamflow Statistics for Streamgage Locations in and near Pennsylvania


Table 2. Selected low-flow statistics for streamgage locations in and near Pennsylvania.—Continued

[ft<sup>3</sup>/s; cubic feet per second; —, statistic not computed; <, less than]

Streamgage number	Period of record used in analysis <sup>1</sup>	Number of years used in analysis	1-day, 10-year (ft <sup>3</sup> /s)	7-day, 10-year (ft <sup>3</sup> /s)	7-day, 2-year (ft <sup>3</sup> /s)	30-day, 10-year (ft <sup>3</sup> /s)	30-day, 2-year (ft <sup>3</sup> /s)	90-day, 10-year (ft <sup>3</sup> /s)
01546000	1912–1934	17	1.8	2.2	6.8	3.7	12.1	11.2
01546400	1986–2008	23	13.5	14.0	19.6	15.4	22.3	18.7
01546500	1942–2008	67	26.8	29.0	41.3	31.2	44.2	33.7
01547100	1969–2008	40	102	105	128	111	133	117
01547200	1957–2008	52	99.4	101	132	106	142	115
01547500	<sup>2</sup> 1971–2008	38	28.2	109	151	131	172	153
01547500	<sup>3</sup> 1956–1969	14	90.0	94.9	123	98.1	131	105
01547700	1957–2008	52	.5	.6	2.7	1.1	3.9	2.2
01547800	1971–1981	11	1.6	1.8	2.4	2.1	2.9	3.5
01547950	1970–2008	39	12.1	13.6	28.2	17.3	36.4	23.8
01548005	<sup>2</sup> 1971–2000	25	142	151	206	178	241	223
01548005	<sup>3</sup> 1912–1969	58	105	114	147	125	165	140
01548500	1920–2008	89	21.2	24.2	50.1	33.6	68.6	49.3
01549000	1910–1920	11	26.0	32.9	78.0	46.4	106	89.8
01549500	1942–2008	67	.6	.8	2.5	1.4	3.9	2.6
01549700	1959–2008	50	33.3	37.2	83.8	51.2	117	78.4
01550000	1915–2008	94	6.6	7.6	16.8	11.2	24.6	18.6
01551500	<sup>2</sup> 1963–2008	46	520	578	1,020	678	1,330	919
01551500	<sup>3</sup> 1901–1961	61	400	439	742	523	943	752
01552000	1927–2008	80	20.5	22.2	49.5	29.2	69.8	49.6
01552500	1942–2008	67	.9	1.2	3.1	1.7	4.4	3.3
01553130	1969–1981	13	1.0	1.1	1.5	1.3	1.8	1.7
01553500	<sup>2</sup> 1968–2008	41	760	838	1,440	1,000	1,850	1,470
01553500	<sup>3</sup> 1941–1966	26	562	619	880	690	1,090	881
01553700	1981–2008	28	9.1	10.9	15.0	12.6	17.1	15.2
01554000	<sup>2</sup> 1981–2008	28	1,830	1,990	3,270	2,320	4,210	3,160
01554000	<sup>3</sup> 1939–1979	41	1,560	1,630	2,870	1,880	3,620	2,570
01554500	1941–1993	53	16.2	22.0	31.2	25.9	35.7	31.4
01555000	1931–2008	78	33.5	37.6	58.8	43.4	69.6	54.6
01555500	1931–2008	78	4.9	6.5	18.0	9.4	24.3	16.6
01556000	1918–2008	91	43.3	47.8	66.0	55.1	75.0	63.7
01557500	1946–2008	63	2.8	3.2	6.3	4.2	8.1	5.8
01558000	1940–2008	69	56.3	59.0	79.8	65.7	86.2	73.7
01559000	1943–2008	66	104	177	249	198	279	227
01559500	1931–1958	28	9.3	10.5	15.0	12.4	17.8	15.8
01559700	1963–1978	16	.1	.1	.2	.1	.3	.2
01560000	1941–2008	68	8.5	9.4	15.6	12.0	20.2	16.2
01561000	1932–1958	27	4	5	1.6	8	2.5	1.7
01562000	1913–2008	96	64.1	67.1	106	77.4	122	94.5
01562500	1931–1957	27	1.1	1.6	3.8	2.3	5.4	3.7
01563200	<sup>2</sup> 1974–2008	35	—	—	—	112	266	129
01563200	<sup>3</sup> 1948–1972	25	10.3	28.2	86.1	64.5	113	95.5
01563500	<sup>2</sup> 1974–2008	35	384	415	519	441	580	493
01563500	<sup>3</sup> 1939–1972	34	153	242	343	278	399	333
01564500	1940–2008	69	3.6	4.2	10.0	6.2	14.4	10.6

### StreamStats Report

Region ID: PA  
 Workspace ID: PA20240506161427054000  
 Clicked Point (Latitude, Longitude): 40.01509, -78.44667  
 Time: 2024-05-06 12:14:54 -0400



Snake Spring Township MA WWTP PA0084077 Modeling Point #1 May 2024

Collapse All

#### > Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	9.33	percent
DRNAREA	Area that drains to a point on a stream	366	square miles
PRECIP	Mean Annual Precipitation	38	inches
ROCKDEP	Depth to rock	4	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.37	miles per square mile

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	366	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	38	inches	35	50.4
STRDEN	Stream Density	2.37	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4	feet	3.32	5.65
CARBON	Percent Carbonate	9.33	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	28.4	ft <sup>3</sup> /s	38	38
30 Day 2 Year Low Flow	38.7	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	13.7	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	19.2	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	29.9	ft <sup>3</sup> /s	36	36

*Low-Flow Statistics Citations*


**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

### StreamStats Report

Region ID: PA  
 Workspace ID: PA20240506161742777000  
 Clicked Point (Latitude, Longitude): 40.01462, -78.42567  
 Time: 2024-05-06 12:18:06 -0400



Snake Spring Township MA WWTP PA0084077 Modeling Point #2 May 2024

[+ Collapse All](#)

#### Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	9.75	percent
DRNAREA	Area that drains to a point on a stream	367	square miles
PRECIP	Mean Annual Precipitation	38	inches
ROCKDEP	Depth to rock	4	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.37	miles per square mile

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	367	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	38	inches	35	50.4
STRDEN	Stream Density	2.37	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4	feet	3.32	5.65
CARBON	Percent Carbonate	9.75	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	28.7	ft <sup>3</sup> /s	38	38
30 Day 2 Year Low Flow	39	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	13.9	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	19.4	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	30.1	ft <sup>3</sup> /s	36	36

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

# Attachment B

## WQM 7.0 Modeling Output Values Toxics Management Spreadsheet Output Values

### WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
11D	13349	RAYSTOWN BRANCH JUNIATA RIVER					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
88.600	Sanke Spring	PA0084077	0.190	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			5

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
11D	13349	RAYSTOWN BRANCH JUNIATA RIVER

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
88.600	Sanke Spring	3.06	50	3.06	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
88.600	Sanke Spring	.64	25	.64	25	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
88.60	Sanke Spring	25	25	25	25	5	5	0	0

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
11D	13349	RAYSTOWN BRANCH JUNIATA RIV	88.600	312.00	366.00	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.089	0.00	0.00	0.000	0.000	0.0	0.00	0.00	23.30	8.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Snake Spring	PA0084077	0.1900	0.1900	0.1900	0.000	25.00	7.28

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
11D	13349	RAYSTOWN BRANCH JUNIATA RIV	<b>86.680</b>	309.00	367.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
<b>Q7-10</b>	0.089	0.00	0.00	0.000	0.000	0.0	0.00	0.00	23.30	8.00	0.00	0.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
11D	13349	RAYSTOWN BRANCH JUNIATA RIVER		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
88.600	0.190	23.315	7.984	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
102.267	1.002	102.108	0.320	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.21	0.115	0.22	0.903	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.214	0.478	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.366	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.037	2.20	0.22	7.76
	0.073	2.18	0.21	7.76
	0.110	2.17	0.20	7.76
	0.147	2.16	0.20	7.76
	0.183	2.15	0.19	7.76
	0.220	2.14	0.18	7.76
	0.257	2.13	0.18	7.76
	0.293	2.12	0.17	7.76
	0.330	2.11	0.17	7.76
	0.366	2.10	0.16	7.76

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
11D		13349		RAYSTOWN BRANCH JUNIATA RIVER								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
88.600	32.50	0.00	32.50	.2939	0.00030	1.002	102.27	102.11	0.32	0.366	23.32	7.98
<b>Q1-10 Flow</b>												
88.600	31.20	0.00	31.20	.2939	0.00030	NA	NA	NA	0.31	0.375	23.32	7.98
<b>Q30-10 Flow</b>												
88.600	37.38	0.00	37.38	.2939	0.00030	NA	NA	NA	0.35	0.339	23.31	7.99

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.96	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.15	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

# Attachment C

## TRC Evaluation

Snake Spring Township WWTP  
PA0084077

May 2024

1A	B	C	D	E	F	G
2	<b>TRC EVALUATION</b>					
3	Input appropriate values in B4:B8 and E4:E7					
4	32.485	= Q stream (cfs)		0.5	= CV Daily	
5	0.19	= Q discharge (MGD)		0.5	= CV Hourly	
6	30	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)		0	= Decay Coefficient (K)	
10	Source	Reference	AFC Calculations		Reference	CFC Calculations
11	TRC	1.3.2.III	WLA_afc = 35.275		1.3.2.III	WLA_cfc = 34.383
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
13	PENTOXSD TRG	5.1b	LTA_afc = 13.144		5.1d	LTA_cfc = 19.988
14						
15	Source	Effluent Limit Calculations				
16	PENTOXSD TRG	5.1f	AML_MULT = 1.231			
17	PENTOXSD TRG	5.1g	AVG_MON_LIMIT (mg/l) = 0.500		BAT/BPJ	
18			INST_MAX_LIMIT (mg/l) = 1.635			
	WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot 0.019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
	LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
	LTA_afc	wla_afc * LTAMULT_afc				
	WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot 0.011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
	LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$				
	LTA_cfc	wla_cfc * LTAMULT_cfc				
	AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$				
	AVG_MON_LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
	INST_MAX_LIMIT	1.5 * (av_mon_limit / AML_MULT) / LTAMULT_afc				

# Attachment D

## Commercial/Industrial Users

## Snake Spring Township Municipal Authority

### Non-Residential Metered Customer List & Wastewater Flow

<u>CUSTOMER NAME</u>	<u>USE</u>	<u>EDU</u>	<u>AVERAGE WASTEWATER FLOW (MGD)</u>
1. Zimmerman, Steve (Country Furniture)	Retail Sales	1	0.000150
2. Quick & Easy Auto	Car Wash	2.26	0.000339
3. Home Nursing Agency	Nursing Services	1	0.000150
4. Wilt, Dr. Brandon	Doctor	1	0.000150
5. AutoZone Store	Retail Services	1	0.000150
6. Bedford Inc.	Eye Doctor	1	0.000150
7. Bedford Plaza	Comm. Spaces/Retail Sales	3.56	0.000534
8. Center for Community	Non-Profit	1	0.000150
9. Pennwood Bible	Religious	2	0.000300
10. Bollman Charter	Charter Bus Service	3.5	0.000525
11. Yanoshak, Stephen	Doctor	4	0.000600
12. Professional Buildings, LLC	Comm. Spaces/Medical Offices	1	0.000150
13. Delaney, Page	Dental services	2	0.000300
14. US Renal Care MS #1	Medical Services	1	0.000150
15. Spring Communication	Cell Services - AT&T	1	0.000150
16. Snake Spring Valley Christian Academy	Institutional	1	0.000150
17. Everett Cash Mutual	Financial Institution	1	0.000150
18. Super C Group	Hair Salon	4.5	0.000675
19. Countryside Garden	Retail Sales/Nursery	1	0.000150
20. McDonald's - Bedford	Restaurant	4.28	0.000642
21. Delaney Building	Dental Services	6	0.000900
22. Dragon Chinese Restaurant	Restaurant	2	0.000300
23. Erlichman, Dr Katherin	Ophthalmologist	1	0.000150
24. Checkered Flag Fast/Jiffy Lube	Retail Sales & Service	1	0.000150
25. Commonwealth Code Inspection Services	Inspection Services	1	0.000150
26. Mile Level Physical	Medical Services	3	0.000450
27. Mile Level Market	Retail Sales	2	0.000300
28. Christian & Miss. Alliance Church	Religious	1	0.000150
29. Everett Cash Mutual	Financial Institution	2	0.000300
30. Central PA Cardiology	Doctor	1	0.000150
31. O'Reilly Automotive	Retail Services	2	0.000300
32. PennKnoll Village	Nursing Home	33.66	0.005049
33. Eich Group - Scalla's Garage	Retail Sales & Service	1	0.000150
34. Gentry, Mike	Medical Services	1	0.000150
35. ProCare Fitness	Fitness	1	0.000150
36. Heavy Duty Tire	Retail Sales & Service	1	0.000150
37. R & R Optical	Wise Eyes/Doctor	1	0.000150
38. SAC, Inc	Convenience Store	3.24	0.000486
39. Altoona First Savings Bank	Financial Institution	1	0.000150

40. Sheetz, Inc #28	Convenience Store	6.82	0.001023
41. Eich Group - Sherwin Williams	Retail Sales	1	0.000150
42. Advanced Auto	Retail Sales	1	0.000150
43. Dollar Tree Stores	Retail Sales	1	0.000150
44. Bedford Co. Technical	Institutional	4.89	0.000734
45. Tractor Supply #746	Retail Sales	1	0.000150
46. ACRP	Child Welfare	4	0.000600
47. UPMC Health-Medical Art's Building	Doctor	4	0.000600
48. Pennwood Family Medicine	Medical Services	1	0.000150
49. UPMC Health System-Doctor Baer	Physician	5	0.000750
50. Bedford Orthopedics-Dr. Glah's	Medical Services	1	0.000150
51. Bedford OBGYN-Royston's Old House	Medical Services	1	0.000150
52. UPMC Health System	Hospital	71.52	0.010728
53. Vreeland, Dr. Darryl	Phsician	1	0.000150
54. Wal-Mart Stores, Inc.	Department Store	12.87	0.001931
55. Lashley's Garage, LLC.	Auto Repair	1	0.000150
56. Warner, Dr. Darryl	Chiropractor/Sports Medicine	1	0.000150
57. Weis Markets #140	Grocery Store	6.28	0.000942
58. Sabo, Randy R. Chimney Doctor	General Contractor	1	0.000150
59. Imler Plaza/Fred Imler	Retail Sales	2	0.000300
60. Heritage Square Rt. 30	Commercial Rental Spaces	6	0.000900
61. Five Star Power Sports	Retail Sales & Service	2	0.000300
62. Homewood Retirement-Spring House Estates	Retirement Community	64.44	0.009666
63. Mile Level Pizza	Take Out Restaurant	1	0.000150
64. 7th Day Adventist	Religious	1	0.000150
65. Amerigas	Office Only	1	0.000150
66. ABC Phones of North	Retail Sales & Service	2	0.000300
67. Pro Happy Nails	Retail Sales & Service	1	0.000150
68. Snake Spring Twp Recreational Park	Recreation	1	0.000150
69. Community Life	Adult Daycare	4	0.000600
70. First Peoples Federal	Financial Institution	1	0.000150
71. Construction Supply	Retail Sales	1	0.000150
72. UGI - 733100 MS#1	Office/Garage	1	0.000150
73. Eich Group-Olde Towne Plaza	Commercial Rental Spaces	7	0.001050
74. Eich Group-Lincoln I Plaza	Commercial Rental Spaces	9	0.001350
75. Eich Group-Lincoln II Plaza	Commercial Rental Spaces	5.6	0.000840
76. Eich Group-Sears Building	Future Distillery Bottling	1	0.000150
77. Bedford Valley Petroleum	Office Only	1	0.000150
78. Durga Bedford Inc.	Retail Sales and Service	1	0.000150
79. EMS Diagnostics	Medical Services	2	0.000300
80. Deja Brew - Imler's	Coffee Shop	1	0.000150
81. Bedford, The County	Currently Empty	2	0.000300