

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0084565  
 APS ID 829648  
 Authorization ID 1463705

**Applicant and Facility Information**

Applicant Name	<u>The York Water Co.</u>	Facility Name	<u>East Prospect STP</u>
Applicant Address	<u>130 E Market Street</u> <u>York, PA 17401-1219</u>	Facility Address	<u>5230 E Prospect Road</u> <u>York, PA 17406</u>
Applicant Contact	<u>Matthew Scarpato</u>	Facility Contact	<u>Vaughn Wenger</u>
Applicant Phone	<u>(717) 718-2977</u>	Facility Phone	<u>(717) 845-3601</u>
Client ID	<u>69800</u>	Site ID	<u>271342</u>
Ch 94 Load Status	<u>Existing Organic Overload</u>	Municipality	<u>Lower Windsor Township</u>
Connection Status	<u>No Limitations</u>	County	<u>York</u>
Date Application Received	<u>December 3, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 6, 2023</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of existing NPDES Permit</u>		

**Summary of Review**

The York Water Company (YWC) has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit for the East Prospect STP. The permit was last reissued to YWC on May 30, 2019. The permit expired on May 31, 2024 but the terms and conditions of the permit have been administratively extended since that time.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted, and a notice of the draft permit be published in the *Pennsylvania Bulletin* for public comments for 30 days. A file review of documents associated with the discharge or permittee may be available at the PA DEP southcentral regional office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file reviews, contact the SCRO file review coordinator at 717.705.4700.

Sludge use and disposal description and location(s): Hauled offsite by Smith's Sanitary Septic Service

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
x		<i>Aaron Baar</i> Aaron Baar / Project Manager	September 13, 2024
x		<i>Maria D. Bebenek</i> for Daniel W. Martin, P.E. / Environmental Engineer Manager	September 17, 2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.0875
Latitude	39° 57' 51.89"	Longitude	-76° 31' 49.86"
Quad Name		Quad Code	
Wastewater Description: Sewage Effluent			
Receiving Waters	Cabin Creek (WWF)	Stream Code	07848
NHD Com ID	57467421	RMI	4.64
Drainage Area	11.7 sq. miles	Yield (cfs/mi <sup>2</sup> )	0.2197
Q <sub>7-10</sub> Flow (cfs)	2.57	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	336.23	Slope (ft/ft)	
Watershed No.	7-1	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	See Below		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	The York Water Company		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI	22.84	Distance from Outfall (mi)	6.02

**Drainage Area**

The discharge is to Cabin Creek at RMI 4.64. A drainage area upstream of the discharge is determined to be 11.7 sq.mi. according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

**Stream Flow**

According to StreamStats, the watershed has a Q<sub>7-10</sub> of 2.57 cfs. This information was used to obtain a LFY, a chronic 30-day (Q<sub>30-10</sub>) and acute (Q<sub>1-10</sub>) exposure stream flows for the discharge point as follows (Guidance No. 391-2000-023).

$$\begin{aligned}
 Q_{7-10} &= 2.57 \text{ cfs} \\
 Q_{30-10} &= 1.36 * 2.57 \text{ cfs} = 3.49 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 0.157 \text{ cfs} = 1.64 \text{ cfs} \\
 LFY &= 0.157 \text{ cfs}/4.4 \text{ mi}^2 = 0.2197 \text{ cfs/mi}^2
 \end{aligned}$$

**Cabin Creek**

25 Pa Code §93.9 classifies the receiving water, Cabin Creek, with a WWF Existing Use designation. Effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. The discharge is in a stream segment listed as not attaining use; the cause of the impairments have been identified as habitat alterations, agriculture and siltation (see *Local Watershed TMDL* below).

**Local Watershed Total Maximum Daily Loads (TMDLs)**

According to PA's 2024 integrated water quality monitoring and assessment report, Cabin Creek in the vicinity of the proposed point of discharge is impaired for aquatic life due to habitat alterations and siltation from habitat modifications other than hydromodification and siltation from agriculture. One impairment is listed as Category 4c in the 2024 integrated report, indicating that Cabin Creek is impaired for one or more uses not needing a TMDL because the impairment is not caused by a pollutant. However, two impairments are listed as Category 5 in the 2024 integrated

report, indicating that the water is impaired for one or more uses by a pollutant that requires the development of a TMDL. No TMDL has been developed for Cabin Creek to date, so no local watershed TMDL has been taken into consideration during this review.

**Public Water Supply Intake**

The nearest downstream public water supply intake is the York Water Company intake located on the Susquehanna River approximately 6 miles from the discharge. Considering the distance and nature, the discharge is not expected to significantly affect the water supply.

**Class A Wild Trout Streams**

The receiving stream is not a Class A Wild Trout stream; therefore, no Class A Wild Trout Fishery is impacted by this discharge.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> East Prospect STP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
6706411 A-4	June 16, 2024			
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	UV Disinfection	0.175
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.210	511	Existing Organic Overload		

The York Water Company owns and operates the East Prospect sanitary wastewater treatment facility located in Lower Windsor Township, York County. The facility serves portions of Lower Windsor Township and East Prospect Borough, all wastes are residential in nature, and all sewer systems are 100% separated. The annual average design flow is 0.175 MGD and the hydraulic design capacity is 0.210 MGD. This facility consists of a Flow Equalization tanks (x11), anoxic tank (x1, 2 trains), extended aeration (x1, 2 trains), secondary clarification (x1, 2 trains), UV disinfection, re-aeration, and solids handling. Solids are treated in aerobic digesters; solids are hauled offsite for disposal. Soda Ash is used to maintain alkalinity, PACL 2040 is used as a coagulant.

Changes Since Last Permit Issuance: The facility was upgraded to accommodate an annual average flow of 0.175 mgd and a max month flow of 0.210 mgd. A WQM amendment was issued on June 16, 2020 for changes to a previously approved WQM permit amendment for the upgrade of the facility. The approved changes in the 2020 WQM amendment were as follows:

1. Modifying the approved design such that new sludge holding tanks will be constructed in lieu of modifying existing structures for the same purpose. The effective sludge holding volume (70,700 gallons) is unchanged from the original design.
2. The addition of a soda ash feed system (with related appurtenances) for alkalinity supplementation is proposed.
3. The replacement of the existing UV disinfection system is proposed instead of modifying the existing system.. The proposed system is a Trojan 3200K-PTP rated for at least 0.175 mgd of flow.
4. The aeration system will be modified such that separate air lines will be extended to each aeration train in lieu of manifolding the supply lines together.
5. A post-disinfection re-aeration basin downstream of the UV disinfection units is proposed to meet the facility's DO limits.

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	DMR results for the past year are presented below.
<b>Summary of Inspections:</b>	Since the last renewal of the facility's NPDES permit, the following inspections have been logged:  May 6, 2020: An administrative inspection was conducted by phone by Austen Randecker. No violations were noted.  June 3, 2021: A CEI was conducted by Erick Ammon. No violations or recommendations were noted.

Other Comments: As of September 13, 2024, there are no open violations associated with this facility or permittee.

**Existing Effluent Limitations and Monitoring Requirements**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
CBOD5	36.0	58.0	XXX	25.0	40.0	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	43.0	65.0	XXX	30.0	45.0	60	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
UV Intensity (mW/cm <sup>2</sup> )	XXX	XXX	XXX	Report	XXX	Report	Continuous	Recorded
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Nitrate-Nitrite (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Total Nitrogen (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Ammonia May 1 - Oct 31	12.4	XXX	XXX	8.5	XXX	17	2/week	24-Hr Composite
Ammonia (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
TKN	XXX	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
TKN (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Phosphorus (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location: Outfall 001

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Total Nitrogen (lbs)	XXX	5859 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Ammonia (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus (lbs)	XXX	974 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation

Compliance Sampling Location: Outfall 001

Compliance History

DMR Data for Outfall 001 (from August 1, 2023 to July 31, 2024)

Parameter	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23
Flow (MGD) Average Monthly	0.061	0.060	0.064	0.060	0.057	0.056	0.061	0.058	0.051	0.052	0.056	0.055
Flow (MGD) Daily Maximum	0.076	0.069	0.079	0.076	0.071	0.071	0.076	0.083	0.059	0.059	0.072	0.072
pH (S.U.) Instantaneous Minimum	6.53	6.6	6.53	6.6	6.39	6.86	6.26	6.22	6.62	6.38	6.72	6.6
pH (S.U.) Instantaneous Maximum	7.31	7.28	7.32	7.53	7.44	7.68	7.69	7.69	7.8	7.53	7.51	8.04
DO (mg/L) Instantaneous Minimum	6.77	7.66	6.82	7.61	8.14	8.57	7.39	8.35	7.32	6.55	6.33	6.32
CBOD5 (lbs/day) Average Monthly	< 1.7	< 1.8	< 1.4	< 1.3	1.9	< 1.3	2.1	< 1.8	< 1.3	1.7	< 1.0	< 1.0
CBOD5 (lbs/day) Weekly Average	2.5	2.9	2.1	< 1.5	2.2	1.9	2.9	< 3.3	1.8	2.3	< 1.0	< 1.0
CBOD5 (mg/L) Average Monthly	< 3.2	< 3.6	< 2.6	< 2.6	4.2	< 2.9	4.2	< 3.9	< 3.2	4.0	< 2.0	< 2.0
CBOD5 (mg/L) Weekly Average	4.7	5.7	3.3	2.8	4.8	4.3	4.8	6.4	4.3	5.3	2.0	< 2.0
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	262	210	178	194	162	140	168	167	172	165	130	157
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	340	320	300	257	192	168	263	184	184	212	148	175
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	506	418	330	401	354	314	338	365	429	399	292	358
TSS (lbs/day) Average Monthly	2.2	3.8	1.7	2.9	1.9	2.1	3.5	3.2	2.3	3.1	3.0	1.0
TSS (lbs/day) Raw Sewage Influent   Average Monthly	271	154	134	157	144	121	119	156	160	175	134	167

**NPDES Permit Fact Sheet  
East Prospect STP**

**NPDES Permit No. PA0084565**

TSS (lbs/day) Raw Sewage Influent   Daily Maximum	399	209	263	235	176	173	210	168	221	239	184	205
TSS (lbs/day) Weekly Average	3.5	6.0	3.4	5.1	2.8	4.1	6.1	4.4	2.9	4.4	5.0	2.0
TSS (mg/L) Average Monthly	4.4	7.5	3.2	6.0	4.3	4.8	7.2	7.0	5.6	7.5	7.0	3.0
TSS (mg/L) Raw Sewage Influent   Average Monthly	520	305	246	332	315	273	235	340	397	426	301	379
TSS (mg/L) Weekly Average	7.0	12.0	7.0	11.0	6.0	9.0	13.0	9.0	7.0	10.0	11.0	5.0
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 2.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	5	< 1	< 1	1	1	2	< 1	4	3	7	1	10.0
UV Intensity (mW/cm <sup>2</sup> ) Average Monthly	10.3	8.4	9.5	8.2	7.3	7.0	7.1	8.3	8.9	10.1	12.4	12.7
UV Intensity (mW/cm <sup>2</sup> ) Instantaneous Maximum	13.6	12.8	14	11.4	8.9	9.9	10.4	12.3	14	14	13.2	14.0
Nitrate-Nitrite (mg/L) Average Monthly	13.7	21.1	17.9	15.8	15.4	15.3	19.4	21.8	23.3	19.9	14.8	< 14.5
Nitrate-Nitrite (lbs) Total Monthly	225	334	317	274	237	221	316	343	300	9.1	215	< 212
Total Nitrogen (mg/L) Average Monthly	< 14.5	< 21.8	< 18.5	< 16.6	< 16.3	< 15.8	< 21.1	< 22.8	< 23.8	< 20.4	< 15.3	< 15.29
Total Nitrogen (lbs) Total Monthly	< 238	< 346	< 327	< 288	252	< 229	< 341	< 362	< 279	< 290	< 222	< 224
Total Nitrogen (lbs) Total Annual											2966	
Ammonia (lbs/day) Average Monthly	< 0.05	< 0.306	< 0.06	< 0.06	< 0.12	< 0.06	< 0.50	< 0.06	< 0.05	< 0.05	< 0.05	< 0.05
Ammonia (mg/L) Average Monthly	< 0.1	< 0.1	< 0.1	< 0.1	< 0.2	< 0.1	< 1.0	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
Ammonia (lbs) Total Monthly	< 1.6	< 1.7	< 1.8	< 1.7	< 3.7	< 1.7	< 15.5	< 1.7	< 1.6	< 1.4	< 1.5	< 1.5
Ammonia (lbs) Total Annual											38	
TKN (mg/L) Average Monthly	< 0.8	< 0.7	< 0.6	< 0.8	< 1.0	< 0.5	< 1.7	< 1.0	< 0.5	< 0.5	< 0.5	< 0.83

**NPDES Permit Fact Sheet  
East Prospect STP**

**NPDES Permit No. PA0084565**

TKN (lbs) Total Monthly	< 13	< 12	< 10	< 14	< 14	< 8	< 26	< 20	< 7	< 7	< 7	< 12.0
Total Phosphorus (lbs/day) Average Monthly	0.4	0.4	0.3	0.2	0.2	0.2	0.3	0.3	0.2	0.3	0.3	0.2
Total Phosphorus (mg/L) Average Monthly	0.73	0.77	0.50	0.32	0.37	0.35	0.49	0.50	0.47	0.62	0.59	0.52
Total Phosphorus (lbs) Total Monthly	12	12	9	6	6	5	8	9	6	8	9.0	8.0
Total Phosphorus (lbs) Total Annual											91	

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>.0875</u>
<b>Latitude</b> <u>39° 57' 53.81"</u>	<b>Longitude</b> <u>-76° 31' 51.17"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: These standards apply, subject to water quality analysis and BPJ where applicable.

**Water Quality-Based Limitations**

*CBOD<sub>5</sub>, NH<sub>3</sub>-N and Dissolved Oxygen (DO)*

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD<sub>5</sub>, NH<sub>3</sub>-N and DO. DEP's guidance no. 391-2000-007 provides the technical methods contained in WQM 7.0 for conducting wasteload allocation and for determining recommended NPDES effluent limits for point source discharges. The model was utilized, and the model output indicated that existing TBEL for CBOD<sub>5</sub> is still protective of water quality and the existing QBELs for NH<sub>3</sub>-N could be higher given current flow conditions in the receiving water, but due to anti-backsliding provisions the existing limits will be left intact.

The model also indicates that the existing DO limit of 5.0 mg/L is still protective of water quality.

**Toxics**

DEP's NPDES permit application for minor sewages requires sampling for Total Copper, Total Lead, and Total Zinc when commercial and industrial operations are in the service area. Sample data for these three parameters was submitted by the permittee and analyzed utilizing the department's Toxic Management Spreadsheet (v. 1.3); no limits or reporting requirements are recommended at this time.

**Best Professional Judgment (BPJ) Limitations**

*Total Phosphorus & Total Nitrogen*

DEP's SOP no. BPNPSM-PMT-033 (Establishing Effluent Limitations for Individual Sewage Permits) recommends monitoring requirements for Total Phosphorus and Total Nitrogen for all sewage facilities. Therefore, a routine monitoring for TKN, Nitrate-Nitrite, and TN are recommended to be continued in this permit. Sampling frequency for TKN, Nitrate-Nitrite, TN, and TP are currently required 1/week.

*UV Disinfection*

SOP No. BPNPSM-PMT- 033 requires monitoring of UV transmittance (%), UV dosage ( $\mu\text{W}/\text{cm}^2$  or  $\text{mj}/\text{cm}^2$ ), or UV intensity ( $\mu\text{W}/\text{cm}^2$  or  $\text{mj}/\text{cm}^2$ ) at the same monitoring frequency that would be used for TRC. The existing monitoring and reporting requirement for UV intensity ( $\text{mW}/\text{cm}^2$ ) from the last renewal will continue. Minor changes were made to the reporting requirements to clarify what is to be reported by the permittee – measurement frequency was update from “continuous” to “1/day” and the requirement to report the instantaneous maximum was changed to reporting of daily minimum to better track when UV disinfection might be impaired.

**Additional Considerations**

*Flow Monitoring*

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

*E. Coli Monitoring*

In conformity with the Department’s *Establishing Effluent Limitations for Individual Sewage Permits* (SOP No. BCW-PMT-033) and as authorized by § 92a.61 of the PA Code, annual E. Coli monitoring has been proposed in this permit. The collection method will be via grab sample.

*Chesapeake Bay TMDL*

The Department formulated a strategy in April 2007, to comply with the EPA’s and Chesapeake Bay Foundation’s requirements to reduce point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP) to the Bay. In the Strategy, sewage dischargers have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers received annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. Phase 4 (0.2 -0.4mgd) and Phase 5 (below 0.2mgd) facilities were required to monitor and report TN and TP during permit renewal at a monitoring frequency following Table 6-3 of DEP’s Technical Guidance for Development and Specification of effluent Limitations (No. 362-0400-001).

EPA published the Chesapeake Bay Total Maximum Daily Load (TMDL) in December of 2010. Despite extensive restoration efforts during the past 25 years, the TMDL was prompted by insufficient progress and continued poor water quality in the Chesapeake Bay and its tidal tributaries.

In order to address the TMDL, Pennsylvania developed, in addition to the Bay Strategy, a Chesapeake Watershed Implementation Plan (WIP) Phase 1 in January 2011, Phase 2 in March 2012 and Phase 3 in December 2019. In accordance with the Phase 3 WIP, re-issuing permits for significant dischargers follow the same phased approach formulated in the original Bay strategy, whilst Phase 4 and Phase 5 will be required to monitor and report TN and TP during permit renewal.

The Phase 3 WIP categorizes this facility as a phase 4 non-significant sewage facility that has a design flow less than 0.4 MGD but greater than or equal to 0.2 MGD. Phase 4 renewed or amended permits that include an increase in design flow will contain Cap Loads based on the lesser of a) existing TN and TP concentrations at current design average annual flow or b) 7,306 lbs/yr TN and 974 lbs/yr TP. Cap loads calculated during the last permit cycle for the upgraded facility will be continued in this permit – 5859 pounds of TN/year and 974 Lbs TP/year.

The WIP recommends monitoring and reporting for Total Nitrogen and Total Phosphorus throughout the permit term at a frequency no less than annual. Ammonia and TP are currently required to be evaluated 2/week. In Conformity with DEP Guidance Document 362-0400-001, the testing frequency of Ammonia and TP are proposed to be reduced to 1/week in this renewal.

*Monitoring Frequency and Sample Type*

Unless discussed otherwise above, the permit’s monitoring frequency and sample type for all parameters will remain unchanged from the last permit renewal.

*Antidegradation Requirements*

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

*Anti-backsliding Requirement*

All effluent limits proposed in this fact sheet are as stringent as effluent limits specified in the existing permit renewal. This approach is in accordance with 40 CFR §122.44(l)(1).

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Daily Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
CBOD5	36.0	28.0	XXX	25.0	40.0	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite
TSS	43.0	65.0	XXX	30.0	45.0	60	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Intensity (mW/cm <sup>2</sup> )	XXX	XXX	Report	Report	XXX	XXX	1/day	Recorded
Nitrate-Nitrite	XXX	XXX	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite
Nitrate-Nitrite (lbs)	Report	XXX	XXX	XXX	XXX	XXX	1/month	Calculation

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date )

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Daily Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/week	Calculation
Total Nitrogen (lbs)	Report	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Ammonia Nov 1 - Apr 30	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite
Ammonia May 1 - Oct 31	12.4	Report Daily Max	XXX	8.5	Report Daily Max	17	1/week	24-Hr Composite
Ammonia (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
TKN	XXX	XXX	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite
TKN (lbs)	Report	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	XXX	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite
Total Phosphorus (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location: Outfall 001

**Proposed Effluent Limitations and Monitoring Requirements**


The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Total Nitrogen (lbs)	XXX	5859 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Ammonia (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus (lbs)	XXX	974 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation


Compliance Sampling Location: Outfall 001

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]



## StreamStats Report

Region ID: PA  
 Workspace ID: PA20240913112906898000  
 Clicked Point (Latitude, Longitude): 39.96439, -76.53053  
 Time: 2024-09-13 07:29:29 -0400



Collapse All

### > Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	6.5985	degrees
DRNAREA	Area that drains to a point on a stream	11.7	square miles
ROCKDEP	Depth to rock	5	feet
URBAN	Percentage of basin with urban development	1.2267	percent

### > Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	11.7	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	6.5985	degrees	1.7	6.4

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
ROCKDEP	Depth to Rock	5	feet	4.13	5.21
URBAN	Percent Urban	1.2267	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	4.61	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	5.34	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	2.57	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	3.03	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	3.81	ft <sup>3</sup> /s

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.


Application Version: 4.23.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

## StreamStats Report

Region ID: PA  
 Workspace ID: PA20240913114359288000  
 Clicked Point (Latitude, Longitude): 39.96166, -76.52445  
 Time: 2024-09-13 07:44:24 -0400



Collapse All

### Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	6.5563	degrees
DRNAREA	Area that drains to a point on a stream	12.2	square miles
ROCKDEP	Depth to rock	5	feet
URBAN	Percentage of basin with urban development	1.5559	percent

### Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	12.2	square miles	4.78	1150

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
BSLOPD	Mean Basin Slope degrees	6.5563	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5	feet	4.13	5.21
URBAN	Percent Urban	1.5559	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	4.8	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	5.57	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	2.68	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	3.16	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	3.98	ft <sup>3</sup> /s

*Low-Flow Statistics Citations*

**Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.23.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
071		7848		CABIN CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
4.640	East Prospect	PA0084565	0.175	CBOD5	25		
				NH3-N	19.02	38.04	
				Dissolved Oxygen			5

**WQM 7.0 Wasteload Allocations**

**SWP Basin**      **Stream Code**                      **Stream Name**  
071                      7848                                      CABIN CREEK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
4.640	East Prospect	11.07	50	11.07	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
4.640	East Prospect	1.37	19.02	1.37	19.02	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
4.64	East Prospect	25	25	19.02	19.02	5	5	0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
07I	7848	CABIN CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
4.640	0.175	25.000	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
21.608	0.595	36.344	0.221	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
4.19	0.807	1.81	1.029	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.934	12.965	Tsivoglou	6	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.130	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.013	4.14	1.79	7.54
	0.026	4.08	1.76	7.54
	0.039	4.03	1.74	7.54
	0.052	3.98	1.72	7.54
	0.065	3.92	1.70	7.54
	0.078	3.87	1.67	7.52
	0.091	3.82	1.65	7.49
	0.104	3.77	1.63	7.46
	0.117	3.72	1.61	7.45
	0.130	3.67	1.59	7.43

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
071		7848				CABIN CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
4.640	2.57	0.00	2.57	.2707	0.00548	.595	21.61	36.34	0.22	0.130	25.00	7.00
<b>Q1-10 Flow</b>												
4.640	1.64	0.00	1.64	.2707	0.00548	NA	NA	NA	0.18	0.162	25.00	7.00
<b>Q30-10 Flow</b>												
4.640	3.50	0.00	3.50	.2707	0.00548	NA	NA	NA	0.26	0.111	25.00	7.00

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07I	7848	CABIN CREEK	<b>4.640</b>	336.23	11.70	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
<b>Q7-10</b>	0.100	0.00	2.57	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
East Prospect	PA0084565	0.1750	0.1750	0.1750	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07I	7848	CABIN CREEK	<b>4.170</b>	322.63	12.20	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
<b>Q7-10</b>	0.100	0.00	2.68	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70



## Discharge Information

Instructions Discharge Stream

Facility: York Water - East Prospect STP NPDES Permit No.: PA0084565 Outfall No.: 001

Evaluation Type: Custom / Additives Wastewater Description: Treated Sewage

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>h</sub>
0.175	100	7						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Total Copper	mg/L	< 0.005									
Total Lead	mg/L	< 0.001									
Total Zinc	mg/L	0.04									



## Stream / Surface Water Information

York Water - East Prospect STP, NPDES Permit No. PA0084565, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: **Cabin Creek** No. Reaches to Model: **1**

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	007848	4.64	336.23	11.7			Yes
End of Reach 1	007848	4.17	322.63	12.2			Yes

**Q<sub>7-10</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	4.64	0.1	2.57									100	7		
End of Reach 1	4.17	0.1	2.68												

**Q<sub>h</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	4.64														
End of Reach 1	4.17														



York Water - East Prospect STP, NPDES Permit No. PA0084565, Outfall 001

Model Results

All
  Inputs
  Results
  Limits

Hydrodynamics

Wasteload Allocations

**AFC** CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0	0	0	13.439	14.0	145	Chem Translator of 0.96 applied
Total Lead	0	0	0	0	64.581	81.6	846	Chem Translator of 0.791 applied
Total Zinc	0	0	0	0	117.180	120	1,241	Chem Translator of 0.978 applied

**CFC** CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0	0	0	8.956	9.33	97.9	Chem Translator of 0.96 applied
Total Lead	0	0	0	0	2.517	3.18	33.4	Chem Translator of 0.791 applied
Total Zinc	0	0	0	0	118.139	120	1,257	Chem Translator of 0.986 applied

**THH** CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0	0	0	N/A	N/A	N/A	
Total Lead	0	0	0	0	N/A	N/A	N/A	
Total Zinc	0	0	0	0	N/A	N/A	N/A	

**CRL** CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0	0	0	N/A	N/A	N/A	

