

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0088307  
 APS ID 310833  
 Authorization ID 1512998

**Applicant and Facility Information**

Applicant Name	<u>Snyders LLP</u>	Facility Name	<u>Eagles Crossing Golf Course</u>
Applicant Address	<u>501 Conodoguinet Avenue</u> <u>Carlisle, PA 17015-8972</u>	Facility Address	<u>501 Conodoguinet Avenue</u> <u>Carlisle, PA 17015-8972</u>
Applicant Contact	<u>Shawn Snyder</u>	Facility Contact	<u>Shawn Snyder</u>
Applicant Phone	<u>(717) 960-0500</u>	Facility Phone	<u>(717) 960-0500</u>
Client ID	<u>139909</u>	Site ID	<u>495028</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>North Middleton Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Cumberland</u>
Date Application Received	<u>January 17, 2025</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>January 29, 2025</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES Permit Renewal.</u>		

**Summary of Review**

Snyders LLP has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on August 4, 2020 and became effective on September 1, 2020. The permit expired on August 31, 2025 but the terms and conditions of the permit has been extended since that time.

Based on the review, it is recommended that the permit be drafted.

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Jinsu Kim</i> Jinsu Kim / Environmental Engineering Specialist	October 9, 2025
x		<i>Maria D. Bebenek</i> for Daniel W. Martin, P.E. / Environmental Engineer Manager	October 20, 2025

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0035</u>
Latitude	<u>40° 12' 55"</u>	Longitude	<u>-77° 14' 24"</u>
Quad Name	<u>Carlisle</u>	Quad Code	<u>1728</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Conodoguinet Creek (WWF)</u>	Stream Code	<u>10194</u>
NHD Com ID	<u>56406665</u>	RMI	<u>41.3</u>
Drainage Area	<u>368 sq.mi.</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.1244</u>
Q <sub>7-10</sub> Flow (cfs)	<u>45.8</u>	Q <sub>7-10</sub> Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u>419</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>7-B</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>None</u>	Existing Use Qualifier	<u>None</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Organic Enrichment/Low D.O.</u>		
Source(s) of Impairment	<u>Unknown</u>		
TMDL Status	<u>N/A</u>	Name	<u>N/A</u>
Nearest Downstream Public Water Supply Intake	<u>Carlisle Water Treatment Plant</u>		
PWS Waters	<u>Conodoguinet Creek</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u>37.03</u>	Distance from Outfall (mi)	<u>4.27</u>

**Drainage Area**

The discharge is to Conodoguinet Creek at RM 41.3. A drainage area upstream of the discharge is estimated to be 368 sq.mi. using USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

**Streamflow**

USGS Stream Stats produced a Q7-10 of 45.8 cfs at the point of discharge.

**Conodoguinet Creek**

Under 25 Pa Code §93.9o, Conodoguinet Creek from PA 997 at Roxbury to Mouth is designated as warm water fishes and supports migratory fishes. Conodoguinet Creek is a tributary of Susquehanna River which is also designated as warm water fishes. No special protection water is therefore impacted by this discharge. DEP's latest integrated water quality report prepared in 2024 shows that sections of the Conodoguinet Creek near the discharge location is impaired for organic enrichment and low dissolved oxygen as a result of unknown sources. This impairment was identified as Category 5 by DEP in 2018 which requires the development of a Total Maximum Daily Load (TMDL). The TMDL development date is not yet defined as of the date of this fact sheet.

**Public Water Supply intake**

The fact sheet developed for the last permit renewal indicates that the nearest downstream PWS is Carlisle Borough in North Middleton Township at RMI 37.03 about 4.27 miles downstream of the discharge. Given the distance and nature, the discharge is not expected to significantly impact the water supply.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Eagles Crossing Golf				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
2100401	4/13/2000			
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary With Ammonia Reduction	Extended Aeration	Chlorine With Dechlorination	0.0035
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.0035	7	Not Overloaded	Aerobic Digestion	Combination of methods

The permittee owns and operates an on-site sanitary wastewater treatment plant to serve a golf course. This facility is an extended aeration activated sludge treatment process consisting of a bar screen, EQ tank, aeration tank, clarifier, chlorine contact tank, dechlorination tank and an outfall structure. The facility has both annual average design flow and hydraulic design capacity of 0.0035 MGD. Norweco tablets are used for both chlorination and dechlorination. A sludge holding tank is available for sludge storage prior to hauled off site via a local septic hauler for land application.



(During 10/7/2025 Site Visit)

Compliance History	
<b>Summary of DMRs:</b>	A summary of past 12-month DMR data is presented on the next page.
<b>Summary of Inspections:</b>	03/23/2022: DEP conducted a routine inspection. No significant violation was noted at the time of inspection.
<b>Other Comments:</b>	DEP's database revealed that there is no open violation associated with this facility or permittee.

Effluent Data

DMR Data for Outfall 001 (from August 1, 2024 to July 31, 2025)

Parameter	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24
Flow (MGD) Average Monthly	0.00065 842	0.00088 377	0.00103 418	0.00044 6	0.00016 577	0.00043 09	0.00031 148	0.00030 174	0.00060 203	0.00063 097	0.00041 89	0.00063 5
Flow (MGD) Daily Maximum	0.00228 6	0.00219 3	0.00257 9	0.00116	0.00054 4	0.00080	0.00196 2	0.00061 5	0.00135 4	0.00175 4	0.00076 8	0.00145
pH (S.U.) Instantaneous Minimum	7.0	7.4	7.7	7.9	8.2	8.0	8.0	8.0	7.9	7.8	7.7	7.7
pH (S.U.) Instantaneous Maximum	7.6	7.8	8.2	8.3	8.4	8.3	8.2	8.2	8.2	8.1	7.9	8.0
DO (mg/L) Daily Minimum	7.16	7.37	7.96	8.96	10.51	12.37	14.52	13.67	9.98	9.18	8.67	8.36
TRC (mg/L) Average Monthly	0.16	0.22	0.24	0.19	0.33	0.30	0.18	0.20	0.23	0.22	0.27	0.23
TRC (mg/L) Daily Maximum	0.29	0.43	0.39	0.39	0.45	0.43	0.30	0.30	0.30	0.39	0.39	0.48
CBOD5 (mg/L) Average Monthly	6.8	< 2.85	5.2	6.05	23.5	9.0	6.3	3.55	< 2.4	< 2.75	< 2.4	2.95
TSS (mg/L) Average Monthly	16	14.5	26	12	23.5	24.5	11.5	12.5	10.5	15.5	5.5	9.0
Fecal Coliform (No./100 ml) Geometric Mean	< 5.0	2.449	3.3166	2.236	< 63.02	< 13.93	< 1.0	< 3.162	2.828	< 22.09	< 3.162	< 44.56
Fecal Coliform (No./100 ml) Daily Maximum	25	6	11	5	1986	194	1.0	< 10	4	488	10	1986
Nitrate-Nitrite (lbs/day) Daily Maximum								< 0.01194				
Nitrate-Nitrite (mg/L) Daily Maximum								< 50.4				
Total Nitrogen (lbs/day) Daily Maximum								< 0.1206				
Total Nitrogen (mg/L) Daily Maximum								< 50.9				
Ammonia (mg/L) Average Monthly	< 0.13	< 0.10	< 0.10	< 0.125	49.5	38	< 0.10	< 0.10	< 0.10	< 0.10	< 0.125	< 0.10
TKN (lbs/day) Daily Maximum								< 0.0012				

**NPDES Permit Fact Sheet  
Eagles Crossing Golf Course**

**NPDES Permit No. PA0088307**

TKN (mg/L) Daily Maximum								< 0.5				
Total Phosphorus (lbs/day) Daily Maximum								0.0178				
Total Phosphorus (mg/L) Daily Maximum								7.5				

**Existing Effluent Limits and Monitoring Requirements**

A table below summarizes effluent limits and monitoring requirements specified in the current permit.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	1.6 Daily Max	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
Total Suspended Solids	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	10000 Daily Max	XXX	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	1000 Daily Max	XXX	2/month	Grab
Nitrate-Nitrite as N	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Total Nitrogen	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	Calculation
Ammonia-Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Kjeldahl Nitrogen	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Total Phosphorus	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u> <b>Latitude</b> <u>40° 12' 55.00"</u> <b>Wastewater Description:</b> <u>Sewage Effluent</u>	<b>Design Flow (MGD)</b> <u>.0035</u> <b>Longitude</b> <u>-77° 14' 24.00"</u>
---	--

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD<sub>5</sub>, NH<sub>3</sub>-N and DO. DEP's technical guidance no. 391-2000-007 describes the technical methods contained in the model for conducting wasteload allocation analyses and for determining recommended limits for point source discharges. When the discharge is to a large stream and there has not been any changes to the water quality criteria and discharge, DEP generally reviews the results of previous modeling efforts and uses those results, if appropriate performed, for the upcoming permit renewal. This permitting approach is consistent with DEP's SOP no. BPNPSM-PMT-033. The modeling efforts from the last permit were appropriately performed; therefore, no WQM modeling will be performed for this permit renewal. The results of the prior modeling effort are attached to this fact sheet.

*Total Residual Chlorine (TRC)*

DEP's TRC\_CALC worksheet was used to determine if a WQBEL for TRC is appropriate. The worksheet indicates that the existing average monthly BAT limit of 0.5 mg/L and the instantaneous maximum limit of 1.6 mg/L are still adequate.

*Toxics*

DEP's minor sewage facility permit application does not require sampling of toxic pollutants for facilities less than 0.1 MGD. No toxic pollutants have therefore been taken into consideration as pollutants of concern at this time.

**Best Professional Judgement (BPJ) Effluent Limitations**

*Dissolved Oxygen*

A minimum of 5.0 mg/L for DO is an existing effluent limit and is a current state water quality criterion found in 25 Pa. Code § 93.7(a). This effluent limit will remain unchanged for the upcoming permit renewal to ensure the protection of water quality standards. This approach is also consistent with DEP's SOP no. BPNPSM-PMT-033. This requirement has also been assigned to other facilities throughout the state.

**Additional Considerations**

*Flow Monitoring*

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

*E. Coli Monitoring Requirement*

DEP's SOP no. BPNPSM-PMT-033 recommends annual routine monitoring of E. Coli for all sewage facilities that have design flow less than 0.05 MGD but greater than 0.002 MGD. Annual monitoring requirement for E. Coli will therefore be included in the permit.

*Local Watershed TMDL*

As mentioned before, Conodoguinet Creek near the discharge point is impaired for organic enrichment and low dissolved oxygen as a result of unknown sources. A TMDL has not been developed to address these impairments. DEP believes that the permit requirements proposed in this fact sheet were developed to ensure that the discharge will not contribute to these impairments.

*Chesapeake Bay TMDL & TN/TP SOP Monitoring Requirement*

The discharge is located within the Chesapeake Bay watershed and is considered under the Supplement to Phase III Watershed Implementation Plan (WIP) a Phase 5 facility designed to treat between 0.002 MGD and 0.2 MGD. It is therefore recommended to maintain existing nutrient monitoring requirements with the current monitoring frequency.

*Monitoring Frequency and Sample Type*

Given the compliance history and the effluent volume discharged from this facility (about 1,000 GPD on average; 2,500 GPD on daily max), it is recommended the existing 2/month monitoring requirement for CBOD, TSS, NH<sub>3</sub>-N and fecal coliform be changed to 1/month. This will be reviewed once again during the next permit renewal application review process.

*Class A Wild Trout Fishery*

A Class A Wild Trout Fishery is not impacted by this discharge.

*Anti-Degradation Requirements*

Unless stated otherwise in this fact sheet, all permit requirements proposed in this fact sheet are at least as stringent as permit requirements specified in the existing permit renewal in accordance with 40 CFR §122.44(l)(1).

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	1.6 Daily Max	XXX	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	1/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	1/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	10000 Daily Max	XXX	1/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	1000 Daily Max	XXX	1/month	Grab
Nitrate-Nitrite	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Total Nitrogen	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	Calculation
Ammonia	XXX	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
TKN	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Total Phosphorus	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
E. Coli (No / 100 mL)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07B	10194	CONODOGUINET CREEK	41.300	419.00	367.80	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	45.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Eagles Crossing	PA0088307	0.0035	0.0035	0.0035	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07B	10194	CONODOGUINET CREEK	40.880	417.00	368.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	45.80	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Council Assembl	PA0082287	0.0250	0.0250	0.0250	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07B	10194	CONODOGUINET CREEK	38.500	412.00	377.59	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	46.80	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70





■

3



